

# Water Test Results

Annapolis Valley Regional Centre for Education



## Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate remediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

## Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

## Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

[www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html](http://www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html)

Copper:

[www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3](http://www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3)

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Aldershot Elementary School	A113a/A122 - Resource Classroom - 100022473	COC2890/MRD361	0.0012	Passed	0.1400	Passed
Aldershot Elementary School	C106/Gym-Girls - Gym-Girls L/R - 100022463	COK1707/NID109	0.0014	Passed	0.1600	Passed
Aldershot Elementary School	117/A133 - Classroom Washroom - 100022465	COK1707/NID087	0.0018	Passed	0.2400	Passed
Aldershot Elementary School	116/A132 - Classroom Washroom - 100022466	COK1707/NID086	0.0060	Exceeds Limit	0.3200	Passed
Aldershot Elementary School	Hall-S/A110 - Hallway South - 100023950	COC2890/MRD350	0.0040	Passed	0.0670	Passed
Aldershot Elementary School	Hall-Gym/C110 - Hallway North Gym - 100023949	COK1707/NID102	0.0000	Passed	0.1500	Passed
Aldershot Elementary School	A115 - Janitor's Room - 100023951	COC2890/MRD362	0.0005	Passed	0.0420	Passed
Aldershot Elementary School	C105/Gym-Boys - Gym-Boys L/R - 100022461	COK1707/NID108	0.0014	Passed	0.2000	Passed
Aldershot Elementary School	A118 - Office Staff Washroom - 100022471	COK1707/NID090	0.0053	Exceeds Limit	0.2100	Passed
Aldershot Elementary School	A131A - Resource Room Washroom - 100022467	COK1707/NID098	0.0012	Passed	0.2100	Passed
Aldershot Elementary School	B15 - Boys Washroom - 100023706	COK1707/NID104	0.0130	Exceeds Limit	0.1700	Passed
Aldershot Elementary School	B15 - Boys Washroom - 100023705	COK1707/NID101	0.0160	Exceeds Limit	0.1300	Passed
Aldershot Elementary School	B15 - Boys Washroom - 100023704	COK1707/NID100	0.0140	Exceeds Limit	0.2000	Passed
Aldershot Elementary School	B16 - Girls Washroom - 100023703	COK1707/NID107	0.0210	Exceeds Limit	0.1800	Passed
Aldershot Elementary School	B16 - Girls Washroom - 100023702	COK1707/NID106	0.0210	Exceeds Limit	0.0770	Passed
Aldershot Elementary School	B16 - Girls Washroom - 100023701	COK1707/NID105	0.0170	Exceeds Limit	0.0720	Passed
Aldershot Elementary School	Hall-N/A130 - Hallway North - 100023948	COC2890/MRD349	0.0005	Passed	0.1200	Passed
Aldershot Elementary School	115/A131 - Learning Centre - 100022469	COC2890/MRD359	0.0000	Passed	0.1400	Passed
Aldershot Elementary School	A129 - Boys Washroom - 100022450	COK1707/NID097	0.0081	Exceeds Limit	0.0740	Passed
Aldershot Elementary School	A128a - Staff Washroom - 100022444	COK1707/NID094	0.0012	Passed	0.0720	Passed
Aldershot Elementary School	A128 - Girls Washroom - 100022445	COK1707/NID091	0.0096	Exceeds Limit	0.1000	Passed
Aldershot Elementary School	A128 - Girls Washroom - 100022446	COK1707/NID092	0.0071	Exceeds Limit	0.1000	Passed
Aldershot Elementary School	A128 - Girls Washroom - 100022447	COK1707/NID093	0.0039	Passed	0.0820	Passed
Aldershot Elementary School	Hall-W - Hallway West A Wing - 100022470	COK1707/NID103	0.0021	Passed	0.1100	Passed
Aldershot Elementary School	A129 - Boys Washroom - 100022449	COK1707/NID096	0.0210	Exceeds Limit	0.1600	Passed
Aldershot Elementary School	C104 - Janitor Room - 100022460	COC2890/MRD358	0.0090	Exceeds Limit	0.2400	Passed
Aldershot Elementary School	122 - Pre-Primary Washroom - 100022451	COK1707/NID088	0.0130	Exceeds Limit	0.0990	Passed
Aldershot Elementary School	122 - Pre-Primary Classroom - 100022452	COC2890/MRD352	0.0012	Passed	0.0520	Passed
Aldershot Elementary School	124 - Pre-Primary Classroom Washroom - 100022454	COK1707/NID089	0.0036	Passed	0.0420	Passed
Aldershot Elementary School	B09a - Music and French Room - 100022459	COC2890/MRD357	0.0017	Passed	0.2000	Passed
Aldershot Elementary School	A129 - Boys Washroom - 100022448	COK1707/NID095	0.0170	Exceeds Limit	0.1400	Passed
Aldershot Elementary School	B10 - Kitchen - 100022457	COC2890/MRD356	0.0019	Passed	0.1100	Passed
Aldershot Elementary School	B13 - Janitor Room - 100022456	COC2890/MRD355	0.0006	Passed	0.1400	Passed
Aldershot Elementary School	124 - Pre-Primary Classroom - 100022455	COC2890/MRD354	0.0025	Passed	0.0220	Passed
Aldershot Elementary School	B10 - Kitchen - 100022458	COK1707/NID099	0.0019	Passed	0.1300	Passed
Aldershot Elementary School	123/B01 - Staff Room - 100022453	COC2890/MRD353	0.0014	Passed	0.0780	Passed
Annapolis East Elementary School	Hall-2 - Hallway 2nd Floor - 100022505	COG6772/NAP658	0.0014	Passed	0.1600	Passed
Annapolis East Elementary School	119 - Office Washroom 2 - 100022504	COG6772/NAP657	0.0022	Passed	0.1000	Passed
Annapolis East Elementary School	U/S Janitor Room - Upstairs Janitor Room - 100023695	COG6772/NAP654	0.0080	Exceeds Limit	0.0950	Passed
Annapolis East Elementary School	119 - Office Washroom 1 - 100022503	COG6772/NAP683	0.0047	Passed	0.1200	Passed
Annapolis East Elementary School	119 - Staff Room - 100022502	COG6772/NAP682	0.0009	Passed	0.0820	Passed
Annapolis East Elementary School	209 - Schools Plus Room - 100022507	COG6772/NAP660	0.0014	Passed	0.3700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Annapolis East Elementary School	D/S Janitor Room - Downstairs Janitor Room - 100023694	COG6772/NAP653	0.0094	Exceeds Limit	0.0730	Passed
Annapolis East Elementary School	120 - Resource Room Boys Washroom - 100022500	COG6772/NAP644	0.0170	Exceeds Limit	0.2700	Passed
Annapolis East Elementary School	Hall-2 - Hallway 2nd Floor - 100022506	COG6772/NAP659	0.0005	Passed	0.2200	Passed
Annapolis East Elementary School	D/S Janitor Room - Downstairs Janitor Room - 100023696	COG6772/NAP655	0.0082	Exceeds Limit	0.1100	Passed
Annapolis East Elementary School	Gym-L/R #1 - Gym-Locker Room #1 - 100023699	COG6772/NAP678	0.0150	Exceeds Limit	0.1200	Passed
Annapolis East Elementary School	120 - Resource Room Girls Washroom - 100022499	COG6772/NAP643	0.0062	Exceeds Limit	0.1600	Passed
Annapolis East Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100022512	COG6772/NAP647	0.0011	Passed	0.1300	Passed
Annapolis East Elementary School	U/S Staff W/R - Upstairs Staff Washroom - 100022508	COG6772/NAP661	0.0070	Exceeds Limit	0.0990	Passed
Annapolis East Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100022509	COG6772/NAP656	0.0015	Passed	0.1200	Passed
Annapolis East Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100022510	COG6772/NAP646	0.0011	Passed	0.1300	Passed
Annapolis East Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100022511	COG6772/NAP636	0.0012	Passed	0.1200	Passed
Annapolis East Elementary School	112 - Classroom Washroom - 100022485	COG6772/NAP640	0.0130	Exceeds Limit	0.0850	Passed
Annapolis East Elementary School	Gym-L/R #2 - Gym-Locker Room #2 - 100023697	COG6772/NAP662	0.0082	Exceeds Limit	0.1100	Passed
Annapolis East Elementary School	121 - Resource Room - 100022501	COG6772/NAP681	0.0360	Exceeds Limit	0.2000	Passed
Annapolis East Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100022514	COG6772/NAP649	0.0037	Passed	0.1300	Passed
Annapolis East Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100022515	COG6772/NAP650	0.0014	Passed	0.1300	Passed
Annapolis East Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100022516	COG6772/NAP651	0.0020	Passed	0.1200	Passed
Annapolis East Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100022517	COG6772/NAP652	0.0012	Passed	0.1200	Passed
Annapolis East Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100022474	COG6772/NAP645	0.0160	Exceeds Limit	0.1000	Passed
Annapolis East Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100022475	COG6772/NAP637	0.0130	Exceeds Limit	0.0890	Passed
Annapolis East Elementary School	Hall-1 - Hallway 1st Floor - 100022476	COG6772/NAP676	0.0005	Passed	0.1800	Passed
Annapolis East Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100022477	COG6772/NAP638	0.0088	Exceeds Limit	0.0850	Passed
Annapolis East Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100022478	COG6772/NAP639	0.0066	Exceeds Limit	0.1800	Passed
Annapolis East Elementary School	Hall-1 - Hallway 1st Floor - 100022479	COG6772/NAP665	0.0045	Passed	0.2300	Passed
Annapolis East Elementary School	Gym-Office - Gym-Office Washroom - 100022480	COG6772/NAP666	0.0420	Exceeds Limit	0.2200	Passed
Annapolis East Elementary School	102 - Time Out Room - 100022482	COG6772/NAP667	0.0520	Exceeds Limit	0.1500	Passed
Annapolis East Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100022513	COG6772/NAP648	0.0010	Passed	0.1500	Passed
Annapolis East Elementary School	112 - Classroom - 100022484	COG6772/NAP669	0.0051	Exceeds Limit	0.1200	Passed
Annapolis East Elementary School	Hall-1 - Hallway 1st Floor - 100022498	COG6772/NAP680	0.0053	Exceeds Limit	0.2600	Passed
Annapolis East Elementary School	113 - Classroom - 100022486	COG6772/NAP670	0.0046	Passed	0.1200	Passed
Annapolis East Elementary School	113 - Classroom Washroom - 100022487	COG6772/NAP641	0.0023	Passed	0.1300	Passed
Annapolis East Elementary School	114 - Classroom Washroom - 100022488	COG6772/NAP642	0.0027	Passed	0.1400	Passed
Annapolis East Elementary School	114 - Classroom - 100022489	COG6772/NAP671	0.0057	Exceeds Limit	0.0890	Passed
Annapolis East Elementary School	111 - Classroom - 100022490	COG6772/NAP672	0.0057	Exceeds Limit	0.1600	Passed
Annapolis East Elementary School	110 - Classroom - 100022491	COG6772/NAP673	0.0042	Passed	0.2600	Passed
Annapolis East Elementary School	109 - Music Room - 100022492	COG6772/NAP674	0.0260	Exceeds Limit	0.2300	Passed
Annapolis East Elementary School	Kitchen - Kitchen - 100022493	COG6772/NAP675	0.0510	Exceeds Limit	0.1200	Passed
Annapolis East Elementary School	Kitchen - Kitchen - 100022494	COG6772/NAP663	0.0021	Passed	0.0610	Passed
Annapolis East Elementary School	Cafeteria - Cafeteria - 100022495	COG6772/NAP677	0.0074	Exceeds Limit	0.2600	Passed
Annapolis East Elementary School	Cafeteria - Cafeteria - 100022496	COG6772/NAP664	0.0055	Exceeds Limit	0.2800	Passed
Annapolis East Elementary School	101 - Resource Room - 100022497	COG6772/NAP679	0.0170	Exceeds Limit	0.3400	Passed
Annapolis East Elementary School	Hall-1 - Hallway 1st Floor - 100022483	COG6772/NAP668	0.0610	Exceeds Limit	0.2800	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Annapolis West Education Centre	309.1 - Washroom - 100022006	COL0534/NJZ856	0.0000	Passed	0.1500	Passed
Annapolis West Education Centre	116 - Girls Washroom - 100021922	COL0534/NJZ828	0.0000	Passed	0.1400	Passed
Annapolis West Education Centre	209 - Kitchen - 100021951	COL0534/NJZ834	0.0190	Exceeds Limit	0.1400	Passed
Annapolis West Education Centre	208 - Art Room - 100021952	COD3950/MTO406	0.0000	Passed	0.1900	Passed
Annapolis West Education Centre	224 - Staff Room - 100021953	COD3950/MTO407	0.0000	Passed	0.1300	Passed
Annapolis West Education Centre	Hall-2-N - Hallway 2nd Floor North - 100021955	COD3950/MTO408	0.0000	Passed	0.0890	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022011	COL0534/NJZ883	0.0056	Exceeds Limit	0.1200	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022010	COL0534/NJZ882	0.0023	Passed	0.1900	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022009	COL0534/NJZ881	0.0044	Passed	0.0860	Passed
Annapolis West Education Centre	209 - Kitchen - 100021949	COD3950/MTO404	0.0012	Passed	0.0870	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022007	COL0534/NJZ879	0.0046	Passed	0.1000	Passed
Annapolis West Education Centre	209 - Kitchen - 100021948	COD3950/MTO403	0.0000	Passed	0.0760	Passed
Annapolis West Education Centre	305.1 - Gender Neutral Washroom - 100022004	COL0534/NJZ855	0.0000	Passed	0.1800	Passed
Annapolis West Education Centre	319 - Janitor Room - 100022003	COL0534/NJZ894	0.0530	Exceeds Limit	0.2000	Passed
Annapolis West Education Centre	319 - Janitor Room - 100022002	COL0534/NJZ893	0.0013	Passed	0.2100	Passed
Annapolis West Education Centre	317 - Boys Washroom - 100022001	COL0534/NJZ892	0.0000	Passed	0.1400	Passed
Annapolis West Education Centre	317 - Boys Washroom - 100022000	COL0534/NJZ891	0.0006	Passed	0.1200	Passed
Annapolis West Education Centre	317 - Boys Washroom - 100021999	COL0534/NJZ890	0.0000	Passed	0.1300	Passed
Annapolis West Education Centre	316 - Girls Washroom - 100021998	COL0534/NJZ889	0.0008	Passed	0.1300	Passed
Annapolis West Education Centre	316 - Girls Washroom - 100021997	COL0534/NJZ888	0.0000	Passed	0.1200	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022008	COL0534/NJZ880	0.0024	Passed	0.1700	Passed
Annapolis West Education Centre	118 - Janitor Room - 100021934	COL0534/NJZ832	0.0200	Exceeds Limit	0.1800	Passed
Annapolis West Education Centre	116 - Girls Washroom - 100021923	COL0534/NJZ829	0.0000	Passed	0.1400	Passed
Annapolis West Education Centre	118 - Janitor Room - 100021924	COL0534/NJZ831	0.0021	Passed	0.1700	Passed
Annapolis West Education Centre	117 - Gender Neutral Washroom - 100021925	COL0534/NJZ830	0.0000	Passed	0.1200	Passed
Annapolis West Education Centre	115 - Boys Washroom - 100021926	COL0534/NJZ826	0.0000	Passed	0.1200	Passed
Annapolis West Education Centre	115 - Boys Washroom - 100021927	COL0534/NJZ827	0.0000	Passed	0.1000	Passed
Annapolis West Education Centre	Hall-1 - Hallway 1st Floor - 100021928	COD3950/MTO409	0.0000	Passed	0.0850	Passed
Annapolis West Education Centre	110 - Mechanic Room - 100021929	COL0534/NJZ824	0.0470	Exceeds Limit	0.3700	Passed
Annapolis West Education Centre	107 - Carpentry Room - 100021931	COL0534/NJZ822	0.0013	Passed	0.1300	Passed
Annapolis West Education Centre	209 - Kitchen - 100021950	COL0534/NJZ833	0.0000	Passed	0.1300	Passed
Annapolis West Education Centre	248.4 - Main Office Washroom - 100021933	COL0534/NJZ854	0.0000	Passed	0.1100	Passed
Annapolis West Education Centre	314 - Biology Lab - 100021994	COL0534/NJZ876	0.0008	Passed	0.1300	Passed
Annapolis West Education Centre	Hall-2-S - Hallway 2nd Floor South - 100021935	COD3950/MTO402	0.0000	Passed	0.0810	Passed
Annapolis West Education Centre	234 - Janitor Room - 100021936	COL0534/NJZ847	0.0180	Exceeds Limit	0.3400	Passed
Annapolis West Education Centre	234 - Janitor Room - 100021937	COL0534/NJZ848	0.0016	Passed	0.0830	Passed
Annapolis West Education Centre	237 - Gym-Girls Locker Room - 100021938	COL0534/NJZ849	0.0000	Passed	0.1100	Passed
Annapolis West Education Centre	237 - Gym-Girls Locker Room - 100021939	COL0534/NJZ850	0.0000	Passed	0.0720	Passed
Annapolis West Education Centre	239 - Gym-Office Washroom - 100021942	COL0534/NJZ851	0.0000	Passed	0.0970	Passed
Annapolis West Education Centre	242 - Gym-Boys Locker Room - 100021944	COL0534/NJZ852	0.0000	Passed	0.1200	Passed
Annapolis West Education Centre	242 - Gym-Boys Locker Room - 100021945	COL0534/NJZ853	0.0000	Passed	0.0780	Passed
Annapolis West Education Centre	215 - Culinary Arts - 100021965	COD3950/MTO416	0.0000	Passed	0.0590	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Annapolis West Education Centre	215 - Culinary Arts - 100021962	COD3950/MTO413	0.0000	Passed	0.0830	Passed
Annapolis West Education Centre	310 - Classroom - 100021974	COL0534/NJZ857	0.0010	Passed	0.2000	Passed
Annapolis West Education Centre	227 - Boys Washroom - 100021973	COL0534/NJZ844	0.0009	Passed	0.1400	Passed
Annapolis West Education Centre	227 - Boys Washroom - 100021972	COL0534/NJZ843	0.0000	Passed	0.0940	Passed
Annapolis West Education Centre	227 - Boys Washroom - 100021971	COL0534/NJZ842	0.0000	Passed	0.1800	Passed
Annapolis West Education Centre	225 - Staff Washroom - 100021956	COL0534/NJZ838	0.0000	Passed	0.1000	Passed
Annapolis West Education Centre	213 - Visual Arts Classroom - 100021957	COD3950/MTO419	0.0045	Passed	0.1100	Passed
Annapolis West Education Centre	213 - Visual Arts Classroom - 100021958	COD3950/MTO410	0.0024	Passed	0.0920	Passed
Annapolis West Education Centre	214.1 - Gender Neutral Washroom - 100021959	COL0534/NJZ836	0.0000	Passed	0.0940	Passed
Annapolis West Education Centre	316 - Girls Washroom - 100021996	COL0534/NJZ887	0.0006	Passed	0.1400	Passed
Annapolis West Education Centre	215 - Culinary Arts - 100021961	COD3950/MTO412	0.0000	Passed	0.1000	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021977	COL0534/NJZ860	0.0009	Passed	0.2000	Passed
Annapolis West Education Centre	215 - Culinary Arts - 100021963	COD3950/MTO414	0.0000	Passed	0.0880	Passed
Annapolis West Education Centre	215 - Culinary Arts - 100021964	COD3950/MTO415	0.0000	Passed	0.1700	Passed
Annapolis West Education Centre	215 - Culinary Arts - 100023886	COL0534/NJZ837	0.0078	Exceeds Limit	0.2000	Passed
Annapolis West Education Centre	226 - Girls Washroom - 100021970	COL0534/NJZ841	0.0000	Passed	0.1200	Passed
Annapolis West Education Centre	226 - Girls Washroom - 100021969	COL0534/NJZ840	0.0000	Passed	0.3000	Passed
Annapolis West Education Centre	226 - Girls Washroom - 100021968	COL0534/NJZ839	0.0000	Passed	0.0930	Passed
Annapolis West Education Centre	227.1 - Custodial Room - 100021967	COL0534/NJZ846	0.0130	Exceeds Limit	0.1700	Passed
Annapolis West Education Centre	227.1 - Custodial Room - 100021966	COL0534/NJZ845	0.0014	Passed	0.1300	Passed
Annapolis West Education Centre	214 - Learning Centre - 100021960	COD3950/MTO401	0.0000	Passed	0.0690	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021984	COL0534/NJZ867	0.0007	Passed	0.0510	Passed
Annapolis West Education Centre	110 - Mechanic Room - 100021930	COL0534/NJZ825	0.0068	Exceeds Limit	0.0940	Passed
Annapolis West Education Centre	314 - Biology Lab - 100021993	COL0534/NJZ875	0.0007	Passed	0.1700	Passed
Annapolis West Education Centre	314 - Biology Lab - 100021992	COL0534/NJZ874	0.0000	Passed	0.0980	Passed
Annapolis West Education Centre	314 - Biology Lab - 100021991	COL0534/NJZ873	0.0007	Passed	0.1400	Passed
Annapolis West Education Centre	314 - Biology Lab - 100021990	COL0534/NJZ872	0.0008	Passed	0.1300	Passed
Annapolis West Education Centre	314.1 - Biology Storage Room - 100021989	COD3950/MTO417	0.0045	Passed	0.1200	Passed
Annapolis West Education Centre	313.1 - Chemistry Lab Storage - 100021988	COL0534/NJZ871	0.0059	Exceeds Limit	0.1400	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021987	COL0534/NJZ870	0.0140	Exceeds Limit	0.2100	Passed
Annapolis West Education Centre	311 - Classroom - 100021975	COL0534/NJZ858	0.0027	Passed	0.2200	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021985	COL0534/NJZ868	0.0000	Passed	0.1100	Passed
Annapolis West Education Centre	312 - Classroom - 100021976	COL0534/NJZ859	0.0029	Passed	0.0120	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021983	COL0534/NJZ866	0.0010	Passed	0.1100	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021982	COL0534/NJZ865	0.0000	Passed	0.1200	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021981	COL0534/NJZ864	0.0008	Passed	0.1100	Passed
Annapolis West Education Centre	109 - Industrial Arts Room - 100024286	COL0534/NJZ896	0.0056	Exceeds Limit	0.1800	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021980	COL0534/NJZ863	0.0000	Passed	0.0560	Passed
Annapolis West Education Centre	2-AHRM - AH Room Upstairs - 100024285	COL0534/NJZ895	0.0006	Passed	0.1100	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021979	COL0534/NJZ862	0.0008	Passed	0.0880	Passed
Annapolis West Education Centre	313 - Chemistry Lab - 100021978	COL0534/NJZ861	0.0000	Passed	0.1100	Passed
Annapolis West Education Centre	314 - Biology Lab - 100021995	COL0534/NJZ877	0.0008	Passed	0.1400	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Annapolis West Education Centre	313 - Chemistry Lab - 100021986	COL0534/NJZ869	0.0000	Passed	0.0920	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022013	COL0534/NJZ885	0.0096	Exceeds Limit	0.1900	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022014	COL0534/NJZ886	0.0044	Passed	0.1700	Passed
Annapolis West Education Centre	Hall-3 - Hallway 3rd Floor - 100022015	COD3950/MTO418	0.0006	Passed	0.1100	Passed
Annapolis West Education Centre	109 - Industrial Arts Room - 100021932	COL0534/NJZ823	0.0150	Exceeds Limit	0.4700	Passed
Annapolis West Education Centre	315 - Physics Lab - 100022012	COL0534/NJZ884	0.0033	Passed	0.1600	Passed
Avon View High School	159A - Gym Office Washroom - 100023847	COH4781/NCI082	0.0009	Passed	0.3600	Passed
Avon View High School	Staff W/R - Staff Washroom - 100022234	COH4781/NCI039	0.0000	Passed	0.0460	Passed
Avon View High School	223 - Science Lab - 100022233	COH4781/NCI064	0.0061	Exceeds Limit	0.1200	Passed
Avon View High School	270 - Classroom - 100023845	COH4781/NCI080	0.0007	Passed	0.0300	Passed
Avon View High School	131B - Sick Room Washroom - 100023846	COH4781/NCI081	0.0000	Passed	0.1800	Passed
Avon View High School	223 - Science Lab - 100022232	COH4781/NCI066	0.0440	Exceeds Limit	1.9000	Passed
Avon View High School	222 - Science Lab - 100022236	COH4781/NCI040	0.0023	Passed	0.2300	Passed
Avon View High School	223 - Science Lab - 100022230	COH4781/NCI073	0.0082	Exceeds Limit	0.4700	Passed
Avon View High School	222 - Science Lab - 100022240	COH4781/NCI044	0.0008	Passed	0.1900	Passed
Avon View High School	167A - Gym Offi	COH4781/NCI084	0.0000	Passed	0.2100	Passed
Avon View High School	U/S Janitor Room - Upstairs Janitor Room - 100023851	COH4781/NCI086	0.0000	Passed	0.0560	Passed
Avon View High School	223 - Science Lab - 100022231	COH4781/NCI048	0.0250	Exceeds Limit	0.4400	Passed
Avon View High School	222 - Science Lab - 100022237	COH4781/NCI041	0.0110	Exceeds Limit	0.1700	Passed
Avon View High School	222 - Science Lab - 100022239	COH4781/NCI043	0.0052	Exceeds Limit	0.2000	Passed
Avon View High School	142B - Staff Washroom - 100023855	COH4781/NCI088	0.0000	Passed	0.1600	Passed
Avon View High School	222 - Science Lab - 100022241	COH4781/NCI045	0.0047	Passed	0.1600	Passed
Avon View High School	222 - Science Lab - 100022242	COH4781/NCI056	0.0068	Exceeds Limit	0.2400	Passed
Avon View High School	222 - Science Lab - 100022243	COH4781/NCI047	0.0042	Passed	0.1400	Passed
Avon View High School	222 - Science Lab - 100022244	COH4781/NCI038	0.0037	Passed	0.1900	Passed
Avon View High School	222 - Science Lab - 100022245	COH4168/NCE679	0.0160	Exceeds Limit	0.0700	Passed
Avon View High School	222 - Science Lab - 100022246	COH4168/NCE663	0.0029	Passed	0.1800	Passed
Avon View High School	224 - Food Lab - 100022247	COH4781/NCI049	0.0041	Passed	0.1800	Passed
Avon View High School	224 - Food Lab - 100022248	COH4781/NCI050	0.0009	Passed	0.1400	Passed
Avon View High School	222 - Science Lab - 100022238	COH4781/NCI042	0.0051	Exceeds Limit	0.2200	Passed
Avon View High School	223 - Science Lab - 100022223	COH4781/NCI067	0.0330	Exceeds Limit	0.3000	Passed
Avon View High School	226 - Science Room - 100022216	COH4781/NCI061	0.1400	Exceeds Limit	2.5000	Exceeds Limit
Avon View High School	226 - Science Room - 100022218	COH4781/NCI062	0.0047	Passed	0.4800	Passed
Avon View High School	226 - Science Room - 100022219	COH4781/NCI063	0.0280	Exceeds Limit	0.3700	Passed
Avon View High School	226 - Science Room - 100022220	COH4781/NCI075	0.0064	Exceeds Limit	0.3700	Passed
Avon View High School	226 - Science Room - 100022221	COH4781/NCI065	0.0540	Exceeds Limit	0.7400	Passed
Avon View High School	226 - Science Room - 100022222	COH4781/NCI057	0.0026	Passed	0.0820	Passed
Avon View High School	227 - Art Room - 100022268	COH4168/NCE672	0.0098	Exceeds Limit	0.2400	Passed
Avon View High School	227 - Art Room - 100022267	COH4168/NCE671	0.0020	Passed	0.2400	Passed
Avon View High School	102 - Old Art Room - 100022266	COH4168/NCE670	0.0060	Exceeds Limit	0.1800	Passed
Avon View High School	114 - Resource Room - 100022264	COH4168/NCE678	0.0000	Passed	0.1500	Passed
Avon View High School	D/S Janitor Room - Downstairs Janitor Room - 100023853	COH4781/NCI087	0.0000	Passed	0.0700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Avon View High School	Girls W/R - Girls Washroom - 100023860	COH4781/NCI096	0.0007	Passed	0.1900	Passed
Avon View High School	142 - Staff Room - 100023854	COH4168/NCE668	0.0000	Passed	0.1400	Passed
Avon View High School	Boys W/R - Boys Washroom - 100023859	COH4781/NCI094	0.0000	Passed	0.1100	Passed
Avon View High School	223 - Science Lab - 100022225	COH4781/NCI068	0.0021	Passed	0.2900	Passed
Avon View High School	223 - Science Lab - 100022226	COH4781/NCI069	0.0031	Passed	0.2600	Passed
Avon View High School	223 - Science Lab - 100022227	COH4781/NCI070	0.0044	Passed	0.2200	Passed
Avon View High School	Boys W/R - Boys Washroom - 100023858	COH4781/NCI092	0.0032	Passed	0.1600	Passed
Avon View High School	Janitor Room - Janitor Room - 100023857	COH4781/NCI090	0.0000	Passed	0.0510	Passed
Avon View High School	142A - Staff Washroom - 100023856	COH4781/NCI089	0.0000	Passed	0.1300	Passed
Avon View High School	223 - Science Lab - 100022228	COH4781/NCI071	0.0100	Exceeds Limit	0.3500	Passed
Avon View High School	223 - Science Lab - 100022229	COH4781/NCI072	0.0041	Passed	0.2500	Passed
Avon View High School	221 - Science Lab - 100022252	COH4781/NCI054	0.0180	Exceeds Limit	0.5800	Passed
Avon View High School	Girls W/R - Girls Washroom - 100023861	COH4781/NCI102	0.0006	Passed	0.2200	Passed
Avon View High School	301 - Skilled Trades Room - 100022205	COH4781/NCI046	0.0000	Passed	0.0410	Passed
Avon View High School	224 - Food Lab - 100022250	COH4781/NCI052	0.0013	Passed	0.1500	Passed
Avon View High School	252 - Upper East Boys Washroom - 100022530	COH4781/NCI129	0.0000	Passed	0.0560	Passed
Avon View High School	231 - Upper West Boys Washroom - 100022529	COH4781/NCI127	0.0032	Passed	0.2100	Passed
Avon View High School	231 - Upper West Boys Washroom - 100022528	COH4781/NCI125	0.0020	Passed	0.3500	Passed
Avon View High School	232 - Upper West Girls Washroom - 100022527	COH4781/NCI123	0.0000	Passed	0.0910	Passed
Avon View High School	232 - Upper West Girls Washroom - 100022526	COH4781/NCI100	0.0006	Passed	0.0570	Passed
Avon View High School	Lower West Girls W/R - Lower West Girls Washroom - 100022525	COH4781/NCI118	0.0011	Passed	0.0810	Passed
Avon View High School	Lower West Girls W/R - Lower West Girls Washroom - 100022524	COH4781/NCI140	0.0000	Passed	0.0760	Passed
Avon View High School	Lower West Boys W/R - Lower West Boys Washroom - 100022523	COH4781/NCI113	0.0000	Passed	0.1200	Passed
Avon View High School	Lower West Boys W/R - Lower West Boys Washroom - 100022522	COH4781/NCI111	0.0000	Passed	0.1200	Passed
Avon View High School	252 - Upper East Boys Washroom - 100022532	COH4781/NCI133	0.0019	Passed	0.2300	Passed
Avon View High School	114 - Resource Room - 100022519	COH4168/NCE673	0.0018	Passed	0.1300	Passed
Avon View High School	253 - Upper East Girls Washroom - 100022533	COH4781/NCI135	0.0000	Passed	0.2400	Passed
Avon View High School	301 - Skilled Trades Room - 100022206	COH4781/NCI058	0.0063	Exceeds Limit	0.1600	Passed
Avon View High School	123 - Industrial Arts Shop - 100022208	COH4781/NCI059	0.0180	Exceeds Limit	0.1100	Passed
Avon View High School	123 - Industrial Arts Shop - 100022209	COH4168/NCE666	0.0000	Passed	0.2200	Passed
Avon View High School	Hall-1-M - Hallway 1st Floor Middle - 100022210	COH4168/NCE658	0.0007	Passed	0.0950	Passed
Avon View High School	178B - Café Kitchen - 100022211	COH4168/NCE659	0.0044	Passed	0.3300	Passed
Avon View High School	102 - Old Art Room - 100022265	COH4168/NCE669	0.0031	Passed	0.2100	Passed
Avon View High School	178B - Café Kitchen - 100022212	COH4168/NCE660	0.0049	Passed	0.0590	Passed
Avon View High School	178B - Café Kitchen - 100022213	COH4168/NCE661	0.0000	Passed	0.1700	Passed
Avon View High School	178B - Café Kitchen - 100022214	COH4168/NCE662	0.0008	Passed	0.1700	Passed
Avon View High School	178B - Café Kitchen - 100022215	COH4781/NCI060	0.0000	Passed	0.1800	Passed
Avon View High School	114 - Resource Room Washroom - 100022520	COH4781/NCI109	0.0000	Passed	0.1300	Passed
Avon View High School	Hall-1-E - Hallway 1st Floor East - 100022544	COH4168/NCE676	0.0013	Passed	0.1800	Passed
Avon View High School	224 - Food Lab - 100022251	COH4781/NCI053	0.0005	Passed	0.1600	Passed
Avon View High School	221 - Science Lab - 100022253	COH4781/NCI055	0.0140	Exceeds Limit	0.2200	Passed
Avon View High School	221 - Science Lab - 100022254	COH4781/NCI076	0.0037	Passed	0.1400	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Avon View High School	221 - Science Lab - 100022255	COH4781/NCI121	0.0038	Passed	0.2000	Passed
Avon View High School	221 - Science Lab - 100022256	COH4781/NCI074	0.0310	Exceeds Limit	0.3300	Passed
Avon View High School	221 - Science Lab - 100022257	COH4781/NCI103	0.0670	Exceeds Limit	2.7000	Exceeds Limit
Avon View High School	221 - Science Lab - 100022258	COH4781/NCI105	0.0480	Exceeds Limit	0.8000	Passed
Avon View High School	Hall-2-E - Hallway 2nd Floor East - 100022259	COH4168/NCE664	0.0005	Passed	0.0790	Passed
Avon View High School	Hall-2-W - Hallway 2nd Floor West - 100022260	COH4168/NCE665	0.0075	Exceeds Limit	0.1800	Passed
Avon View High School	189C - Washroom - 100022261	COH4781/NCI107	0.0000	Passed	0.1100	Passed
Avon View High School	252 - Upper East Boys Washroom - 100022531	COH4781/NCI131	0.0000	Passed	0.1900	Passed
Avon View High School	121 - Music Room - 100022263	COH4168/NCE667	0.0027	Passed	0.1500	Passed
Avon View High School	224 - Food Lab - 100022249	COH4781/NCI051	0.0012	Passed	0.1600	Passed
Avon View High School	Hall-1-M - Hallway 1st Floor Middle - 100022543	COH4168/NCE675	0.0000	Passed	0.3100	Passed
Avon View High School	Hall-1-W - Hallway 1st Floor West - 100022542	COH4168/NCE674	0.0045	Passed	0.2800	Passed
Avon View High School	Lower East Girls W/R - Lower East Girls Washroom - 100022541	COH4781/NCI079	0.0010	Passed	0.1700	Passed
Avon View High School	Lower East Girls W/R - Lower East Girls Washroom - 100022540	COH4781/NCI078	0.0008	Passed	0.3300	Passed
Avon View High School	Lower East Girls W/R - Lower East Girls Washroom - 100022539	COH4781/NCI077	0.0006	Passed	0.4600	Passed
Avon View High School	Lower East Boys W/R - Lower East Boys Washroom - 100022538	COH4781/NCI115	0.0005	Passed	0.6000	Passed
Avon View High School	Lower East Boys W/R - Lower East Boys Washroom - 100022537	COH4781/NCI083	0.0006	Passed	0.3300	Passed
Avon View High School	Lower East Boys W/R - Lower East Boys Washroom - 100022536	COH4781/NCI085	0.0030	Passed	0.5000	Passed
Avon View High School	253 - Upper East Girls Washroom - 100022535	COH4781/NCI139	0.0032	Passed	0.1500	Passed
Avon View High School	253 - Upper East Girls Washroom - 100022534	COH4781/NCI137	0.0010	Passed	0.1300	Passed
Avon View High School	120 - Classroom - 100022262	COH4168/NCE677	0.0009	Passed	0.1900	Passed
Berwick & District School	165 - Family Studies Room - 100021873	COG6709/NAP160	0.0093	Exceeds Limit	0.1100	Passed
Berwick & District School	122 - Janitor Room - 100021862	COG6709/NAP185	0.0073	Exceeds Limit	0.2800	Passed
Berwick & District School	143 - Janitor Room - 100021863	COG6709/NAP173	0.0097	Exceeds Limit	0.2600	Passed
Berwick & District School	123 - Boys Washroom - 100021864	COG6709/NAP172	0.0450	Exceeds Limit	0.8400	Passed
Berwick & District School	123 - Boys Washroom - 100021865	COG6709/NAP171	0.0330	Exceeds Limit	0.6500	Passed
Berwick & District School	124 - Girls Washroom - 100021866	COG6709/NAP170	0.1700	Exceeds Limit	0.8200	Passed
Berwick & District School	124 - Girls Washroom - 100021867	COG6709/NAP175	0.0210	Exceeds Limit	0.1700	Passed
Berwick & District School	Hall-1-E - Hallway 1st Floor East - 100021868	B9V1710/LFP107	0.0000	Passed	0.1500	Passed
Berwick & District School	167 - Staff Room - 100021869	B9V1710/LFP108	0.0000	Passed	0.0520	Passed
Berwick & District School	167 - Staff Room Washroom - 100021870	COG6709/NAP169	0.0130	Exceeds Limit	0.2800	Passed
Berwick & District School	210 - Science Classroom - 100024255	COG6709/NAP198	0.0081	Exceeds Limit	0.1800	Passed
Berwick & District School	165 - Family Studies Room - 100021872	COG6709/NAP161	0.0033	Passed	0.0430	Passed
Berwick & District School	203 - Art Room - 100021858	B9V1710/LFP104	0.0021	Passed	0.6700	Passed
Berwick & District School	165 - Family Studies Room - 100021874	COG6709/NAP159	0.0038	Passed	0.0590	Passed
Berwick & District School	160 - Industrial Arts Room - 100021875	COG6709/NAP167	0.0150	Exceeds Limit	0.3000	Passed
Berwick & District School	144 - Girls Washroom - 100021876	COG6709/NAP166	0.1500	Exceeds Limit	1.3000	Passed
Berwick & District School	145 - Boys Washroom - 100021877	COG6709/NAP188	0.0130	Exceeds Limit	0.2000	Passed
Berwick & District School	139 - Music Room - 100021878	COG6709/NAP158	0.0160	Exceeds Limit	0.0700	Passed
Berwick & District School	139 - Music Room - 100021879	COG6709/NAP157	0.0300	Exceeds Limit	0.1500	Passed
Berwick & District School	139 - Music Room - 100021880	COG6709/NAP156	0.0190	Exceeds Limit	0.0510	Passed
Berwick & District School	Hall-1-W - Hallway 1st Floor West - 100021881	B9V1710/LFP106	0.0047	Passed	0.1600	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Berwick & District School	181 - Gym-Office - 100021882	COG6709/NAP174	0.0200	Exceeds Limit	0.1800	Passed
Berwick & District School	182 - Gym-Office - 100021884	COG6709/NAP199	0.0470	Exceeds Limit	0.1300	Passed
Berwick & District School	167 - Staff Room Washroom - 100021871	COG6709/NAP168	0.0050	Exceeds Limit	0.1400	Passed
Berwick & District School	Hall-2-E - Hallway 2nd Floor East - 100021847	COG6709/NAP163	0.0200	Exceeds Limit	0.2000	Passed
Berwick & District School	148 - Kitchen - 100023683	B9V1710/LFP111	0.0027	Passed	0.2200	Passed
Berwick & District School	148 - Kitchen - 100023684	COG6709/NAP155	0.0065	Exceeds Limit	0.1400	Passed
Berwick & District School	131 - Staff Washroom - 100023685	COG6709/NAP195	0.0220	Exceeds Limit	0.2800	Passed
Berwick & District School	108 - Classroom Washroom - 100023686	COG6709/NAP194	0.0096	Exceeds Limit	0.1500	Passed
Berwick & District School	108 - Classroom Washroom - 100023687	COG6709/NAP193	0.1600	Exceeds Limit	0.8800	Passed
Berwick & District School	186 - Gym-Girls Locker Room - 100023688	COG6709/NAP192	0.0077	Exceeds Limit	0.1400	Passed
Berwick & District School	186 - Gym-Girls Locker Room - 100023689	COG6709/NAP191	0.0046	Passed	0.1600	Passed
Berwick & District School	177 - Gym-Boys Locker Room - 100023691	COG6709/NAP189	0.0069	Exceeds Limit	0.1400	Passed
Berwick & District School	177 - Gym-Boys Locker Room - 100023692	COG6709/NAP200	0.0093	Exceeds Limit	0.2000	Passed
Berwick & District School	217 - Girls Washroom - 100022546	COG6709/NAP196	0.0300	Exceeds Limit	0.3900	Passed
Berwick & District School	207 - Staff Washroom - 100021861	COG6709/NAP164	0.0092	Exceeds Limit	0.1600	Passed
Berwick & District School	118 - Classroom - 100021846	B9V1710/LFP100	0.0025	Passed	0.1300	Passed
Berwick & District School	206 - Staff Washroom - 100021860	COG6709/NAP176	0.0150	Exceeds Limit	0.1900	Passed
Berwick & District School	118 - Classroom Washroom - 100021848	COG6709/NAP165	0.0027	Passed	0.1100	Passed
Berwick & District School	117 - Classroom Washroom - 100021849	COG6709/NAP184	0.0610	Exceeds Limit	1.3000	Passed
Berwick & District School	116 - Pre-Primary Classroom Washroom - 100021850	COG6709/NAP183	0.0067	Exceeds Limit	0.1100	Passed
Berwick & District School	210 - Science Classroom - 100021851	COG6709/NAP182	0.0630	Exceeds Limit	0.3400	Passed
Berwick & District School	210 - Science Classroom - 100021852	COG6709/NAP181	0.0260	Exceeds Limit	0.2500	Passed
Berwick & District School	210 - Science Classroom - 100021853	COG6709/NAP180	0.0410	Exceeds Limit	0.1600	Passed
Berwick & District School	210 - Science Classroom - 100021854	COG6709/NAP179	0.0800	Exceeds Limit	0.2400	Passed
Berwick & District School	210 - Science Classroom - 100021855	COG6709/NAP178	0.0900	Exceeds Limit	0.4100	Passed
Berwick & District School	215 - Janitor Room - 100021856	COG6709/NAP177	0.0120	Exceeds Limit	0.2200	Passed
Berwick & District School	202 - Classroom - 100021859	B9V1710/LFP105	0.0009	Passed	0.4900	Passed
Berwick & District School	216 - Boys Washroom - 100022545	COG6709/NAP197	0.0480	Exceeds Limit	0.4200	Passed
Berwick & District School	165 - Family Studies Room - 100023905	COG6709/NAP154	0.0032	Passed	0.0870	Passed
Berwick & District School	217 - Girls Washroom - 100023915	COG6709/NAP190	0.0230	Exceeds Limit	0.3100	Passed
Berwick & District School	217 - Girls Washroom - 100023914	COG6709/NAP186	0.0430	Exceeds Limit	0.5000	Passed
Berwick & District School	216 - Boys Washroom - 100023913	COG6709/NAP187	0.0650	Exceeds Limit	0.4100	Passed
Berwick & District School	Hall-2-W - Hallway 2nd Floor West - 100021857	COG6709/NAP162	0.0230	Exceeds Limit	0.9800	Passed
Berwick & District School	115 - Classroom - 100023916	B9V1710/LFP102	0.0031	Passed	0.1200	Passed
Bridgetown Regional Community School	112A.1 - Classroom Washroom - 100021713	COF4119/MXU994	0.0000	Passed	0.3100	Passed
Bridgetown Regional Community School	Hall-1-W - Hallway 1st Floor West - 100021803	COF4229/MXW387	0.0000	Passed	0.0840	Passed
Bridgetown Regional Community School	Hall-1-W - Hallway 1st Floor West - 100021804	COF4229/MXW386	0.0000	Passed	0.0960	Passed
Bridgetown Regional Community School	152 - Kitchen - 100024250	COF4119/MXV035	0.0020	Passed	0.2800	Passed
Bridgetown Regional Community School	154.1 - Washroom - 100021806	COF4119/MXV003	0.0630	Exceeds Limit	0.7800	Passed
Bridgetown Regional Community School	112 - Classroom - 100021712	COF4229/MXW368	0.0008	Passed	0.1600	Passed
Bridgetown Regional Community School	137A - Chemistry Lab Storage - 100024247	COF4119/MXV009	0.0830	Exceeds Limit	0.4500	Passed
Bridgetown Regional Community School	Fountain - Fountain - 100024248	COF4119/MXV015	0.0000	Passed	0.0830	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bridgetown Regional Community School	145 - Physics Lab - 100021740	COF4119/MXU975	0.2100	Exceeds Limit	0.9000	Passed
Bridgetown Regional Community School	147 - Classroom - 100021807	COF4119/MXV017	0.0007	Passed	0.3500	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021741	COF4119/MXU976	0.0620	Exceeds Limit	0.7700	Passed
Bridgetown Regional Community School	153 - Art Room - 100021742	COF4229/MXW372	0.0024	Passed	0.2700	Passed
Bridgetown Regional Community School	124.1 - Washroom - 100021805	COF4119/MXV013	0.0000	Passed	0.2000	Passed
Bridgetown Regional Community School	153 - Art Room - 100021743	COF4229/MXW371	0.0030	Passed	0.2500	Passed
Bridgetown Regional Community School	163C - Gym Shower - 100024252	COF4119/MXV026	0.0065	Exceeds Limit	0.2900	Passed
Bridgetown Regional Community School	147 - Classroom - 100021808	COF4119/MXV018	0.0028	Passed	0.3300	Passed
Bridgetown Regional Community School	163D - Gym Shower - 100024253	COF4119/MXV040	0.0087	Exceeds Limit	0.5800	Passed
Bridgetown Regional Community School	Fountain - Fountain - 100021802	COF4229/MXW388	0.0000	Passed	0.0730	Passed
Bridgetown Regional Community School	Hall-1-E - Hallway 1st Floor East - 100023757	COF4229/MXW411	0.0000	Passed	0.3000	Passed
Bridgetown Regional Community School	212A.1 - Washroom - 100021801	COF4119/MXV033	0.0000	Passed	0.3800	Passed
Bridgetown Regional Community School	W/R - Washroom - 100021800	COF4119/MXV011	0.0000	Passed	0.3000	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021799	COF4119/MXV008	0.0018	Passed	0.2400	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021798	COF4119/MXV007	0.0017	Passed	0.2500	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021797	COF4119/MXV006	0.0030	Passed	0.2500	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021796	COF4119/MXV005	0.0009	Passed	0.1600	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021795	COF4119/MXV004	0.0012	Passed	0.2700	Passed
Bridgetown Regional Community School	216 - Classroom - 100021755	COF4229/MXW397	0.0000	Passed	0.1700	Passed
Bridgetown Regional Community School	163B - Gym Shower - 100024251	COF4119/MXV037	0.0017	Passed	0.4900	Passed
Bridgetown Regional Community School	U/S Boys W/R - Upstairs Boys Washroom - 100021761	COF4119/MXU985	0.0000	Passed	0.2600	Passed
Bridgetown Regional Community School	U/S Girls W/R - Upstairs Girls Washroom - 100021756	COF4119/MXU990	0.0000	Passed	0.2000	Passed
Bridgetown Regional Community School	U/S Girls W/R - Upstairs Girls Washroom - 100021757	COF4119/MXU981	0.0000	Passed	0.0490	Passed
Bridgetown Regional Community School	214 - Classroom - 100021754	COF4229/MXW408	0.0007	Passed	0.1400	Passed
Bridgetown Regional Community School	205 - Classroom - 100021753	COF4229/MXW409	0.0000	Passed	0.1600	Passed
Bridgetown Regional Community School	203 - Classroom - 100021752	COF4229/MXW410	0.0000	Passed	0.1800	Passed
Bridgetown Regional Community School	Boiler Room - Boiler Room - 100021751	COF4119/MXU979	0.0012	Passed	0.4000	Passed
Bridgetown Regional Community School	Mechanical Room - Mechanical Room - 100021750	COF4119/MXU978	0.0047	Passed	0.3100	Passed
Bridgetown Regional Community School	Mechanical Room - Mechanical Room - 100021749	COF4119/MXU977	0.0000	Passed	0.1300	Passed
Bridgetown Regional Community School	220 - Classroom - 100021748	COF4229/MXW377	0.0000	Passed	0.1800	Passed
Bridgetown Regional Community School	222 - Classroom - 100021747	COF4229/MXW394	0.0005	Passed	0.1900	Passed
Bridgetown Regional Community School	104.1 - Learning Centre Washroom - 100024254	COF4229/MXW413	0.0022	Passed	0.6300	Passed
Bridgetown Regional Community School	U/S Girls W/R - Upstairs Girls Washroom - 100021758	COF4119/MXU971	0.0005	Passed	0.2300	Passed
Bridgetown Regional Community School	156.1 - Recycle Room - 100021745	COF4229/MXW369	0.0046	Passed	0.6900	Passed
Bridgetown Regional Community School	U/S Boys W/R - Upstairs Boys Washroom - 100021760	COF4119/MXU984	0.0010	Passed	0.2400	Passed
Bridgetown Regional Community School	127.1 - Handicap Washroom - 100023888	COF4119/MXV044	0.0077	Exceeds Limit	0.2000	Passed
Bridgetown Regional Community School	Hall-2 - Hallway 2nd Floor - 100021765	COF4229/MXW395	0.0000	Passed	0.1400	Passed
Bridgetown Regional Community School	210 - Janitor Room - 100021763	COF4229/MXW396	0.0058	Exceeds Limit	0.4600	Passed
Bridgetown Regional Community School	202 - Staff Room - 100021766	COF4229/MXW385	0.0000	Passed	0.1300	Passed
Bridgetown Regional Community School	202 - Staff Room - 100021767	COF4119/MXU987	0.0000	Passed	0.2500	Passed
Bridgetown Regional Community School	147 - Classroom - 100021811	COF4119/MXV031	0.4900	Exceeds Limit	0.9900	Passed
Bridgetown Regional Community School	Fountain - Fountain - 100024249	COF4119/MXV016	0.0000	Passed	0.0510	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bridgetown Regional Community School	147 - Classroom - 100021810	COF4119/MXV030	0.0015	Passed	0.2700	Passed
Bridgetown Regional Community School	147 - Classroom - 100021809	COF4119/MXV019	0.0025	Passed	0.2500	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021792	COF4119/MXV014	0.0014	Passed	0.3300	Passed
Bridgetown Regional Community School	192 - Classroom - 100021746	COF4229/MXW392	0.0010	Passed	0.3400	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021793	COF4119/MXV025	0.0013	Passed	0.2500	Passed
Bridgetown Regional Community School	151 - Music Room - 100021744	COF4229/MXW370	0.0006	Passed	0.1500	Passed
Bridgetown Regional Community School	U/S Boys W/R - Upstairs Boys Washroom - 100021759	COF4119/MXU983	0.0006	Passed	0.1800	Passed
Bridgetown Regional Community School	Recycle Room - Recycle Room - 100021703	COF4229/MXW383	0.0006	Passed	0.3000	Passed
Bridgetown Regional Community School	Elementary Girls W/R - Elementary Girls Washroom - 100021721	COF4119/MXU999	0.0000	Passed	0.2200	Passed
Bridgetown Regional Community School	Elementary Girls W/R - Elementary Girls Washroom - 100021722	COF4119/MXV002	0.0000	Passed	0.2300	Passed
Bridgetown Regional Community School	Elementary Boys W/R - Elementary Boys Washroom - 100021723	COF4229/MXW399	0.0000	Passed	0.1700	Passed
Bridgetown Regional Community School	Elementary Boys W/R - Elementary Boys Washroom - 100021724	COF4119/MXU991	0.0000	Passed	0.1600	Passed
Bridgetown Regional Community School	Elementary Boys W/R - Elementary Boys Washroom - 100021725	COF4229/MXW401	0.0000	Passed	0.1500	Passed
Bridgetown Regional Community School	Staff W/R - Staff Washroom - 100021726	COF4229/MXW402	0.0000	Passed	0.3600	Passed
Bridgetown Regional Community School	190 - Industrial Arts Shop - 100021727	COF4229/MXW403	0.0000	Passed	0.4000	Passed
Bridgetown Regional Community School	Girls W/R - Girls Washroom - 100021728	COF4229/MXW404	0.0000	Passed	0.2100	Passed
Bridgetown Regional Community School	Girls W/R - Girls Washroom - 100021729	COF4229/MXW405	0.0007	Passed	0.2100	Passed
Bridgetown Regional Community School	Recycle Room - Recycle Room - 100021702	COF4229/MXW375	0.0000	Passed	0.0940	Passed
Bridgetown Regional Community School	Girls W/R - Girls Washroom - 100021730	COF4229/MXW406	0.0007	Passed	0.1800	Passed
Bridgetown Regional Community School	Boys W/R - Boys Washroom - 100021731	COF4229/MXW407	0.0008	Passed	0.2500	Passed
Bridgetown Regional Community School	Boys W/R - Boys Washroom - 100021732	COF4119/MXV000	0.0006	Passed	0.2300	Passed
Bridgetown Regional Community School	137 - Chemistry Lab - 100021794	COF4119/MXV023	0.0010	Passed	0.2400	Passed
Bridgetown Regional Community School	106 - Classroom - 100021709	COF4229/MXW380	0.0017	Passed	0.1700	Passed
Bridgetown Regional Community School	210 - Janitor Room - 100021764	COF4119/MXU986	0.2200	Exceeds Limit	0.8700	Passed
Bridgetown Regional Community School	127.1 - Handicap Washroom - 100021738	COF4119/MXU973	0.0009	Passed	0.3500	Passed
Bridgetown Regional Community School	137A - Chemistry Lab Storage - 100021737	COF4229/MXW373	0.0100	Exceeds Limit	0.2600	Passed
Bridgetown Regional Community School	L/R - Change Room - 100021736	COF4119/MXU972	0.0009	Passed	0.2900	Passed
Bridgetown Regional Community School	130A - Janitor Room - 100021735	COF4229/MXW398	0.0097	Exceeds Limit	0.4400	Passed
Bridgetown Regional Community School	Boys W/R - Boys Washroom - 100021733	COF4119/MXU982	0.0005	Passed	0.1900	Passed
Bridgetown Regional Community School	108 - Classroom - 100021710	COF4229/MXW379	0.0000	Passed	0.1300	Passed
Bridgetown Regional Community School	Staff W/R - Staff Washroom - 100021734	COF4229/MXW400	0.0012	Passed	1.1000	Passed
Bridgetown Regional Community School	109 - Classroom - 100021708	COF4229/MXW381	0.0007	Passed	0.1300	Passed
Bridgetown Regional Community School	157 - Nutrition - 100021707	COF4119/MXU993	0.0008	Passed	0.2100	Passed
Bridgetown Regional Community School	107A - Janitor Room - 100021706	COF4119/MXU992	0.0008	Passed	0.4000	Passed
Bridgetown Regional Community School	104.1 - Learning Centre Washroom - 100021705	COF4119/MXU989	0.0000	Passed	0.2300	Passed
Bridgetown Regional Community School	102 - Learning Centre - 100021704	COF4229/MXW382	0.0000	Passed	0.1500	Passed
Bridgetown Regional Community School	115 - Classroom - 100021718	COF4229/MXW374	0.0006	Passed	0.1400	Passed
Bridgetown Regional Community School	111 - Classroom - 100021711	COF4229/MXW378	0.0009	Passed	0.2200	Passed
Bridgetown Regional Community School	184 - Janitor Room - 100021785	COF4119/MXV027	0.0013	Passed	0.3700	Passed
Bridgetown Regional Community School	Elementary Girls W/R - Elementary Girls Washroom - 100021720	COF4119/MXU998	0.0000	Passed	0.2200	Passed
Bridgetown Regional Community School	145 - Physics Lab - 100021780	COF4119/MXV022	0.0020	Passed	0.3400	Passed
Bridgetown Regional Community School	145 - Physics Lab - 100021781	COF4119/MXV045	0.0013	Passed	0.3000	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bridgetown Regional Community School	145 - Physics Lab - 100021782	COF4119/MXV024	0.0000	Passed	0.3100	Passed
Bridgetown Regional Community School	Resource Kitchen - Resource - 100021783	COF4229/MXW390	0.0007	Passed	0.1600	Passed
Bridgetown Regional Community School	190 - Industrial Arts Shop - 100021778	COF4119/MXV020	0.1400	Exceeds Limit	0.6400	Passed
Bridgetown Regional Community School	152 - Kitchen - 100021739	COF4119/MXU974	0.0000	Passed	0.1500	Passed
Bridgetown Regional Community School	190 - Industrial Arts Shop - 100021777	COF4119/MXV039	0.0019	Passed	0.2300	Passed
Bridgetown Regional Community School	184 - Janitor Room - 100021786	COF4119/MXV028	0.1200	Exceeds Limit	0.6300	Passed
Bridgetown Regional Community School	186.1 - Washroom - 100021787	COF4119/MXV029	0.0000	Passed	0.4900	Passed
Bridgetown Regional Community School	Hall-1-N - Hallway 1st Floor North - 100021788	COF4229/MXW389	0.0000	Passed	0.0620	Passed
Bridgetown Regional Community School	158.1 - Change Room - 100021789	COF4119/MXV041	0.0000	Passed	0.3100	Passed
Bridgetown Regional Community School	159.1 - Change Room - 100021790	COF4119/MXV042	0.0006	Passed	0.3000	Passed
Bridgetown Regional Community School	L/R - Change Room - 100021791	COF4119/MXV043	0.0000	Passed	0.2000	Passed
Bridgetown Regional Community School	170C.1 - Main Office Staff Washroom - 100021784	COF4119/MXV034	0.0000	Passed	0.2700	Passed
Bridgetown Regional Community School	107A - Janitor Room - 100021771	COF4119/MXV001	0.1500	Exceeds Limit	0.7200	Passed
Bridgetown Regional Community School	114A.1 - Classroom Washroom - 100021717	COF4119/MXU996	0.0000	Passed	0.3200	Passed
Bridgetown Regional Community School	114 - Classroom - 100021716	COF4229/MXW384	0.0000	Passed	0.1200	Passed
Bridgetown Regional Community School	113A.1 - Classroom Washroom - 100021715	COF4119/MXU995	0.0000	Passed	0.2700	Passed
Bridgetown Regional Community School	Mechanical Room - Mechanical Room - 100021769	COF4119/MXV012	0.0006	Passed	0.1800	Passed
Bridgetown Regional Community School	145 - Physics Lab - 100021779	COF4119/MXV021	0.0008	Passed	0.3700	Passed
Bridgetown Regional Community School	113 - Classroom - 100021714	COF4229/MXW376	0.0007	Passed	0.1300	Passed
Bridgetown Regional Community School	115A.1 - Classroom Washroom - 100021719	COF4119/MXU997	0.0000	Passed	0.2800	Passed
Bridgetown Regional Community School	202 - Staff Room - 100021768	COF4119/MXU988	0.0000	Passed	0.3500	Passed
Bridgetown Regional Community School	130A - Janitor Room - 100021772	COF4119/MXV036	0.5700	Exceeds Limit	1.1000	Passed
Bridgetown Regional Community School	152 - Kitchen - 100021773	COF4229/MXW393	0.0000	Passed	0.2000	Passed
Bridgetown Regional Community School	152 - Kitchen - 100021774	COF4119/MXV038	0.0082	Exceeds Limit	0.4800	Passed
Bridgetown Regional Community School	157 - Nutrition - 100021775	COF4229/MXW412	0.0000	Passed	0.2700	Passed
Bridgetown Regional Community School	157 - Nutrition - 100021776	COF4229/MXW391	0.0006	Passed	0.2100	Passed
Bridgetown Regional Community School	Mechanical Room - Mechanical Room - 100021770	COF4119/MXU980	0.0019	Passed	0.1500	Passed
Brooklyn District Elementary School	Staff Room - Staff Room - 100022573	B9U1982/LDL917	0.0091	Exceeds Limit	1.1000	Passed
Brooklyn District Elementary School	Hall-1-E - Hallway 1st Floor East - 100022572	B9Z1966/LOL284	0.0000	Passed	1.2000	Passed
Brooklyn District Elementary School	28 - Science Room - 100023964	B9U1982/LDL916	0.0088	Exceeds Limit	0.8000	Passed
Brooklyn District Elementary School	Music - Music Room - 100023963	B9U1982/LDL912	0.0570	Exceeds Limit	0.9400	Passed
Brooklyn District Elementary School	5 - Classroom - 100022547	B9U1982/LDL909	0.0000	Passed	1.0000	Passed
Brooklyn District Elementary School	Kitchen - Kitchen - 100022563	B9U1982/LDL913	0.0340	Exceeds Limit	2.8000	Exceeds Limit
Brooklyn District Elementary School	Kitchen - Kitchen - 100022564	B9U1982/LDL914	0.0870	Exceeds Limit	0.7200	Passed
Brooklyn District Elementary School	Hall-1-W - Hallway 1st Floor West - 100022571	B9U1982/LDL910	0.0074	Exceeds Limit	2.5000	Exceeds Limit
Brooklyn District Elementary School	Hall-2-E - Hallway 2nd Floor East - 100022584	B9Z1966/LOL283	0.0068	Exceeds Limit	1.4000	Passed
Brooklyn District Elementary School	Kitchen - Kitchen - 100022565	B9U1982/LDL915	0.0110	Exceeds Limit	0.6200	Passed
Cambridge & District Elementary School	Hall-1 - Hallway 1st Floor - 100022331	B9U1614/LDJ122	0.0007	Passed	0.4000	Passed
Cambridge & District Elementary School	Kitchen - Kitchen - 100022595	COM3252/NMS232	0.0100	Exceeds Limit	0.2000	Passed
Cambridge & District Elementary School	103 - Classroom Washroom - 100022324	COM3252/NMS192	0.0012	Passed	0.0860	Passed
Cambridge & District Elementary School	102 - Classroom - 100022327	COM3252/NMS191	0.0066	Exceeds Limit	0.1900	Passed
Cambridge & District Elementary School	110 - Staff Room Washroom - 100022323	COM3252/NMS195	0.0290	Exceeds Limit	1.7000	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cambridge & District Elementary School	110 - Staff Room - 100022322	B9U1614/LDJ121	0.0043	Passed	0.0840	Passed
Cambridge & District Elementary School	Hall-1 - Hallway 1st Floor - 100022332	B9U1614/LDJ119	0.0000	Passed	0.4800	Passed
Cambridge & District Elementary School	104 - Pre-Primary Classroom Washroom - 100022330	C0M3252/NMS193	0.0035	Passed	0.0850	Passed
Cambridge & District Elementary School	Kitchen - Kitchen - 100022594	B9U1614/LDJ123	0.0038	Passed	0.1200	Passed
Cambridge & District Elementary School	Girls W/R - Girls Washroom - 100022586	C0M3252/NMS227	0.0055	Exceeds Limit	0.0870	Passed
Cambridge & District Elementary School	104 - Pre-Primary Classroom - 100022329	B9U1614/LDJ120	0.0025	Passed	0.0810	Passed
Cambridge & District Elementary School	105 - Classroom Washroom - 100022328	C0M3252/NMS194	0.0028	Passed	0.1300	Passed
Cambridge & District Elementary School	Female Staff W/R - Female Staff Washroom - 100022590	C0M3252/NMS198	0.0140	Exceeds Limit	0.1300	Passed
Cambridge & District Elementary School	101 - Classroom Washroom - 100022325	C0M3252/NMS190	0.0028	Passed	0.1000	Passed
Cambridge & District Elementary School	Hall-Gym - Hallway by Gym - 100023966	B9U1614/LDJ118	0.0019	Passed	0.0610	Passed
Cambridge & District Elementary School	Janitor Room - Janitor Room - 100022592	C0M3252/NMS230	0.0026	Passed	0.1200	Passed
Cambridge & District Elementary School	Girls W/R - Girls Washroom - 100022587	C0M3252/NMS228	0.0071	Exceeds Limit	0.0820	Passed
Cambridge & District Elementary School	Boys W/R - Boys Washroom - 100022588	C0M3252/NMS196	0.0067	Exceeds Limit	0.4300	Passed
Cambridge & District Elementary School	100 - Classroom Washroom - 100022326	C0M3252/NMS189	0.0021	Passed	0.1200	Passed
Cambridge & District Elementary School	Boys W/R - Boys Washroom - 100022589	C0M3252/NMS197	0.0027	Passed	0.3500	Passed
Cambridge & District Elementary School	Janitor Room - Janitor Room - 100022593	C0M3252/NMS231	0.0032	Passed	0.1200	Passed
Cambridge & District Elementary School	Male Staff W/R - Male Staff Washroom - 100022591	C0M3252/NMS233	0.0026	Passed	0.0970	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022431	C0G5324/NAG918	0.0960	Exceeds Limit	0.9400	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022430	C0G5324/NAG919	0.0770	Exceeds Limit	0.4000	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022429	C0G5324/NAG920	0.0640	Exceeds Limit	0.2700	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022428	C0G5324/NAG929	0.0160	Exceeds Limit	0.0920	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022427	C0G5324/NAG922	0.0850	Exceeds Limit	0.5800	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022426	C0G5324/NAG914	0.1100	Exceeds Limit	0.3300	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022425	C0G5324/NAG924	0.0970	Exceeds Limit	0.5900	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022423	C0G5324/NAG926	0.0180	Exceeds Limit	0.1600	Passed
Central Kings Rural High School	C105 - Main Lobby Boys Washroom - 100022436	C0G5324/NAG923	0.0016	Passed	0.1700	Passed
Central Kings Rural High School	C120 - Gym Office - 100022422	C0G5324/NAG927	20.0000	Exceeds Limit	42.0000	Exceeds Limit
Central Kings Rural High School	C123 - Gym Office - 100022420	C0G5324/NAG928	0.1100	Exceeds Limit	1.4000	Passed
Central Kings Rural High School	C123 - Gym Office - 100022419	C0G5324/NAG871	0.0290	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	C121 - Gym Teacher Office - 100022418	C0G5286/NAG553	0.0150	Exceeds Limit	0.2000	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022417	C0G5324/NAG887	0.0410	Exceeds Limit	0.1300	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022424	C0G5324/NAG925	0.0120	Exceeds Limit	0.1600	Passed
Central Kings Rural High School	C141 - General Science Classroom - 100022441	C0G5286/NAG566	0.0150	Exceeds Limit	0.3000	Passed
Central Kings Rural High School	Hall-2-C - Hallway 2nd Floor C-Wing - 100024269	C0G5294/NAG717	0.0150	Exceeds Limit	0.1400	Passed
Central Kings Rural High School	C141 - General Science Classroom - 100024256	C0G5294/NAG720	0.0010	Passed	0.2600	Passed
Central Kings Rural High School	Hall-2-B - Hallway 2nd Floor B-Wing - 100024270	C0G5294/NAG718	0.0008	Passed	0.1300	Passed
Central Kings Rural High School	C141 - General Science Classroom - 100024271	C0G5294/NAG719	1.4000	Exceeds Limit	0.6700	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022408	C0G5324/NAG851	0.0084	Exceeds Limit	0.1400	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022416	C0G5286/NAG564	0.0410	Exceeds Limit	0.1600	Passed
Central Kings Rural High School	C106 - Main Lobby Girls Washroom - 100022434	C0G5324/NAG937	0.0014	Passed	0.0720	Passed
Central Kings Rural High School	C147 - Washroom - 100022442	C0G5324/NAG940	0.0029	Passed	0.1300	Passed
Central Kings Rural High School	C129 - Senior Gym-Girls Locker Room - 100022432	C0G5324/NAG917	0.0520	Exceeds Limit	0.3700	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Central Kings Rural High School	C130 - Tech Ed. Room - 100022440	COG5324/NAG941	0.0290	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	C130 - Tech Ed. Room Washroom - 100022439	COG5324/NAG942	0.0087	Exceeds Limit	0.1800	Passed
Central Kings Rural High School	A128 - Janitor Room - 100022438	COG5324/NAG943	0.0079	Exceeds Limit	0.2700	Passed
Central Kings Rural High School	C103 - Main Lobby Janitor Room - 100022437	COG5324/NAG944	0.0000	Passed	0.1200	Passed
Central Kings Rural High School	C105 - Main Lobby Boys Washroom - 100022435	COG5324/NAG921	0.0000	Passed	0.1600	Passed
Central Kings Rural High School	C141 - General Science Classroom - 100024273	COG5294/NAG720	0.0010	Passed	0.2600	Passed
Central Kings Rural High School	C106 - Main Lobby Girls Washroom - 100022433	COG5324/NAG916	0.0006	Passed	0.0950	Passed
Central Kings Rural High School	C141 - General Science Classroom - 100024274	COG5294/NAG721	0.0610	Exceeds Limit	0.4700	Passed
Central Kings Rural High School	B215 - Biology Lab - 100022395	COG5286/NAG549	0.0260	Exceeds Limit	0.1700	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022386	COG5286/NAG556	0.0320	Exceeds Limit	0.1300	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022387	COG5286/NAG555	0.0290	Exceeds Limit	0.1400	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022388	COG5286/NAG548	0.0290	Exceeds Limit	0.1700	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022389	COG5286/NAG554	0.0180	Exceeds Limit	0.0850	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022390	COG5286/NAG561	0.0130	Exceeds Limit	0.0940	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022391	COG5286/NAG552	0.0280	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	Hall-2-C - Hallway 2nd Floor C-Wing - 100022370	COG5324/NAG826	0.0000	Passed	0.2300	Passed
Central Kings Rural High School	B215 - Biology Lab - 100022394	COG5286/NAG550	0.0260	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022383	COG5286/NAG559	0.2700	Exceeds Limit	0.1400	Passed
Central Kings Rural High School	B215 - Biology Lab - 100022396	COG5324/NAG848	0.0130	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022382	COG5286/NAG560	0.0270	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	B216 - Biology Lab Washroom - 100022397	COG5324/NAG850	0.0400	Exceeds Limit	0.2700	Passed
Central Kings Rural High School	B211 - Physics Lab - 100022402	COG5324/NAG840	0.0360	Exceeds Limit	0.1800	Passed
Central Kings Rural High School	Lobby - Front Lobby - 100022403	COG5324/NAG841	0.0000	Passed	0.0770	Passed
Central Kings Rural High School	C150 - Kitchen - 100022404	COG5324/NAG852	0.0100	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	C150 - Kitchen - 100022405	COG5324/NAG842	0.0230	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022392	COG5286/NAG551	0.0096	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022377	COG5324/NAG873	0.0370	Exceeds Limit	0.1600	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022414	COG5324/NAG845	0.0560	Exceeds Limit	0.2800	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022413	COG5324/NAG846	4.3000	Exceeds Limit	1.2000	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022412	COG5324/NAK528	0.0490	Exceeds Limit	0.1300	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022410	COG5324/NAG849	0.0490	Exceeds Limit	0.2700	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022409	COG5286/NAG562	0.0150	Exceeds Limit	0.1600	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022381	COG5324/NAG856	0.0260	Exceeds Limit	0.1300	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022380	COG5324/NAG876	0.0440	Exceeds Limit	0.1800	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022385	COG5286/NAG557	0.0250	Exceeds Limit	0.1700	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022378	COG5324/NAG872	0.0260	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022384	COG5286/NAG558	0.0320	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022376	COG5324/NAG874	0.0320	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022375	COG5324/NAG875	0.0360	Exceeds Limit	0.0990	Passed
Central Kings Rural High School	B218 - Art Room - 100022367	COG5324/NAG877	0.0170	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	Lower B-wing Staff W/R - Lower B-wing Staff Washroom - 100023737	COG5324/NAG882	0.0050	Exceeds Limit	0.0790	Passed
Central Kings Rural High School	C150 - Kitchen - 100022407	COG5324/NAG844	0.0530	Exceeds Limit	0.1400	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Central Kings Rural High School	C150 - Kitchen - 100022406	COG5324/NAG843	0.0200	Exceeds Limit	0.1100	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022415	COG5286/NAG565	0.0170	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	B206 - Chem Lab - 100022379	COG5324/NAG853	0.0350	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	Lower C-wing Girls W/R - Lower C-wing Girls Washroom - 100023724	COG5324/NAG893	0.0021	Passed	0.2400	Passed
Central Kings Rural High School	Lower B-Wing Staff W/R - Lower B-wing Staff Washroom - 100023738	COG5324/NAG904	0.0031	Passed	0.2100	Passed
Central Kings Rural High School	B105 - Lower B-wing Girls Washroom - 100023736	COG5324/NAG883	0.0110	Exceeds Limit	0.0730	Passed
Central Kings Rural High School	C117 - Senior Gym-Boys Locker Room - 100022411	COG5324/NAG854	0.0610	Exceeds Limit	0.1400	Passed
Central Kings Rural High School	B105 - Lower B-wing Girls Washroom - 100023734	COG5324/NAG885	0.0130	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	B104 - Lower B-wing Boys Washroom - 100023733	COG5324/NAG886	0.0064	Exceeds Limit	0.0970	Passed
Central Kings Rural High School	B104 - Lower B-wing Boys Washroom - 100023732	COG5324/NAG896	0.0250	Exceeds Limit	0.2200	Passed
Central Kings Rural High School	B104 - Lower B-wing Boys Washroom - 100023731	COG5324/NAG888	0.0069	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	Hall-1-B - Hallway 1st Floor B-Wing - 100023730	COG5286/NAG572	0.0000	Passed	0.1800	Passed
Central Kings Rural High School	Lower B-wing Janitor Room - Lower B-wing Janitor Room - 100023729	COG5324/NAG881	0.0033	Passed	0.0980	Passed
Central Kings Rural High School	Upper B-wing Boys W/R - Upper B-Wing Boys Washroom - 100023713	COG5324/NAG933	0.0150	Exceeds Limit	0.3500	Passed
Central Kings Rural High School	Lower C-wing Girls W/R - Lower C-wing Girls Washroom - 100023725	COG5324/NAG892	0.0017	Passed	0.2400	Passed
Central Kings Rural High School	C190 - Storage - 100023741	COG5324/NAG889	0.0007	Passed	0.1800	Passed
Central Kings Rural High School	Lower C-wing Boys W/R - Lower C-wing Boys Washroom - 100023723	COG5324/NAG894	0.0036	Passed	0.1000	Passed
Central Kings Rural High School	Lower C-wing Boys W/R - Lower C-wing Boys Washroom - 100023722	COG5324/NAG895	0.0019	Passed	0.1300	Passed
Central Kings Rural High School	Lower C-wing Boys W/R - Lower C-wing Boys Washroom - 100023721	COG5324/NAG915	0.0024	Passed	0.1200	Passed
Central Kings Rural High School	Lower C-wing Boys W/R - Lower C-wing Boys Washroom - 100023720	COG5324/NAG939	0.0220	Exceeds Limit	0.4200	Passed
Central Kings Rural High School	A126 - - 100023719	COG5286/NAG570	0.0000	Passed	0.1600	Passed
Central Kings Rural High School	A223 - - 100023718	COG5324/NAG912	0.0000	Passed	0.3300	Passed
Central Kings Rural High School	C215 - - 100023717	COG5324/NAG932	0.0470	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	Hall-2-C - Hallway 2nd Floor C-Wing - 100023716	COG5286/NAG569	0.0110	Exceeds Limit	0.1400	Passed
Central Kings Rural High School	B219 - - 100023715	COG5286/NAG568	0.5200	Exceeds Limit	0.2100	Passed
Central Kings Rural High School	B219 - - 100023714	COG5286/NAG567	0.4000	Exceeds Limit	0.1700	Passed
Central Kings Rural High School	Lower C-wing Girls W/R - Lower C-wing Girls Washroom - 100023727	COG5324/NAG890	0.0015	Passed	0.2000	Passed
Central Kings Rural High School	Middle School Gym Girls L/R - Middle School Gym Girls Locker Room - 100023751	COG5324/NAG902	0.0035	Passed	0.0840	Passed
Central Kings Rural High School	C239 - Staff Room - 100022333	COG5324/NAG837	0.0027	Passed	0.2000	Passed
Central Kings Rural High School	C239 - Staff Room Washroom - 100022334	COG5286/NAG563	0.0032	Passed	0.2000	Passed
Central Kings Rural High School	C239 - Staff Room Washroom - 100022335	COG5324/NAG869	0.0017	Passed	0.1200	Passed
Central Kings Rural High School	C237 - Work Room - 100022336	COG5324/NAG827	0.0016	Passed	0.2300	Passed
Central Kings Rural High School	C221 - Janitor Room - 100022337	COG5324/NAG868	0.0013	Passed	0.1500	Passed
Central Kings Rural High School	C218 - Classroom - 100022338	COG5324/NAG867	0.0110	Exceeds Limit	0.1100	Passed
Central Kings Rural High School	B105 - Lower B-wing Girls Washroom - 100023735	COG5324/NAG884	0.0360	Exceeds Limit	0.8000	Passed
Central Kings Rural High School	A143 - Middle School Gym Office Washroom - 100023756	COG5324/NAG931	0.0000	Passed	0.2400	Passed
Central Kings Rural High School	Middle School Gym Girls L/R - Middle School Gym Girls Locker Room - 100023755	COG5324/NAG898	0.0044	Passed	0.2300	Passed
Central Kings Rural High School	Middle School Gym Girls L/R - Middle School Gym Girls Locker Room - 100023754	COG5324/NAG899	0.0040	Passed	0.1700	Passed
Central Kings Rural High School	Hall-1-C - Hallway 1st Floor C-Wing - 100023739	COG5324/NAG839	0.0220	Exceeds Limit	0.1300	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Central Kings Rural High School	Middle School Gym Girls L/R - Middle School Gym Girls Locker Room - 100023752	COG5324/NAG901	0.0210	Exceeds Limit	0.2800	Passed
Central Kings Rural High School	C146 - - 100023740	COG5324/NAG906	0.0140	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	Middle School Gym Girls L/R - Middle School Gym Girls Locker Room - 100023750	COG5324/NAG903	0.0029	Passed	0.1100	Passed
Central Kings Rural High School	Middle School Gym Boys L/R - Middle School Gym Boys Locker Room - 100023749	COG5324/NAG913	0.0290	Exceeds Limit	0.2200	Passed
Central Kings Rural High School	Middle School Gym Boys L/R - Middle School Gym Boys Locker Room - 100023748	COG5324/NAG905	0.0320	Exceeds Limit	0.8200	Passed
Central Kings Rural High School	Middle School Gym Boys L/R - Middle School Gym Boys Locker Room - 100023747	COG5324/NAG897	0.0098	Exceeds Limit	0.1600	Passed
Central Kings Rural High School	Middle School Gym Boys L/R - Middle School Gym Boys Locker Room - 100023746	COG5324/NAG907	0.0150	Exceeds Limit	0.4600	Passed
Central Kings Rural High School	Middle School Gym Boys L/R - Middle School Gym Boys Locker Room - 100023745	COG5324/NAG908	0.0022	Passed	0.0810	Passed
Central Kings Rural High School	Middle School Gym Boys L/R - Middle School Gym Boys Locker Room - 100023744	COG5324/NAG909	0.0036	Passed	0.0750	Passed
Central Kings Rural High School	New Imech Shop - New Imech Shop - 100023743	COG5324/NAG910	0.0008	Passed	0.4100	Passed
Central Kings Rural High School	C168 - Washroom - 100023742	COG5324/NAG911	0.0006	Passed	0.0550	Passed
Central Kings Rural High School	Lower C-wing Girls W/R - Lower C-wing Girls Washroom - 100023726	COG5324/NAG891	0.0021	Passed	0.2500	Passed
Central Kings Rural High School	Middle School Gym Girls L/R - Middle School Gym Girls Locker Room - 100023753	COG5324/NAG900	0.0480	Exceeds Limit	0.5300	Passed
Central Kings Rural High School	A204 - Upper A-wing Girls Washroom - 100022358	COG5324/NAG859	0.0021	Passed	0.1400	Passed
Central Kings Rural High School	C215 - Classroom - 100022347	COG5324/NAG834	0.0086	Exceeds Limit	0.3700	Passed
Central Kings Rural High School	C215 - Classroom - 100022348	COG5324/NAG835	0.0350	Exceeds Limit	0.3900	Passed
Central Kings Rural High School	C214 - Classroom - 100022349	COG5324/NAG836	0.0066	Exceeds Limit	0.1700	Passed
Central Kings Rural High School	A225 - Storage - 100022350	COG5324/NAG865	0.0045	Passed	0.2400	Passed
Central Kings Rural High School	B218 - Art Room - 100022365	COG5324/NAG878	0.1500	Exceeds Limit	0.0800	Passed
Central Kings Rural High School	A205 - Upper A-wing Boys Washroom - 100022353	COG5324/NAG855	0.0025	Passed	0.2300	Passed
Central Kings Rural High School	A205 - Upper A-wing Boys Washroom - 100022355	COG5324/NAG870	0.0019	Passed	0.2900	Passed
Central Kings Rural High School	C217 - Classroom - 100022345	COG5324/NAG833	0.0046	Passed	0.2500	Passed
Central Kings Rural High School	A204 - Upper A-wing Girls Washroom - 100022357	COG5324/NAG860	0.0029	Passed	0.4700	Passed
Central Kings Rural High School	A207 - Senior Resource Room - 100022352	COG5324/NAG838	0.0070	Exceeds Limit	0.3100	Passed
Central Kings Rural High School	A204 - Upper A-wing Girls Washroom - 100022359	COG5324/NAG858	0.0045	Passed	0.5600	Passed
Central Kings Rural High School	A204 - Upper A-wing Girls Washroom - 100022360	COG5324/NAG857	0.0016	Passed	0.2200	Passed
Central Kings Rural High School	B213 - Bio Lab - 100022362	COG5324/NAG862	0.0520	Exceeds Limit	0.1500	Passed
Central Kings Rural High School	B213 - Bio Lab - 100022363	COG5324/NAG864	0.0290	Exceeds Limit	0.1900	Passed
Central Kings Rural High School	B213 - Bio Lab - 100022364	COG5324/NAG879	0.0260	Exceeds Limit	0.2000	Passed
Central Kings Rural High School	Upper B-wing Boys W/R - Upper B-Wing Boys Washroom - 100023712	COG5324/NAG934	0.0066	Exceeds Limit	0.1200	Passed
Central Kings Rural High School	Hall-1-C - Hallway 1st Floor C-Wing - 100023728	COG5286/NAG571	0.0000	Passed	1.9000	Passed
Central Kings Rural High School	A205 - Upper A-wing Boys Washroom - 100022356	COG5324/NAG861	0.0020	Passed	0.2800	Passed
Central Kings Rural High School	C240 - Washroom - 100023707	COG5324/NAG930	0.0093	Exceeds Limit	0.1600	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Central Kings Rural High School	Upper B-wing Boys W/R - Upper B-Wing Boys Washroom - 100023711	COG5324/NAG935	0.0130	Exceeds Limit	0.1100	Passed
Central Kings Rural High School	Upper B-wing Girls W/R - Upper B-wing Girls Washroom - 100023710	COG5324/NAG936	0.0170	Exceeds Limit	0.2200	Passed
Central Kings Rural High School	A205 - Upper A-wing Boys Washroom - 100022354	COG5324/NAG863	0.0017	Passed	0.2300	Passed
Central Kings Rural High School	Upper B-wing Girls W/R - Upper B-wing Girls Washroom - 100023708	COG5324/NAG938	0.0059	Exceeds Limit	0.0980	Passed
Central Kings Rural High School	C217 - Classroom - 100022344	COG5324/NAG832	0.0140	Exceeds Limit	0.2800	Passed
Central Kings Rural High School	C218 - Classroom - 100022339	COG5324/NAG866	0.0120	Exceeds Limit	0.0750	Passed
Central Kings Rural High School	C217 - Classroom - 100022340	COG5324/NAG828	0.0190	Exceeds Limit	0.2100	Passed
Central Kings Rural High School	C217 - Classroom - 100022342	COG5324/NAG830	0.0100	Exceeds Limit	0.2200	Passed
Central Kings Rural High School	C217 - Classroom - 100022341	COG5324/NAG829	0.0130	Exceeds Limit	0.2400	Passed
Central Kings Rural High School	Upper B-wing Girls W/R - Upper B-wing Girls Washroom - 100023709	COG5324/NAG945	0.0062	Exceeds Limit	0.0920	Passed
Central Kings Rural High School	C217 - Classroom - 100022343	COG5324/NAG831	0.0096	Exceeds Limit	0.3500	Passed
Champlain Elementary School	7 - Primary - 100023980	COJ8174/NHI478	0.0007	Passed	0.0570	Passed
Champlain Elementary School	5 - Primary - 100023978	COJ8174/NHI469	0.0000	Passed	0.0740	Passed
Champlain Elementary School	77 - Kitchen - 100024267	COJ8174/NHI485	0.0046	Passed	0.1300	Passed
Champlain Elementary School	7 - Primary - 100023979	COJ8174/NHI477	0.0006	Passed	0.0730	Passed
Champlain Elementary School	6 - Primary - 100023981	COJ8174/NHI473	0.0013	Passed	0.0860	Passed
Champlain Elementary School	6 - Primary - 100023982	COJ8174/NHI474	0.0000	Passed	0.0540	Passed
Champlain Elementary School	4 - Primary - 100023983	COJ8174/NHI462	0.0000	Passed	0.0700	Passed
Champlain Elementary School	2 - Learning Support - 100023984	COJ8174/NHI448	0.0000	Passed	0.1100	Passed
Champlain Elementary School	35 - Asst. Care WR - 100023985	COJ8174/NHI456	0.0000	Passed	0.0810	Passed
Champlain Elementary School	1 - Classroom - 100023986	COJ8174/NHI441	0.0000	Passed	0.0900	Passed
Champlain Elementary School	60 - Library - 100024268	COJ8174/NHI486	0.0009	Passed	0.1800	Passed
Champlain Elementary School	3 - Classroom - 100023976	COJ8174/NHI454	0.0000	Passed	0.0620	Passed
Champlain Elementary School	21 - Sick Room - 100023974	COJ8174/NHI449	0.0006	Passed	0.0500	Passed
Champlain Elementary School	9 - Classroom - 100024017	COJ8174/NHI484	0.0005	Passed	0.0840	Passed
Champlain Elementary School	27 - Staff - 100023975	COJ8174/NHI453	0.0014	Passed	0.0570	Passed
Champlain Elementary School	67 - Boys Change Room - 100024016	COJ8174/NHI475	0.0000	Passed	0.1100	Passed
Champlain Elementary School	68 - Girls Change Room - 100024015	COJ8174/NHI476	0.0000	Passed	0.1000	Passed
Champlain Elementary School	43 - Boys WR - 100024014	COJ8174/NHI465	0.0006	Passed	0.1000	Passed
Champlain Elementary School	43 - Boys WR - 100024013	COJ8174/NHI464	0.0012	Passed	0.1100	Passed
Champlain Elementary School	44 - Girls WR - 100024012	COJ8174/NHI467	0.0000	Passed	0.0870	Passed
Champlain Elementary School	25 - WC - 100023987	COJ8174/NHI452	0.0000	Passed	0.0960	Passed
Champlain Elementary School	44 - Girls WR - 100024011	COJ8174/NHI466	0.0006	Passed	0.1100	Passed
Champlain Elementary School	5 - Primary - 100023977	COJ8174/NHI468	0.0006	Passed	0.0760	Passed
Champlain Elementary School	10 - Classroom - 100024008	COJ8174/NHI442	0.0540	Exceeds Limit	0.7200	Passed
Champlain Elementary School	15 - Music/Art Room - 100023998	COJ8174/NHI447	0.0012	Passed	0.0900	Passed
Champlain Elementary School	75 - Recycle Storage - 100023999	COJ8174/NHI479	0.0000	Passed	0.1200	Passed
Champlain Elementary School	77 - Kitchen - 100024000	COJ8174/NHI480	0.0000	Passed	0.0820	Passed
Champlain Elementary School	78 - Kitchen - 100024001	COJ8174/NHI481	0.0055	Exceeds Limit	0.1200	Passed
Champlain Elementary School	57 - Office/Store - 100024002	COJ8174/NHI472	0.0000	Passed	0.0780	Passed
Champlain Elementary School	54 - Seminar Room - 100024003	COJ8174/NHI471	0.0024	Passed	0.0820	Passed
Champlain Elementary School	80 - Janitor - 100023997	COJ8174/NHI483	0.0014	Passed	0.0800	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Champlain Elementary School	11 - Language Classroom - 100024004	COJ8174/NHI443	0.0019	Passed	0.1000	Passed
Champlain Elementary School	13 - Classroom - 100024005	COJ8174/NHI445	0.0084	Exceeds Limit	0.2600	Passed
Champlain Elementary School	12 - Classroom - 100024007	COJ8174/NHI444	0.0130	Exceeds Limit	0.1800	Passed
Champlain Elementary School	24 - WC - 100023988	COJ8174/NHI451	0.0000	Passed	0.0740	Passed
Champlain Elementary School	8 - Classroom - 100024009	COJ8174/NHI482	0.0014	Passed	0.0650	Passed
Champlain Elementary School	39 - North Corr - 100023996	COJ8174/NHI461	0.0014	Passed	0.1300	Passed
Champlain Elementary School	32 - East Corridor - 100023995	COJ8174/NHI455	0.0000	Passed	0.0560	Passed
Champlain Elementary School	38 - Girls WR - 100023994	COJ8174/NHI460	0.0000	Passed	0.1000	Passed
Champlain Elementary School	38 - Girls WR - 100023993	COJ8174/NHI459	0.0000	Passed	0.0740	Passed
Champlain Elementary School	37 - Boys WR - 100023992	COJ8174/NHI458	0.0000	Passed	0.0820	Passed
Champlain Elementary School	37 - Boys WR - 100023991	COJ8174/NHI457	0.0000	Passed	0.1100	Passed
Champlain Elementary School	51 - West Corridor - 100024010	COJ8174/NHI470	0.0000	Passed	0.0540	Passed
Champlain Elementary School	4 - Primary - 100023990	COJ8174/NHI463	0.0000	Passed	0.0960	Passed
Champlain Elementary School	23 - WC - 100023989	COJ8174/NHI450	0.0007	Passed	0.0530	Passed
Champlain Elementary School	14 - Classroom - 100024006	COJ8174/NHI446	0.0007	Passed	0.0920	Passed
Clark Rutherford Memorial School	19A - Kitchen - 100023883	COK1729/NID381	0.0027	Passed	0.1400	Passed
Clark Rutherford Memorial School	9 - Girls Washroom - 100022029	COK1729/NID383	0.0040	Passed	0.1200	Passed
Clark Rutherford Memorial School	11 - Janitor Room - 100022027	COK1729/NID373	0.0008	Passed	0.0180	Passed
Clark Rutherford Memorial School	19A - Kitchen - 100023862	COK1729/NID388	0.0043	Passed	0.1400	Passed
Clark Rutherford Memorial School	20 - Pre-Primary Classroom - 100022016	COK1729/NID379	0.0000	Passed	0.0023	Passed
Clark Rutherford Memorial School	20 - Pre-Primary Classroom - 100022017	COK1729/NID389	0.0510	Exceeds Limit	0.2800	Passed
Clark Rutherford Memorial School	21 - Pre-Primary Classroom - 100022019	COK1729/NID390	0.0000	Passed	0.0040	Passed
Clark Rutherford Memorial School	15 - Boys Washroom - 100022021	COK1729/NID375	0.0067	Exceeds Limit	0.3000	Passed
Clark Rutherford Memorial School	1A - Classroom Washroom - 100023863	COK1729/NID387	0.0000	Passed	0.0027	Passed
Clark Rutherford Memorial School	13 - Girls Washroom - 100022024	COK1729/NID378	0.0067	Exceeds Limit	0.1200	Passed
Clark Rutherford Memorial School	16 - Staff Washroom - 100022020	COK1729/NID374	0.0064	Exceeds Limit	0.0670	Passed
Clark Rutherford Memorial School	12 - Staff Room - 100022025	B9U1935/LDL583	0.0012	Passed	0.0930	Passed
Clark Rutherford Memorial School	12 - Staff Room Washroom - 100022026	COK1729/NID380	0.0080	Exceeds Limit	0.1300	Passed
Clark Rutherford Memorial School	11 - Janitor Room - 100022028	COK1729/NID382	0.0029	Passed	0.0330	Passed
Clark Rutherford Memorial School	6 - Boys Washroom - 100022031	COK1729/NID385	0.0028	Passed	0.0390	Passed
Clark Rutherford Memorial School	6 - Boys Washroom - 100022032	COK1729/NID386	0.0033	Passed	0.0420	Passed
Clark Rutherford Memorial School	9 - Girls Washroom - 100022030	COK1729/NID384	0.0031	Passed	0.1000	Passed
Clark Rutherford Memorial School	13 - Girls Washroom - 100022023	COK1729/NID377	0.0040	Passed	0.1100	Passed
Clark Rutherford Memorial School	15 - Boys Washroom - 100022022	COK1729/NID376	0.0055	Exceeds Limit	0.2800	Passed
Coldbrook & District School	Cafeteria/Kitchen - Cafeteria/Kitchen - 100022630	COC2952/MRD651	0.0050	Exceeds Limit	1.6000	Passed
Coldbrook & District School	C3 - Classroom - 100022314	COC2952/MRD678	0.0170	Exceeds Limit	0.8800	Passed
Coldbrook & District School	Cafeteria/Kitchen - Cafeteria/Kitchen - 100022631	COC2952/MRD652	0.0094	Exceeds Limit	1.3000	Passed
Coldbrook & District School	A14 - Classroom - 100022302	COC2952/MRD665	0.0580	Exceeds Limit	1.0000	Passed
Coldbrook & District School	B14(?) - Art Classroom - 100022318	COC2952/MRD676	0.0042	Passed	0.8500	Passed
Coldbrook & District School	Hall-1-A - Hallway 1st Floor A-Wing - 100023902	COC2952/MRD670	0.0056	Exceeds Limit	1.1000	Passed
Coldbrook & District School	Staff Room - Staff Room - 100022614	COC2952/MRD667	0.0000	Passed	2.3000	Exceeds Limit
Coldbrook & District School	Hall-1-A - Hallway 1st Floor A-Wing - 100023903	COC2952/MRD671	0.0200	Exceeds Limit	0.9300	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Coldbrook & District School	Lobby - Main Lobby - 100023900	COC2952/MRD673	0.0000	Passed	0.8000	Passed
Coldbrook & District School	C2 - Classroom - 100022312	COC2952/MRD679	0.0075	Exceeds Limit	0.4200	Passed
Coldbrook & District School	Hall-1-B - Hallway 1st Floor B-Wing - 100022321	COC2952/MRD680	0.0000	Passed	0.8600	Passed
Coldbrook & District School	Industrial Arts Shop - Industrial Arts Shop - 100022625	COC2952/MRD656	0.0110	Exceeds Limit	1.2000	Passed
Coldbrook & District School	Music - Music Room - 100022628	COC2952/MRD655	0.0028	Passed	0.7900	Passed
Coldbrook & District School	Waste Disposal Room - Waste Disposal Room - 100022629	COC2952/MRD654	0.0100	Exceeds Limit	1.5000	Passed
Coldbrook & District School	B12 - Classroom - 100022319	COC2952/MRD674	0.0065	Exceeds Limit	1.3000	Passed
Coldbrook & District School	A2 - Pre-Primary Classroom - 100022306	COC2952/MRD663	0.0100	Exceeds Limit	1.4000	Passed
Coldbrook & District School	Home Economics - Home Economics - 100022624	COC2952/MRD658	0.0100	Exceeds Limit	0.9900	Passed
Coldbrook & District School	A11 - Classroom - 100022300	COC2952/MRD666	0.0050	Exceeds Limit	3.4000	Exceeds Limit
Coldbrook & District School	Home Economics - Home Economics - 100022623	COC2952/MRD657	0.0280	Exceeds Limit	1.3000	Passed
Coldbrook & District School	Home Economics - Home Economics - 100022622	COC2952/MRD662	0.0170	Exceeds Limit	1.1000	Passed
Coldbrook & District School	Home Economics - Home Economics - 100022621	COC2952/MRD659	0.0190	Exceeds Limit	0.8400	Passed
Coldbrook & District School	Cafeteria/Kitchen - Cafeteria/Kitchen - 100022632	COC2952/MRD653	0.0094	Exceeds Limit	2.0000	Exceeds Limit
Coldbrook & District School	A12 - Classroom - 100022304	COC2952/MRD664	0.0026	Passed	1.1000	Passed
Coldbrook & District School	Janitor Room - Janitor Room U/S next to boys w/r - 100023901	COC2952/MRD669	0.0120	Exceeds Limit	2.1000	Exceeds Limit
Coldbrook & District School	A1 - Classroom - 100022308	COC2952/MRD675	0.0300	Exceeds Limit	0.9100	Passed
Coldbrook & District School	C1 - Classroom - 100022310	COC2952/MRD668	0.0220	Exceeds Limit	0.8400	Passed
Coldbrook & District School	Home Economics - Home Economics - 100022619	COC2952/MRD661	0.0570	Exceeds Limit	1.1000	Passed
Coldbrook & District School	Hall-1 - Hallway 1st Floor - 100023904	COC2952/MRD672	0.0000	Passed	0.8800	Passed
Coldbrook & District School	C4 - Classroom - 100022316	COC2952/MRD677	0.0210	Exceeds Limit	0.4500	Passed
Coldbrook & District School	Home Economics - Home Economics - 100022620	COC2952/MRD660	0.0420	Exceeds Limit	1.1000	Passed
Dr. Arthur Hines Elementary School	Boys W/R - Boys Washroom - 100022675	COM1447/NMH560	0.0110	Exceeds Limit	0.0630	Passed
Dr. Arthur Hines Elementary School	Boys W/R - Boys Washroom - 100022676	COM1447/NMH561	0.0089	Exceeds Limit	0.0870	Passed
Dr. Arthur Hines Elementary School	Hall-1 - Hallway 1st Floor - 100022674	COM1447/NMH569	0.0022	Passed	0.2700	Passed
Dr. Arthur Hines Elementary School	Janitor Room - Janitor Room - 100022673	COM1447/NMH573	0.0470	Exceeds Limit	1.0000	Passed
Dr. Arthur Hines Elementary School	Janitor Room - Janitor Room - 100022672	COM1447/NMH572	0.2900	Exceeds Limit	4.2000	Exceeds Limit
Dr. Arthur Hines Elementary School	Kitchen - Kitchen - 100023582	COM1447/NMH574	0.0051	Exceeds Limit	0.1700	Passed
Dr. Arthur Hines Elementary School	Kitchen - Kitchen - 100023583	COM1447/NMH575	0.0130	Exceeds Limit	0.1800	Passed
Dr. Arthur Hines Elementary School	Kitchen - Kitchen - 100023584	COM1447/NMH576	0.1200	Exceeds Limit	0.2700	Passed
Dr. Arthur Hines Elementary School	Boys W/R - Boys Washroom - 100022677	COM1447/NMH562	0.0057	Exceeds Limit	0.0580	Passed
Dr. Arthur Hines Elementary School	Guidance/Meeting Room - Guidance/Meeting Room - 100022685	COM1447/NMH568	0.0250	Exceeds Limit	0.4400	Passed
Dr. Arthur Hines Elementary School	W/R - Wheelchair Washroom - 100023581	COM1447/NMH580	0.0380	Exceeds Limit	0.6100	Passed
Dr. Arthur Hines Elementary School	Boys W/R - Boys Washroom - 100022678	COM1447/NMH563	0.0150	Exceeds Limit	0.0660	Passed
Dr. Arthur Hines Elementary School	Staff Room - Staff Room - 100023586	COM1447/NMH578	0.0390	Exceeds Limit	0.5700	Passed
Dr. Arthur Hines Elementary School	2 - Classroom - 100023587	COM1447/NMH559	0.0220	Exceeds Limit	0.3800	Passed
Dr. Arthur Hines Elementary School	Staff Room - Staff Room - 100023585	COM1447/NMH577	0.0890	Exceeds Limit	0.4900	Passed
Dr. Arthur Hines Elementary School	Hall-1 - Hallway 1st Floor - 100022679	COM1447/NMH570	0.0010	Passed	0.1300	Passed
Dr. Arthur Hines Elementary School	Girls W/R - Girls Washroom - 100022680	COM1447/NMH564	0.0320	Exceeds Limit	0.7800	Passed
Dr. Arthur Hines Elementary School	Girls W/R - Girls Washroom - 100022681	COM1447/NMH565	0.0610	Exceeds Limit	0.8300	Passed
Dr. Arthur Hines Elementary School	Girls W/R - Girls Washroom - 100022682	COM1447/NMH566	0.0490	Exceeds Limit	0.8300	Passed
Dr. Arthur Hines Elementary School	Hall-1 - Hallway 1st Floor - 100022684	COM1447/NMH571	0.0040	Passed	0.2900	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dr. Arthur Hines Elementary School	Staff W/R - Staff Washroom - 100022686	COM1447/NMH579	0.0130	Exceeds Limit	0.2700	Passed
Dr. Arthur Hines Elementary School	Girls W/R - Girls Washroom - 100022683	COM1447/NMH567	0.0230	Exceeds Limit	0.5300	Passed
Dwight Ross Elementary School	135 - After School Program Room - 100023615	COF3753/MXT187	0.0170	Exceeds Limit	0.2700	Passed
Dwight Ross Elementary School	Principal Office - Principal Office - 100023599	COF3753/MXT156	0.0058	Exceeds Limit	0.3800	Passed
Dwight Ross Elementary School	113 - Girls Washroom - 100022658	COF3753/MXT157	0.0350	Exceeds Limit	0.3300	Passed
Dwight Ross Elementary School	Hall-2 - Hallway 2nd Floor - 100023621	COF3753/MXT150	0.0025	Passed	0.3300	Passed
Dwight Ross Elementary School	135 - After School Program Room - 100023620	COF3753/MXT174	0.6800	Exceeds Limit	0.5700	Passed
Dwight Ross Elementary School	135 - After School Program Room - 100023617	COF3753/MXT185	0.0400	Exceeds Limit	0.2100	Passed
Dwight Ross Elementary School	135 - After School Program Room - 100023614	COF3753/MXT188	0.0130	Exceeds Limit	0.3200	Passed
Dwight Ross Elementary School	133 - School Counselor Room - 100023611	COF3753/MXT191	0.0110	Exceeds Limit	0.3100	Passed
Dwight Ross Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100023610	COF3753/MXT163	0.0074	Exceeds Limit	0.2400	Passed
Dwight Ross Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100023609	COF3753/MXT162	0.0170	Exceeds Limit	0.2200	Passed
Dwight Ross Elementary School	111 - Downstairs Janitor Room - 100023608	B9U2257/LDN590	0.0010	Passed	0.1100	Passed
Dwight Ross Elementary School	Lobby - Main Lobby - 100023595	B9U2257/LDN587	0.0018	Passed	0.3700	Passed
Dwight Ross Elementary School	- Washroom - 100023596	COF3753/MXT165	0.0750	Exceeds Limit	0.2800	Passed
Dwight Ross Elementary School	113 - Girls Washroom - 100022659	COF3753/MXT172	0.0300	Exceeds Limit	0.3100	Passed
Dwight Ross Elementary School	Hall-1-E - Hallway 1st Floor East - 100023598	COF3753/MXT164	0.2000	Exceeds Limit	0.4900	Passed
Dwight Ross Elementary School	135 - After School Program Room - 100023616	COF3753/MXT186	0.0390	Exceeds Limit	0.3300	Passed
Dwight Ross Elementary School	Pre-Primary W/R - Pre-Primary Classroom Washroom - 100023600	COF3753/MXT173	0.0048	Passed	0.1100	Passed
Dwight Ross Elementary School	138 - Pre-Primary Classroom - 100023601	COF3753/MXT152	0.0021	Passed	0.1900	Passed
Dwight Ross Elementary School	W/R - Washroom - 100023602	COF3753/MXT161	0.0043	Passed	0.3100	Passed
Dwight Ross Elementary School	124 - Cafeteria Kitchen - 100023603	COF3753/MXT160	0.0027	Passed	0.5400	Passed
Dwight Ross Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100023607	COF3753/MXT183	0.0078	Exceeds Limit	0.2500	Passed
Dwight Ross Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100023606	COF3753/MXT158	0.0270	Exceeds Limit	0.4300	Passed
Dwight Ross Elementary School	124 - Cafeteria Kitchen - 100023605	COF3753/MXT151	0.0150	Exceeds Limit	0.4400	Passed
Dwight Ross Elementary School	124 - Cafeteria Kitchen - 100023604	COF3753/MXT159	0.0040	Passed	0.3500	Passed
Dwight Ross Elementary School	Hall-1-W - Hallway 1st Floor West - 100022657	COF3753/MXT154	0.0310	Exceeds Limit	0.4500	Passed
Dwight Ross Elementary School	Hall-1-W - Hallway 1st Floor West - 100022656	COF3753/MXT155	0.0140	Exceeds Limit	0.4200	Passed
Dwight Ross Elementary School	218 - Learning Centre - 100023623	COF3753/MXT148	0.0024	Passed	0.1600	Passed
Dwight Ross Elementary School	119 - Boiler Room - 100023597	COF3753/MXT153	0.0140	Exceeds Limit	0.1900	Passed
Dwight Ross Elementary School	221 - Upstairs Girls Washroom - 100023631	COF3753/MXT176	0.0700	Exceeds Limit	0.4500	Passed
Dwight Ross Elementary School	Hall-2 - Hallway 2nd Floor - 100023622	COF3753/MXT149	0.0140	Exceeds Limit	0.3400	Passed
Dwight Ross Elementary School	218 - Learning Centre - 100023624	COF3753/MXT192	0.0310	Exceeds Limit	0.2700	Passed
Dwight Ross Elementary School	218 - Learning Centre - 100023625	COF3753/MXT182	0.0150	Exceeds Limit	0.6100	Passed
Dwight Ross Elementary School	224 - Upstairs Boys Washroom - 100023626	COF3753/MXT181	0.0260	Exceeds Limit	0.2700	Passed
Dwight Ross Elementary School	224 - Upstairs Boys Washroom - 100023627	COF3753/MXT180	0.0330	Exceeds Limit	0.3300	Passed
Dwight Ross Elementary School	224 - Upstairs Boys Washroom - 100023628	COF3753/MXT179	0.0110	Exceeds Limit	0.3100	Passed
Dwight Ross Elementary School	134 - Washroom - 100023612	COF3753/MXT190	0.0130	Exceeds Limit	0.2200	Passed
Dwight Ross Elementary School	221 - Upstairs Girls Washroom - 100023630	COF3753/MXT177	0.0076	Exceeds Limit	0.1700	Passed
Dwight Ross Elementary School	113 - Girls Washroom - 100022660	COF3753/MXT171	0.0130	Exceeds Limit	0.4100	Passed
Dwight Ross Elementary School	221 - Upstairs Girls Washroom - 100023632	COF3753/MXT175	0.0300	Exceeds Limit	0.2900	Passed
Dwight Ross Elementary School	221 - Upstairs Girls Washroom - 100023633	COF3753/MXT184	0.0480	Exceeds Limit	0.2600	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dwight Ross Elementary School	202 - Staff Room U/S - 100023634	COF3753/MXT147	0.0150	Exceeds Limit	0.1900	Passed
Dwight Ross Elementary School	U/S Staff W/R - Upstairs Staff Washroom - 100023635	COF3753/MXT146	0.1100	Exceeds Limit	0.4400	Passed
Dwight Ross Elementary School	U/S Staff W/R - Upstairs Staff Washroom - 100023636	COF3753/MXT145	0.0360	Exceeds Limit	0.3600	Passed
Dwight Ross Elementary School	117 - Boys Washroom - 100022665	COF3753/MXT166	0.0110	Exceeds Limit	0.1700	Passed
Dwight Ross Elementary School	224 - Upstairs Boys Washroom - 100023629	COF3753/MXT178	0.0058	Exceeds Limit	0.1800	Passed
Dwight Ross Elementary School	117 - Boys Washroom - 100022662	COF3753/MXT169	0.0033	Passed	0.1300	Passed
Dwight Ross Elementary School	117 - Boys Washroom - 100022663	COF3753/MXT168	0.0078	Exceeds Limit	0.1700	Passed
Dwight Ross Elementary School	117 - Boys Washroom - 100022664	COF3753/MXT167	0.0160	Exceeds Limit	0.1600	Passed
Dwight Ross Elementary School	134 - Washroom - 100023613	COF3753/MXT189	0.0260	Exceeds Limit	0.4900	Passed
Dwight Ross Elementary School	139 - Pre-Primary Classroom - 100022666	B9U2257/LDN589	0.0018	Passed	0.0530	Passed
Dwight Ross Elementary School	113 - Girls Washroom - 100022661	COF3753/MXT170	0.0150	Exceeds Limit	0.2800	Passed
Evangeline Middle School	3 - Staff Room - 100022296	COG5983/NAK298	0.0063	Exceeds Limit	1.0000	Passed
Evangeline Middle School	3 - Staff Room - 100022297	COG5983/NAK297	0.0130	Exceeds Limit	0.7400	Passed
Evangeline Middle School	Janitor Room - Janitor Room - 100023868	COG5983/NAK287	0.0093	Exceeds Limit	0.3700	Passed
Evangeline Middle School	19 - Resource Room - 100022298	COC5972/MRV044	0.0210	Exceeds Limit	1.0000	Passed
Evangeline Middle School	Main Office W/R - Main Office Staff Washroom - 100022294	COG5983/NAK290	0.0083	Exceeds Limit	0.7500	Passed
Evangeline Middle School	Hall-1 - Fountain - 100022293	COC5972/MRV042	0.0007	Passed	0.1800	Passed
Evangeline Middle School	12 - Industrial Arts Shop - 100022299	COC5972/MRV045	0.0037	Passed	0.6400	Passed
Evangeline Middle School	3 - Staff Room - 100022295	COC5972/MRV043	0.0016	Passed	0.8300	Passed
Evangeline Middle School	Girls W/R - Girls Washroom - 100023867	COG5983/NAK288	0.0140	Exceeds Limit	0.4000	Passed
Evangeline Middle School	Boys W/R - Boys W/R - 100023866	COG5983/NAK289	0.0130	Exceeds Limit	0.5900	Passed
Evangeline Middle School	Boys W/R - Boys Washroom - 100023864	COG5983/NAK291	0.3500	Exceeds Limit	2.4000	Exceeds Limit
Evangeline Middle School	Family Studies Room - Family Studies Room - 100022671	COC5972/MRV049	0.0140	Exceeds Limit	0.6300	Passed
Evangeline Middle School	Gym-Boys L/R - Gym-Boys Locker Room - 100023875	COG5983/NAK292	0.0340	Exceeds Limit	0.1700	Passed
Evangeline Middle School	11 - Music Room - 100023869	COC5972/MRV053	0.0017	Passed	0.9900	Passed
Evangeline Middle School	Janitor Room - Janitor Room - 100022667	COG5983/NAK296	0.0092	Exceeds Limit	0.8600	Passed
Evangeline Middle School	Family Studies Room - Family Studies Room - 100022668	COC5972/MRV046	0.0120	Exceeds Limit	0.7600	Passed
Evangeline Middle School	Family Studies Room - Family Studies Room - 100022669	COC5972/MRV047	0.0340	Exceeds Limit	0.6700	Passed
Evangeline Middle School	Family Studies Room - Family Studies Room - 100022670	COC5972/MRV048	0.0120	Exceeds Limit	0.8000	Passed
Evangeline Middle School	Girls W/R - Girls Washroom - 100023865	COG5983/NAK299	0.0059	Exceeds Limit	0.4500	Passed
Evangeline Middle School	Girls W/R - Girls Washroom - 100023588	COG5983/NAK295	0.0025	Passed	1.6000	Passed
Evangeline Middle School	Girls W/R - Girls Washroom - 100023937	COG5983/NAK305	0.0085	Exceeds Limit	0.4900	Passed
Evangeline Middle School	Boys W/R - Boys Washroom - 100023938	COG5983/NAK304	0.0450	Exceeds Limit	0.5500	Passed
Evangeline Middle School	7 - Classroom - 100023939	COC5972/MRV057	0.0180	Exceeds Limit	0.7300	Passed
Evangeline Middle School	Hall-1 - Hallway 1st Floor - 100023594	COC5972/MRV052	0.0029	Passed	0.2900	Passed
Evangeline Middle School	Cafeteria/Kitchen - Cafeteria/Kitchen - 100023592	COC5972/MRV050	0.0110	Exceeds Limit	0.3300	Passed
Evangeline Middle School	Boys W/R - Boys Washroom - 100023591	COG5983/NAK283	0.0018	Passed	1.4000	Passed
Evangeline Middle School	178 - Mechanical Room - 100023936	COG5983/NAK306	0.0180	Exceeds Limit	0.5400	Passed
Evangeline Middle School	Girls W/R - Girls Washroom - 100023589	COG5983/NAK294	0.0023	Passed	1.7000	Passed
Evangeline Middle School	7 - Classroom - 100023940	COC5972/MRV058	0.0330	Exceeds Limit	0.5800	Passed
Evangeline Middle School	17 - Science Lab - 100023944	COG5983/NAK302	0.0370	Exceeds Limit	0.5300	Passed
Evangeline Middle School	176 - Staff Washroom - 100023870	COG5983/NAK286	0.0029	Passed	1.9000	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Evangeline Middle School	17 - Science Lab - 100023943	COG5983/NAK303	0.0250	Exceeds Limit	0.4700	Passed
Evangeline Middle School	Gym-Boys L/R - Gym-Boys Locker Room - 100023873	COG5983/NAK307	0.0077	Exceeds Limit	0.1600	Passed
Evangeline Middle School	17 - Science Lab - 100023942	COC5972/MRV060	0.0034	Passed	0.7000	Passed
Evangeline Middle School	18 - Classroom - 100023941	COC5972/MRV059	0.0170	Exceeds Limit	0.4700	Passed
Evangeline Middle School	Boys W/R - Boys Washroom - 100023590	COG5983/NAK293	0.0015	Passed	1.6000	Passed
Evangeline Middle School	Gym-Girls L/R - Gym-Girls Locker Room - 100023877	COG5983/NAK314	0.0610	Exceeds Limit	0.0730	Passed
Evangeline Middle School	Gym-Boys L/R - Gym-Boys Locker Room - 100023871	COG5983/NAK285	0.0860	Exceeds Limit	0.5500	Passed
Evangeline Middle School	Gym-Boys L/R - Gym-Boys Locker Room - 100023872	COG5983/NAK284	0.0230	Exceeds Limit	0.0500	Passed
Evangeline Middle School	Gym-Boys L/R - Gym-Boys Locker Room - 100023874	COG5983/NAK309	0.0130	Exceeds Limit	0.1600	Passed
Evangeline Middle School	Hall-1 - Hallway 1st Floor - 100023593	COC5972/MRV051	0.0008	Passed	0.4600	Passed
Evangeline Middle School	Gym-Girls L/R - Gym-Girls Locker Room - 100023876	COG5983/NAK315	0.0028	Passed	0.5700	Passed
Evangeline Middle School	Gym-Girls L/R - Gym-Girls Locker Room - 100023935	COC5972/MRV056	3.3000	Exceeds Limit	1.1000	Passed
Evangeline Middle School	Gym-Girls L/R - Gym-Girls Locker Room - 100023878	COG5983/NAK313	0.0360	Exceeds Limit	0.0740	Passed
Evangeline Middle School	Gym-Girls L/R - Gym-Girls Locker Room - 100023879	COG5983/NAK312	0.0260	Exceeds Limit	0.0980	Passed
Evangeline Middle School	17 - Science Lab - 100023945	COG5983/NAK301	0.0180	Exceeds Limit	0.4800	Passed
Evangeline Middle School	Gym Office W/R - Gym Office Washroom - 100023881	COG5983/NAK310	0.5700	Exceeds Limit	1.2000	Passed
Evangeline Middle School	Gym Office W/R - Gym Office Washroom - 100023882	COG5983/NAK300	0.1100	Exceeds Limit	0.0400	Passed
Evangeline Middle School	12 - Industrial Arts Shop - 100023932	COG5983/NAK308	0.0011	Passed	0.7600	Passed
Evangeline Middle School	Gym-Boys L/R - Gym-Boys Locker Room - 100023934	COC5972/MRV055	0.0013	Passed	0.5500	Passed
Evangeline Middle School	17 - Science Lab - 100023946	COG5983/NAK316	0.0190	Exceeds Limit	0.9200	Passed
Evangeline Middle School	Gym-Girls L/R - Gym-Girls Locker Room - 100023880	COG5983/NAK311	0.0300	Exceeds Limit	0.0670	Passed
Falmouth District School	21 - Boys Locker Room - 100022708	COK2579/NII513	0.0240	Exceeds Limit	0.1600	Passed
Falmouth District School	21 - Boys Locker Room - 100022709	COK2579/NII514	0.0210	Exceeds Limit	0.1500	Passed
Falmouth District School	19 - Girls Locker Room - 100022711	COK2579/NII511	0.0310	Exceeds Limit	0.1700	Passed
Falmouth District School	19 - Girls Locker Room - 100022712	COK2579/NII512	0.0360	Exceeds Limit	0.2100	Passed
Falmouth District School	14 - Library - 100022714	COK2579/NII510	0.0017	Passed	0.0130	Passed
Falmouth District School	Hall-1 - Hallway 1st Floor - 100022715	B9U1977/LDL883	0.0012	Passed	0.0890	Passed
Falmouth District School	30 - Learning Centre 1 - 100023959	COK2579/NIJ343	0.0019	Passed	0.0910	Passed
Falmouth District School	32 - Kitchen - 100022718	COK2579/NII526	0.0007	Passed	0.0220	Passed
Falmouth District School	31 - Janitor Room - 100022688	COK2579/NII524	0.0028	Passed	0.0360	Passed
Falmouth District School	27 - Girls Washroom - 100022707	COK2579/NII522	0.0190	Exceeds Limit	0.0290	Passed
Falmouth District School	32 - Kitchen - 100022717	COK2579/NII525	0.0013	Passed	0.0520	Passed
Falmouth District School	35 - Staff Washroom - 100022698	COK2579/NII530	0.0008	Passed	0.0220	Passed
Falmouth District School	31 - Janitor Room - 100022687	COK2579/NII523	0.0023	Passed	0.0310	Passed
Falmouth District School	30 - Learning Centre 1 - 100022689	B9U1977/LDL884	0.0021	Passed	0.2100	Passed
Falmouth District School	34 - Boys Washroom - 100022693	COK2579/NII527	0.0120	Exceeds Limit	0.0410	Passed
Falmouth District School	Hall-1 - Hallway 1st Floor - 100022690	COK2579/NII531	0.0034	Passed	0.0220	Passed
Falmouth District School	34 - Boys Washroom - 100022695	COK2579/NII529	0.0028	Passed	0.0240	Passed
Falmouth District School	27 - Girls Washroom - 100022706	COK2579/NII521	0.0041	Passed	0.0320	Passed
Falmouth District School	24 - Staff Room - 100022699	B9U1977/LDL890	0.0000	Passed	0.0600	Passed
Falmouth District School	25 - Staff Washroom - 100022700	COK2579/NII515	0.0012	Passed	0.0250	Passed
Falmouth District School	26 - Washroom - 100022701	COK2579/NII516	1.8000	Exceeds Limit	0.5600	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Falmouth District School	27 - Girls Washroom - 100022702	C0K2579/NII517	0.0160	Exceeds Limit	0.0410	Passed
Falmouth District School	27 - Girls Washroom - 100022703	C0K2579/NII518	0.0052	Exceeds Limit	0.0350	Passed
Falmouth District School	27 - Girls Washroom - 100022704	C0K2579/NII519	0.0047	Passed	0.0360	Passed
Falmouth District School	27 - Girls Washroom - 100022705	C0K2579/NII520	0.0028	Passed	0.0320	Passed
Falmouth District School	34 - Boys Washroom - 100022694	C0K2579/NII528	0.0022	Passed	0.0200	Passed
Gaspereau Valley Elementary School	202 - Upstairs Staff Room - 100023677	C0C5949/MRU874	0.0027	Passed	1.2000	Passed
Gaspereau Valley Elementary School	202 - Upstairs Staff Room Washroom - 100023678	C0K2596/NII715	0.0230	Exceeds Limit	1.2000	Passed
Gaspereau Valley Elementary School	105C - Janitor Room - 100022729	C0K2596/NII709	0.0091	Exceeds Limit	1.7000	Passed
Gaspereau Valley Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100022723	C0K2596/NII729	0.0058	Exceeds Limit	0.7400	Passed
Gaspereau Valley Elementary School	108 - Kitchen - 100022735	C0C5949/MRU880	0.0160	Exceeds Limit	0.7700	Passed
Gaspereau Valley Elementary School	108 - Kitchen - 100022734	C0C5949/MRU881	0.0320	Exceeds Limit	0.6400	Passed
Gaspereau Valley Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100022733	C0K2596/NII726	0.0059	Exceeds Limit	0.9700	Passed
Gaspereau Valley Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100022732	C0K2596/NII725	0.0041	Passed	1.0000	Passed
Gaspereau Valley Elementary School	105C - Janitor Room - 100022730	C0K2596/NII710	0.0091	Exceeds Limit	1.9000	Passed
Gaspereau Valley Elementary School	103 - Learning Centre - 100022726	C0C5949/MRU883	0.0028	Passed	0.6500	Passed
Gaspereau Valley Elementary School	108 - Kitchen - 100022736	C0C5949/MRU879	0.0062	Exceeds Limit	0.5500	Passed
Gaspereau Valley Elementary School	105A - Staff Washroom - 100022724	C0K2596/NII707	0.0210	Exceeds Limit	0.9400	Passed
Gaspereau Valley Elementary School	Hall-1 - Hallway 1st Floor - 100022728	C0C5949/MRU882	0.0340	Exceeds Limit	1.6000	Passed
Gaspereau Valley Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100022722	C0K2596/NII728	0.0052	Exceeds Limit	1.1000	Passed
Gaspereau Valley Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100022721	C0K2596/NII727	0.0074	Exceeds Limit	1.1000	Passed
Gaspereau Valley Elementary School	Hall-1 - Hallway 1st Floor - 100022720	C0C5949/MRU884	0.0016	Passed	0.4800	Passed
Gaspereau Valley Elementary School	Hall-1 - Hallway 1st Floor - 100022719	C0C5949/MRU885	0.0012	Passed	1.2000	Passed
Gaspereau Valley Elementary School	205B - Janitor Room - 100022757	C0K2596/NII719	0.0630	Exceeds Limit	1.8000	Passed
Gaspereau Valley Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100022731	C0K2596/NII724	0.0050	Exceeds Limit	0.7700	Passed
Gaspereau Valley Elementary School	103 - Learning Centre Washroom - 100022727	C0K2596/NII706	0.0390	Exceeds Limit	0.4500	Passed
Gaspereau Valley Elementary School	Hall-2 - Hallway 2nd Floor - 100022750	C0C5949/MRU875	0.0016	Passed	0.4200	Passed
Gaspereau Valley Elementary School	205C - Upstairs Boys Washrroom - 100022756	C0K2596/NII722	0.0075	Exceeds Limit	0.7500	Passed
Gaspereau Valley Elementary School	205C - Upstairs Boys Washrroom - 100022755	C0K2596/NII721	0.0084	Exceeds Limit	0.8500	Passed
Gaspereau Valley Elementary School	105B - Staff Washroom - 100022725	C0K2596/NII708	0.0031	Passed	0.8100	Passed
Gaspereau Valley Elementary School	109A - Classroom Washroom - 100022737	C0K2596/NII711	0.0370	Exceeds Limit	0.7600	Passed
Gaspereau Valley Elementary School	205 - Upstairs Girls Washroom - 100022753	C0K2596/NII718	0.0410	Exceeds Limit	1.7000	Passed
Gaspereau Valley Elementary School	205 - Upstairs Girls Washroom - 100022751	C0K2596/NII716	0.0280	Exceeds Limit	2.0000	Exceeds Limit
Gaspereau Valley Elementary School	205C - Upstairs Boys Washrroom - 100022754	C0K2596/NII720	0.0074	Exceeds Limit	0.9000	Passed
Gaspereau Valley Elementary School	Hall-2 - Hallway 2nd Floor - 100022749	C0C5949/MRU876	0.0041	Passed	0.5200	Passed
Gaspereau Valley Elementary School	1101 - Office Staff Washroom - 100022741	C0K2596/NII713	0.0057	Exceeds Limit	0.7600	Passed
Gaspereau Valley Elementary School	106A - Sink Room - 100022738	C0C5949/MRU878	0.0049	Passed	2.2000	Exceeds Limit
Gaspereau Valley Elementary School	110 - Classroom Washroom - 100022739	C0K2596/NII712	0.0360	Exceeds Limit	1.0000	Passed
Gaspereau Valley Elementary School	205 - Upstairs Girls Washroom - 100022752	C0K2596/NII717	0.0300	Exceeds Limit	1.5000	Passed
Gaspereau Valley Elementary School	107 - Classroom - 100022740	C0C5949/MRU877	0.0019	Passed	0.3900	Passed
Gaspereau Valley Elementary School	2502 - Mechanical Room - 100022748	C0K2596/NII723	0.0081	Exceeds Limit	0.9500	Passed
Gaspereau Valley Elementary School	Gym-Boys L/R - Gym-Boys Locker Room - 100022742	C0K2596/NII730	0.0130	Exceeds Limit	0.6700	Passed
Gaspereau Valley Elementary School	Gym-Girls L/R - Gym-Girls Locker Room - 100022744	C0K2596/NII731	0.0110	Exceeds Limit	0.6300	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Gaspereau Valley Elementary School	1405 - Gym-Office Washroom - 100022746	C0K2596/NII714	0.0210	Exceeds Limit	0.5300	Passed
Glooscap Elementary School	103 - Kitchen - 100022786	C0I8486/NFD662	0.0015	Passed	0.1700	Passed
Glooscap Elementary School	111A - Staff Washroom - 100022782	C0I8486/NFD676	0.0011	Passed	0.3800	Passed
Glooscap Elementary School	111B - Staff Washroom - 100022783	C0I8486/NFD677	0.0030	Passed	0.4400	Passed
Glooscap Elementary School	110B - Downstairs Boys Washroom - 100022779	C0I8486/NFD673	0.0034	Passed	0.4900	Passed
Glooscap Elementary School	102A - Classroom Washroom - 100022784	C0I8486/NFD661	0.0037	Passed	0.1300	Passed
Glooscap Elementary School	110B - Downstairs Boys Washroom - 100022780	C0I8486/NFD674	0.0061	Exceeds Limit	0.4400	Passed
Glooscap Elementary School	104A - Classroom Washroom - 100022785	C0I8486/NFD665	0.0055	Exceeds Limit	0.4100	Passed
Glooscap Elementary School	Hall-1 - Hallway 1st Floor - 100022781	C0I8486/NFD695	0.0072	Exceeds Limit	0.0870	Passed
Glooscap Elementary School	103 - Kitchen - 100022787	C0I8486/NFD663	0.0070	Exceeds Limit	0.3600	Passed
Glooscap Elementary School	103 - Kitchen - 100022788	C0I8486/NFD664	0.0220	Exceeds Limit	0.5000	Passed
Glooscap Elementary School	101 - Sink Room - 100022789	C0I8486/NFD660	0.0061	Exceeds Limit	0.2000	Passed
Glooscap Elementary School	106 - Learning Support - 100022790	C0I8486/NFD666	0.0080	Exceeds Limit	0.6200	Passed
Glooscap Elementary School	106A - Learning Support Washroom - 100022791	C0I8486/NFD667	0.0036	Passed	0.2600	Passed
Glooscap Elementary School	112 - Staff Room - 100022794	C0I8486/NFD678	0.0010	Passed	0.3600	Passed
Glooscap Elementary School	110B - Downstairs Boys Washroom - 100022778	C0I8486/NFD672	0.0038	Passed	0.2500	Passed
Glooscap Elementary School	Hall-2 - Hallway 2nd Floor - 100022764	C0I8486/NFD698	0.0015	Passed	0.1900	Passed
Glooscap Elementary School	108 - Pre-Primary Classroom Washroom - 100022793	C0I8486/NFD668	0.0006	Passed	0.4200	Passed
Glooscap Elementary School	210A - Upstairs Girls Washroom - 100022763	C0I8486/NFD686	0.0042	Passed	0.3800	Passed
Glooscap Elementary School	Hall-2 - Hallway 2nd Floor - 100022758	C0I8486/NFD697	0.0110	Exceeds Limit	0.1900	Passed
Glooscap Elementary School	210C - Upstairs Janitor Room - 100022759	C0I8486/NFD691	0.0021	Passed	0.2700	Passed
Glooscap Elementary School	Hall-1 - Hallway 1st Floor - 100023671	C0I8486/NFD696	0.0000	Passed	0.1600	Passed
Glooscap Elementary School	1406 - Gym-Boys Washroom - 100023672	C0I8486/NFD680	0.0019	Passed	0.3600	Passed
Glooscap Elementary School	1408 - Gym-Girls Washroom - 100023674	C0I8486/NFD681	0.0014	Passed	0.3700	Passed
Glooscap Elementary School	1404 - Gym Office Washroom - 100023676	C0I8486/NFD679	0.0110	Exceeds Limit	0.4700	Passed
Glooscap Elementary School	210A - Upstairs Girls Washroom - 100022760	C0I8486/NFD683	0.0040	Passed	0.5600	Passed
Glooscap Elementary School	Hall-2 - Hallway 2nd Floor - 100022766	C0I8486/NFD699	0.0110	Exceeds Limit	0.1600	Passed
Glooscap Elementary School	210A - Upstairs Girls Washroom - 100022762	C0I8486/NFD685	0.0023	Passed	0.3600	Passed
Glooscap Elementary School	Hall-1 - Hallway 1st Floor - 100022777	C0I8486/NFD694	0.0054	Exceeds Limit	0.0880	Passed
Glooscap Elementary School	210D - Staff Washroom - 100022765	C0I8486/NFD692	0.0061	Exceeds Limit	0.5600	Passed
Glooscap Elementary School	210B - Upstairs Boys Washroom - 100022767	C0I8486/NFD687	0.0015	Passed	0.3900	Passed
Glooscap Elementary School	210B - Upstairs Boys Washroom - 100022768	C0I8486/NFD688	0.0024	Passed	0.3400	Passed
Glooscap Elementary School	210B - Upstairs Boys Washroom - 100022769	C0I8486/NFD689	0.0036	Passed	0.3300	Passed
Glooscap Elementary School	210B - Upstairs Boys Washroom - 100022770	C0I8486/NFD690	0.0027	Passed	0.2700	Passed
Glooscap Elementary School	209 - Art Room - 100022771	C0I8486/NFD682	0.0047	Passed	0.2600	Passed
Glooscap Elementary School	Hall-1 - Hallway 1st Floor - 100022772	C0I8486/NFD693	0.0073	Exceeds Limit	0.1100	Passed
Glooscap Elementary School	110C - Downstairs Janitor Room - 100022773	C0I8486/NFD675	0.0036	Passed	0.2200	Passed
Glooscap Elementary School	110A - Downstairs Girls Washroom - 100022774	C0I8486/NFD669	0.0013	Passed	0.4700	Passed
Glooscap Elementary School	110A - Downstairs Girls Washroom - 100022775	C0I8486/NFD670	0.0077	Exceeds Limit	0.4400	Passed
Glooscap Elementary School	110A - Downstairs Girls Washroom - 100022776	C0I8486/NFD671	0.0042	Passed	0.4100	Passed
Glooscap Elementary School	210A - Upstairs Girls Washroom - 100022761	C0I8486/NFD684	0.0028	Passed	0.3700	Passed
Hantsport School	Hall-1-E - Hallway 1st Floor East - 100022795	B9U2271/LDN677	0.0000	Passed	0.1900	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Hantsport School	Gym-Boys L/R - Gym- Boys Locker Room - 100022796	COG6806/NAP836	0.0036	Passed	0.5800	Passed
Hantsport School	Hall-1-W - Hallway 1st Floor West - 100022819	B9U2271/LDN679	0.0000	Passed	0.3400	Passed
Hantsport School	202 - Upstairs Boys Washroom - 100022832	COG6806/NAP862	0.0006	Passed	0.4300	Passed
Hantsport School	113 - Family Studies Room - 100022815	B9U2271/LDN686	0.0000	Passed	0.3400	Passed
Hantsport School	111.2 - Staff Room - 100022818	B9U2271/LDN687	0.0009	Passed	0.3000	Passed
Hantsport School	118 - Kitchen - 100022820	B9U2271/LDN680	0.0000	Passed	0.1900	Passed
Hantsport School	118 - Kitchen - 100022822	B9U2271/LDN684	0.0038	Passed	0.9100	Passed
Hantsport School	Gym-Girls L/R - Gym-Girls Locker Room - 100022823	COG6806/NAP838	0.0046	Passed	0.7800	Passed
Hantsport School	Gym-Girls L/R - Gym-Girls Locker Room - 100022824	COG6806/NAP837	0.0021	Passed	0.5600	Passed
Hantsport School	218 - Primary Classroom Washroom - 100022827	COG6806/NAP844	0.0000	Passed	0.4600	Passed
Hantsport School	201 - Upstairs Girls Washroom - 100022828	COG6806/NAP866	0.0005	Passed	0.3900	Passed
Hantsport School	114 - Visual Arts Room - 100022814	B9U2271/LDN685	0.0009	Passed	0.4300	Passed
Hantsport School	201 - Upstairs Girls Washroom - 100022830	COG6806/NAP864	0.0006	Passed	0.3700	Passed
Hantsport School	202 - Upstairs Boys Washroom - 100022831	COG6806/NAP863	0.0000	Passed	0.3600	Passed
Hantsport School	204 - Upstairs Boys Washroom - 100022834	COG6806/NAP860	0.0007	Passed	0.3600	Passed
Hantsport School	204 - Upstairs Boys Washroom - 100022835	COG6806/NAP859	0.0008	Passed	0.2700	Passed
Hantsport School	204 - Upstairs Boys Washroom - 100022836	COG6806/NAP852	0.0010	Passed	0.2900	Passed
Hantsport School	206 - Upstairs Girls Washroom - 100022837	COG6806/NAP858	0.0011	Passed	0.1700	Passed
Hantsport School	206 - Upstairs Girls Washroom - 100022838	COG6806/NAP867	0.0018	Passed	0.2000	Passed
Hantsport School	206 - Upstairs Girls Washroom - 100022839	COG6806/NAP857	0.0012	Passed	0.3400	Passed
Hantsport School	Gym-Boys L/R - Gym- Boys Locker Room - 100022797	COG6806/NAP850	0.0044	Passed	0.6900	Passed
Hantsport School	118 - Kitchen - 100022821	B9U2271/LDN681	0.0000	Passed	0.2800	Passed
Hantsport School	201 - Upstairs Girls Washroom - 100022829	COG6806/NAP865	0.0007	Passed	0.3000	Passed
Hantsport School	206 - Science Lab - 100023669	B9U2271/LDN688	0.0009	Passed	0.3000	Passed
Hantsport School	202 - Upstairs Boys Washroom - 100022833	COG6806/NAP861	0.0009	Passed	0.3600	Passed
Hantsport School	112 - Learning Centre Washroom - 100022813	COG6806/NAP839	0.0022	Passed	0.4500	Passed
Hantsport School	D/S Janitor Room - Janitor Room - 100022801	COG6806/NAP848	0.0018	Passed	0.1900	Passed
Hantsport School	Hall-2 - Hallway 2nd Floor - 100022802	B9U2271/LDN678	0.0000	Passed	0.1200	Passed
Hantsport School	U/S Janitor Room - Upstairs Janitor Room - 100022804	COG6806/NAP847	0.0760	Exceeds Limit	2.2000	Exceeds Limit
Hantsport School	122 - Music Room - 100023670	COG6806/NAP868	0.0240	Exceeds Limit	0.2100	Passed
Hantsport School	D/S Janitor Room - Janitor Room - 100022800	COG6806/NAP849	0.0067	Exceeds Limit	0.3300	Passed
Hantsport School	Hall-1 - Hallway 1st Floor - 100023667	COG6806/NAP869	0.0079	Exceeds Limit	2.5000	Exceeds Limit
Hantsport School	Hall-1 - Hallway 1st Floor - 100023666	COG6806/NAP870	0.0510	Exceeds Limit	2.8000	Exceeds Limit
Hantsport School	111.1 - Washroom - 100023665	COG6806/NAP853	0.0080	Exceeds Limit	1.0000	Passed
Hantsport School	D/S Girls W/R - Downstairs Girls Washroom - 100022810	COG6806/NAP842	0.0005	Passed	0.2800	Passed
Hantsport School	D/S Girls W/R - Downstairs Girls Washroom - 100022812	COG6806/NAP840	0.0009	Passed	0.3600	Passed
Hantsport School	U/S Janitor Room - Upstairs Janitor Room - 100022805	COG6806/NAP846	0.0075	Exceeds Limit	0.2000	Passed
Hantsport School	D/S Girls W/R - Downstairs Girls Washroom - 100022811	COG6806/NAP841	0.0006	Passed	0.3500	Passed
Hantsport School	111.1 - Washroom - 100023664	COG6806/NAP854	0.0011	Passed	0.4300	Passed
Hantsport School	D/S Boys Washroom - Downstairs Boys Washroom - 100022809	COG6806/NAP851	0.0006	Passed	0.5000	Passed
Hantsport School	D/S Boys Washroom - Downstairs Boys Washroom - 100022808	COG6806/NAP843	0.0000	Passed	0.6700	Passed
Hantsport School	D/S Boys Washroom - Downstairs Boys Washroom - 100022807	COG6806/NAP835	0.0008	Passed	0.4700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Hantsport School	Boiler Room - Boiler Room - 100022806	COG6806/NAP845	0.0940	Exceeds Limit	0.2500	Passed
Hantsport School	105 - Office Washroom - 100023662	COG6806/NAP856	0.0000	Passed	0.5600	Passed
Hantsport School	108 - Library - 100023663	COG6806/NAP855	0.0073	Exceeds Limit	0.4000	Passed
Horton High School	2621 - Chemistry Lab - 100023360	COF3704/MXS840	0.0110	Exceeds Limit	0.2700	Passed
Horton High School	2621 - Chemistry Lab - 100023353	COF3704/MXS847	0.0290	Exceeds Limit	0.3900	Passed
Horton High School	2621 - Chemistry Lab - 100023354	COF3704/MXS837	0.0210	Exceeds Limit	0.5800	Passed
Horton High School	2621 - Chemistry Lab - 100023355	COF3704/MXS845	0.0440	Exceeds Limit	0.8700	Passed
Horton High School	2621 - Chemistry Lab - 100023356	COF3704/MXS853	0.0170	Exceeds Limit	0.4000	Passed
Horton High School	2621 - Chemistry Lab - 100023357	COF3704/MXS843	0.0400	Exceeds Limit	0.6000	Passed
Horton High School	2612 - Chemistry Lab - 100023361	COF3704/MXS839	0.0051	Exceeds Limit	0.1800	Passed
Horton High School	2621 - Chemistry Lab - 100023359	COF3704/MXS841	0.0820	Exceeds Limit	0.2900	Passed
Horton High School	2621 - Chemistry Lab - 100023352	COF3704/MXS848	0.1200	Exceeds Limit	0.6100	Passed
Horton High School	Girls W/R - Girls Washroom - 100023363	COF3704/MXS821	0.0068	Exceeds Limit	0.7400	Passed
Horton High School	Janitor Room - Janitor Room - 100023362	COF3704/MXS838	0.0070	Exceeds Limit	0.7200	Passed
Horton High School	2621 - Chemistry Lab - 100023358	COF3704/MXS842	0.0240	Exceeds Limit	0.5900	Passed
Horton High School	2621 - Chemistry Lab - 100023351	COF3704/MXS849	0.0800	Exceeds Limit	0.5400	Passed
Horton High School	2621 - Chemistry Lab - 100023350	COF3704/MXS850	0.0260	Exceeds Limit	0.4400	Passed
Horton High School	2621 - Chemistry Lab - 100023349	COF3704/MXS851	0.0300	Exceeds Limit	0.8100	Passed
Horton High School	2621 - Chemistry Lab - 100023348	COF3704/MXS830	0.0260	Exceeds Limit	0.2900	Passed
Horton High School	2621 - Chemistry Lab - 100023347	COF3704/MXS846	0.0210	Exceeds Limit	0.3200	Passed
Horton High School	2621 - Chemistry Lab - 100023346	COF3704/MXS844	0.0230	Exceeds Limit	0.5800	Passed
Horton High School	2621 - Chemistry Lab - 100023345	COF3704/MXS824	0.0068	Exceeds Limit	0.2300	Passed
Horton High School	2621 - Chemistry Lab - 100023344	COF3704/MXS825	0.0240	Exceeds Limit	0.7000	Passed
Horton High School	2621 - Chemistry Lab - 100023343	COF3704/MXS826	0.0260	Exceeds Limit	0.8600	Passed
Horton High School	2621 - Chemistry Lab - 100023341	COF3704/MXS827	0.0016	Passed	0.0870	Passed
Horton High School	Girls W/R - Girls Washroom - 100023364	COF3704/MXS798	0.0061	Exceeds Limit	0.6700	Passed
Horton High School	2811 - Science 10 Lab - 100023398	COF3704/MXS812	0.0150	Exceeds Limit	0.4700	Passed
Horton High School	2621 - Chemistry Lab - 100023342	COF3704/MXS774	0.0140	Exceeds Limit	0.8300	Passed
Horton High School	2815 - Biology Lab - 100023388	COF3704/MXS800	0.0360	Exceeds Limit	0.3300	Passed
Horton High School	Penthouse - Penthouse - 100023402	COF3704/MXS808	0.0046	Passed	0.3000	Passed
Horton High School	2811 - Science 10 Lab - 100023400	COF3704/MXS809	0.0074	Exceeds Limit	0.5000	Passed
Horton High School	2811 - Science 10 Lab - 100023399	COF3704/MXS810	7.7000	Exceeds Limit	0.5300	Passed
Horton High School	W/R - Washroom - 100023338	COF3704/MXS823	0.0039	Passed	0.7400	Passed
Horton High School	2812 - Science 10 Lab - 100023397	COF3704/MXS813	0.0250	Exceeds Limit	0.4500	Passed
Horton High School	W/R - Washroom - 100023339	COF3704/MXS829	0.0065	Exceeds Limit	0.5300	Passed
Horton High School	2812 - Science 10 Lab - 100023395	COF3704/MXS814	0.0027	Passed	0.2400	Passed
Horton High School	2812 - Science 10 Lab - 100023394	COF3704/MXS807	0.0032	Passed	0.3000	Passed
Horton High School	2821 - Physics Lab - 100023393	COF3704/MXS816	0.1100	Exceeds Limit	0.7400	Passed
Horton High School	2821 - Physics Lab - 100023392	COF3704/MXS817	0.0420	Exceeds Limit	0.5800	Passed
Horton High School	2815 - Biology Lab - 100023391	COF3704/MXS818	0.0510	Exceeds Limit	0.6600	Passed
Horton High School	2812 - Science 10 Lab - 100023396	COF3704/MXS822	0.0200	Exceeds Limit	0.2300	Passed
Horton High School	2815 - Biology Lab - 100023389	COF3704/MXS820	0.0410	Exceeds Limit	1.0000	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Horton High School	Girls W/R - Girls Washroom - 100023365	COF3704/MXS828	0.0060	Exceeds Limit	0.5900	Passed
Horton High School	2815 - Biology Lab - 100023387	COF3704/MXS815	0.0910	Exceeds Limit	2.5000	Exceeds Limit
Horton High School	2824 - Science 9 Lab - 100023379	COF3704/MXS795	0.0110	Exceeds Limit	0.5900	Passed
Horton High School	2824 - Science 9 Lab - 100023378	COF3704/MXS796	0.0670	Exceeds Limit	1.1000	Passed
Horton High School	2824 - Science 9 Lab - 100023377	COF3704/MXS797	0.0610	Exceeds Limit	0.7600	Passed
Horton High School	2815 - Biology Lab - 100023373	COF3704/MXS799	0.5200	Exceeds Limit	2.5000	Exceeds Limit
Horton High School	2814 - Biology Lab - 100023372	COF3704/MXS794	0.0210	Exceeds Limit	0.4000	Passed
Horton High School	2814 - Biology Lab - 100023371	COF3704/MXS801	0.0440	Exceeds Limit	1.2000	Passed
Horton High School	2814 - Biology Lab - 100023370	COF3704/MXS802	0.9800	Exceeds Limit	6.8000	Exceeds Limit
Horton High School	Boys W.R - Boys Washroom - 100023368	COF3704/MXS803	0.0170	Exceeds Limit	0.8200	Passed
Horton High School	Boys W.R - Boys Washroom - 100023367	COF3704/MXS804	0.0160	Exceeds Limit	0.8600	Passed
Horton High School	Boys W.R - Boys Washroom - 100023366	COF3704/MXS805	0.0120	Exceeds Limit	0.8400	Passed
Horton High School	2815 - Biology Lab - 100023390	COF3704/MXS819	0.0160	Exceeds Limit	0.5300	Passed
Horton High School	1621 - Ladies Locker Room - 100023279	COF3704/MXS778	0.1100	Exceeds Limit	0.9900	Passed
Horton High School	1470 - Girls Washroom - 100023267	COF3704/MXS791	0.0190	Exceeds Limit	0.9600	Passed
Horton High School	1610 - Food Lab - 100023268	COF3704/MXS726	0.0038	Passed	0.2900	Passed
Horton High School	1610 - Food Lab - 100023269	COF3704/MXS751	0.4600	Exceeds Limit	1.5000	Passed
Horton High School	1610 - Food Lab - 100023270	COF3704/MXS728	0.0027	Passed	0.2600	Passed
Horton High School	1610 - Food Lab - 100023271	COF3704/MXS717	0.0040	Passed	0.2500	Passed
Horton High School	1610 - Food Lab - 100023272	COF3704/MXS730	0.0069	Exceeds Limit	0.1900	Passed
Horton High School	1610 - Food Lab - 100023273	COF3704/MXS731	0.0058	Exceeds Limit	0.3500	Passed
Horton High School	1621 - Ladies Locker Room - 100023275	COF3704/MXS790	0.0110	Exceeds Limit	0.5200	Passed
Horton High School	1621 - Ladies Locker Room - 100023276	COF3704/MXS789	0.0380	Exceeds Limit	0.6500	Passed
Horton High School	1631 - Mens Locker Room - 100023289	COF3704/MXS770	0.6200	Exceeds Limit	11.0000	Exceeds Limit
Horton High School	1621 - Ladies Locker Room - 100023278	COF3704/MXS787	0.1800	Exceeds Limit	1.3000	Passed
Horton High School	1472 - Boys Washroom - 100023264	COF3704/MXS784	0.0200	Exceeds Limit	0.7900	Passed
Horton High School	1621 - Ladies Locker Room - 100023280	COF3704/MXS785	0.0024	Passed	0.6800	Passed
Horton High School	1621 - Ladies Locker Room - 100023281	COF3704/MXS793	0.0410	Exceeds Limit	0.3500	Passed
Horton High School	1621 - Ladies Locker Room - 100023282	COF3704/MXS783	0.0077	Exceeds Limit	0.7300	Passed
Horton High School	1631 - Mens Locker Room - 100023283	COF3704/MXS782	0.0078	Exceeds Limit	0.2300	Passed
Horton High School	1631 - Mens Locker Room - 100023284	COF3704/MXS781	0.0210	Exceeds Limit	0.6900	Passed
Horton High School	1631 - Mens Locker Room - 100023285	COF3704/MXS780	0.0690	Exceeds Limit	1.1000	Passed
Horton High School	1631 - Mens Locker Room - 100023286	COF3704/MXS779	0.0110	Exceeds Limit	0.7100	Passed
Horton High School	1631 - Mens Locker Room - 100023287	COF3704/MXS756	0.1800	Exceeds Limit	1.8000	Passed
Horton High School	2621 - Chemistry Lab - 100023340	COF3704/MXS836	0.0030	Passed	0.7600	Passed
Horton High School	1621 - Ladies Locker Room - 100023277	COF3704/MXS788	0.4900	Exceeds Limit	0.7100	Passed
Horton High School	W/R - Washroom - 100023252	COF3704/MXS771	0.0079	Exceeds Limit	0.9600	Passed
Horton High School	Hall-1-W - Hallway 1st Floor West - 100023238	COF3704/MXS718	0.0015	Passed	0.4500	Passed
Horton High School	D/S Boys W/R - Downstairs Boys Washroom - 100023239	COF3704/MXS708	0.0082	Exceeds Limit	0.4000	Passed
Horton High School	D/S Boys W/R - Downstairs Boys Washroom - 100023240	COF3704/MXS776	0.0061	Exceeds Limit	0.4500	Passed
Horton High School	D/S Girls W/R - Downstairs Girls Washroom - 100023241	COF3704/MXS775	0.0072	Exceeds Limit	0.4200	Passed
Horton High School	D/S Girls W/R - Downstairs Girls Washroom - 100023242	COF3704/MXS774	0.0140	Exceeds Limit	0.8300	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Horton High School	1111 - Tech Ed Production Lab - 100023243	COF3704/MXS719	0.0200	Exceeds Limit	0.2300	Passed
Horton High School	1111 - Tech Ed Production Lab - 100023244	COF3704/MXS773	0.0094	Exceeds Limit	0.4900	Passed
Horton High School	1116 - Module Lab - 100023245	COF3704/MXS720	0.0070	Exceeds Limit	0.5200	Passed
Horton High School	1118 - Communications Lab - 100023246	COF3704/MXS721	0.0810	Exceeds Limit	0.8700	Passed
Horton High School	1470 - Girls Washroom - 100023266	COF3704/MXS772	0.0200	Exceeds Limit	0.8600	Passed
Horton High School	Janitor Room - Janitor Room - 100023251	COF3704/MXS764	0.0014	Passed	0.5200	Passed
Horton High School	1470 - Girls Washroom - 100023265	COF3704/MXS786	0.0180	Exceeds Limit	0.8300	Passed
Horton High School	W/R - Washroom - 100023253	COF3704/MXS777	0.0260	Exceeds Limit	1.8000	Passed
Horton High School	1450 - Kitchen - 100023254	COF3704/MXS723	0.0022	Passed	0.2800	Passed
Horton High School	1450 - Kitchen - 100023255	COF3704/MXS724	0.0038	Passed	0.2800	Passed
Horton High School	1450 - Kitchen - 100023256	COF3704/MXS725	0.0016	Passed	0.2400	Passed
Horton High School	1423 - Janitor Room - 100023257	COF3704/MXS769	0.0220	Exceeds Limit	0.8100	Passed
Horton High School	1224 - Washroom - 100023260	COF3704/MXS768	0.0072	Exceeds Limit	0.1500	Passed
Horton High School	1228 - Instrument Storage - 100023261	COF3704/MXS767	0.0079	Exceeds Limit	0.2700	Passed
Horton High School	1472 - Boys Washroom - 100023262	COF3704/MXS766	0.0540	Exceeds Limit	0.7900	Passed
Horton High School	1472 - Boys Washroom - 100023263	COF3704/MXS765	0.0160	Exceeds Limit	0.6800	Passed
Horton High School	1631 - Mens Locker Room - 100023290	COF3704/MXS737	0.2400	Exceeds Limit	3.1000	Exceeds Limit
Horton High School	1316 - Classroom - 100023249	COF3704/MXS722	0.0086	Exceeds Limit	0.2400	Passed
Horton High School	2470 - Washroom - 100023326	COF3704/MXS741	0.0040	Passed	0.2600	Passed
Horton High School	2112 - Geography Classroom - 100023315	COF3704/MXT096	0.0190	Exceeds Limit	0.6000	Passed
Horton High School	2117 - Textile Lab - 100023316	COF3704/MXS759	0.0130	Exceeds Limit	0.4500	Passed
Horton High School	2122 - Multimedia (Art) - 100023317	COF3704/MXS748	0.0170	Exceeds Limit	0.5100	Passed
Horton High School	Girls W/R - Girls Washroom - 100023318	COF3704/MXS758	0.0087	Exceeds Limit	0.8600	Passed
Horton High School	Girls W/R - Girls Washroom - 100023319	COF3704/MXS757	0.0130	Exceeds Limit	0.9700	Passed
Horton High School	Boys W/R - Boys Washroom - 100023320	COF3704/MXS739	0.0150	Exceeds Limit	1.0000	Passed
Horton High School	Boys W/R - Boys Washroom - 100023321	COF3704/MXS755	0.0190	Exceeds Limit	0.6500	Passed
Horton High School	2472 - Washroom - 100023322	COF3704/MXS763	0.0100	Exceeds Limit	0.4600	Passed
Horton High School	2472 - Washroom - 100023323	COF3704/MXS753	0.0047	Passed	0.4100	Passed
Horton High School	1631 - Mens Locker Room - 100023288	COF3704/MXS792	0.0230	Exceeds Limit	0.8300	Passed
Horton High School	2470 - Washroom - 100023325	COF3704/MXS742	0.0065	Exceeds Limit	0.5900	Passed
Horton High School	2118 - Art Studio - 100023313	COF3704/MXS746	0.0130	Exceeds Limit	0.7800	Passed
Horton High School	2470 - Washroom - 100023327	COF3704/MXS740	0.0077	Exceeds Limit	0.7900	Passed
Horton High School	Janitor Room - Janitor Room - 100023328	COF3704/MXS806	0.0036	Passed	0.6800	Passed
Horton High School	Hall-2-W - Hall 2nd Floor West - 100023329	COF3704/MXS749	0.0061	Exceeds Limit	0.0750	Passed
Horton High School	W/R - Washroom - 100023330	COF3704/MXS852	0.0370	Exceeds Limit	0.4900	Passed
Horton High School	2545 - Conference Room - 100023332	COF3704/MXS750	0.0180	Exceeds Limit	0.3200	Passed
Horton High School	2542 - Main Office Washroom - 100023333	COF3704/MXS835	0.0018	Passed	0.1400	Passed
Horton High School	Sick Bay - Sick Bay - 100023334	COF3704/MXS834	0.0200	Exceeds Limit	0.7100	Passed
Horton High School	2513 - Washroom - 100023335	COF3704/MXS833	0.0085	Exceeds Limit	0.1900	Passed
Horton High School	W/R - Washroom - 100023336	COF3704/MXS832	0.0240	Exceeds Limit	0.2000	Passed
Horton High School	W/R - Washroom - 100023337	COF3704/MXS831	0.0250	Exceeds Limit	0.2600	Passed
Horton High School	2472 - Washroom - 100023324	COF3704/MXS752	0.0085	Exceeds Limit	0.3700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Horton High School	1731 - Girls Locker Room - 100023303	COF3704/MXS709	0.0140	Exceeds Limit	0.2600	Passed
Horton High School	1645 - Fitness Studio Office - 100023291	COF3704/MXS736	0.0120	Exceeds Limit	0.5900	Passed
Horton High School	1645 - Fitness Studio Office - 100023292	COF3704/MXS735	0.1100	Exceeds Limit	0.4100	Passed
Horton High School	1640 - Fitness Studio Office - 100023293	COF3704/MXS734	0.0210	Exceeds Limit	0.3700	Passed
Horton High School	1640 - Fitness Studio Office - 100023294	COF3704/MXS733	0.4800	Exceeds Limit	0.2600	Passed
Horton High School	Hall-1-E - Hallway 1st Floor East - 100023295	COF3704/MXS732	0.0040	Passed	0.4100	Passed
Horton High School	Boys W/R - Boys Washroom - 100023296	COF3704/MXS716	0.0430	Exceeds Limit	0.7500	Passed
Horton High School	Boys W/R - Boys Washroom - 100023297	COF3704/MXS707	0.0091	Exceeds Limit	0.2400	Passed
Horton High School	Boys W/R - Boys Washroom - 100023298	COF3704/MXS714	0.0150	Exceeds Limit	0.2900	Passed
Horton High School	Girls W/R - Girls Washroom - 100023299	COF3704/MXS738	0.0190	Exceeds Limit	0.5000	Passed
Horton High School	Girls W/R - Girls Washroom - 100023300	COF3704/MXS712	0.0340	Exceeds Limit	0.8200	Passed
Horton High School	1731 - Girls Locker Room - 100023302	COF3704/MXS710	0.0260	Exceeds Limit	0.2800	Passed
Horton High School	Hall-2-W - Hall 2nd Floor West - 100023314	COF3704/MXS747	0.0007	Passed	0.2800	Passed
Horton High School	1731 - Girls Locker Room - 100023304	COF3704/MXS754	0.2700	Exceeds Limit	1.0000	Passed
Horton High School	1731 - Girls Locker Room - 100023305	COF3704/MXS713	0.0240	Exceeds Limit	0.1500	Passed
Horton High School	1721 - Boys Locker Room - 100023306	COF3704/MXS715	0.0240	Exceeds Limit	0.4300	Passed
Horton High School	1721 - Boys Locker Room - 100023307	COF3704/MXS762	0.0120	Exceeds Limit	0.1700	Passed
Horton High School	1721 - Boys Locker Room - 100023308	COF3704/MXS761	0.5600	Exceeds Limit	1.8000	Passed
Horton High School	1721 - Boys Locker Room - 100023309	COF3704/MXS760	0.0340	Exceeds Limit	0.9300	Passed
Horton High School	2005 - Staff Room - 100023310	COF3704/MXS743	0.0014	Passed	0.6800	Passed
Horton High School	2111 - Geography Classroom - 100023311	COF3704/MXS744	0.0063	Exceeds Limit	0.6800	Passed
Horton High School	2118 - Art Studio - 100023312	COF3704/MXS745	0.0036	Passed	0.3700	Passed
Horton High School	1110 - Intensive Resource Room - 100023237	COF3704/MXS727	0.0026	Passed	0.2900	Passed
Horton High School	Girls W/R - Girls Washroom - 100023301	COF3704/MXS711	0.0280	Exceeds Limit	0.7300	Passed
Kings County Academy	151 - Washroom - 100022177	COF3722/MXS947	0.0021	Passed	0.1800	Passed
Kings County Academy	226 - Janitor Room - 100022150	COF3722/MXS959	0.0000	Passed	0.1500	Passed
Kings County Academy	U/S Boys W/R - Upstairs Boys Washroom - 100022140	COF3722/MXT009	0.0030	Passed	0.1900	Passed
Kings County Academy	U/S Boys W/R - Upstairs Boys Washroom - 100022141	COF3722/MXT008	0.0009	Passed	0.2000	Passed
Kings County Academy	U/S Boys W/R - Upstairs Boys Washroom - 100022142	COF3722/MXS954	0.0022	Passed	0.1300	Passed
Kings County Academy	U/S Girls W/R - Upstairs Girls Washroom - 100022143	COF3722/MXT006	0.0028	Passed	0.2200	Passed
Kings County Academy	U/S Girls W/R - Upstairs Girls Washroom - 100022144	COF3722/MXS998	0.0024	Passed	0.2000	Passed
Kings County Academy	U/S Girls W/R - Upstairs Girls Washroom - 100022145	COF3722/MXT004	0.0023	Passed	0.2200	Passed
Kings County Academy	U/S Girls W/R - Upstairs Girls Washroom - 100022146	COF3722/MXS963	0.0009	Passed	0.1700	Passed
Kings County Academy	225 - Upstairs Janitor Room - 100022147	COF3722/MXS962	0.0066	Exceeds Limit	0.1900	Passed
Kings County Academy	139 - Kitchen - 100022159	COF3722/MXS987	0.0034	Passed	0.2100	Passed
Kings County Academy	245 - Staff Washroom - 100022149	COF3722/MXS960	0.0018	Passed	0.2000	Passed
Kings County Academy	215 - Nutrition/Family Studies Room - 100022137	COF3722/MXT011	0.0019	Passed	0.1800	Passed
Kings County Academy	255 - Learning Centre - 100022151	COF3722/MXS984	0.0013	Passed	0.1200	Passed
Kings County Academy	175 - Classroom - 100022152	COF3722/MXS992	0.0060	Exceeds Limit	0.1800	Passed
Kings County Academy	176 - Staff Room - 100022153	COF3722/MXS971	0.0046	Passed	0.0700	Passed
Kings County Academy	178 - Learning Centre - 100022154	COF3722/MXS990	0.0260	Exceeds Limit	0.2200	Passed
Kings County Academy	179 - Learning Centre Washroom - 100022155	COF3722/MXS958	0.0070	Exceeds Limit	0.1700	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Kings County Academy	144 - Recycle Room - 100022156	COF3722/MXS989	0.0060	Exceeds Limit	0.1500	Passed
Kings County Academy	139 - Kitchen - 100022157	COF3722/MXS957	0.0130	Exceeds Limit	0.1900	Passed
Kings County Academy	152 - Washroom - 100022179	COF3722/MXS946	0.0054	Exceeds Limit	0.2100	Passed
Kings County Academy	234 - Staff Washroom - 100022148	COF3722/MXS961	0.0029	Passed	0.2000	Passed
Kings County Academy	212 - General Science Classroom - 100022128	COF3722/MXS996	0.0110	Exceeds Limit	0.0780	Passed
Kings County Academy	142 - Washroom - 100023921	COF3722/MXS953	0.0058	Exceeds Limit	0.2900	Passed
Kings County Academy	245 - Staff Washroom - 100023920	COF3722/MXT000	0.0310	Exceeds Limit	0.1700	Passed
Kings County Academy	234 - Staff Washroom - 100023919	COF3722/MXT001	0.0340	Exceeds Limit	0.5900	Passed
Kings County Academy	226 - Janitor Room - 100023918	COF3722/MXT002	0.0081	Exceeds Limit	0.1800	Passed
Kings County Academy	179 - Learning Centre Washroom - 100023917	COF3722/MXT003	0.1200	Exceeds Limit	0.2300	Passed
Kings County Academy	207 - Tech Production - 100022123	COF3722/MXT005	0.0068	Exceeds Limit	0.1500	Passed
Kings County Academy	207 - Tech Production - 100022124	COF3722/MXS985	0.0037	Passed	0.2500	Passed
Kings County Academy	205 - Tech Innovations - 100022125	COF3722/MXS970	0.0065	Exceeds Limit	0.0560	Passed
Kings County Academy	U/S Boys W/R - Upstairs Boys Washroom - 100022139	COF3722/MXT010	0.0025	Passed	0.2000	Passed
Kings County Academy	212 - General Science Classroom - 100022127	COF3722/MXS997	0.0051	Exceeds Limit	0.2600	Passed
Kings County Academy	217 - Change/Storage - 100022138	COF3722/MXS964	0.0000	Passed	0.0290	Passed
Kings County Academy	212 - General Science Classroom - 100022129	COF3722/MXS995	0.0120	Exceeds Limit	0.6600	Passed
Kings County Academy	212 - General Science Classroom - 100022130	COF3722/MXS994	0.0077	Exceeds Limit	0.1500	Passed
Kings County Academy	212 - General Science Classroom - 100022131	COF3722/MXT013	0.0200	Exceeds Limit	0.2100	Passed
Kings County Academy	212 - General Science Classroom - 100022132	COF3722/MXT012	0.0045	Passed	0.1700	Passed
Kings County Academy	215 - Nutrition/Family Studies Room - 100022133	COF3722/MXS968	0.0072	Exceeds Limit	0.1200	Passed
Kings County Academy	215 - Nutrition/Family Studies Room - 100022134	COF3722/MXS967	0.0053	Exceeds Limit	0.4000	Passed
Kings County Academy	215 - Nutrition/Family Studies Room - 100022135	COF3722/MXS966	0.0027	Passed	0.2500	Passed
Kings County Academy	215 - Nutrition/Family Studies Room - 100022136	COF3722/MXS965	0.0018	Passed	0.1600	Passed
Kings County Academy	139 - Kitchen - 100022160	COF3722/MXS986	0.0013	Passed	0.3300	Passed
Kings County Academy	Hall-2-N - Hallway 2nd Floor North - 100022126	COF3722/MXS969	0.0000	Passed	0.0810	Passed
Kings County Academy	Gym-Girls L/R - Gym-Girls Locker Room - 100022194	COF3722/MXS941	0.0180	Exceeds Limit	0.6200	Passed
Kings County Academy	157 - Washroom - 100022184	COF3722/MXS944	0.0051	Exceeds Limit	0.1900	Passed
Kings County Academy	160 - Classroom - 100022185	COF3722/MXS972	0.0086	Exceeds Limit	0.2100	Passed
Kings County Academy	163 - Classroom - 100022186	COF3722/MXS980	0.0130	Exceeds Limit	0.2300	Passed
Kings County Academy	166 - Classroom - 100022187	COF3722/MXT019	0.0050	Exceeds Limit	0.3300	Passed
Kings County Academy	167 - Classroom - 100022188	COF3722/MXS978	0.0034	Passed	0.1300	Passed
Kings County Academy	168 - Staff Washroom - 100022189	COF3722/MXS943	0.0000	Passed	0.2200	Passed
Kings County Academy	170 - Classroom - 100022190	COF3722/MXS977	0.0032	Passed	0.1600	Passed
Kings County Academy	172 - Classroom - 100022191	COF3722/MXS976	0.0025	Passed	0.2100	Passed
Kings County Academy	139 - Kitchen - 100022158	COF3722/MXS988	0.0030	Passed	0.1900	Passed
Kings County Academy	Gym-Girls L/R - Gym-Girls Locker Room - 100022193	COF3722/MXS999	0.0000	Passed	0.0860	Passed
Kings County Academy	156 - Washroom - 100022181	COF3722/MXS945	0.0014	Passed	0.1300	Passed
Kings County Academy	Gym-Girls L/R - Gym-Girls Locker Room - 100022195	COF3722/MXT020	0.0450	Exceeds Limit	3.7000	Exceeds Limit
Kings County Academy	Gym-Boys L/R - Gym-Boys Locker Room - 100022196	COF3722/MXS939	0.0015	Passed	0.0810	Passed
Kings County Academy	Gym-Boys L/R - Gym-Boys Locker Room - 100022197	COF3722/MXS938	0.0065	Exceeds Limit	0.3800	Passed
Kings County Academy	Gym-Boys L/R - Gym-Boys Locker Room - 100022198	COF3722/MXS937	0.0130	Exceeds Limit	0.0860	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Kings County Academy	Hall-1-S - Hallway 1st Floor South - 100022200	COF3722/MXS974	0.0017	Passed	0.2500	Passed
Kings County Academy	254 - Learning Centre Washroom - 100022201	COF3722/MXS936	0.0026	Passed	0.2100	Passed
Kings County Academy	254 - Learning Centre Washroom - 100022202	COF3722/MXS935	0.0170	Exceeds Limit	0.1500	Passed
Kings County Academy	206 - Pump Room - 100022203	COF3722/MXS973	0.0240	Exceeds Limit	0.4000	Passed
Kings County Academy	Hall-2-N - Hallway 2nd Floor North - 100022192	COF3722/MXS975	0.0008	Passed	0.1400	Passed
Kings County Academy	D/S Boys W/R - Downstairs Boys Washroom - 100022171	COF3722/MXT007	0.0030	Passed	0.2200	Passed
Kings County Academy	124 - Music Room - 100022161	COF3722/MXS979	0.0075	Exceeds Limit	0.1700	Passed
Kings County Academy	119 - Band Room - 100022162	COF3722/MXS991	0.0150	Exceeds Limit	0.2300	Passed
Kings County Academy	117 - Library - 100022163	COF3722/MXS993	0.0320	Exceeds Limit	0.2700	Passed
Kings County Academy	118 - Visual Arts Room - 100022164	COF3722/MXT018	0.0110	Exceeds Limit	0.2300	Passed
Kings County Academy	118 - Visual Arts Room - 100022165	COF3722/MXT017	0.0140	Exceeds Limit	0.1800	Passed
Kings County Academy	Hall-1-N - Hallway 1st Floor North - 100022166	COF3722/MXT016	0.0530	Exceeds Limit	0.2700	Passed
Kings County Academy	133 - Staff Office Washroom - 100022167	COF3722/MXS956	0.0047	Passed	0.2000	Passed
Kings County Academy	D/S Boys W/R - Downstairs Boys Washroom - 100022168	COF3722/MXS955	0.0130	Exceeds Limit	0.2200	Passed
Kings County Academy	159 - Classroom - 100022183	COF3722/MXS982	0.0140	Exceeds Limit	0.1000	Passed
Kings County Academy	D/S Boys W/R - Downstairs Boys Washroom - 100022170	COF3722/MXS942	0.0030	Passed	0.2000	Passed
Kings County Academy	155 - Classroom - 100022182	COF3722/MXS983	0.0047	Passed	0.1100	Passed
Kings County Academy	D/S Girls W/R - Downstairs Girls Washroom - 100022172	COF3722/MXS952	0.0027	Passed	0.1900	Passed
Kings County Academy	D/S Girls W/R - Downstairs Girls Washroom - 100022173	COF3722/MXS951	0.0025	Passed	0.2500	Passed
Kings County Academy	D/S Girls W/R - Downstairs Girls Washroom - 100022174	COF3722/MXS950	0.0120	Exceeds Limit	0.2500	Passed
Kings County Academy	D/S Girls W/R - Downstairs Girls Washroom - 100022175	COF3722/MXS949	0.0027	Passed	0.1900	Passed
Kings County Academy	146 - Janitor Room - 100022176	COF3722/MXS948	0.0011	Passed	0.1300	Passed
Kings County Academy	149 - Classroom - 100022178	COF3722/MXT015	0.0059	Exceeds Limit	0.1700	Passed
Kings County Academy	153 - Classroom - 100022180	COF3722/MXT014	0.0120	Exceeds Limit	0.1800	Passed
Kings County Academy	3rd Floor AHU Room - 3rd Floor Air Handling Unit Room - 100022204	COF3722/MXS981	0.0015	Passed	0.2600	Passed
Kings County Academy	D/S Boys W/R - Downstairs Boys Washroom - 100022169	COF3722/MXS940	0.0094	Exceeds Limit	0.2000	Passed
Kingston & District School	U/S Boys W/R - Upstairs Boys Washroom - 100023433	COH4093/NCE237	0.0150	Exceeds Limit	1.2000	Passed
Kingston & District School	U/S Girls W/R - Upstairs Girls Washroom - 100023437	COH4093/NCE264	0.0180	Exceeds Limit	1.3000	Passed
Kingston & District School	Boys W/R - Boys Washroom - 100023225	COH4093/NCE231	0.0073	Exceeds Limit	1.3000	Passed
Kingston & District School	D/S Boys W/R - Downstairs Boys Washroom - 100023451	COH4093/NCE256	0.0067	Exceeds Limit	1.2000	Passed
Kingston & District School	D/S Boys W/R - Downstairs Boys Washroom - 100023450	COH4093/NCE268	0.0045	Passed	1.2000	Passed
Kingston & District School	D/S Boys W/R - Downstairs Boys Washroom - 100023449	COH4093/NCE258	0.0150	Exceeds Limit	1.4000	Passed
Kingston & District School	D/S Boys W/R - Downstairs Boys Washroom - 100023448	COH4093/NCE248	0.0032	Passed	1.2000	Passed
Kingston & District School	Hall-1 - Hallway 1st Floor - 100023447	COH4093/NCE220	0.0100	Exceeds Limit	1.1000	Passed
Kingston & District School	105 - Washroom - 100023446	COH4093/NCE260	0.0048	Passed	1.3000	Passed
Kingston & District School	105 - Washroom - 100023444	COH4093/NCE261	0.0210	Exceeds Limit	0.5700	Passed
Kingston & District School	103 - Classroom - 100023443	COH4093/NCE221	0.0052	Exceeds Limit	0.8500	Passed
Kingston & District School	Hall-1 - Hallway 1st Floor - 100023442	COH4093/NCE222	0.0000	Passed	0.5200	Passed
Kingston & District School	204 - Classroom - 100023441	COH4093/NCE223	0.0140	Exceeds Limit	0.6000	Passed
Kingston & District School	202 - Classroom - 100023440	COH4093/NCE224	0.0140	Exceeds Limit	0.8400	Passed
Kingston & District School	D/S Girls W/R - Downstairs Girls Washroom - 100023453	COH4093/NCE254	0.0041	Passed	1.3000	Passed
Kingston & District School	U/S Girls W/R - Upstairs Girls Washroom - 100023438	COH4093/NCE263	0.0340	Exceeds Limit	1.1000	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Kingston & District School	D/S Girls W/R - Downstairs Girls Washroom - 100023454	COH4093/NCE253	0.0039	Passed	1.3000	Passed
Kingston & District School	U/S Girls W/R - Upstairs Girls Washroom - 100023436	COH4093/NCE265	0.0210	Exceeds Limit	1.2000	Passed
Kingston & District School	U/S Girls W/R - Upstairs Girls Washroom - 100023435	COH4093/NCE266	0.0078	Exceeds Limit	0.8600	Passed
Kingston & District School	U/S Boys W/R - Upstairs Boys Washroom - 100023434	COH4093/NCE267	0.0280	Exceeds Limit	1.2000	Passed
Kingston & District School	U/S Boys W/R - Upstairs Boys Washroom - 100023431	COH4093/NCE257	0.0240	Exceeds Limit	1.0000	Passed
Kingston & District School	U/S Boys W/R - Upstairs Boys Washroom - 100023432	COH4093/NCE235	0.0140	Exceeds Limit	1.2000	Passed
Kingston & District School	Hall-2 - Hallway 2nd Floor - 100023429	COH4093/NCE200	0.0077	Exceeds Limit	1.1000	Passed
Kingston & District School	205 - Classroom - 100023428	COH4093/NCE215	0.0660	Exceeds Limit	0.6600	Passed
Kingston & District School	203 - Classroom - 100023427	COH4093/NCE195	0.0077	Exceeds Limit	0.8400	Passed
Kingston & District School	201 - Classroom - 100023426	COH4093/NCE196	0.0120	Exceeds Limit	0.5900	Passed
Kingston & District School	Hall-1 - Hallway 1st Floor - 100023229	B9U1572/LDI970	0.0000	Passed	0.2900	Passed
Kingston & District School	Girls W/R - Girls Washroom - 100023228	COH4093/NCE228	0.0200	Exceeds Limit	1.4000	Passed
Kingston & District School	Girls W/R - Girls Washroom - 100023227	COH4093/NCE229	0.0490	Exceeds Limit	2.5000	Exceeds Limit
Kingston & District School	Boys W/R - Boys Washroom - 100023226	COH4093/NCE230	0.0058	Exceeds Limit	1.3000	Passed
Kingston & District School	U/S Staff W/R - Upstairs Staff Washroom - 100023439	COH4093/NCE262	0.0100	Exceeds Limit	1.2000	Passed
Kingston & District School	J21 - Janitor Room - 100023468	COH4093/NCE217	0.0084	Exceeds Limit	0.5800	Passed
Kingston & District School	102 - Before & After School Room - 100023967	B9U1572/LDI997	0.0037	Passed	1.0000	Passed
Kingston & District School	Hall-1 - Hallway 1st Floor - 100022068	COH4093/NCE194	0.0240	Exceeds Limit	1.6000	Passed
Kingston & District School	21 - Cafeteria/Kitchen - 100022069	COH4093/NCE206	0.0220	Exceeds Limit	1.8000	Passed
Kingston & District School	21 - Cafeteria/Kitchen - 100022070	COH4093/NCE205	0.0110	Exceeds Limit	1.1000	Passed
Kingston & District School	21 - Cafeteria/Kitchen - 100022071	COH4093/NCE249	0.2200	Exceeds Limit	0.8200	Passed
Kingston & District School	M/E Girls W/R - Main Entrance Girls Washroom - 100022072	COH4093/NCE227	0.0045	Passed	1.5000	Passed
Kingston & District School	M/E Girls W/R - Main Entrance Girls Washroom - 100022073	COH4093/NCE246	0.0048	Passed	1.3000	Passed
Kingston & District School	M/E Boys W/R - Main Entrance Boys Washroom - 100022074	COH4093/NCE245	0.0087	Exceeds Limit	1.1000	Passed
Kingston & District School	M/E Boys W/R - Main Entrance Boys Washroom - 100022075	COH4093/NCE244	0.0140	Exceeds Limit	1.2000	Passed
Kingston & District School	M/E Guidance Office W/R - Main Entrance Guidance Office Washroom - 100022076	COH4093/NCE243	0.0073	Exceeds Limit	1.4000	Passed
Kingston & District School	M/O W/R - Main Office Washroom - 100022077	COH4093/NCE242	0.0031	Passed	1.3000	Passed
Kingston & District School	Staff W/R - Staff Washroom - 100022078	COH4093/NCE241	0.0070	Exceeds Limit	1.1000	Passed
Kingston & District School	D/S Girls W/R - Downstairs Girls Washroom - 100023452	COH4093/NCE255	0.0011	Passed	1.7000	Passed
Kingston & District School	Staff Room - Staff Room - 100022080	COH4093/NCE204	0.2800	Exceeds Limit	1.1000	Passed
Kingston & District School	Hall-2 - Hallway 2nd Floor - 100023430	COH4093/NCE202	0.0000	Passed	0.8300	Passed
Kingston & District School	Gym - Gym - 100023467	COH4093/NCE209	0.0008	Passed	0.7100	Passed
Kingston & District School	Hall-1 - Hallway 1st Floor - 100023466	COH4093/NCE210	0.0087	Exceeds Limit	0.9000	Passed
Kingston & District School	112 - Classroom - 100023465	COH4093/NCE211	0.0082	Exceeds Limit	0.8600	Passed
Kingston & District School	110 - Classroom - 100023464	COH4093/NCE212	0.0038	Passed	0.9500	Passed
Kingston & District School	108 - Classroom - 100023463	COH4093/NCE213	0.0220	Exceeds Limit	0.9600	Passed
Kingston & District School	Janitor Room - Janitor Room - 100023462	COH4093/NCE251	0.0045	Passed	0.4600	Passed
Kingston & District School	106 - Classroom - 100023461	COH4093/NCE214	0.0050	Exceeds Limit	0.8400	Passed
Kingston & District School	104 - Play & Learn Room - 100023460	COH4093/NCE225	0.0068	Exceeds Limit	0.5100	Passed
Kingston & District School	113 - Meeting Room - 100023459	COH4093/NCE216	0.0150	Exceeds Limit	1.2000	Passed
Kingston & District School	111 - Classroom - 100023458	COH4093/NCE269	0.0089	Exceeds Limit	0.8500	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Kingston & District School	109 - Classroom - 100023457	COH4093/NCE259	0.0079	Exceeds Limit	1.5000	Passed
Kingston & District School	107 - Classroom - 100023456	COH4093/NCE250	0.0150	Exceeds Limit	0.8000	Passed
Kingston & District School	D/S Girls W/R - Downstairs Girls Washroom - 100023455	COH4093/NCE252	0.0035	Passed	1.2000	Passed
Kingston & District School	Staff W/R - Staff Washroom - 100022079	COH4093/NCE240	0.0053	Exceeds Limit	0.9800	Passed
Kingston & District School	11 - Classroom Washroom - 100023205	COH4093/NCE239	0.0053	Exceeds Limit	1.1000	Passed
Kingston & District School	206 - Classroom - 100023224	COH4093/NCE197	0.0200	Exceeds Limit	1.1000	Passed
Kingston & District School	11 - Classroom - 100023204	B9U1572/LDI957	0.0048	Passed	1.0000	Passed
Kingston & District School	12 - Classroom - 100023206	B9U1572/LDI958	0.0120	Exceeds Limit	0.8100	Passed
Kingston & District School	12 - Classroom Washroom - 100023207	COH4093/NCE238	0.0028	Passed	1.2000	Passed
Kingston & District School	13 - Classroom - 100023208	B9U1572/LDI959	0.0100	Exceeds Limit	0.9400	Passed
Kingston & District School	13 - Classroom Washroom - 100023209	COH4093/NCE226	0.0034	Passed	1.3000	Passed
Kingston & District School	14 - Classroom - 100023210	B9U1572/LDI960	0.0088	Exceeds Limit	1.0000	Passed
Kingston & District School	14 - Classroom Washroom - 100023211	COH4093/NCE236	0.0021	Passed	1.4000	Passed
Kingston & District School	15 - Music Room - 100023212	COH4093/NCE247	0.0390	Exceeds Limit	0.6800	Passed
Kingston & District School	16 - Learning Centre - 100023213	COH4093/NCE203	0.0160	Exceeds Limit	0.8500	Passed
Kingston & District School	208 - Classroom - 100023222	COH4093/NCE198	0.0210	Exceeds Limit	0.9000	Passed
Kingston & District School	207 - Classroom - 100023223	B9U1572/LDI976	0.0000	Passed	0.5200	Passed
Kingston & District School	Hall-1 - Hallway 1st Floor - 100023215	B9U1572/LDI969	0.0006	Passed	0.5900	Passed
Kingston & District School	Boys L/R - Boys Locker Room - 100023216	COH4093/NCE233	0.0054	Exceeds Limit	1.1000	Passed
Kingston & District School	Girls L/R - Girls Locker Room - 100023217	COH4093/NCE232	0.0053	Exceeds Limit	0.7000	Passed
Kingston & District School	213 - Classroom - 100023218	COH4093/NCE193	0.0130	Exceeds Limit	0.8000	Passed
Kingston & District School	211 - Classroom - 100023219	COH4093/NCE201	0.0210	Exceeds Limit	0.9900	Passed
Kingston & District School	210 - Classroom - 100023220	COH4093/NCE207	0.0210	Exceeds Limit	0.7800	Passed
Kingston & District School	209 - Classroom - 100023221	COH4093/NCE199	0.0100	Exceeds Limit	1.0000	Passed
Kingston & District School	17 - Small Cafeteria - 100023214	COH4093/NCE234	0.0120	Exceeds Limit	1.3000	Passed
L.E. Shaw Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100023068	COG6835/NAP974	0.0022	Passed	0.9100	Passed
L.E. Shaw Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100023069	COG6835/NAP975	0.0044	Passed	0.9000	Passed
L.E. Shaw Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100023070	COG6835/NAP976	0.0064	Exceeds Limit	0.8500	Passed
L.E. Shaw Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100023071	COG6835/NAP977	0.0073	Exceeds Limit	0.9600	Passed
L.E. Shaw Elementary School	D/S Staff W/R - Downstairs Staff Washroom - 100023072	COG6835/NAP978	0.0100	Exceeds Limit	1.4000	Passed
L.E. Shaw Elementary School	5 - Classroom Washroom - 100023073	COG6835/NAP979	0.0099	Exceeds Limit	0.8300	Passed
L.E. Shaw Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100023067	COG6835/NAP973	0.0029	Passed	0.8400	Passed
L.E. Shaw Elementary School	2 - Pre-Primary Classroom Washroom - 100023075	B9U1616/LDJ133	0.0015	Passed	0.7300	Passed
L.E. Shaw Elementary School	115 - Boys Washroom - 100023061	COG6835/NAP970	0.0036	Passed	1.9000	Passed
L.E. Shaw Elementary School	6 - Classroom Washroom - 100023074	COG6835/NAP980	0.0200	Exceeds Limit	1.3000	Passed
L.E. Shaw Elementary School	135 - Boiler Room - 100023066	B9U1616/LDJ131	0.0048	Passed	0.9100	Passed
L.E. Shaw Elementary School	134 - Kitchen - 100023065	B9U1616/LDJ130	0.0017	Passed	0.9700	Passed
L.E. Shaw Elementary School	134 - Kitchen - 100023064	B9U1616/LDJ129	0.0016	Passed	1.1000	Passed
L.E. Shaw Elementary School	Lobby - Front Lobby - 100023968	B9U1616/LDJ125	0.0007	Passed	0.5400	Passed
L.E. Shaw Elementary School	115 - Boys Washroom - 100023062	COG6835/NAP971	0.0047	Passed	1.4000	Passed
L.E. Shaw Elementary School	115 - Girls Washroom - 100023059	COG6835/NAP969	0.0072	Exceeds Limit	1.4000	Passed
L.E. Shaw Elementary School	112 - Janitor Room - 100023058	COG6835/NAP981	0.0028	Passed	1.2000	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
L.E. Shaw Elementary School	1 - Classroom Washroom - 100023076	COG6835/NAP986	0.0290	Exceeds Limit	1.2000	Passed
L.E. Shaw Elementary School	U/S Janitor Room - Upstairs Janitor Room - 100023079	COG6835/NAP995	0.0028	Passed	1.3000	Passed
L.E. Shaw Elementary School	Hall-1-S - Hallway 1 South - 100023969	B9U1616/LDJ127	0.0008	Passed	0.5200	Passed
L.E. Shaw Elementary School	132 - Washroom - 100023063	COG6835/NAP972	0.0010	Passed	1.5000	Passed
L.E. Shaw Elementary School	205 - Staff Foom - 100023090	B9U1616/LDJ137	0.0007	Passed	0.8500	Passed
L.E. Shaw Elementary School	D/S Janitor Room - Downstairs Janitor Room - 100023077	COG6835/NAP997	0.0027	Passed	1.3000	Passed
L.E. Shaw Elementary School	Main Office - Main Office - 100023057	B9U1616/LDJ126	0.0019	Passed	1.1000	Passed
L.E. Shaw Elementary School	Gym-Girls L/R - Gym-Girls Locker Room - 100023098	COG6835/NAP983	0.0100	Exceeds Limit	3.1000	Exceeds Limit
L.E. Shaw Elementary School	Gym-Boys L/R - Gym-Boys Locker Room - 100023096	COG6835/NAP984	0.0280	Exceeds Limit	2.7000	Exceeds Limit
L.E. Shaw Elementary School	Gym-Office W/R - Gym-Office Washroom - 100023094	COG6835/NAP985	0.0089	Exceeds Limit	2.1000	Exceeds Limit
L.E. Shaw Elementary School	Hall-2 - Hallway 2nd Floor - 100023093	B9U1616/LDJ128	0.0000	Passed	0.2300	Passed
L.E. Shaw Elementary School	207 - Staff Washroom - 100023091	COG6835/NAP987	0.0052	Exceeds Limit	1.9000	Passed
L.E. Shaw Elementary School	U/S Staff W/R - Upstairs Staff Washroom - 100023088	COG6835/NAP982	0.0140	Exceeds Limit	1.1000	Passed
L.E. Shaw Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023082	COG6835/NAP968	0.0160	Exceeds Limit	1.1000	Passed
L.E. Shaw Elementary School	4 - Classroom - 100023078	COG6835/NAP996	0.0052	Exceeds Limit	1.0000	Passed
L.E. Shaw Elementary School	208 - Staff Washroom - 100023092	COG6835/NAP994	0.0097	Exceeds Limit	3.4000	Exceeds Limit
L.E. Shaw Elementary School	16 - Resource Room Washroom - 100023081	COG6835/NAP988	0.0033	Passed	0.4000	Passed
L.E. Shaw Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023087	COG6835/NAP989	0.0055	Exceeds Limit	2.4000	Exceeds Limit
L.E. Shaw Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023083	COG6835/NAP993	0.0250	Exceeds Limit	0.8600	Passed
L.E. Shaw Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023084	COG6835/NAP992	0.0140	Exceeds Limit	0.9300	Passed
L.E. Shaw Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023085	COG6835/NAP991	0.0043	Passed	2.2000	Exceeds Limit
L.E. Shaw Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023086	COG6835/NAP990	0.0054	Exceeds Limit	2.0000	Exceeds Limit
L.E. Shaw Elementary School	16 - Resource Room - 100023080	B9U1616/LDJ134	0.0022	Passed	0.3500	Passed
Lawrencetown Consolidated School	21 - Main Office - 100022039	B9U1944/LDL269	0.0062	Exceeds Limit	1.2000	Passed
Lawrencetown Consolidated School	24 - Kitchen - 100022065	B9U1944/LDL636	0.0170	Exceeds Limit	0.8100	Passed
Lawrencetown Consolidated School	19 - Janitor Office Room - 100022034	B9U1944/LDL625	0.0340	Exceeds Limit	1.3000	Passed
Lawrencetown Consolidated School	18 - Staff Room - 100022035	B9U1944/LDL626	0.0062	Exceeds Limit	1.0000	Passed
Lawrencetown Consolidated School	16 - Art Room - 100022036	B9U1944/LDL627	0.0820	Exceeds Limit	0.3000	Passed
Lawrencetown Consolidated School	Hall-1 - Hallway 1st Floor - 100022037	B9U1944/LDL628	0.0000	Passed	0.2100	Passed
Lawrencetown Consolidated School	2 - Classroom Washroom - 100022042	B9U1944/LDL630	0.0057	Exceeds Limit	0.7700	Passed
Lawrencetown Consolidated School	Hall-1 - Hallway 1st Floor - 100022043	B9U1944/LDL631	0.0009	Passed	0.8100	Passed
Lawrencetown Consolidated School	24 - Kitchen - 100022062	B9U1944/LDL633	0.0093	Exceeds Limit	1.7000	Passed
Lawrencetown Consolidated School	24 - Kitchen - 100022064	B9U1944/LDL635	0.0200	Exceeds Limit	1.0000	Passed
Lawrencetown Consolidated School	Hall-1 - Hallway 1st Floor - 100022067	B9U1944/LDL632	0.0013	Passed	0.9100	Passed
Lawrencetown Consolidated School	24 - Kitchen - 100022063	B9U1944/LDL634	0.0089	Exceeds Limit	1.0000	Passed
Lawrencetown Education Centre	Lobby - Main Lobby - 100023765	B9U1923/LDL522	0.0320	Exceeds Limit	2.0000	Exceeds Limit
Lawrencetown Education Centre	11 - Staff Kitchen - 100023767	B9U1923/LDL523	0.0027	Passed	1.0000	Passed
Lawrencetown Education Centre	4 - Family Matters room. - 100023769	B9U1923/LDL518	0.0470	Exceeds Limit	1.4000	Passed
Lawrencetown Education Centre	12 - Classroom - 100023770	B9U1923/LDL521	0.0600	Exceeds Limit	1.3000	Passed
Lawrencetown Education Centre	13 - Classroom - 100023960	B9U1923/LDL520	0.0190	Exceeds Limit	1.5000	Passed
Lawrencetown Education Centre	Hall-2 - Hallway 2nd Floor - 100023196	B9U1923/LDL516	0.0000	Passed	0.0650	Passed
Lawrencetown Education Centre	Hall-1 - Hallway 1st Floor - 100023203	B9U1923/LDL517	0.0008	Passed	0.6100	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Middleton Bus Garage	Kitchen - Kitchen - 100023933	COD3849/MTN952	0.0017	Passed	0.0760	Passed
Middleton Regional High School	105 - Art Room - 100022974	COI8556/NFE147	0.0220	Exceeds Limit	0.1200	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022938	COI8556/NFE194	0.0360	Exceeds Limit	0.2100	Passed
Middleton Regional High School	209 - Biology Lab - 100022931	COI8556/NFE187	0.0380	Exceeds Limit	0.1700	Passed
Middleton Regional High School	209 - Biology Lab - 100022932	COI8556/NFE188	0.0180	Exceeds Limit	0.1100	Passed
Middleton Regional High School	209 - Biology Lab - 100022933	COI8556/NFE189	0.0280	Exceeds Limit	0.1200	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022934	COI8556/NFE190	0.0042	Passed	0.1300	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022935	COI8556/NFE191	0.0190	Exceeds Limit	0.1800	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022945	COI8556/NFE201	0.0940	Exceeds Limit	0.4300	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022937	COI8556/NFE193	0.0240	Exceeds Limit	0.2700	Passed
Middleton Regional High School	208 - Physics Lab - 100022928	COI8556/NFE184	0.0200	Exceeds Limit	0.0630	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022939	COI8556/NFE195	0.0120	Exceeds Limit	0.0520	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022940	COI8556/NFE196	0.0098	Exceeds Limit	0.3300	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022941	COI8556/NFE197	0.0330	Exceeds Limit	0.1700	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022942	COI8556/NFE198	0.0270	Exceeds Limit	0.2100	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022943	COI8556/NFE199	0.0670	Exceeds Limit	0.1900	Passed
Middleton Regional High School	206 - Classroom - 100022913	COI8556/NFE169	0.0510	Exceeds Limit	0.2000	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022936	COI8556/NFE192	0.0160	Exceeds Limit	0.1800	Passed
Middleton Regional High School	208 - Physics Lab - 100022922	COI8556/NFE178	0.0240	Exceeds Limit	0.1200	Passed
Middleton Regional High School	Hall-2 - Hallway 2nd Floor - 100022914	COI8556/NFE247	0.0000	Passed	0.0720	Passed
Middleton Regional High School	208 - Physics Lab - 100022915	COI8556/NFE171	0.0550	Exceeds Limit	0.2400	Passed
Middleton Regional High School	208 - Physics Lab - 100022916	COI8556/NFE172	0.0630	Exceeds Limit	0.0730	Passed
Middleton Regional High School	208 - Physics Lab - 100022917	COI8556/NFE173	0.0380	Exceeds Limit	0.1700	Passed
Middleton Regional High School	208 - Physics Lab - 100022918	COI8556/NFE174	0.0220	Exceeds Limit	0.0810	Passed
Middleton Regional High School	208 - Physics Lab - 100022919	COI8556/NFE175	0.0210	Exceeds Limit	0.1200	Passed
Middleton Regional High School	209 - Biology Lab - 100022930	COI8556/NFE186	0.0380	Exceeds Limit	0.0880	Passed
Middleton Regional High School	208 - Physics Lab - 100022921	COI8556/NFE177	0.0360	Exceeds Limit	0.1500	Passed
Middleton Regional High School	208 - Physics Lab - 100022929	COI8556/NFE185	0.2100	Exceeds Limit	0.4900	Passed
Middleton Regional High School	208 - Physics Lab - 100022923	COI8556/NFE179	0.0230	Exceeds Limit	0.1600	Passed
Middleton Regional High School	208 - Physics Lab - 100022924	COI8556/NFE180	0.0280	Exceeds Limit	0.1700	Passed
Middleton Regional High School	208 - Physics Lab - 100022925	COI8556/NFE181	0.0210	Exceeds Limit	0.2100	Passed
Middleton Regional High School	208 - Physics Lab - 100022926	COI8556/NFE182	0.0250	Exceeds Limit	0.1300	Passed
Middleton Regional High School	208 - Physics Lab - 100022927	COI8556/NFE183	0.0410	Exceeds Limit	0.2100	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022946	COI8556/NFE202	0.0750	Exceeds Limit	3.0000	Exceeds Limit
Middleton Regional High School	208 - Physics Lab - 100022920	COI8556/NFE176	0.0180	Exceeds Limit	0.0340	Passed
Middleton Regional High School	Boys W/R beside Room 104 - Boys Washroom beside Room 104 - 100022986	COI8556/NFE226	0.0048	Passed	0.1100	Passed
Middleton Regional High School	Kitchen - Kitchen - 100022979	COI8556/NFE259	0.0000	Passed	0.0430	Passed
Middleton Regional High School	W/R across from Room 200 - Washroom across from Room 200 - 100022980	COI8556/NFE280	0.0380	Exceeds Limit	0.1000	Passed
Middleton Regional High School	Gold Room - Gold Room - 100022981	COI8556/NFE240	0.0190	Exceeds Limit	0.1400	Passed
Middleton Regional High School	Janitor Room by Kitchen - Janitor Room by Kitchen - 100022982	COI8556/NFE251	0.0000	Passed	0.0210	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Middleton Regional High School	Janitor Room across from Room 102 - Janitor Room across from Room 102 - 100022983	CO18556/NFE249	0.0047	Passed	0.0660	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022944	CO18556/NFE200	0.0420	Exceeds Limit	0.1800	Passed
Middleton Regional High School	Girls W/R beside Room 104 - Girls Washroom beside Room 104 - 100022985	CO18556/NFE239	0.0023	Passed	0.0810	Passed
Middleton Regional High School	107 - Classroom - 100022976	CO18556/NFE149	0.0150	Exceeds Limit	0.1500	Passed
Middleton Regional High School	Janitor Room-New Gym Girls L/R - Janitor Room-New Gym Girls Locker Room - 100022987	CO18556/NFE253	0.0039	Passed	0.0380	Passed
Middleton Regional High School	115 - Classroom - 100023661	CO18556/NFE161	0.0530	Exceeds Limit	0.3600	Passed
Middleton Regional High School	Janitor Room - Janitor Room - 100023660	CO18556/NFE248	0.0006	Passed	0.0310	Passed
Middleton Regional High School	Hall - Hallway - 100023659	CO18556/NFE242	0.3600	Exceeds Limit	0.3700	Passed
Middleton Regional High School	Janitor Room O/S Room 106 - Janitor Room Outside Room 106 - 100022972	CO18556/NFE252	0.0200	Exceeds Limit	0.1300	Passed
Middleton Regional High School	New Gym Office W/R - New Gym Office Washroom - 100022840	CO18556/NFE263	0.0013	Passed	0.1700	Passed
Middleton Regional High School	Hall-1 - Hallway 1st Floor - 100022984	CO18556/NFE244	0.0000	Passed	0.0680	Passed
Middleton Regional High School	Old Gym Office #1 W/R - Old Gym Office #1 Washroom - 100022956	CO18556/NFE271	0.0200	Exceeds Limit	0.1200	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022947	CO18556/NFE203	0.0660	Exceeds Limit	0.0350	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022948	CO18556/NFE204	0.1200	Exceeds Limit	0.0960	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022949	CO18556/NFE205	0.0930	Exceeds Limit	0.1400	Passed
Middleton Regional High School	210 - Chemistry Lab - 100022950	CO18556/NFE206	0.0320	Exceeds Limit	0.0270	Passed
Middleton Regional High School	Main Office Kitchenette - Main Office Kitchenette - 100022952	CO18556/NFE260	0.0014	Passed	0.1000	Passed
Middleton Regional High School	Main Office W/R #1 - Main Office Washroom #1 - 100022953	CO18556/NFE261	0.0064	Exceeds Limit	0.1400	Passed
Middleton Regional High School	Kitchen - Kitchen - 100022978	CO18556/NFE258	0.0420	Exceeds Limit	0.1500	Passed
Middleton Regional High School	Student Support Room - Student Support Room Near Old Gym - 100022955	CO18556/NFE276	0.0082	Exceeds Limit	0.1500	Passed
Middleton Regional High School	Kitchen - Kitchen - 100022977	CO18556/NFE257	0.0066	Exceeds Limit	0.2000	Passed
Middleton Regional High School	Old Gym Boys L/R - Old Gym Boys Locker Room - 100022959	CO18556/NFE269	0.0064	Exceeds Limit	0.1300	Passed
Middleton Regional High School	Old Gym Office #2 W/R - Old Gym Office #2 Washroom - 100022965	CO18556/NFE272	0.0530	Exceeds Limit	0.0940	Passed
Middleton Regional High School	Old Gym Girls L/R - Old Gym Girls Locker Room - 100022967	CO18556/NFE270	0.0030	Passed	0.1100	Passed
Middleton Regional High School	105 - Art Room - 100022973	CO18556/NFE146	0.0060	Exceeds Limit	0.1700	Passed
Middleton Regional High School	107 - Classroom - 100022975	CO18556/NFE148	0.0120	Exceeds Limit	0.1500	Passed
Middleton Regional High School	Boys Locker Room - Boys Locker Room - 100022958	CO18556/NFE218	0.0024	Passed	0.1700	Passed
Middleton Regional High School	Main Office W/R #2 - Main Office Washroom #2 - 100022954	CO18556/NFE262	0.0097	Exceeds Limit	0.2000	Passed
Middleton Regional High School	Boys W/R across from Custodial Office - Boys Washroom across from Custodial Office - 100022870	CO18556/NFE222	0.0180	Exceeds Limit	0.0860	Passed
Middleton Regional High School	109 - Family Studies Room - 100022863	CO18556/NFE155	0.0340	Exceeds Limit	0.0740	Passed
Middleton Regional High School	109 - Family Studies Room - 100022864	CO18556/NFE156	0.0037	Passed	0.4200	Passed
Middleton Regional High School	109 - Family Studies Room - 100022865	CO18556/NFE157	0.0030	Passed	0.4100	Passed
Middleton Regional High School	109 - Family Studies Room - 100022866	CO18556/NFE158	0.0120	Exceeds Limit	0.4100	Passed
Middleton Regional High School	Boys W/R across from Custodial Office - Boys Washroom across from Custodial Office - 100022867	CO18556/NFE219	0.0045	Passed	0.2400	Passed
Middleton Regional High School	133 - Music Room Office - 100022877	CO18556/NFE165	0.0023	Passed	0.0480	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Middleton Regional High School	Boys W/R across from Custodial Office - Boys Washroom across from Custodial Office - 100022869	CO18556/NFE221	0.0064	Exceeds Limit	0.2800	Passed
Middleton Regional High School	109 - Family Studies Room - 100022859	CO18556/NFE151	0.0080	Exceeds Limit	0.4100	Passed
Middleton Regional High School	Girls W/R across from Custodial Office - Girls Washroom across from Custodial Office - 100022871	CO18556/NFE230	0.0130	Exceeds Limit	0.1200	Passed
Middleton Regional High School	Girls W/R across from Custodial Office - Girls Washroom across from Custodial Office - 100022872	CO18556/NFE231	0.0420	Exceeds Limit	0.1900	Passed
Middleton Regional High School	Girls W/R across from Custodial Office - Girls Washroom across from Custodial Office - 100022873	CO18556/NFE232	0.0110	Exceeds Limit	0.2200	Passed
Middleton Regional High School	Girls W/R across from Custodial Office - Girls Washroom across from Custodial Office - 100022874	CO18556/NFE233	0.0088	Exceeds Limit	0.3100	Passed
Middleton Regional High School	Janitor Room across from Room 110 - Janitor Room across from Room 110 - 100022875	CO18556/NFE250	0.0055	Exceeds Limit	0.0470	Passed
Middleton Regional High School	132 - Music Room Maintenance Room - 100022876	CO18556/NFE164	0.0047	Passed	0.0350	Passed
Middleton Regional High School	Boys W/R across from Custodial Office - Boys Washroom across from Custodial Office - 100022868	CO18556/NFE220	0.0035	Passed	0.1800	Passed
Middleton Regional High School	120 - Industrial Arts Room - 100022853	CO18556/NFE163	0.0021	Passed	0.1300	Passed
Middleton Regional High School	New Gym-Boys L/R #1 - New Gym-Boys Locker Room #1 - 100022846	CO18556/NFE265	0.0019	Passed	0.1100	Passed
Middleton Regional High School	New Gym-Boys L/R #2 - New Gym-Boys Locker Room #2 - 100022848	CO18556/NFE266	0.0023	Passed	0.1200	Passed
Middleton Regional High School	Hall-1-N - Hallway 1st Floor North - 100022850	CO18556/NFE245	0.0310	Exceeds Limit	0.3300	Passed
Middleton Regional High School	New Gym-Girls L/R #2 - New Gym-Girls Locker Room #2 - 100022844	CO18556/NFE268	0.0039	Passed	0.1900	Passed
Middleton Regional High School	New Gym-Girls L/R #1 - New Gym-Girls Locker Room #1 - 100022842	CO18556/NFE267	0.0014	Passed	0.1200	Passed
Middleton Regional High School	Girls Locker Room - Girls Locker Room - 100022964	CO18556/NFE229	0.0130	Exceeds Limit	0.1800	Passed
Middleton Regional High School	W/R #1 - New Gym Lobby - New Gym Lobby-Washroom #1 - 100022851	CO18556/NFE277	0.0000	Passed	0.1600	Passed
Middleton Regional High School	W/R #2 - New Gym Lobby - New Gym Lobby-Washroom #2 - 100022852	CO18556/NFE278	0.0009	Passed	0.1700	Passed
Middleton Regional High School	109 - Family Studies Room - 100022861	CO18556/NFE153	0.0270	Exceeds Limit	0.4300	Passed
Middleton Regional High School	Hall-1 - Hallway 1st Floor - 100022854	CO18556/NFE243	0.0009	Passed	0.1100	Passed
Middleton Regional High School	116 - Industrial Arts Room - 100022855	CO18556/NFE162	0.0088	Exceeds Limit	0.2600	Passed
Middleton Regional High School	113 - Classroom - 100022856	CO18556/NFE160	0.0095	Exceeds Limit	0.1900	Passed
Middleton Regional High School	111 - Classroom Washroom - 100022857	CO18556/NFE159	0.0130	Exceeds Limit	0.1900	Passed
Middleton Regional High School	109 - Family Studies Room - 100022858	CO18556/NFE150	0.0150	Exceeds Limit	0.3000	Passed
Middleton Regional High School	109 - Family Studies Room - 100022862	CO18556/NFE154	0.0120	Exceeds Limit	0.1000	Passed
Middleton Regional High School	206 - Classroom - 100022911	CO18556/NFE168	0.0410	Exceeds Limit	0.0320	Passed
Middleton Regional High School	Hall - Hallway - 100022878	CO18556/NFE241	0.0000	Passed	0.0400	Passed
Middleton Regional High School	Boys W/R across from Room 218 - Boys Washroom across from Room 218 - 100022894	CO18556/NFE224	0.0029	Passed	0.3400	Passed
Middleton Regional High School	Boys W/R across from Room 218 - Boys Washroom across from Room 218 - 100022895	CO18556/NFE225	0.0099	Exceeds Limit	0.3300	Passed
Middleton Regional High School	200 - Classroom - 100022896	CO18556/NFE166	0.0330	Exceeds Limit	0.0470	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Middleton Regional High School	W/R across from Room 200 - Washroom across from Room 200 - 100022897	CO18556/NFE279	0.0110	Exceeds Limit	0.0840	Passed
Middleton Regional High School	Jr. Staff Room W/R - Jr. Staff Room Washroom - 100022899	CO18556/NFE255	0.0058	Exceeds Limit	0.1100	Passed
Middleton Regional High School	Boys W/R next to Room 204 - Boys Washroom next to Room 204 - 100022905	CO18556/NFE227	0.0028	Passed	0.1900	Passed
Middleton Regional High School	Boys W/R across from Room 218 - Boys Washroom across from Room 218 - 100022893	CO18556/NFE223	0.0034	Passed	0.3200	Passed
Middleton Regional High School	Sr. Staff Room W/R - Sr. Staff Room Washroom - 100022902	CO18556/NFE274	0.0029	Passed	0.1000	Passed
Middleton Regional High School	Jr. Staff Room - Jr. Staff Room - 100022898	CO18556/NFE254	0.0048	Passed	0.0840	Passed
Middleton Regional High School	109 - Family Studies Room - 100022860	CO18556/NFE152	0.0170	Exceeds Limit	0.4000	Passed
Middleton Regional High School	206 - Classroom - 100022910	CO18556/NFE167	0.0250	Exceeds Limit	0.3800	Passed
Middleton Regional High School	Staff W/R next to Room 206 - Staff Washroom next to Room 206 - 100022909	CO18556/NFE275	0.0290	Exceeds Limit	0.2000	Passed
Middleton Regional High School	Hall-2 - Hallway 2nd Floor - 100022908	CO18556/NFE246	0.0000	Passed	0.0960	Passed
Middleton Regional High School	Girls W/R across from Sr. Staff Room - Girls Washroom across from Sr. Staff Room - 100022903	CO18556/NFE237	0.0130	Exceeds Limit	0.1600	Passed
Middleton Regional High School	Girls W/R across from Sr. Staff Room - Girls Washroom across from Sr. Staff Room - 100022904	CO18556/NFE238	0.0017	Passed	0.1000	Passed
Middleton Regional High School	Boys W/R next to Room 204 - Boys Washroom next to Room 204 - 100022906	CO18556/NFE228	0.0049	Passed	0.1100	Passed
Middleton Regional High School	Sr. Staff Room - Sr. Staff Room - 100022901	CO18556/NFE273	0.0110	Exceeds Limit	0.1100	Passed
Middleton Regional High School	221 - Classroom - 100022887	CO18556/NFE209	0.0240	Exceeds Limit	0.0690	Passed
Middleton Regional High School	224 - Classroom - 100022884	CO18556/NFE211	0.0038	Passed	0.0570	Passed
Middleton Regional High School	Jr. Staff Room W/R - Jr. Staff Room Washroom - 100022900	CO18556/NFE256	0.0063	Exceeds Limit	0.1100	Passed
Middleton Regional High School	224 - Classroom - 100022883	CO18556/NFE210	0.0044	Passed	0.1300	Passed
Middleton Regional High School	Girls W/R across from Room 218 - Girls Washroom across from Room 218 - 100022892	CO18556/NFE236	0.0097	Exceeds Limit	0.2600	Passed
Middleton Regional High School	226 - Classroom - 100022882	CO18556/NFE217	0.0490	Exceeds Limit	0.8500	Passed
Middleton Regional High School	224 - Classroom - 100022885	CO18556/NFE212	0.0540	Exceeds Limit	0.8200	Passed
Middleton Regional High School	226 - Classroom - 100022881	CO18556/NFE216	0.0180	Exceeds Limit	0.2200	Passed
Middleton Regional High School	224 - Classroom - 100022886	CO18556/NFE213	0.0052	Exceeds Limit	0.2000	Passed
Middleton Regional High School	219 - Classroom - 100022888	CO18556/NFE207	0.0100	Exceeds Limit	0.0870	Passed
Middleton Regional High School	226 - Classroom - 100022880	CO18556/NFE215	0.0140	Exceeds Limit	0.1600	Passed
Middleton Regional High School	219 - Classroom Washroom - 100022889	CO18556/NFE208	0.0036	Passed	0.1200	Passed
Middleton Regional High School	Girls W/R across from Room 218 - Girls Washroom across from Room 218 - 100022890	CO18556/NFE234	0.0065	Exceeds Limit	0.2100	Passed
Middleton Regional High School	Girls W/R across from Room 218 - Girls Washroom across from Room 218 - 100022891	CO18556/NFE235	0.0029	Passed	0.1300	Passed
Middleton Regional High School	226 - Classroom - 100022879	CO18556/NFE214	0.0250	Exceeds Limit	0.2200	Passed
New Minas Elementary School	Hall-1 - Hallway 1st Floor - 100022121	COC2970/MRD741	0.0046	Passed	0.7300	Passed
New Minas Elementary School	2501 - Air Handling Unit Room - 100023947	CO18463/NFD561	0.0047	Passed	1.6000	Passed
New Minas Elementary School	Hall-2 - Hallway 2nd Floor - 100022119	COC2970/MRD738	0.0006	Passed	0.3900	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
New Minas Elementary School	Hall-1 - Hallway 1st Floor - 100022122	COC2970/MRD740	0.0011	Passed	0.5800	Passed
New Minas Elementary School	Hall-2 - Hallway 2nd Floor - 100022120	COC2970/MRD739	0.0011	Passed	0.9800	Passed
New Minas Elementary School	Hall-1 - Hallway 1st Floor - 100022081	COC2970/MRD742	0.0036	Passed	1.2000	Passed
New Minas Elementary School	1408 - Girls W/R-Gym - 100022084	COI8463/NFD551	0.0053	Exceeds Limit	1.5000	Passed
New Minas Elementary School	1404 - Gym Office - 100022086	COI8463/NFD550	0.0160	Exceeds Limit	1.4000	Passed
New Minas Elementary School	101 - Sink room - 100022088	COC2970/MRD745	0.0005	Passed	1.1000	Passed
New Minas Elementary School	103 - Kitchen - 100022089	COI8463/NFD549	0.0080	Exceeds Limit	1.3000	Passed
New Minas Elementary School	103 - Kitchen - 100022090	COC2970/MRD744	0.0019	Passed	1.5000	Passed
New Minas Elementary School	104A - Classroom Washroom - 100022095	COI8463/NFD552	0.0110	Exceeds Limit	0.4800	Passed
New Minas Elementary School	102A - Learning Support Room Washroom - 100022093	COI8463/NFD541	0.0046	Passed	0.8300	Passed
New Minas Elementary School	210C - Boys Washroom - 100022109	COI8463/NFD563	0.0044	Passed	0.8400	Passed
New Minas Elementary School	103 - Kitchen - 100022091	COC2970/MRD743	0.0025	Passed	1.3000	Passed
New Minas Elementary School	102 - Learning Support Room - 100022092	COC2970/MRD746	0.0000	Passed	0.5300	Passed
New Minas Elementary School	1406 - Boys W/R-Gym - 100022082	COI8463/NFD542	0.0024	Passed	2.1000	Exceeds Limit
New Minas Elementary School	212 - Classroom - 100022108	COC2970/MRD737	0.0000	Passed	0.8400	Passed
New Minas Elementary School	210A - Girls Washroom - 100022117	COI8463/NFD555	0.0016	Passed	2.0000	Exceeds Limit
New Minas Elementary School	210A - Girls Washroom - 100022116	COI8463/NFD556	0.0290	Exceeds Limit	1.8000	Passed
New Minas Elementary School	210A - Girls Washroom - 100022115	COI8463/NFD557	0.0140	Exceeds Limit	1.0000	Passed
New Minas Elementary School	106A - Classroom Washroom - 100022096	COI8463/NFD546	0.0120	Exceeds Limit	0.5000	Passed
New Minas Elementary School	210A - Girls Washroom - 100022114	COI8463/NFD558	0.0190	Exceeds Limit	1.1000	Passed
New Minas Elementary School	210D - Staff Washroom - 100022113	COI8463/NFD568	0.0020	Passed	1.7000	Passed
New Minas Elementary School	210B - Janitor Room - 100022118	COI8463/NFD554	0.0086	Exceeds Limit	1.0000	Passed
New Minas Elementary School	210C - Boys Washroom - 100022112	COI8463/NFD560	0.0210	Exceeds Limit	2.0000	Exceeds Limit
New Minas Elementary School	110B - Janitor Room - 100022107	COI8463/NFD564	0.0085	Exceeds Limit	0.8300	Passed
New Minas Elementary School	210C - Boys Washroom - 100022110	COI8463/NFD562	0.0290	Exceeds Limit	1.3000	Passed
New Minas Elementary School	108A - Classroom Washroom - 100022097	COI8463/NFD545	0.0088	Exceeds Limit	0.5100	Passed
New Minas Elementary School	111B - Staff Washroom - 100022106	COI8463/NFD565	0.0360	Exceeds Limit	3.6000	Exceeds Limit
New Minas Elementary School	111A - Staff Washroom - 100022105	COI8463/NFD566	0.0110	Exceeds Limit	1.5000	Passed
New Minas Elementary School	111 - Staff Room - 100022104	COC2970/MRD736	0.0028	Passed	1.1000	Passed
New Minas Elementary School	110C - Boys Washroom - 100022103	COI8463/NFD567	0.0170	Exceeds Limit	1.2000	Passed
New Minas Elementary School	110C - Boys Washroom - 100022102	COI8463/NFD548	0.0420	Exceeds Limit	1.7000	Passed
New Minas Elementary School	110C - Boys Washroom - 100022101	COI8463/NFD547	0.0042	Passed	1.6000	Passed
New Minas Elementary School	110A - Girls Washroom - 100022100	COI8463/NFD559	0.0350	Exceeds Limit	1.4000	Passed
New Minas Elementary School	110A - Girls Washroom - 100022099	COI8463/NFD543	0.0220	Exceeds Limit	0.8800	Passed
New Minas Elementary School	110A - Girls Washroom - 100022098	COI8463/NFD544	0.0065	Exceeds Limit	0.6600	Passed
New Minas Elementary School	210C - Boys Washroom - 100022111	COI8463/NFD553	0.0330	Exceeds Limit	1.2000	Passed
Northeast Kings Education Centre	224 - Food - 100024284	COK1723/NID327	0.0006	Passed	0.3000	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024106	COK1723/NID317	0.0031	Passed	0.2000	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024107	COK1723/NID318	0.0033	Passed	0.1700	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024108	COK1723/NID319	0.0013	Passed	0.1800	Passed
Northeast Kings Education Centre	Hall-MS-Gym - Hallway Mid/sch Gym - 100024144	COK1723/NID354	0.0100	Exceeds Limit	0.6400	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024109	COK1723/NID320	0.0020	Passed	0.1500	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Northeast Kings Education Centre	222 - Chemistry Lab - 100024111	COK1723/NID322	0.0024	Passed	0.2000	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024112	COK1723/NID323	0.0021	Passed	0.2100	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024113	COK1723/NID324	0.0570	Exceeds Limit	0.0580	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024110	COK1723/NID321	0.0021	Passed	0.3600	Passed
Northeast Kings Education Centre	224 - Food - 100024283	COK1723/NID326	0.0000	Passed	0.2700	Passed
Northeast Kings Education Centre	263 - Guidance Office - 100024138	COK1723/NID350	0.0005	Passed	0.1700	Passed
Northeast Kings Education Centre	224 - Food - 100024114	COK1723/NID328	0.0016	Passed	0.3800	Passed
Northeast Kings Education Centre	224 - Food - 100024115	COK1723/NID329	0.0022	Passed	0.3500	Passed
Northeast Kings Education Centre	224 - Food - 100024116	COK1723/NID330	0.0007	Passed	0.2000	Passed
Northeast Kings Education Centre	226 - Textile - 100024117	COK1723/NID331	0.0014	Passed	0.3400	Passed
Northeast Kings Education Centre	227 - Visual Arts - 100024118	COK1723/NID332	0.0011	Passed	0.0900	Passed
Northeast Kings Education Centre	227 - Visual Arts - 100024119	COK1723/NID333	0.0022	Passed	0.0880	Passed
Northeast Kings Education Centre	228 - Learning Support - 100024120	COK1723/NID334	0.0000	Passed	0.3000	Passed
Northeast Kings Education Centre	234 - Teacher Storage - 100024128	COK1723/NID341	0.0086	Exceeds Limit	0.3800	Passed
Northeast Kings Education Centre	251 - Stairs No. 11 / Janitors Rm - 100024129	COK1723/NID342	0.0012	Passed	0.2700	Passed
Northeast Kings Education Centre	223 - Physics Lab - 100024281	COK1723/NID325	0.0023	Passed	0.1700	Passed
Northeast Kings Education Centre	256 - WC - 100024137	COK1723/NID349	0.0012	Passed	0.2100	Passed
Northeast Kings Education Centre	158 - Boy's Changeroom - 100024058	COK1723/NID281	0.0005	Passed	0.4000	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024105	COK1723/NID316	0.0034	Passed	0.2000	Passed
Northeast Kings Education Centre	142D - Washroom - 100024045	COK1723/NID270	0.0006	Passed	0.4200	Passed
Northeast Kings Education Centre	139A - Washroom - 100024041	COK1723/NID266	0.0006	Passed	0.2800	Passed
Northeast Kings Education Centre	232 - Girl's Washroom MS - 100024126	COK1723/NID339	0.0026	Passed	0.4300	Passed
Northeast Kings Education Centre	167 - Gym Office - 100024072	COK1723/NID288	0.0000	Passed	0.3300	Passed
Northeast Kings Education Centre	231 - Boy's Washroom MS - 100024124	COK1723/NID337	0.0011	Passed	0.4300	Passed
Northeast Kings Education Centre	253 - Girl's Washroom HS - 100024135	COK1723/NID348	0.0014	Passed	0.1900	Passed
Northeast Kings Education Centre	253 - Girl's Washroom HS - 100024134	COK1723/NID347	0.0024	Passed	0.4100	Passed
Northeast Kings Education Centre	253 - Girl's Washroom HS - 100024133	COK1723/NID346	0.0008	Passed	0.4000	Passed
Northeast Kings Education Centre	252 - Boy's Washroom HS - 100024132	COK1723/NID345	0.0006	Passed	0.2400	Passed
Northeast Kings Education Centre	Hall-HS-Gym - Hallway H/S Gym - 100024141	COK1723/NID351	0.0000	Passed	0.1800	Passed
Northeast Kings Education Centre	252 - Boy's Washroom HS - 100024130	COK1723/NID343	0.0022	Passed	0.2800	Passed
Northeast Kings Education Centre	229 - Dark Room - 100024122	COK1723/NID335	0.0084	Exceeds Limit	0.1600	Passed
Northeast Kings Education Centre	Hall-2nd-HS - Hallway H/S 2nd Floor - 100024140	COK1723/NIE727	0.0023	Passed	0.6300	Passed
Northeast Kings Education Centre	Hall-Mid-Lower - Hallway M/S Lower - 100024143	COK1723/NID353	0.0068	Exceeds Limit	0.8300	Passed
Northeast Kings Education Centre	Hall-HS-Lower - Hallway H/S Lower - 100024142	COK1723/NID352	0.0026	Passed	0.6000	Passed
Northeast Kings Education Centre	174A - Wet Storage - Kitchen - 100024080	COK1723/NID291	0.0180	Exceeds Limit	1.3000	Passed
Northeast Kings Education Centre	150 - Janitor's Room - 100024049	COK1723/NID272	0.0028	Passed	0.3500	Passed
Northeast Kings Education Centre	142B - Staff Washroom - 100024044	COK1723/NID269	0.0007	Passed	0.1900	Passed
Northeast Kings Education Centre	142A - Staff Washroom - 100024043	COK1723/NID268	0.0008	Passed	0.1900	Passed
Northeast Kings Education Centre	131B - Washroom - 100024040	COK1723/NID265	0.0006	Passed	0.3900	Passed
Northeast Kings Education Centre	128A - Office of Library - 100024038	COK1723/NID263	0.0010	Passed	0.5600	Passed
Northeast Kings Education Centre	114B - Learning Center Kitchen - 100024032	COK1723/NID257	0.0029	Passed	0.1800	Passed
Northeast Kings Education Centre	103B - Washroom - 100024030	COK1723/NID256	0.0005	Passed	0.2700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Northeast Kings Education Centre	229 - Dark Room - 100024123	COK1723/NID336	0.0120	Exceeds Limit	0.1300	Passed
Northeast Kings Education Centre	252 - Boy's Washroom HS - 100024131	COK1723/NID344	0.0011	Passed	0.1700	Passed
Northeast Kings Education Centre	155 - Boys Washroom - 100024054	COK1723/NID277	0.0000	Passed	0.2400	Passed
Northeast Kings Education Centre	156 - Girls Washroom - 100024056	COK1723/NID279	0.0005	Passed	0.1700	Passed
Northeast Kings Education Centre	115 - Classroom - 100024033	COK1723/NID258	0.0033	Passed	0.3100	Passed
Northeast Kings Education Centre	117 - Classroom - 100024034	COK1723/NID259	0.0014	Passed	0.2800	Passed
Northeast Kings Education Centre	119 - Science - 100024035	COK1723/NID260	0.0032	Passed	0.3300	Passed
Northeast Kings Education Centre	120 - Drama - 100024036	COK1723/NID261	0.0017	Passed	0.5900	Passed
Northeast Kings Education Centre	123 - Tech Ed - 100024037	COK1723/NID262	0.0071	Exceeds Limit	0.5400	Passed
Northeast Kings Education Centre	130 - Seminar - 100024039	COK1723/NID264	0.0009	Passed	0.4400	Passed
Northeast Kings Education Centre	142 - Staff Room Kitchen - 100024042	COK1723/NID267	0.0032	Passed	0.2500	Passed
Northeast Kings Education Centre	151 - M/S Girls Washroom - 100024050	COK1723/NID273	0.0006	Passed	0.2500	Passed
Northeast Kings Education Centre	151 - M/S Girls Washroom - 100024051	COK1723/NID274	0.0013	Passed	0.3900	Passed
Northeast Kings Education Centre	168 - H/S Boys Change Room - 100024074	COK1723/NID289	0.0032	Passed	0.4200	Passed
Northeast Kings Education Centre	152 - M/S Boys Washroom - 100024053	COK1723/NID276	0.0018	Passed	0.3100	Passed
Northeast Kings Education Centre	168 - H/S Boys Change Room - 100024075	COK1723/NID290	0.0006	Passed	0.6200	Passed
Northeast Kings Education Centre	155 - Boys Washroom - 100024055	COK1723/NID278	0.0000	Passed	0.4200	Passed
Northeast Kings Education Centre	143B - Kitchen - 100024046	COK1723/NID271	0.0024	Passed	0.2800	Passed
Northeast Kings Education Centre	156 - Girls Washroom - 100024057	COK1723/NID280	0.0000	Passed	0.1700	Passed
Northeast Kings Education Centre	232 - Girl's Washroom MS - 100024127	COK1723/NID340	0.0020	Passed	0.2900	Passed
Northeast Kings Education Centre	158 - Boy's Changeroom - 100024059	COK1723/NID282	0.0014	Passed	0.1300	Passed
Northeast Kings Education Centre	159 - Office - 100024279	COK1723/NID283	0.0000	Passed	0.2100	Passed
Northeast Kings Education Centre	160 - Girl's Changeroom - 100024062	COK1723/NID284	0.0009	Passed	0.3500	Passed
Northeast Kings Education Centre	160 - Girl's Changeroom - 100024063	COK1723/NID285	0.0009	Passed	0.2700	Passed
Northeast Kings Education Centre	166 - H/S Girls Change Room - 100024066	COK1723/NID286	0.0000	Passed	0.2400	Passed
Northeast Kings Education Centre	166 - H/S Girls Change Room - 100024067	COK1723/NID287	0.0024	Passed	0.9600	Passed
Northeast Kings Education Centre	152 - M/S Boys Washroom - 100024052	COK1723/NID275	0.0005	Passed	0.3200	Passed
Northeast Kings Education Centre	186 - Girl's Washroom - 100024091	COK1723/NID302	0.0017	Passed	0.3900	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024103	COK1723/NID314	0.0320	Exceeds Limit	0.1700	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024102	COK1723/NID313	0.0012	Passed	0.0980	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024101	COK1723/NID312	0.0018	Passed	0.1900	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024100	COK1723/NID311	0.0037	Passed	0.1200	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024099	COK1723/NID310	0.0015	Passed	0.1700	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024098	COK1723/NID309	0.0025	Passed	0.0630	Passed
Northeast Kings Education Centre	221 - Biology Lab - 100024097	COK1723/NID308	0.0058	Exceeds Limit	0.1400	Passed
Northeast Kings Education Centre	220 - Science - 100024096	COK1723/NID307	0.0010	Passed	0.2400	Passed
Northeast Kings Education Centre	215 - Science - 100024095	COK1723/NID306	0.0023	Passed	0.1800	Passed
Northeast Kings Education Centre	201 - Grade 10 Science Classroom - 100024094	COK1723/NID305	0.0110	Exceeds Limit	1.2000	Passed
Northeast Kings Education Centre	102 - Social Sciences - 100024029	COK1723/NID255	0.0019	Passed	0.3100	Passed
Northeast Kings Education Centre	186 - Girl's Washroom - 100024092	COK1723/NID303	0.0027	Passed	0.3100	Passed
Northeast Kings Education Centre	222 - Chemistry Lab - 100024104	COK1723/NID315	0.0027	Passed	0.2400	Passed
Northeast Kings Education Centre	186 - Girl's Washroom - 100024090	COK1723/NID301	0.0006	Passed	0.6500	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Northeast Kings Education Centre	186 - Girl's Washroom - 100024089	COK1723/NID300	0.0017	Passed	0.4100	Passed
Northeast Kings Education Centre	185 - Boy's Washroom - 100024088	COK1723/NID299	0.0022	Passed	0.6300	Passed
Northeast Kings Education Centre	185 - Boy's Washroom - 100024087	COK1723/NID298	0.0011	Passed	0.4500	Passed
Northeast Kings Education Centre	185 - Boy's Washroom - 100024086	COK1723/NID297	0.0007	Passed	0.4300	Passed
Northeast Kings Education Centre	175 - Cafeteria/kitchen - 100024085	COK1723/NID296	0.0017	Passed	0.2000	Passed
Northeast Kings Education Centre	175 - Cafeteria/kitchen - 100024084	COK1723/NID295	0.0057	Exceeds Limit	0.1300	Passed
Northeast Kings Education Centre	175 - Cafeteria/kitchen - 100024083	COK1723/NID294	0.0130	Exceeds Limit	0.2400	Passed
Northeast Kings Education Centre	175 - Cafeteria/kitchen - 100024082	COK1723/NID293	0.0013	Passed	0.2100	Passed
Northeast Kings Education Centre	175 - Cafeteria/kitchen - 100024081	COK1723/NID292	0.0012	Passed	0.1200	Passed
Northeast Kings Education Centre	201 - Grade 10 Science Classroom - 100024093	COK1723/NID304	0.0052	Exceeds Limit	0.3900	Passed
Northeast Kings Education Centre	231 - Boy's Washroom MS - 100024125	COK1723/NID338	0.0047	Passed	0.2600	Passed
Operations Centre	WR_Shop - Washroom Shop - 100023956	COC2964/MRD725	0.0035	Passed	0.0300	Passed
Operations Centre	Off_Jani - Office Janitor's Room - 100023952	COC2964/MRD726	0.0130	Exceeds Limit	0.0440	Passed
Operations Centre	Off_Kitchen - Office Kitchen - 100023953	COC2964/MRD724	0.0012	Passed	0.0180	Passed
Pine Ridge Middle School	115 - Technology Education Production Lab - 100024177	COK1743/NID528	0.0018	Passed	0.2200	Passed
Pine Ridge Middle School	172 - Staff Lounge - 100024156	COK1743/NID557	0.0024	Passed	0.1100	Passed
Pine Ridge Middle School	201 - Science Classroom - 100024206	COK1743/NID562	0.0130	Exceeds Limit	0.2300	Passed
Pine Ridge Middle School	205 - Classroom - 100024205	COK1743/NID563	0.0073	Exceeds Limit	0.2100	Passed
Pine Ridge Middle School	206 - Classroom - 100024204	COK1743/NID564	0.0066	Exceeds Limit	0.1800	Passed
Pine Ridge Middle School	172 - Staff Lounge - 100024157	COK1743/NID558	0.0032	Passed	0.2800	Passed
Pine Ridge Middle School	211 - Classroom - 100024203	COK1743/NID566	0.0068	Exceeds Limit	0.1200	Passed
Pine Ridge Middle School	221 - Staff WR - 100024207	COK1743/NID575	0.0013	Passed	0.2000	Passed
Pine Ridge Middle School	143 - Girl's WR - 100024176	COK1743/NID543	0.0029	Passed	0.1200	Passed
Pine Ridge Middle School	124 - Corridor - 100024225	COK1743/NID532	0.0000	Passed	0.1500	Passed
Pine Ridge Middle School	115 - Technology Education Production Lab - 100024178	COK1743/NID529	0.0012	Passed	0.1400	Passed
Pine Ridge Middle School	114 - Technology Education Modular Lab - 100024179	COK1743/NID527	0.0120	Exceeds Limit	0.6800	Passed
Pine Ridge Middle School	144 - Boy's WR - 100024174	COK1743/NID544	0.0000	Passed	0.0740	Passed
Pine Ridge Middle School	146A - Jan Closet - 100024173	COK1743/NID545	0.0010	Passed	0.0880	Passed
Pine Ridge Middle School	108 - Science Classroom - 100024180	COK1743/NID522	0.0200	Exceeds Limit	0.4900	Passed
Pine Ridge Middle School	112 - Classroom - 100024182	COK1743/NID526	0.0058	Exceeds Limit	0.1400	Passed
Pine Ridge Middle School	143 - Girl's WR - 100024175	COK1743/NID542	0.0016	Passed	0.1200	Passed
Pine Ridge Middle School	135 - Girl's WR - 100024218	COK1743/NID538	0.0018	Passed	0.1500	Passed
Pine Ridge Middle School	222 - Corridor - 100024209	COK1743/NID576	0.0000	Passed	0.1200	Passed
Pine Ridge Middle School	235 - Boy's WR - 100024210	COK1743/NID581	0.0008	Passed	0.1500	Passed
Pine Ridge Middle School	235 - Boy's WR - 100024211	COK1743/NID582	0.0050	Exceeds Limit	0.5200	Passed
Pine Ridge Middle School	229 - Girl's WR - 100024212	COK1743/NID578	0.0000	Passed	0.1500	Passed
Pine Ridge Middle School	229 - Girl's WR - 100024213	COK1743/NID579	0.0029	Passed	0.3600	Passed
Pine Ridge Middle School	229 - Girl's WR - 100024214	COK1743/NID580	0.0008	Passed	0.1700	Passed
Pine Ridge Middle School	212 - Classroom - 100024202	COK1743/NID567	0.0082	Exceeds Limit	0.2100	Passed
Pine Ridge Middle School	237 - Assisted Care WR - 100024216	COK1743/NID583	0.0016	Passed	0.1700	Passed
Pine Ridge Middle School	218 - Science Classroom - 100024208	COK1743/NID574	0.0230	Exceeds Limit	0.3500	Passed
Pine Ridge Middle School	135 - Girl's WR - 100024219	COK1743/NID539	0.0014	Passed	0.1700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Pine Ridge Middle School	135 - Girl's WR - 100024220	COK1743/NID540	0.0035	Passed	0.1700	Passed
Pine Ridge Middle School	135 - Girl's WR - 100024221	COK1743/NID541	0.0000	Passed	0.1100	Passed
Pine Ridge Middle School	134 - Boy's WR - 100024222	COK1743/NID535	0.0010	Passed	0.0900	Passed
Pine Ridge Middle School	134 - Boy's WR - 100024223	COK1743/NID536	0.0007	Passed	0.1400	Passed
Pine Ridge Middle School	134 - Boy's WR - 100024224	COK1743/NID537	0.0140	Exceeds Limit	0.5300	Passed
Pine Ridge Middle School	229 - Girl's WR - 100024215	COK1743/NID577	0.0043	Passed	0.1700	Passed
Pine Ridge Middle School	230A - Janitors Closet - 100024289	COK1743/NID584	0.0000	Passed	0.0920	Passed
Pine Ridge Middle School	110 - Classroom - 100024181	COK1743/NID524	0.0071	Exceeds Limit	0.1000	Passed
Pine Ridge Middle School	215 - Textiles/Tech Ed - 100024200	COK1743/NID568	0.0088	Exceeds Limit	0.0950	Passed
Pine Ridge Middle School	208 - Science Classroom - 100024201	COK1743/NID565	0.0140	Exceeds Limit	0.2100	Passed
Pine Ridge Middle School	150 - Corridor - 100024172	COK1743/NID546	0.0000	Passed	0.1700	Passed
Pine Ridge Middle School	152 - Girl's Change Room - 100024169	COK1743/NID548	0.0000	Passed	0.1200	Passed
Pine Ridge Middle School	152 - Girl's Change Room - 100024168	COK1743/NID547	0.0000	Passed	0.1100	Passed
Pine Ridge Middle School	216 - Family Studies - 100024198	COK1743/NID571	0.0032	Passed	0.1500	Passed
Pine Ridge Middle School	154 - Gym Office WR - 100024164	COK1743/NID549	0.0009	Passed	0.1100	Passed
Pine Ridge Middle School	216 - Family Studies - 100024197	COK1743/NID570	0.0021	Passed	0.1600	Passed
Pine Ridge Middle School	157 - Boy's Change Room - 100024161	COK1743/NID552	0.0000	Passed	0.1100	Passed
Pine Ridge Middle School	157 - Boy's Change Room - 100024160	COK1743/NID551	0.0007	Passed	0.1500	Passed
Pine Ridge Middle School	116A - Store - 100024159	COK1743/NID530	0.0053	Exceeds Limit	0.0830	Passed
Pine Ridge Middle School	180 - Sick Room - 100024151	COK1743/NID560	0.0061	Exceeds Limit	0.2300	Passed
Pine Ridge Middle School	181 - WR - 100024152	COK1743/NID561	0.0064	Exceeds Limit	0.1700	Passed
Pine Ridge Middle School	164 - Kitchen - 100024153	COK1743/NID553	0.0011	Passed	0.1500	Passed
Pine Ridge Middle School	156 - Gym Office WR - 100024167	COK1743/NID550	0.0009	Passed	0.1200	Passed
Pine Ridge Middle School	101 - Classroom - 100024189	COK1743/NID517	0.0130	Exceeds Limit	0.1700	Passed
Pine Ridge Middle School	164 - Kitchen - 100024155	COK1743/NID555	0.0007	Passed	0.1100	Passed
Pine Ridge Middle School	172 - Staff Lounge - 100024158	COK1743/NID559	0.0017	Passed	0.1400	Passed
Pine Ridge Middle School	111 - Classroom - 100024183	COK1743/NID525	0.0063	Exceeds Limit	0.1200	Passed
Pine Ridge Middle School	109 - Classroom - 100024184	COK1743/NID523	0.0065	Exceeds Limit	0.1600	Passed
Pine Ridge Middle School	107 - Classroom - 100024185	COK1743/NID521	0.0310	Exceeds Limit	0.4000	Passed
Pine Ridge Middle School	106 - Classroom - 100024186	COK1743/NID520	0.0031	Passed	0.1000	Passed
Pine Ridge Middle School	216 - Family Studies - 100024199	COK1743/NID572	0.0048	Passed	0.1600	Passed
Pine Ridge Middle School	103 - Classroom - 100024188	COK1743/NID518	0.0013	Passed	0.2000	Passed
Pine Ridge Middle School	164 - Kitchen - 100024154	COK1743/NID554	0.0038	Passed	0.3800	Passed
Pine Ridge Middle School	126 - Assisted Care - 100024191	COK1743/NID534	0.0000	Passed	0.1100	Passed
Pine Ridge Middle School	125 - Seminar Room - 100024192	COK1743/NID533	0.0240	Exceeds Limit	0.3000	Passed
Pine Ridge Middle School	123 - Office/Storage - 100024193	COK1743/NID531	0.0043	Passed	0.2000	Passed
Pine Ridge Middle School	165 - Recycle Room - 100024194	COK1743/NID556	0.0320	Exceeds Limit	0.2700	Passed
Pine Ridge Middle School	217 - Art Room - 100024195	COK1743/NID573	0.0032	Passed	0.0680	Passed
Pine Ridge Middle School	216 - Family Studies - 100024196	COK1743/NID569	0.0054	Exceeds Limit	0.1300	Passed
Pine Ridge Middle School	105 - Classroom - 100024187	COK1743/NID519	0.0068	Exceeds Limit	0.1100	Passed
Port Williams Elementary School	Resource Room W/R - Resource Room Washroom - 100023000	COG6024/NAK590	0.0078	Exceeds Limit	0.7800	Passed
Port Williams Elementary School	Girls W/R - Girls Washroom - 100022990	COG6024/NAK573	0.0081	Exceeds Limit	0.5100	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Port Williams Elementary School	116 - Art Room - 100023006	B9U1912/LDL442	0.0035	Passed	0.1900	Passed
Port Williams Elementary School	112 - Classroom Washroom - 100023005	COG6024/NAK572	0.0120	Exceeds Limit	0.6800	Passed
Port Williams Elementary School	111 - Classroom Washroom - 100023004	COG6024/NAK596	0.0093	Exceeds Limit	0.4400	Passed
Port Williams Elementary School	110 - Classroom Washroom - 100023003	COG6024/NAK594	0.0025	Passed	0.3800	Passed
Port Williams Elementary School	14 - Staff Washroom - 100023008	COG6024/NAK583	0.0028	Passed	0.5500	Passed
Port Williams Elementary School	109 - Pre-Primary Classroom Washroom - 100023001	COG6024/NAK582	0.0140	Exceeds Limit	0.4500	Passed
Port Williams Elementary School	13 - Janitor Room - 100023009	COG6024/NAK592	0.0029	Passed	0.5000	Passed
Port Williams Elementary School	Resource Room W/R - Resource Room Washroom - 100022999	COG6024/NAK580	0.0019	Passed	0.8200	Passed
Port Williams Elementary School	Janitor Room - Janitor Room - 100022998	COG6024/NAK579	0.0015	Passed	0.3900	Passed
Port Williams Elementary School	Janitor Room - Janitor Room - 100022997	COG6024/NAK578	0.0083	Exceeds Limit	0.4600	Passed
Port Williams Elementary School	Resource Room - Resource Room - 100022996	B9U1912/LDL440	0.0086	Exceeds Limit	1.3000	Passed
Port Williams Elementary School	104 - Music Room - 100022995	COG6024/NAK597	0.0240	Exceeds Limit	0.1600	Passed
Port Williams Elementary School	Boys W/R - Boys Washroom - 100022994	COG6024/NAK577	0.0086	Exceeds Limit	0.5200	Passed
Port Williams Elementary School	109 - Pre-Primary Classroom - 100023002	B9U1912/LDL441	0.0047	Passed	0.8300	Passed
Port Williams Elementary School	110 - Kitchen - 100023018	COG6024/NAK591	0.0038	Passed	0.0910	Passed
Port Williams Elementary School	Boys W/R - Boys Washroom - 100022993	COG6024/NAK576	0.0064	Exceeds Limit	0.6500	Passed
Port Williams Elementary School	Girls W/R - Girls Washroom - 100022989	COI8556/NFE264	0.0720	Exceeds Limit	1.7000	Passed
Port Williams Elementary School	Boys W/R - Boys Washroom - 100022992	COG6024/NAK575	0.0095	Exceeds Limit	0.7100	Passed
Port Williams Elementary School	108A - Classroom - 100023655	COG6024/NAK598	0.0013	Passed	0.1100	Passed
Port Williams Elementary School	108A - Classroom Washroom - 100023656	COG6024/NAK588	0.0028	Passed	0.0970	Passed
Port Williams Elementary School	115 - Staff Room - 100023007	B9U1912/LDL443	0.0040	Passed	0.7800	Passed
Port Williams Elementary School	110 - Kitchen - 100023019	B9U1912/LDL446	0.0000	Passed	0.0760	Passed
Port Williams Elementary School	Hall-1 - Hallway 1st Floor - 100022988	COI8556/NFE170	0.0110	Exceeds Limit	0.0100	Passed
Port Williams Elementary School	110 - Kitchen - 100023017	COG6024/NAK593	0.0047	Passed	0.2200	Passed
Port Williams Elementary School	Boys L/R - Boys Locker Room - 100023015	COG6024/NAK587	0.0047	Passed	0.6700	Passed
Port Williams Elementary School	Boys L/R - Boys Locker Room - 100023014	COG6024/NAK586	0.0340	Exceeds Limit	0.4700	Passed
Port Williams Elementary School	Girls L/R - Girls Locker Room - 100023012	COG6024/NAK585	0.0033	Passed	0.7200	Passed
Port Williams Elementary School	Girls L/R - Girls Locker Room - 100023011	COG6024/NAK584	0.0017	Passed	0.6700	Passed
Port Williams Elementary School	Hall-1 - Hallway 1st Floor - 100023010	B9U1912/LDL444	0.0012	Passed	0.5200	Passed
Port Williams Elementary School	108A - Classroom Washroom - 100023657	COG6024/NAK589	0.0084	Exceeds Limit	0.2200	Passed
Port Williams Elementary School	Girls W/R - Girls Washroom - 100022991	COG6024/NAK574	0.0054	Exceeds Limit	0.5000	Passed
Somerset & District Elementary School	112 - Learning Support Room - 100021818	COG5397/NAH297	0.0026	Passed	0.1200	Passed
Somerset & District Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100021831	COG5404/NAH366	0.0012	Passed	0.1600	Passed
Somerset & District Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100021830	COG5404/NAH342	0.0008	Passed	0.1300	Passed
Somerset & District Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100021829	COG5404/NAH341	0.0018	Passed	0.1000	Passed
Somerset & District Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100021828	COG5404/NAH340	0.0012	Passed	0.1200	Passed
Somerset & District Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100021827	COG5404/NAH339	0.0010	Passed	0.1100	Passed
Somerset & District Elementary School	1409 - Gym-Girls Locker Room - 100021826	COG5404/NAH338	0.0110	Exceeds Limit	0.4400	Passed
Somerset & District Elementary School	1409 - Gym-Girls Locker Room - 100021825	COG5404/NAH337	0.0000	Passed	0.1800	Passed
Somerset & District Elementary School	1408 - Gym-Boys Locker Room - 100021824	COG5404/NAH336	0.0110	Exceeds Limit	0.5700	Passed
Somerset & District Elementary School	1408 - Gym-Boys Locker Room - 100021823	COG5404/NAH335	0.0007	Passed	0.1400	Passed
Somerset & District Elementary School	1404 - Gym Office Washroom - 100021822	COG5404/NAH334	0.0000	Passed	0.2200	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Somerset & District Elementary School	Lobby - Gym Lobby - 100021821	COG5397/NAH295	0.0020	Passed	0.4200	Passed
Somerset & District Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100021832	COG5404/NAH382	0.0010	Passed	0.1400	Passed
Somerset & District Elementary School	112A - Learning Support Room Washroom - 100021819	COG5404/NAH333	0.0038	Passed	0.2500	Passed
Somerset & District Elementary School	104 - Sink Room - 100021815	COG5397/NAH300	0.0038	Passed	0.1400	Passed
Somerset & District Elementary School	2501 - Mechanical Room - 100023020	COG5397/NAH292	0.0042	Passed	0.1900	Passed
Somerset & District Elementary School	105 - Classroom Washroom - 100023651	COG5404/NAH379	0.0006	Passed	0.1600	Passed
Somerset & District Elementary School	107 - Classroom Washroom - 100023652	COG5404/NAH380	0.0006	Passed	0.1500	Passed
Somerset & District Elementary School	109 - Classroom Washroom - 100023653	COG5404/NAH381	0.0009	Passed	0.1600	Passed
Somerset & District Elementary School	111 - Classroom Washroom - 100023654	COG5404/NAH369	0.0018	Passed	0.1100	Passed
Somerset & District Elementary School	Hall-1 - Hallway 1st Floor - 100021817	COG5397/NAH298	0.0016	Passed	0.4800	Passed
Somerset & District Elementary School	110 - Staff Room - 100021816	COG5397/NAH299	0.0009	Passed	0.1300	Passed
Somerset & District Elementary School	Office Staff W/R - Staff Washroom (Office) - 100021845	COG5404/NAH378	0.0000	Passed	0.1700	Passed
Somerset & District Elementary School	106 - Kitchen - 100021814	COG5397/NAH301	0.0014	Passed	0.1900	Passed
Somerset & District Elementary School	106 - Kitchen - 100021812	COG5404/NAH367	0.0013	Passed	0.1700	Passed
Somerset & District Elementary School	Hall-1 - Hallway 1st Floor - 100021820	COG5397/NAH296	0.0007	Passed	0.1100	Passed
Somerset & District Elementary School	207A - Girls Washroom - 100021837	COG5404/NAH370	0.0013	Passed	0.0940	Passed
Somerset & District Elementary School	Hall-2 - Hallway 2nd Floor - 100021836	COG5397/NAH293	0.0006	Passed	0.0990	Passed
Somerset & District Elementary School	207A - Girls Washroom - 100021838	COG5404/NAH371	0.0013	Passed	0.1300	Passed
Somerset & District Elementary School	207A - Girls Washroom - 100021839	COG5404/NAH372	0.0010	Passed	0.1800	Passed
Somerset & District Elementary School	207B - Custodial Room - 100021840	COG5404/NAH373	0.0043	Passed	0.6300	Passed
Somerset & District Elementary School	207C - Staff Washroom - 100021841	COG5404/NAH374	0.0011	Passed	0.1500	Passed
Somerset & District Elementary School	207D - Boys Washroom - 100021842	COG5404/NAH375	0.0009	Passed	0.1200	Passed
Somerset & District Elementary School	Staff W/R - Staff Washroom - 100021834	COG5404/NAH332	0.0006	Passed	0.2700	Passed
Somerset & District Elementary School	207D - Boys Washroom - 100021843	COG5404/NAH376	0.0008	Passed	0.1200	Passed
Somerset & District Elementary School	207D - Boys Washroom - 100021844	COG5404/NAH377	0.0010	Passed	0.1100	Passed
Somerset & District Elementary School	106 - Kitchen - 100021813	COG5397/NAH302	0.0005	Passed	0.1100	Passed
Somerset & District Elementary School	108B - Custodial Room - 100021833	COG5404/NAH368	0.0044	Passed	0.4600	Passed
Somerset & District Elementary School	Hall-2 - Hallway 2nd Floor - 100021835	COG5397/NAH294	0.0190	Exceeds Limit	0.1500	Passed
St. Mary's Elementary School	210A - Upstairs Janitor Room - 100021918	COH4646/NCH404	0.0074	Exceeds Limit	0.3000	Passed
St. Mary's Elementary School	110 - Janitor Room - 100021904	COH4646/NCH392	0.0059	Exceeds Limit	0.1100	Passed
St. Mary's Elementary School	108 - Pre-Primary Room - 100021905	COB3917/MTO219	0.0030	Passed	0.0150	Passed
St. Mary's Elementary School	108A - Pre-Primary Washroom - 100021906	COH4646/NCH411	0.0180	Exceeds Limit	0.0250	Passed
St. Mary's Elementary School	103 - Sink Room - 100021907	COB3917/MTO218	0.0092	Exceeds Limit	0.0033	Passed
St. Mary's Elementary School	101 - Kitchen - 100021908	COH4646/NCH410	0.0100	Exceeds Limit	0.0100	Passed
St. Mary's Elementary School	101 - Kitchen - 100021909	COB3917/MTO217	0.0044	Passed	0.0034	Passed
St. Mary's Elementary School	Hall-2 - Hallway 2nd Floor - 100021910	COB3917/MTO216	0.0000	Passed	0.0250	Passed
St. Mary's Elementary School	100 - Art Room/Cafeteria - 100021911	COB3917/MTO215	0.0096	Exceeds Limit	0.0050	Passed
St. Mary's Elementary School	U/S Staff W/R - Upstairs Staff Washroom - 100021912	COH4646/NCH409	0.0045	Passed	0.0090	Passed
St. Mary's Elementary School	210C - Upstairs Boys Washroom - 100021913	COH4646/NCH408	0.0021	Passed	0.0830	Passed
St. Mary's Elementary School	210C - Upstairs Boys Washroom - 100021914	COH4646/NCH407	0.0036	Passed	0.0840	Passed
St. Mary's Elementary School	Hall-2 - Hallway 2nd Floor - 100021916	COB3917/MTO214	0.0000	Passed	0.0150	Passed
St. Mary's Elementary School	104 - Classroom Washroom - 100023649	COH4646/NCH399	0.0081	Exceeds Limit	0.0250	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Mary's Elementary School	109 - Staff Room - 100021886	COD3917/MTO223	0.0016	Passed	0.0060	Passed
St. Mary's Elementary School	210 - Upstairs Girls Washroom - 100021919	COH4646/NCH412	0.0016	Passed	0.0680	Passed
St. Mary's Elementary School	102 - Classroom Washroom - 100023648	COH4646/NCH400	0.0150	Exceeds Limit	0.0150	Passed
St. Mary's Elementary School	210 - Upstairs Girls Washroom - 100021920	COH4646/NCH402	0.0026	Passed	0.0430	Passed
St. Mary's Elementary School	210 - Upstairs Girls Washroom - 100021921	COH4646/NCH401	0.0015	Passed	0.0260	Passed
St. Mary's Elementary School	101 - Kitchen - 100023896	COD3917/MTO213	0.0023	Passed	0.0750	Passed
St. Mary's Elementary School	Hall - Hallway - 100023897	COH4646/NCH405	0.0000	Passed	0.0250	Passed
St. Mary's Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100021902	COH4646/NCH403	0.0051	Exceeds Limit	0.0310	Passed
St. Mary's Elementary School	210C - Upstairs Boys Washroom - 100021915	COH4646/NCH406	0.0027	Passed	0.0990	Passed
St. Mary's Elementary School	Staff W/R - Staff Washroom - 100021889	COH4646/NCH397	0.0064	Exceeds Limit	0.0082	Passed
St. Mary's Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100021898	COH4646/NCH389	0.0044	Passed	0.0670	Passed
St. Mary's Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100021899	COH4646/NCH388	0.0037	Passed	0.0700	Passed
St. Mary's Elementary School	D/S Boys W/R - Downstairs Boys Washroom - 100021900	COH4646/NCH387	0.0040	Passed	0.0630	Passed
St. Mary's Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100021901	COH4646/NCH386	0.0043	Passed	0.0500	Passed
St. Mary's Elementary School	D/S Girls W/R - Downstairs Girls Washroom - 100021903	COH4646/NCH390	0.0056	Exceeds Limit	0.0820	Passed
St. Mary's Elementary School	1220 - Learning Support - 100021897	COD3917/MTO220	0.0039	Passed	0.0250	Passed
St. Mary's Elementary School	112A - Learning Support Washroom - 100021895	COH4646/NCH391	0.0048	Passed	0.0430	Passed
St. Mary's Elementary School	106 - Pre-Primary Classroom Washroom - 100023650	COH4646/NCH398	0.0076	Exceeds Limit	0.0310	Passed
St. Mary's Elementary School	1409 - Gym-Girls Locker Room - 100021894	COH4646/NCH393	0.0030	Passed	0.0680	Passed
St. Mary's Elementary School	1408 - Gym-Boys Locker Room - 100021893	COH4646/NCH395	0.0013	Passed	0.0200	Passed
St. Mary's Elementary School	Hall-1 - Hallway 1st Floor - 100021890	COD3917/MTO221	0.0000	Passed	0.0130	Passed
St. Mary's Elementary School	111 - Staff Washroom - 100021888	COH4646/NCH385	0.0054	Exceeds Limit	0.0120	Passed
St. Mary's Elementary School	Lobby - Gym Lobby - 100021887	COD3917/MTO222	0.0000	Passed	0.0100	Passed
St. Mary's Elementary School	1404 - Gym-Office - 100021891	COH4646/NCH396	0.0046	Passed	0.0400	Passed
Three Mile Plains District School	112 - Staff Room - 100023032	COH4658/NCH467	0.0011	Passed	0.2400	Passed
Three Mile Plains District School	Boys W/R - Boys Washroom - 100023028	COH4658/NCH478	0.0016	Passed	0.1100	Passed
Three Mile Plains District School	Girls W/R - Girls Washroom - 100023026	COH4658/NCH479	0.0048	Passed	0.2000	Passed
Three Mile Plains District School	Boys W/R - Boys Washroom - 100023029	COH4658/NCH477	0.0016	Passed	0.1200	Passed
Three Mile Plains District School	Girls W/R - Girls Washroom - 100023025	COH4658/NCH480	0.0011	Passed	0.0750	Passed
Three Mile Plains District School	Girls W/R - Girls Washroom - 100023023	COH4658/NCH482	0.0054	Exceeds Limit	0.2900	Passed
Three Mile Plains District School	Girls W/R - Girls Washroom - 100023024	COH4658/NCH481	0.0028	Passed	0.0890	Passed
Three Mile Plains District School	Janitor Room - Janitor Room - 100023035	COH4658/NCH474	0.0009	Passed	0.0620	Passed
Three Mile Plains District School	Hall-1 - Hallway 1st Floor - 100023021	B9U1949/LDL702	0.0000	Passed	0.0590	Passed
Three Mile Plains District School	Boys W/R - Boys Washroom - 100023030	COH4658/NCH476	0.0036	Passed	0.2100	Passed
Three Mile Plains District School	Resource Room - Resource Room - 100023031	COH4658/NCH468	0.0057	Exceeds Limit	0.0760	Passed
Three Mile Plains District School	Boys W/R - Boys Washroom - 100023027	COH4658/NCH470	0.0023	Passed	0.2100	Passed
Three Mile Plains District School	114 - Classroom - 100023022	COH4658/NCH469	0.0022	Passed	0.1200	Passed
Three Mile Plains District School	118 - Reading Recovery Room - 100023033	COH4658/NCH466	0.0052	Exceeds Limit	0.3700	Passed
Three Mile Plains District School	118 - Reading Recovery Washroom - 100023034	COH4658/NCH475	0.0016	Passed	0.3500	Passed
Three Mile Plains District School	113 - Classroom - 100023041	COH4658/NCH462	0.0012	Passed	0.1100	Passed
Three Mile Plains District School	116 - Kitchen - 100023040	COH4658/NCH463	0.0200	Exceeds Limit	0.5600	Passed
Three Mile Plains District School	114 - Classroom - 100023962	B9U1949/LDL707	0.0031	Passed	0.1700	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Three Mile Plains District School	116 - Kitchen - 100023039	COH4658/NCH472	0.0087	Exceeds Limit	0.8000	Passed
Three Mile Plains District School	113 - Classroom - 100023961	B9U1949/LDL706	0.0023	Passed	0.2400	Passed
Three Mile Plains District School	101 - Classroom - 100023647	COH4658/NCH471	0.0000	Passed	0.0580	Passed
Three Mile Plains District School	116 - Kitchen - 100023038	COH4658/NCH464	0.0043	Passed	0.2000	Passed
Three Mile Plains District School	116 - Kitchen - 100023037	COH4658/NCH465	0.0061	Exceeds Limit	0.1900	Passed
Three Mile Plains District School	115 - Washroom - 100023036	COH4658/NCH473	0.0008	Passed	0.0350	Passed
West Hants Middle School	2103 - Hallway Lower West - 100023837	COI2635/NDX629	0.0000	Passed	0.0480	Passed
West Hants Middle School	2223 - Janitor Room - 100022290	COI2432/NDW444	0.0036	Passed	0.0950	Passed
West Hants Middle School	2110 - Grade 6 Room - 100022292	COI2635/NDX617	0.0000	Passed	0.0900	Passed
West Hants Middle School	2213 - Staff Room - 100022291	COI2635/NDX616	0.0035	Passed	0.1500	Passed
West Hants Middle School	1136A - Washroom - 100023844	COI2432/NDW505	0.0031	Passed	0.3300	Passed
West Hants Middle School	Gr 7 Unisex W/R - Gr 7 Unisex Washroom - 100023843	COI2432/NDW488	0.0056	Exceeds Limit	0.2700	Passed
West Hants Middle School	2102 - Hallway Lower East - 100023842	COI2635/NDX624	0.0000	Passed	0.4500	Passed
West Hants Middle School	2106 - Learning Centre Washroom - 100023840	COI2432/NDW487	0.0018	Passed	0.2100	Passed
West Hants Middle School	1135 - Hallway Lower East - 100023838	COI2635/NDX630	0.0013	Passed	0.1200	Passed
West Hants Middle School	2201 - Hallway Upper East Section 2 - 100023836	COI2635/NDX628	0.0014	Passed	0.3000	Passed
West Hants Middle School	2201 - Hallway Upper East Section 2 - 100023835	COI2635/NDX627	0.0000	Passed	0.4000	Passed
West Hants Middle School	2304 - Food Lab - 100022289	COI2432/NDW465	0.0035	Passed	0.1900	Passed
West Hants Middle School	2308 - Science Lab - 100022275	COI2432/NDW462	0.0020	Passed	0.1000	Passed
West Hants Middle School	2201 - Hallway Upper East - 100023834	COI2635/NDX626	0.0014	Passed	0.1600	Passed
West Hants Middle School	2103 - Hallway Upper West Section 2 - 100023833	COI2635/NDX625	0.0015	Passed	0.4100	Passed
West Hants Middle School	1203 - Hallway Lower East - 100023839	COI2635/NDX631	0.0013	Passed	0.1800	Passed
West Hants Middle School	2308 - Science Lab - 100022279	COI2432/NDW466	0.0066	Exceeds Limit	0.0830	Passed
West Hants Middle School	1138 - Gr 8 Gender Neutral Washroom East - 100023791	COI2432/NDW481	0.0031	Passed	0.1600	Passed
West Hants Middle School	2214 - Staff Washroom - 100023832	COI2432/NDW486	0.0017	Passed	0.1500	Passed
West Hants Middle School	1136 - Janitor Room - 100022269	COI2432/NDW455	0.0000	Passed	0.2500	Passed
West Hants Middle School	1136 - Janitor Room - 100022270	COI2432/NDW458	0.0011	Passed	0.4400	Passed
West Hants Middle School	1302 - Hallway Lower East - 100022271	COI2635/NDX622	0.0000	Passed	0.2700	Passed
West Hants Middle School	1220 - Schools Plus Room - 100022272	COI2432/NDW459	0.0050	Exceeds Limit	0.1800	Passed
West Hants Middle School	1320 - Janitor Room - 100022273	COI2432/NDW460	0.0140	Exceeds Limit	0.3300	Passed
West Hants Middle School	2308 - Science Lab - 100022274	COI2432/NDW461	0.0040	Passed	0.1600	Passed
West Hants Middle School	2308 - Science Lab - 100022277	COI2432/NDW464	0.0070	Exceeds Limit	0.1800	Passed
West Hants Middle School	2308 - Science Lab - 100022278	COI2432/NDW475	0.0044	Passed	0.1400	Passed
West Hants Middle School	2304 - Food Lab - 100022288	COI2432/NDW467	0.0031	Passed	0.2800	Passed
West Hants Middle School	2308 - Science Lab - 100022280	COI2432/NDW457	0.0060	Exceeds Limit	0.2700	Passed
West Hants Middle School	2308 - Science Lab - 100022281	COI2432/NDW468	0.0020	Passed	0.0290	Passed
West Hants Middle School	2304 - Food Lab - 100022282	COI2432/NDW469	0.0023	Passed	0.1500	Passed
West Hants Middle School	2304 - Food Lab - 100022283	COI2432/NDW470	0.0044	Passed	0.1500	Passed
West Hants Middle School	2304 - Food Lab - 100022284	COI2432/NDW471	0.0028	Passed	0.1900	Passed
West Hants Middle School	2304 - Food Lab - 100022285	COI2432/NDW472	0.0037	Passed	0.2100	Passed
West Hants Middle School	2304 - Food Lab - 100022286	COI2432/NDW473	0.0029	Passed	0.1600	Passed
West Hants Middle School	2304 - Food Lab - 100022287	COI2432/NDW449	0.0035	Passed	0.2100	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
West Hants Middle School	2308 - Science Lab - 100022276	COI2432/NDW463	0.0027	Passed	0.1800	Passed
West Hants Middle School	1138 - Gr 8 Gender Neutral Washroom East - 100023792	COI2432/NDW448	0.0360	Exceeds Limit	0.3300	Passed
West Hants Middle School	2205 - Learning Centre - 100023793	COI2635/NDX618	0.0024	Passed	0.1300	Passed
West Hants Middle School	1213 - Kitchen - 100023803	COI2635/NDX620	0.0034	Passed	0.1500	Passed
West Hants Middle School	1213 - Kitchen - 100023802	COI2635/NDX619	0.0018	Passed	0.1700	Passed
West Hants Middle School	1228 - Learning Centre Washroom - 100023800	COI2432/NDW495	0.0078	Exceeds Limit	0.2100	Passed
West Hants Middle School	1225 - Gr 7 Girls Washroom - 100023799	COI2432/NDW494	0.0083	Exceeds Limit	0.3000	Passed
West Hants Middle School	1225 - Gr 7 Girls Washroom - 100023798	COI2432/NDW493	0.0091	Exceeds Limit	0.2300	Passed
West Hants Middle School	1225 - Gr 7 Girls Washroom - 100023797	COI2432/NDW492	0.0064	Exceeds Limit	0.1500	Passed
West Hants Middle School	1224 - Gr 7 Boys Washroom - 100023796	COI2432/NDW491	0.0069	Exceeds Limit	0.1700	Passed
West Hants Middle School	1213 - Kitchen - 100023805	COI2635/NDX632	0.0084	Exceeds Limit	0.1200	Passed
West Hants Middle School	1224 - Gr 7 Boys Washroom - 100023794	COI2432/NDW474	0.0053	Exceeds Limit	0.2100	Passed
West Hants Middle School	1213 - Kitchen - 100023806	COI2635/NDX623	0.0130	Exceeds Limit	0.2000	Passed
West Hants Middle School	1138 - Gr 8 Gender Neutral Washroom East - 100023790	COI2432/NDW454	0.0069	Exceeds Limit	0.1800	Passed
West Hants Middle School	1137 - Gr 8 Gender Neutral Washroom West - 100023789	COI2432/NDW453	0.0035	Passed	0.1900	Passed
West Hants Middle School	1137 - Gr 8 Gender Neutral Washroom West - 100023788	COI2432/NDW452	0.0043	Passed	0.3000	Passed
West Hants Middle School	1137 - Gr 8 Gender Neutral Washroom West - 100023787	COI2432/NDW451	0.0060	Exceeds Limit	0.2900	Passed
West Hants Middle School	Small Gym Office W/R - Small Gym Office Washroom - 100023785	COI2432/NDW450	0.0043	Passed	0.3000	Passed
West Hants Middle School	Small Gym Boys W/R - Small Gym Boys Washroom - 100023782	COI2432/NDW456	0.0007	Passed	0.1600	Passed
West Hants Middle School	Small Gym Boys W/R - Small Gym Boys Washroom - 100023781	COI2432/NDW447	0.0028	Passed	0.2500	Passed
West Hants Middle School	Small Gym Girls W/R - Small Gym Girls Washroom - 100023778	COI2432/NDW446	0.0012	Passed	0.1700	Passed
West Hants Middle School	Small Gym Girls W/R - Small Gym Girls Washroom - 100023777	COI2432/NDW445	0.0009	Passed	0.1500	Passed
West Hants Middle School	1224 - Gr 7 Boys Washroom - 100023795	COI2432/NDW490	0.0120	Exceeds Limit	0.2300	Passed
West Hants Middle School	2224 - Gr 8 Boys Washroom - 100023816	COI2432/NDW504	0.0034	Passed	0.1900	Passed
West Hants Middle School	1311 - Big Gym Office Washroom - 100023829	COI2432/NDW484	0.0065	Exceeds Limit	0.2800	Passed
West Hants Middle School	1313 - Big Gym Office Washroom - 100023827	COI2432/NDW482	0.0052	Exceeds Limit	0.3300	Passed
West Hants Middle School	1308 - Big Gym Washroom - 100023825	COI2432/NDW480	0.0058	Exceeds Limit	0.3000	Passed
West Hants Middle School	1308 - Big Gym Washroom - 100023824	COI2432/NDW479	0.0140	Exceeds Limit	0.2800	Passed
West Hants Middle School	1316 - Big Gym Washroom - 100023822	COI2432/NDW478	0.0082	Exceeds Limit	0.2900	Passed
West Hants Middle School	1316 - Big Gym Washroom - 100023821	COI2432/NDW477	0.0089	Exceeds Limit	0.3800	Passed
West Hants Middle School	1223 - Janitor Room - 100023820	COI2432/NDW476	0.0110	Exceeds Limit	0.3900	Passed
West Hants Middle School	2225 - Gr 8 Girls Washroom - 100023819	COI2432/NDW496	0.0190	Exceeds Limit	0.1600	Passed
West Hants Middle School	1213 - Kitchen - 100023804	COI2635/NDX621	0.0047	Passed	0.1900	Passed
West Hants Middle School	2225 - Gr 8 Girls Washroom - 100023817	COI2432/NDW483	0.0077	Exceeds Limit	0.1400	Passed
West Hants Middle School	2215 - Staff Washroom - 100023831	COI2432/NDW485	0.0038	Passed	0.1800	Passed
West Hants Middle School	2224 - Gr 8 Boys Washroom - 100023815	COI2432/NDW503	0.0030	Passed	0.1400	Passed
West Hants Middle School	2224 - Gr 8 Boys Washroom - 100023814	COI2432/NDW502	0.0039	Passed	0.1200	Passed
West Hants Middle School	1127 - Gr 6 Boys Washroom - 100023813	COI2432/NDW501	0.0045	Passed	0.3100	Passed
West Hants Middle School	1127 - Gr 6 Boys Washroom - 100023812	COI2432/NDW500	0.0046	Passed	0.2900	Passed
West Hants Middle School	1127 - Gr 6 Boys Washroom - 100023811	COI2432/NDW499	0.0088	Exceeds Limit	0.5400	Passed
West Hants Middle School	1129 - Gr 6 Girls Washroom - 100023810	COI2432/NDW489	0.0068	Exceeds Limit	0.2900	Passed
West Hants Middle School	1129 - Gr 6 Girls Washroom - 100023809	COI2432/NDW497	0.0120	Exceeds Limit	0.2100	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
West Hants Middle School	1129 - Gr 6 Girls Washroom - 100023808	C0I2432/NDW506	0.0079	Exceeds Limit	0.2500	Passed
West Hants Middle School	1202 - Hallway Lower East - 100023807	C0I2635/NDX615	0.0000	Passed	0.2500	Passed
West Hants Middle School	2225 - Gr 8 Girls Washroom - 100023818	C0I2432/NDW498	0.0048	Passed	0.1800	Passed
West Kings District High School	Girls W/R - Girls Washroom - 100024261	C0K2644/NIJ059	0.0007	Passed	0.0770	Passed
West Kings District High School	111 - AHU Room - 100024262	C0K2644/NIJ061	0.0028	Passed	0.1600	Passed
West Kings District High School	Girls W/R - Girls Washroom - 100024260	C0K2644/NIJ058	0.0008	Passed	0.0950	Passed
West Kings District High School	B-wing Girls W/R - B-wing Girls Washroom - 100024259	C0K2644/NIJ057	0.0007	Passed	0.1200	Passed
West Kings District High School	A-wing Girls W/R - A-wing Girls Washroom - 100024258	C0K2644/NIJ054	0.0008	Passed	0.1100	Passed
West Kings District High School	A-wing Girls W/R - A-wing Girls Washroom - 100024257	C0K2644/NIJ052	0.0007	Passed	0.0750	Passed
West Kings District High School	C132 - Physics Lab - 100023561	C0D3813/MTN833	0.0047	Passed	0.6000	Passed
West Kings District High School	B078 - Boiler Room - 100024263	C0K2644/NIJ060	0.0035	Passed	0.0970	Passed
West Kings District High School	B-wing Girls W/R - B-wing Girls Washroom - 100023521	C0K2644/NIJ118	0.0009	Passed	0.1200	Passed
West Kings District High School	C023 - Lower C-wing Girls Washroom - 100023534	C0K2644/NIJ124	0.0081	Exceeds Limit	0.2200	Passed
West Kings District High School	A-wing Boys W/R - A-wing Boys Washroom - 100023509	C0K2644/NIJ066	0.0013	Passed	0.1000	Passed
West Kings District High School	A-wing Boys W/R - A-wing Boys Washroom - 100023510	C0K2644/NIJ087	0.0008	Passed	0.0930	Passed
West Kings District High School	A-wing Girls W/R - A-wing Girls Washroom - 100023511	C0K2644/NIJ053	0.0014	Passed	0.1300	Passed
West Kings District High School	A-wing Girls W/R - A-wing Girls Washroom - 100023512	C0K2644/NIJ082	0.0014	Passed	0.1200	Passed
West Kings District High School	A017 - Hallway A-Wing - 100023513	C0D3813/MTN820	0.0024	Passed	0.1500	Passed
West Kings District High School	A041A - Janitor Room - 100023514	C0K2644/NIJ112	0.0034	Passed	0.1200	Passed
West Kings District High School	A041 - Recycle Room - 100023515	C0D3813/MTN821	0.0032	Passed	0.1100	Passed
West Kings District High School	001B - Staff Washroom in Main Office - 100023516	C0K2644/NIJ113	0.0000	Passed	0.0620	Passed
West Kings District High School	B-wing Boys W/R - B-wing Boys Washroom - 100023517	C0K2644/NIJ114	0.0015	Passed	0.0810	Passed
West Kings District High School	B-wing Boys W/R - B-wing Boys Washroom - 100023518	C0K2644/NIJ115	0.0048	Passed	0.1700	Passed
West Kings District High School	A051A - Gym Office Washroom - 100023506	C0K2644/NIJ064	0.0012	Passed	0.1100	Passed
West Kings District High School	B-wing Girls W/R - B-wing Girls Washroom - 100023520	C0K2644/NIJ117	0.0022	Passed	0.1100	Passed
West Kings District High School	A049A - Gym Office Washroom - 100023504	C0K2644/NIJ063	0.0024	Passed	0.1200	Passed
West Kings District High School	B-wing Girls W/R - B-wing Girls Washroom - 100023522	C0K2644/NIJ119	0.0011	Passed	0.1100	Passed
West Kings District High School	B044 - Hallway B-Wing - 100023523	C0D3813/MTN822	0.0072	Exceeds Limit	0.2700	Passed
West Kings District High School	C010 - Staff Room - 100023524	C0D3813/MTN823	0.0040	Passed	0.1400	Passed
West Kings District High School	C019 - Storage Room - 100023525	C0D3813/MTN824	0.0270	Exceeds Limit	0.5800	Passed
West Kings District High School	C020 - Kitchen - 100023526	C0D3813/MTN838	0.0033	Passed	0.1800	Passed
West Kings District High School	C020 - Kitchen - 100023527	C0D3813/MTN826	0.0210	Exceeds Limit	0.4100	Passed
West Kings District High School	C020 - Kitchen - 100023528	C0D3813/MTN815	0.0068	Exceeds Limit	0.2300	Passed
West Kings District High School	C020 - Kitchen - 100023529	C0D3813/MTN828	0.0210	Exceeds Limit	0.6100	Passed
West Kings District High School	C021 - Lower C-wing Boys Washroom - 100023530	C0K2644/NIJ120	0.0060	Exceeds Limit	0.1700	Passed
West Kings District High School	C021 - Lower C-wing Boys Washroom - 100023531	C0K2644/NIJ121	0.0028	Passed	0.7200	Passed
West Kings District High School	C021 - Lower C-wing Boys Washroom - 100023532	C0K2644/NIJ122	0.0013	Passed	0.0910	Passed
West Kings District High School	C021 - Lower C-wing Boys Washroom - 100023533	C0K2644/NIJ138	0.0028	Passed	0.1300	Passed
West Kings District High School	B-wing Boys W/R - B-wing Boys Washroom - 100023519	C0K2644/NIJ116	0.0008	Passed	0.1400	Passed
West Kings District High School	B012 - Learning Centre Washroom - 100023481	C0K2644/NIJ079	0.0120	Exceeds Limit	0.2800	Passed
West Kings District High School	- Hallway C-Wing Lower - 100023230	C0D3813/MTN825	0.0031	Passed	0.1800	Passed
West Kings District High School	- Lower C-Wing Washroom - 100023231	C0K2644/NIJ067	0.0027	Passed	0.1600	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
West Kings District High School	Lower C-Wing W/R - Lower C-Wing Washroom - 100023232	COK2644/NIJ070	0.0024	Passed	0.1300	Passed
West Kings District High School	C033 - Janitor Room - 100023233	COK2644/NIJ071	0.0093	Exceeds Limit	0.2200	Passed
West Kings District High School	B022 - Staff Washroom - 100023234	COK2644/NIJ072	0.0016	Passed	0.0840	Passed
West Kings District High School	Upper C-wing Girls W/R - Upper C-wing Girls Washroom - 100023563	COK2644/NIJ095	0.0081	Exceeds Limit	0.2300	Passed
West Kings District High School	B017 - Industrial Arts Shop - 100023235	COK2644/NIJ073	0.0026	Passed	0.0930	Passed
West Kings District High School	B036 - Hallway B-Wing - Locker Pod - 100023475	COD3813/MTN816	0.0012	Passed	0.0930	Passed
West Kings District High School	Boys W/R - Boys Washroom - 100023476	COK2644/NIJ075	0.0030	Passed	0.3000	Passed
West Kings District High School	Boys W/R - Boys Washroom - 100023477	COK2644/NIJ076	0.0015	Passed	0.2800	Passed
West Kings District High School	Girls W/R - Girls Washroom - 100023478	COK2644/NIJ077	0.0051	Exceeds Limit	0.2500	Passed
West Kings District High School	A035 - A-wing Janitor Room - 100023508	COK2644/NIJ065	0.0009	Passed	0.0920	Passed
West Kings District High School	B012 - Learning Centre - 100023480	COD3813/MTN817	0.0073	Exceeds Limit	0.1800	Passed
West Kings District High School	B017 - Industrial Arts Shop - 100023236	COK2644/NIJ074	0.0030	Passed	0.1500	Passed
West Kings District High School	A042 - Kitchen - 100023482	COK2644/NIJ080	0.0007	Passed	0.1100	Passed
West Kings District High School	A042 - Kitchen - 100023483	COD3813/MTN818	0.0050	Exceeds Limit	0.2200	Passed
West Kings District High School	A042 - Kitchen - 100023484	COK2644/NIJ085	0.0027	Passed	0.0970	Passed
West Kings District High School	A053 - Girls Locker Room - 100023485	COK2644/NIJ081	0.0012	Passed	0.0790	Passed
West Kings District High School	A053 - Girls Locker Room - 100023486	COK2644/NIJ069	0.0008	Passed	0.0850	Passed
West Kings District High School	A052 - Girls Locker Room - 100023487	COK2644/NIJ083	0.0000	Passed	0.1000	Passed
West Kings District High School	A052 - Girls Locker Room - 100023488	COK2644/NIJ084	0.0000	Passed	0.1000	Passed
West Kings District High School	A047 - Boys Locker Room - 100023494	COK2644/NIJ055	0.0025	Passed	0.1200	Passed
West Kings District High School	A047 - Boys Locker Room - 100023495	COK2644/NIJ056	0.0008	Passed	0.1100	Passed
West Kings District High School	A048 - Boys Locker Room - 100023498	COK2644/NIJ062	0.0010	Passed	0.0870	Passed
West Kings District High School	A048 - Boys Locker Room - 100023499	COK2644/NIJ068	0.0007	Passed	0.1100	Passed
West Kings District High School	Hallway Gym - Hallway Gym - 100023503	COD3813/MTN819	0.0094	Exceeds Limit	0.1600	Passed
West Kings District High School	Girls W/R - Girls Washroom - 100023479	COK2644/NIJ078	0.0014	Passed	0.0750	Passed
West Kings District High School	D-wing Girls W/R - D-wing Girls Washroom - 100023574	COK2644/NIJ103	0.0008	Passed	0.0900	Passed
West Kings District High School	C134 - Upper C-wing Janitor Room - 100023562	COK2644/NIJ094	0.0021	Passed	0.1100	Passed
West Kings District High School	Upper C-wing Girls W/R - Upper C-wing Girls Washroom - 100023564	COK2644/NIJ096	0.0042	Passed	0.3000	Passed
West Kings District High School	Upper C-wing Boys W/R - Upper C-wing Boys Washroom - 100023565	COK2644/NIJ097	0.0015	Passed	0.0850	Passed
West Kings District High School	Upper C-wing Boys W/R - Upper C-wing Boys Washroom - 100023566	COK2644/NIJ098	0.0082	Exceeds Limit	0.3200	Passed
West Kings District High School	Upper C-wing W/R - Upper C-wing Washroom - 100023567	COK2644/NIJ110	0.0020	Passed	0.1200	Passed
West Kings District High School	- Hallway D-Wing - 100023568	COD3813/MTN834	0.0029	Passed	0.1200	Passed
West Kings District High School	D004 - Art Room - 100023569	COD3813/MTN835	0.0043	Passed	0.1500	Passed
West Kings District High School	D004 - Art Room - 100023570	COD3813/MTN836	0.0090	Exceeds Limit	0.1600	Passed
West Kings District High School	D006 - Band Room Storage - 100023571	COK2644/NIJ100	0.0027	Passed	0.1100	Passed
West Kings District High School	C132 - Physics Lab - 100023560	COD3813/MTN832	0.0032	Passed	0.4100	Passed
West Kings District High School	D-wing Boys W/R - D-wing Boys Washroom - 100023573	COK2644/NIJ102	0.0024	Passed	0.1200	Passed
West Kings District High School	A042 - Kitchen - 100023889	COD3813/MTN837	0.0240	Exceeds Limit	0.3000	Passed
West Kings District High School	D-wing Girls W/R - D-wing Girls Washroom - 100023575	COK2644/NIJ104	0.0010	Passed	0.0990	Passed
West Kings District High School	D108 - D-wing Staff Washroom - 100023576	COK2644/NIJ105	0.0037	Passed	0.1500	Passed
West Kings District High School	D109 - D-wing Janitor Room - 100023577	COK2644/NIJ106	0.0260	Exceeds Limit	0.5900	Passed
West Kings District High School	D107 - Technology Classroom Storage - 100023578	COK2644/NIJ107	0.0061	Exceeds Limit	0.0680	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
West Kings District High School	D103 - Technology Classroom - 100023579	COK2644/NIJ108	0.0008	Passed	0.0750	Passed
West Kings District High School	A042 - Kitchen - 100023890	COD3813/MTN827	0.0170	Exceeds Limit	0.4300	Passed
West Kings District High School	C128 - Chemistry Lab - 100023892	COK2644/NIJ109	0.0035	Passed	0.2000	Passed
West Kings District High School	Upper C-Wing Staff W/R - Upper C-Wing Staff Washroom - 100023895	COK2644/NIJ125	0.0023	Passed	0.2500	Passed
West Kings District High School	C023 - Lower C-wing Girls Washroom - 100023535	COK2644/NIJ111	0.0079	Exceeds Limit	0.2800	Passed
West Kings District High School	D-wing Boys W/R - D-wing Boys Washroom - 100023572	COK2644/NIJ086	0.0034	Passed	0.1500	Passed
West Kings District High School	C120 - Science Lab - 100023544	COK2644/NIJ133	0.0025	Passed	0.1500	Passed
West Kings District High School	B024 - Yoga Classroom - 100023538	COD3813/MTN829	0.0077	Exceeds Limit	0.5600	Passed
West Kings District High School	C023 - Lower C-wing Girls Washroom - 100023537	COK2644/NIJ127	0.0036	Passed	0.1600	Passed
West Kings District High School	C023 - Lower C-wing Girls Washroom - 100023536	COK2644/NIJ126	0.0012	Passed	0.1300	Passed
West Kings District High School	C132 - Physics Lab - 100023559	COD3813/MTN831	0.0160	Exceeds Limit	0.1400	Passed
West Kings District High School	B019 - B-wing Janitor/Staff Room - 100023539	COK2644/NIJ128	0.0049	Passed	0.2800	Passed
West Kings District High School	C118 - Biology Lab - 100023540	COK2644/NIJ129	0.0012	Passed	0.1200	Passed
West Kings District High School	C118 - Biology Lab - 100023541	COK2644/NIJ130	0.0016	Passed	0.1400	Passed
West Kings District High School	C120 - Science Lab - 100023543	COK2644/NIJ132	0.0140	Exceeds Limit	0.3300	Passed
West Kings District High School	C120 - Science Lab - 100023545	COK2644/NIJ134	0.0029	Passed	0.1900	Passed
West Kings District High School	C124 - Science Classroom - 100023546	COK2644/NIJ135	0.0067	Exceeds Limit	0.1700	Passed
West Kings District High School	C128 - Chemistry Lab - 100023553	COK2644/NIJ089	0.0130	Exceeds Limit	0.1700	Passed
West Kings District High School	C128 - Chemistry Lab - 100023557	COK2644/NIJ093	0.0079	Exceeds Limit	0.2200	Passed
West Kings District High School	C128 - Chemistry Lab - 100023556	COK2644/NIJ092	0.0110	Exceeds Limit	0.4400	Passed
West Kings District High School	C128 - Chemistry Lab - 100023555	COK2644/NIJ091	0.0140	Exceeds Limit	0.1700	Passed
West Kings District High School	C118 - Biology Lab - 100023542	COK2644/NIJ131	0.0012	Passed	0.1100	Passed
West Kings District High School	C128 - Chemistry Lab - 100023554	COK2644/NIJ090	0.0091	Exceeds Limit	0.2000	Passed
West Kings District High School	C124 - Science Classroom - 100023547	COK2644/NIJ136	0.0130	Exceeds Limit	0.1200	Passed
West Kings District High School	C128 - Chemistry Lab - 100023552	COK2644/NIJ088	0.0043	Passed	0.1400	Passed
West Kings District High School	C128 - Chemistry Lab - 100023551	COK2644/NIJ123	0.0093	Exceeds Limit	0.2900	Passed
West Kings District High School	C128 - Chemistry Lab - 100023550	COK2644/NIJ099	0.0078	Exceeds Limit	0.2100	Passed
West Kings District High School	C128 - Chemistry Lab - 100023549	COK2644/NIJ101	0.0025	Passed	0.1300	Passed
West Kings District High School	C124 - Science Classroom - 100023548	COK2644/NIJ137	0.0140	Exceeds Limit	0.1300	Passed
Windsor Elementary School	Hall-2-NW - Hallway 2nd Floor NW - 100023102	B9V1717/LFP140	0.0006	Passed	0.0820	Passed
Windsor Elementary School	118 - Downstairs Boys Washroom - 100023113	COK8382/NJN447	0.0030	Passed	0.0740	Passed
Windsor Elementary School	111 - Classroom - 100023117	B9V1717/LFP145	0.0011	Passed	0.0960	Passed
Windsor Elementary School	106 - Staff Room - 100023116	B9V1717/LFP141	0.0034	Passed	0.1000	Passed
Windsor Elementary School	Hall-1-NW - Hallway 1st Floor NW - 100023100	B9V1717/LFP139	0.0000	Passed	0.0500	Passed
Windsor Elementary School	120 - Janitor Room - 100023101	B9V1717/LFP151	0.0000	Passed	0.0720	Passed
Windsor Elementary School	111 - Classroom Washroom - 100023118	COK8382/NJN439	0.0055	Exceeds Limit	0.2100	Passed
Windsor Elementary School	Hall-2-NE - Hallway 2nd Floor NE - 100023103	B9V1717/LFP142	0.0000	Passed	0.0590	Passed
Windsor Elementary School	Staff W/R - Staff Washroom - 100023104	COK8382/NJN454	0.0140	Exceeds Limit	0.1800	Passed
Windsor Elementary School	Staff W/R - Staff Washroom - 100023105	COK8382/NJN455	0.0026	Passed	0.4300	Passed
Windsor Elementary School	104 - Schools Plus Room - 100023106	B9V1717/LFP143	0.0012	Passed	0.0580	Passed
Windsor Elementary School	116 - Downstairs Girls Washroom - 100023108	COK8382/NJN442	0.0082	Exceeds Limit	0.1200	Passed
Windsor Elementary School	116 - Downstairs Girls Washroom - 100023109	COK8382/NJN443	0.0031	Passed	0.0620	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Windsor Elementary School	116 - Downstairs Girls Washroom - 100023110	COK8382/NJN444	0.0220	Exceeds Limit	0.0640	Passed
Windsor Elementary School	118 - Downstairs Boys Washroom - 100023111	COK8382/NJN445	0.0047	Passed	0.0610	Passed
Windsor Elementary School	112 - Pre-Primary Classroom - 100023119	B9V1717/LFP146	0.0006	Passed	0.1800	Passed
Windsor Elementary School	110 - Classroom Washroom - 100023115	COK8382/NJN438	0.0017	Passed	0.0310	Passed
Windsor Elementary School	118 - Downstairs Boys Washroom - 100023112	COK8382/NJN446	0.0170	Exceeds Limit	0.0990	Passed
Windsor Elementary School	Gym-Office W/R - Gym-Office Washroom - 100023130	COK8382/NJN452	0.0240	Exceeds Limit	0.3900	Passed
Windsor Elementary School	205 - Science Classroom - 100023142	B9V1717/LFP153	0.0038	Passed	0.3200	Passed
Windsor Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023140	COK8382/NJN463	0.0069	Exceeds Limit	0.0680	Passed
Windsor Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023139	COK8382/NJN462	0.0037	Passed	0.0460	Passed
Windsor Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023138	COK8382/NJN461	0.0069	Exceeds Limit	0.0320	Passed
Windsor Elementary School	U/S Girls W/R - Upstairs Girls Washroom - 100023137	COK8382/NJN460	0.0024	Passed	0.0320	Passed
Windsor Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023136	COK8382/NJN459	0.0043	Passed	0.0740	Passed
Windsor Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023135	COK8382/NJN458	0.0110	Exceeds Limit	0.0690	Passed
Windsor Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023134	COK8382/NJN457	0.0038	Passed	0.0920	Passed
Windsor Elementary School	Gym-Girls W/R - Gym-Girls Washroom - 100023126	COK8382/NJN451	0.0024	Passed	0.1900	Passed
Windsor Elementary School	Fan Room 1 - Fan Room 1 - 100023132	COK8382/NJN449	0.0015	Passed	0.0260	Passed
Windsor Elementary School	113 - Classroom - 100023120	COK8382/NJN440	0.0013	Passed	0.0140	Passed
Windsor Elementary School	Gym-Boys W/R - Gym-Boys Washroom - 100023128	COK8382/NJN450	0.0110	Exceeds Limit	0.1400	Passed
Windsor Elementary School	110 - Classroom - 100023114	B9V1717/LFP144	0.0014	Passed	0.1300	Passed
Windsor Elementary School	205 - Science Classroom - 100023141	B9V1717/LFP152	0.0010	Passed	0.1400	Passed
Windsor Elementary School	150 - Music Room - 100023125	B9V1717/LFP150	0.0045	Passed	0.1900	Passed
Windsor Elementary School	Kitchen - Kitchen - 100023124	COK8382/NJN453	0.0200	Exceeds Limit	0.3000	Passed
Windsor Elementary School	Kitchen - Kitchen - 100023123	B9V1717/LFP149	0.0013	Passed	0.0690	Passed
Windsor Elementary School	146 - Janitor Room - 100023122	COK8382/NJN448	0.0007	Passed	0.0360	Passed
Windsor Elementary School	114 - Pre-Primary Classroom - 100023121	COK8382/NJN441	0.0008	Passed	0.0110	Passed
Windsor Elementary School	U/S Boys W/R - Upstairs Boys Washroom - 100023133	COK8382/NJN456	0.0084	Exceeds Limit	0.0460	Passed
Windsor Forks District School	Kitchen - Kitchen - 100023053	COG6758/NAP492	0.0330	Exceeds Limit	0.1100	Passed
Windsor Forks District School	2 - Classroom - 100023972	COG6758/NAP496	0.0000	Passed	0.0850	Passed
Windsor Forks District School	Janitor Room - Janitor Room - 100024266	COG6758/NAP499	0.0015	Passed	0.1300	Passed
Windsor Forks District School	New Portable - New Portable - 100024265	COG6758/NAP498	0.0040	Passed	0.0650	Passed
Windsor Forks District School	Hall-1-S - Hallway South - 100023042	COG6758/NAP494	0.0022	Passed	0.0630	Passed
Windsor Forks District School	Girls W/R - Girls Washroom - 100023043	COG6758/NAP486	0.0250	Exceeds Limit	0.1900	Passed
Windsor Forks District School	Girls W/R - Girls Washroom - 100023044	COG6758/NAP485	0.0350	Exceeds Limit	0.2600	Passed
Windsor Forks District School	Girls W/R - Girls Washroom - 100023045	COG6758/NAP484	0.0360	Exceeds Limit	0.1500	Passed
Windsor Forks District School	New Portable - New Portable - 100023474	COG6758/NAP475	0.0022	Passed	0.0420	Passed
Windsor Forks District School	Resource Room #1 - Resource Room #1 WR - 100023473	COG6758/NAP476	0.0310	Exceeds Limit	0.1600	Passed
Windsor Forks District School	4 - Learning Centre - 100023472	COG6758/NAP477	0.0030	Passed	0.1300	Passed
Windsor Forks District School	4 - Learning Centre - 100023471	COG6758/NAP487	0.0031	Passed	0.0680	Passed
Windsor Forks District School	Kitchen - Kitchen - 100023055	COG6758/NAP490	0.0370	Exceeds Limit	0.1000	Passed
Windsor Forks District School	2 - Classroom - 100023470	COG6758/NAP488	0.0470	Exceeds Limit	0.0820	Passed
Windsor Forks District School	1 - Classroom - 100023469	COG6758/NAP489	0.3400	Exceeds Limit	0.1600	Passed
Windsor Forks District School	- Resource #1 - 100023970	B9U1965/LDL837	0.0031	Passed	0.3200	Passed

## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Windsor Forks District School	1 - Classroom - 100023971	COG6758/NAP495	0.0007	Passed	0.1800	Passed
Windsor Forks District School	Janitor Room - Janitor Room - 100023047	COG6758/NAP483	0.0076	Exceeds Limit	0.2000	Passed
Windsor Forks District School	Boys W/R - Boys Washroom - 100023048	COG6758/NAP482	0.0081	Exceeds Limit	0.1300	Passed
Windsor Forks District School	Boys W/R - Boys Washroom - 100023050	COG6758/NAP480	0.0170	Exceeds Limit	0.1400	Passed
Windsor Forks District School	Staff Room - Staff Room - 100023051	COG6758/NAP493	0.0190	Exceeds Limit	0.0680	Passed
Windsor Forks District School	Staff W/R - Staff Washroom - 100023052	COG6758/NAP479	0.0230	Exceeds Limit	0.1400	Passed
Windsor Forks District School	Kitchen - Kitchen - 100023054	COG6758/NAP491	0.0410	Exceeds Limit	0.0910	Passed
Windsor Forks District School	Hall-1-S - Hallway South - 100023046	COG6758/NAP481	0.0096	Exceeds Limit	0.1100	Passed
Windsor Forks District School	Kitchen - Kitchen - 100023056	COG6758/NAP478	0.0410	Exceeds Limit	0.2100	Passed
Wolfville School	136 - Boys Washroom - 100023172	COI1507/NDR139	0.0027	Passed	0.1000	Passed
Wolfville School	257 - Food Lab - 100023191	COC5954/MRU919	0.0250	Exceeds Limit	0.7300	Passed
Wolfville School	135 - Girls Washroom - 100023170	COI1507/NDR115	0.0071	Exceeds Limit	0.3100	Passed
Wolfville School	151 - Staff Washroom - 100023176	COI1507/NDR146	0.0086	Exceeds Limit	1.1000	Passed
Wolfville School	150 - Staff Room - 100023178	COC5954/MRU918	0.0070	Exceeds Limit	0.7000	Passed
Wolfville School	160 - Boys Locker Room - 100023179	COI1507/NDR145	0.0110	Exceeds Limit	0.4300	Passed
Wolfville School	162 - Girls Locker Room - 100023181	COI1507/NDR144	0.0330	Exceeds Limit	1.2000	Passed
Wolfville School	211 - Janitor Room - 100023183	COI1507/NDR143	0.0058	Exceeds Limit	1.1000	Passed
Wolfville School	238 - Girls Washroom - 100023184	COI1507/NDR142	0.0085	Exceeds Limit	0.3800	Passed
Wolfville School	238 - Girls Washroom - 100023185	COI1507/NDR131	0.0120	Exceeds Limit	0.4500	Passed
Wolfville School	238 - Girls Washroom - 100023186	COI1507/NDR140	0.0190	Exceeds Limit	0.5300	Passed
Wolfville School	239 - Boys Washroom - 100023187	COI1507/NDR147	0.0073	Exceeds Limit	0.3200	Passed
Wolfville School	239 - Boys Washroom - 100023188	COI1507/NDR138	0.0063	Exceeds Limit	0.2800	Passed
Wolfville School	136 - Boys Washroom - 100023174	COI1507/NDR122	0.0042	Passed	0.1400	Passed
Wolfville School	243 - Washroom - 100023190	COI1507/NDR136	0.0020	Passed	2.2000	Exceeds Limit
Wolfville School	136 - Boys Washroom - 100023173	COI1507/NDR120	0.0052	Exceeds Limit	0.1600	Passed
Wolfville School	257 - Food Lab - 100023192	COC5954/MRU920	0.0130	Exceeds Limit	0.8300	Passed
Wolfville School	257 - Food Lab - 100023193	COC5954/MRU921	0.0065	Exceeds Limit	0.7200	Passed
Wolfville School	257 - Food Lab - 100023194	COC5954/MRU922	0.0130	Exceeds Limit	0.5900	Passed
Wolfville School	259 - Family Studies Room - 100023195	COI1507/NDR135	0.0020	Passed	1.6000	Passed
Wolfville School	174 - Music Room - 100023644	COC5954/MRU917	0.0075	Exceeds Limit	1.3000	Passed
Wolfville School	168 - Kitchen - 100023643	COI1507/NDR141	0.0052	Exceeds Limit	0.9500	Passed
Wolfville School	168 - Kitchen - 100023642	COC5954/MRU924	0.0089	Exceeds Limit	1.0000	Passed
Wolfville School	168 - Kitchen - 100023641	COI1507/NDR132	0.0068	Exceeds Limit	1.3000	Passed
Wolfville School	167 - Recycle Room - 100023640	COC5954/MRU923	0.0028	Passed	1.4000	Passed
Wolfville School	262 - Washroom - 100023639	COI1507/NDR133	0.0026	Passed	0.2000	Passed
Wolfville School	217 - Washroom - 100023638	COI1507/NDR134	0.0055	Exceeds Limit	0.1000	Passed
Wolfville School	239 - Boys Washroom - 100023189	COI1507/NDR137	0.0056	Exceeds Limit	0.2500	Passed
Wolfville School	260 - Science Lab - 100023158	COI1507/NDR130	0.0100	Exceeds Limit	0.1700	Passed
Wolfville School	111 - Janitor Room - 100023144	COI1507/NDR113	0.0099	Exceeds Limit	0.5300	Passed
Wolfville School	111 - Janitor Room - 100023145	COI1507/NDR129	0.0150	Exceeds Limit	0.6400	Passed
Wolfville School	137 - Fountain - 100023146	COC5954/MRU908	0.0000	Passed	0.8200	Passed
Wolfville School	118 - Washroom? - 100023148	COI1507/NDR128	0.0120	Exceeds Limit	0.2600	Passed



## Annapolis Valley Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Wolfville School	117 - Classroom - 100023149	COC5954/MRU909	0.0100	Exceeds Limit	0.5300	Passed
Wolfville School	170 - Industrial Arts Shop - 100023150	COI1507/NDR127	0.0046	Passed	1.3000	Passed
Wolfville School	170 - Industrial Arts Shop - 100023151	COI1507/NDR126	0.0160	Exceeds Limit	0.8000	Passed
Wolfville School	120 - Classroom - 100023152	COC5954/MRU910	0.0220	Exceeds Limit	0.6600	Passed
Wolfville School	260 - Science Lab - 100023153	COI1507/NDR125	0.0048	Passed	1.2000	Passed
Wolfville School	260 - Science Lab - 100023154	COI1507/NDR124	0.0140	Exceeds Limit	0.4800	Passed
Wolfville School	260 - Science Lab - 100023155	COI1507/NDR123	0.0110	Exceeds Limit	0.6000	Passed
Wolfville School	148 - Classroom - 100023175	COC5954/MRU907	0.0540	Exceeds Limit	0.5800	Passed
Wolfville School	260 - Science Lab - 100023157	COI1507/NDR121	0.0170	Exceeds Limit	1.1000	Passed
Wolfville School	Fountain - Fountain - 100023143	COC5954/MRU915	0.0011	Passed	1.2000	Passed
Wolfville School	121 - Classroom - 100023159	COC5954/MRU911	0.0098	Exceeds Limit	0.6700	Passed
Wolfville School	123 - Washroom? - 100023160	COI1507/NDR119	0.0032	Passed	1.3000	Passed
Wolfville School	130 - Classroom - 100023161	COC5954/MRU912	0.0110	Exceeds Limit	0.9000	Passed
Wolfville School	132 - Classroom - 100023162	COC5954/MRU913	0.0420	Exceeds Limit	1.9000	Passed
Wolfville School	114 - Washroom - 100023163	COI1507/NDR118	0.0055	Exceeds Limit	1.4000	Passed
Wolfville School	115 - Classroom - 100023165	COC5954/MRU914	0.0082	Exceeds Limit	0.6400	Passed
Wolfville School	124 - Art Room - 100023166	COC5954/MRU925	0.0052	Exceeds Limit	1.4000	Passed
Wolfville School	124 - Art Room - 100023167	COC5954/MRU916	0.0055	Exceeds Limit	1.4000	Passed
Wolfville School	139 - Staff Washroom - 100023168	COI1507/NDR117	0.0045	Passed	1.0000	Passed
Wolfville School	135 - Girls Washroom - 100023169	COI1507/NDR116	0.0052	Exceeds Limit	0.1800	Passed
Wolfville School	135 - Girls Washroom - 100023171	COI1507/NDR114	0.0092	Exceeds Limit	0.1900	Passed
Wolfville School	260 - Science Lab - 100023156	COI1507/NDR112	0.0140	Exceeds Limit	0.7500	Passed