

# Water Test Results

Cape Breton – Victoria Regional Centre for Education



## Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate remediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

## Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

## Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

[www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html](http://www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html)

Copper:

[www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3](http://www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3)

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Adult High School (Ashby)	Fountain	ASH-DF-1 (1)	0,0000	Passed	0,0370	Passed
Adult High School (Ashby)	Fountain	ASH-DF-1 (2)	0,0026	Passed	0,5400	Passed
Adult High School (Ashby)	Washroom	ASH-KS-FWR2-1	0,0014	Passed	0,4100	Passed
Adult High School (Ashby)	Washroom	ASH-KS-MWR2-1	0,0017	Passed	1,5000	Passed
Adult High School (Ashby)	Main	ASH-MAIN-1	0,0170	Exceeds Limit	1,2000	Passed
Adult High School (Ashby)	Main	ASH-MAIN-2	0,0094	Exceeds Limit	0,8100	Passed
Baddeck Academy	Fountain	BAD-DF-1	0,0000	Passed	0,0350	Passed
Baddeck Academy	Fountain	BAD-DF-3	0,0004	Passed	0,0420	Passed
Baddeck Academy	Washroom	BAD-KS-ACWR	0,0010	Passed	0,0410	Passed
Baddeck Academy	Lab	BAD-KS-BIO-1	0,0120	Exceeds Limit	0,1500	Passed
Baddeck Academy	Lab	BAD-KS-BIO-2	0,0041	Passed	0,0900	Passed
Baddeck Academy	Lab	BAD-KS-BIO-3	0,0055	Exceeds Limit	0,0580	Passed
Baddeck Academy	Washroom	BAD-KS-BLWR	0,0110	Exceeds Limit	0,0280	Passed
Baddeck Academy	Lab	BAD-KS-CHEM-1	0,0049	Passed	0,0470	Passed
Baddeck Academy	Lab	BAD-KS-CHEM-2	0,0054	Exceeds Limit	0,0650	Passed
Baddeck Academy	Lab	BAD-KS-CHEM-3	0,0061	Exceeds Limit	0,0500	Passed
Baddeck Academy	Lab	BAD-KS-CHEM-4	0,0042	Passed	0,0810	Passed
Baddeck Academy	Lab	BAD-KS-CHEM-5	0,0034	Passed	0,0490	Passed
Baddeck Academy	Lab	BAD-KS-CHEM-6	0,0033	Passed	0,0530	Passed
Baddeck Academy	Washroom	BAD-KS-ELBWR-1	0,0000	Passed	0,0270	Passed
Baddeck Academy	Washroom	BAD-KS-ELBWR-2	0,0000	Passed	0,0160	Passed
Baddeck Academy	Washroom	BAD-KS-ELGWR-1	0,0005	Passed	0,0290	Passed
Baddeck Academy	Washroom	BAD-KS-ELGWR-2	0,0020	Passed	0,0900	Passed
Baddeck Academy	Staff	BAD-KS-ELSTF	0,0000	Passed	0,0190	Passed
Baddeck Academy	Washroom	BAD-KS-GBWR-1	0,0044	Passed	0,0320	Passed
Baddeck Academy	Washroom	BAD-KS-GBWR-2	0,0006	Passed	0,0360	Passed
Baddeck Academy	Washroom	BAD-KS-GGWR-1	0,0007	Passed	0,0380	Passed
Baddeck Academy	Washroom	BAD-KS-GGWR-2	0,0006	Passed	0,0610	Passed
Baddeck Academy	Washroom	BAD-KS-GLWR	0,0071	Exceeds Limit	0,0450	Passed
Baddeck Academy	Office	BAD-KS-GOFF-1	0,1700	Exceeds Limit	0,1600	Passed
Baddeck Academy	Office	BAD-KS-GOFF-2	0,0340	Exceeds Limit	0,1600	Passed
Baddeck Academy	Washroom	BAD-KS-JBWR-1	0,0000	Passed	0,0290	Passed
Baddeck Academy	Washroom	BAD-KS-JBWR-2	0,0000	Passed	0,0170	Passed
Baddeck Academy	Washroom	BAD-KS-JGWR-1	0,0000	Passed	0,0360	Passed
Baddeck Academy	Washroom	BAD-KS-JGWR-2	0,0006	Passed	0,0390	Passed
Baddeck Academy	Learning Center	BAD-KS-LSLs	0,0007	Passed	0,0260	Passed
Baddeck Academy	Music	BAD-KS-MSc	0,0027	Passed	0,0540	Passed
Baddeck Academy	Pre-primary	BAD-KS-PPR1-1	0,0000	Passed	0,0180	Passed
Baddeck Academy	Pre-primary	BAD-KS-PPR1-2	0,0000	Passed	0,0230	Passed
Baddeck Academy	Pre-primary	BAD-KS-PPR1-3	0,0025	Passed	0,0230	Passed
Baddeck Academy	Lab	BAD-KS-PREP	0,0086	Exceeds Limit	0,0910	Passed
Baddeck Academy	Washroom	BAD-KS-SWR-1	0,0005	Passed	0,0250	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Baddeck Academy	Washroom	BAD-KS-SWR-2	0,0008	Passed	0,0390	Passed
Baddeck Academy	Tech Room	BAD-KS-TECH	0,0030	Passed	0,0470	Passed
Boularderie Elementary School	Fountain	BOU-DF-1	0,0000	Passed	0,0540	Passed
Boularderie Elementary School	Fountain	BOU-DF-2	0,0029	Passed	0,2900	Passed
Boularderie Elementary School	Fountain	BOU-DF-3	0,0007	Passed	0,0460	Passed
Boularderie Elementary School	Room 102	BOU-KS-102	0,0021	Passed	0,2600	Passed
Boularderie Elementary School	Room 108	BOU-KS-108	0,0220	Exceeds Limit	0,7500	Passed
Boularderie Elementary School	Room 138	BOU-KS-138	0,0055	Exceeds Limit	0,1100	Passed
Boularderie Elementary School	Room A113	BOU-KS-A113	0,1000	Exceeds Limit	3,0000	Exceeds Limit
Boularderie Elementary School	Washroom	BOU-KS-ACWR-1	0,0540	Exceeds Limit	3,5000	Exceeds Limit
Boularderie Elementary School	Washroom	BOU-KS-ACWR-2	0,0250	Exceeds Limit	0,5800	Passed
Boularderie Elementary School	Sick	BOU-KS-SICK	0,0420	Exceeds Limit	0,1200	Passed
Boularderie Elementary School	Staff	BOU-KS-STAFF	0,0026	Passed	0,0340	Passed
Boularderie Elementary School	Washroom	BOU-KS-SWR-1	0,0058	Exceeds Limit	0,0500	Passed
Boularderie Elementary School	Washroom	BOU-KS-SWR-2	0,0110	Exceeds Limit	0,1400	Passed
Bras d'Or Elementary School	Fountain	BRD-DF-1	0,0000	Passed	0,1300	Passed
Bras d'Or Elementary School	Fountain	BRD-DF-4	0,0000	Passed	0,1400	Passed
Bras d'Or Elementary School	Fountain	BRD-DF-BL	0,0000	Passed	0,2900	Passed
Bras d'Or Elementary School	Fountain	BRD-DF-GL	0,0000	Passed	0,4400	Passed
Bras d'Or Elementary School	Room 2	BRD-KS-2	0,0000	Passed	0,2000	Passed
Bras d'Or Elementary School	Room 28	BRD-KS-28	0,0000	Passed	0,3400	Passed
Bras d'Or Elementary School	Room 40	BRD-KS-40	0,0011	Passed	0,4200	Passed
Bras d'Or Elementary School	Room 6	BRD-KS-6	0,0000	Passed	0,6100	Passed
Bras d'Or Elementary School	Cafeteria	BRD-KS-CAF	0,0000	Passed	0,1200	Passed
Bras d'Or Elementary School	Kitchen	BRD-KS-KIT	0,0000	Passed	0,4700	Passed
Bras d'Or Elementary School	Washroom	BRD-KS-LCWR	0,0000	Passed	0,0230	Passed
Bras d'Or Elementary School	Pre-primary	BRD-KS-PR1	0,0000	Passed	0,1800	Passed
Bras d'Or Elementary School	Pre-primary	BRD-KS-PREK	0,0000	Passed	0,4900	Passed
Bras d'Or Elementary School	Staff	BRD-KS-STAFF	0,0000	Passed	0,1100	Passed
Bras d'Or Elementary School	Main	BRD-MAIN	0,0008	Passed	0,0065	Passed
Breton Education Centre	Fountain	BEC-DF-1	0,0000	Passed	0,0720	Passed
Breton Education Centre	Fountain	BEC-DF-2	0,0000	Passed	0,0390	Passed
Breton Education Centre	Fountain	BEC-DF-3	0,0000	Passed	0,1500	Passed
Breton Education Centre	Room 1	BEC-KS-A10-1	0,0023	Passed	0,4300	Passed
Breton Education Centre	Room 2	BEC-KS-A10-2	0,0260	Exceeds Limit	0,3300	Passed
Breton Education Centre	Room 3	BEC-KS-A10-3	0,0005	Passed	0,1300	Passed
Breton Education Centre	Room 4	BEC-KS-A10-4	0,0360	Exceeds Limit	0,2600	Passed
Breton Education Centre	Room 5	BEC-KS-A10-5	0,0086	Exceeds Limit	0,3700	Passed
Breton Education Centre	Room 6	BEC-KS-A10-6	0,0170	Exceeds Limit	0,5300	Passed
Breton Education Centre	Room 14	BEC-KS-A14	0,0050	Passed	0,0880	Passed
Breton Education Centre	Room 15	BEC-KS-A15	0,0590	Exceeds Limit	0,3200	Passed
Breton Education Centre	Room 20	BEC-KS-A20	0,0075	Exceeds Limit	0,7500	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Breton Education Centre	Room A7-1	BEC-KS-A7-1	0,0012	Passed	0,3500	Passed
Breton Education Centre	Room A7-2	BEC-KS-A7-2	0,0000	Passed	0,2000	Passed
Breton Education Centre	Room At-3	BEC-KS-A7-3	0,0016	Passed	0,3900	Passed
Breton Education Centre	Room A7-4	BEC-KS-A7-4	0,0032	Passed	0,6000	Passed
Breton Education Centre	Room A7-5	BEC-KS-A7-5	0,0000	Passed	0,3700	Passed
Breton Education Centre	Room A7-6	BEC-KS-A7-6	0,0010	Passed	0,3800	Passed
Breton Education Centre	Music	BEC-KS-BAND	0,0016	Passed	0,1400	Passed
Breton Education Centre	Fitness Area	BEC-KS-BFIT-1	0,0032	Passed	0,2600	Passed
Breton Education Centre	Lab	BEC-KS-BIO-1	0,0410	Exceeds Limit	0,0790	Passed
Breton Education Centre	Lab	BEC-KS-BIO-2	0,0490	Exceeds Limit	0,1700	Passed
Breton Education Centre	Lab	BEC-KS-BIO-3	0,1200	Exceeds Limit	0,4200	Passed
Breton Education Centre	Lab	BEC-KS-BIO-4	0,0380	Exceeds Limit	0,1000	Passed
Breton Education Centre	Break room	BEC-KS-BRK	0,0000	Passed	0,3100	Passed
Breton Education Centre	Lab	BEC-KS-CHEM-1	0,0790	Exceeds Limit	1,8000	Passed
Breton Education Centre	Lab	BEC-KS-CHEM-2	0,0380	Exceeds Limit	0,1700	Passed
Breton Education Centre	Lab	BEC-KS-CHEM-3	0,0090	Exceeds Limit	0,2400	Passed
Breton Education Centre	Lab	BEC-KS-CHEM-4	0,0610	Exceeds Limit	0,2000	Passed
Breton Education Centre	Lab	BEC-KS-CHEM-5	0,0110	Exceeds Limit	0,4100	Passed
Breton Education Centre	Cleaner Closet	BEC-KS-CLN	0,0007	Passed	0,2000	Passed
Breton Education Centre	Coal bowl wing	BEC-KS-COAL	0,0190	Exceeds Limit	0,3100	Passed
Breton Education Centre	Custodian	BEC-KS-CUST	0,0023	Passed	0,2700	Passed
Breton Education Centre	Exam	BEC-KS-EXAM	0,0033	Passed	0,3700	Passed
Breton Education Centre	Fitness Area	BEC-KS-GFIT-1	0,0230	Exceeds Limit	0,7900	Passed
Breton Education Centre	Fitness Area	BEC-KS-GFIT-2	0,0170	Exceeds Limit	0,7400	Passed
Breton Education Centre	Office	BEC-KS-GOFF-1	0,0017	Passed	0,3800	Passed
Breton Education Centre	Office	BEC-KS-GOFF-2	0,0011	Passed	0,0310	Passed
Breton Education Centre	Art 1	BEC-KS-JART-1	0,0210	Exceeds Limit	0,2900	Passed
Breton Education Centre	Art 2	BEC-KS-JART-2	0,0110	Exceeds Limit	0,1500	Passed
Breton Education Centre	Art 3	BEC-KS-JART-3	0,0120	Exceeds Limit	0,1600	Passed
Breton Education Centre	Science	BEC-KS-JSCI	0,0220	Exceeds Limit	0,2400	Passed
Breton Education Centre	Cleaner Closet	BEC-KS-JSTF	0,0079	Exceeds Limit	0,6200	Passed
Breton Education Centre	Kitchen	BEC-KS-KIT-1	0,0000	Passed	0,0470	Passed
Breton Education Centre	Kitchen	BEC-KS-KIT-2	0,0015	Passed	0,3300	Passed
Breton Education Centre	Learning Center	BEC-KS-LC3	0,0059	Exceeds Limit	0,3500	Passed
Breton Education Centre	Learning Center	BEC-KS-LC4	0,0000	Passed	0,1400	Passed
Breton Education Centre	Library	BEC-KS-LIB	0,0220	Exceeds Limit	0,9400	Passed
Breton Education Centre	Lab	BEC-KS-PHYS-1	0,0670	Exceeds Limit	0,2800	Passed
Breton Education Centre	Lab	BEC-KS-PHYS-2	0,0190	Exceeds Limit	0,5300	Passed
Breton Education Centre	Lab	BEC-KS-PHYS-3	0,0310	Exceeds Limit	0,2900	Passed
Breton Education Centre	Lab	BEC-KS-PHYS-4	0,0450	Exceeds Limit	0,2400	Passed
Breton Education Centre	Art room	BEC-KS-SART	0,0013	Passed	0,3300	Passed
Breton Education Centre	Storage	BEC-KS-STOR	0,0920	Exceeds Limit	0,2900	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Breton Education Centre	Main	BEC-MAIN	0,0039	Passed	1,6000	Passed
Brookland Elementary School	In gym	BRK-DF-1	0,0000	Passed	0,4500	Passed
Brookland Elementary School	Hall outside of room 229	BRK-DF-2	0,0000	Passed	0,5200	Passed
Brookland Elementary School	Hall outside of room 115	BRK-DF-3	0,0000	Passed	0,2800	Passed
Brookland Elementary School	Room 104	BRK-KS-104	0,0007	Passed	0,3700	Passed
Brookland Elementary School	Staff Room	BRK-KS-105	0,0026	Passed	0,5000	Passed
Brookland Elementary School	Room 108	BRK-KS-108	0,0005	Passed	0,6800	Passed
Brookland Elementary School	Room 109	BRK-KS-109	0,0009	Passed	0,4700	Passed
Brookland Elementary School	Room 115	BRK-KS-115	0,0006	Passed	0,3500	Passed
Brookland Elementary School	Room 117	BRK-KS-117	0,0000	Passed	0,4500	Passed
Brookland Elementary School	Room 121	BRK-KS-121	0,0027	Passed	0,8200	Passed
Brookland Elementary School	Room 122	BRK-KS-122	0,0010	Passed	0,4000	Passed
Brookland Elementary School	Room 123	BRK-KS-123	0,0010	Passed	0,5400	Passed
Brookland Elementary School	Room 150	BRK-KS-150	0,0000	Passed	0,3800	Passed
Brookland Elementary School	Room 151	BRK-KS-151	0,0010	Passed	0,6500	Passed
Brookland Elementary School	Library	BRK-KS-201	0,0020	Passed	0,7700	Passed
Brookland Elementary School	Music room	BRK-KS-204	0,0013	Passed	0,6300	Passed
Brookland Elementary School	Kitchen	BRK-KS-205-1 (1)	0,0008	Passed	0,7000	Passed
Brookland Elementary School	Kitchen	BRK-KS-205-1 (2)	0,0007	Passed	0,6900	Passed
Brookland Elementary School	Kitchen	BRK-KS-205-1 (3)	0,0033	Passed	0,5900	Passed
Brookland Elementary School	Kitchen	BRK-KS-205-1 (4)	0,0000	Passed	0,7400	Passed
Brookland Elementary School	Kitchen	BRK-KS-205-1 (5)	0,0000	Passed	0,7100	Passed
Brookland Elementary School	Kitchen	BRK-KS-205-1 (6)	0,0000	Passed	0,6600	Passed
Brookland Elementary School	Kitchen storage	BRK-KS-205-3 (1)	0,0008	Passed	0,7500	Passed
Brookland Elementary School	Room 216	BRK-KS-216	0,0007	Passed	0,3600	Passed
Brookland Elementary School	Room 217	BRK-KS-217	0,0000	Passed	0,6700	Passed
Brookland Elementary School	Room 221	BRK-KS-221	0,0014	Passed	0,5600	Passed
Brookland Elementary School	Room 222	BRK-KS-222	0,0000	Passed	0,4800	Passed
Brookland Elementary School	Room 224	BRK-KS-224	0,0000	Passed	0,6100	Passed
Brookland Elementary School	Room 229	BRK-KS-229	0,0000	Passed	0,5500	Passed
Brookland Elementary School	Room 230	BRK-KS-230	0,0005	Passed	0,4200	Passed
Brookland Elementary School	Room 231	BRK-KS-231	0,0014	Passed	0,5300	Passed
Brookland Elementary School	Room 234	BRK-KS-234	0,0007	Passed	0,6100	Passed
Brookland Elementary School	Room 235	BRK-KS-235	0,0000	Passed	0,6900	Passed
Brookland Elementary School	Room 236	BRK-KS-236	0,0007	Passed	0,8300	Passed
Brookland Elementary School	Room 237	BRK-KS-237	0,0000	Passed	0,6600	Passed
Brookland Elementary School	In art room	BRK-KS-ART1	0,0130	Exceeds Limit	0,4000	Passed
Brookland Elementary School	In art room	BRK-KS-ART2	0,0011	Passed	0,5600	Passed
Brookland Elementary School	In storage room 103	BRK-MAIN	0,0036	Passed	0,0830	Passed
Cabot Education Centre	Sick Room	CAB-KS-HCSICK	0,0048	Passed	0,0580	Passed
Cabot Education Centre	Home Ec	CAB-KS-HEC-1	0,1200	Exceeds Limit	0,4300	Passed
Cabot Education Centre	Home Ec	CAB-KS-HEC-2	0,4700	Exceeds Limit	0,1100	Passed



## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cabot Education Centre	Home Ec	CAB-KS-HEC-3	0,0320	Exceeds Limit	0,7900	Passed
Cabot Education Centre	Home Ec	CAB-KS-HEC-4	0,0027	Passed	0,0530	Passed
Cabot Education Centre	Kitchen	CAB-KS-KIT-1	0,1400	Exceeds Limit	0,0590	Passed
Cabot Education Centre	Kitchen	CAB-KS-KIT-2	0,0030	Passed	0,0400	Passed
Cabot Education Centre	Kitchen	CAB-KS-KIT-3	0,3400	Exceeds Limit	0,4700	Passed
Cabot Education Centre	Music	CAB-KS-MUSC	0,0300	Exceeds Limit	0,1300	Passed
Cape Smokey Elementary School	Room 107	CSE-KS-107	0,0000	Passed	0,0550	Passed
Cape Smokey Elementary School	Room 109	CSE-KS-109	0,0000	Passed	0,0600	Passed
Cape Smokey Elementary School	Room 117	CSE-KS-117	0,0000	Passed	0,0410	Passed
Cape Smokey Elementary School	Room 123	CSE-KS-123(1)	0,0011	Passed	0,0320	Passed
Cape Smokey Elementary School	Room 124	CSE-KS-124	0,0035	Passed	0,0440	Passed
Cape Smokey Elementary School	Room 130	CSE-KS-130	0,0000	Passed	0,0330	Passed
Cape Smokey Elementary School	Room 144	CSE-KS-144	0,0005	Passed	0,0270	Passed
Cape Smokey Elementary School	Room 145	CSE-KS-145	0,0000	Passed	0,0350	Passed
Cape Smokey Elementary School	Room 150	CSE-KS-150	0,0000	Passed	0,0460	Passed
Cape Smokey Elementary School	Room 151	CSE-KS-151	0,0000	Passed	0,0500	Passed
Cape Smokey Elementary School	Room 174	CSE-KS-174	0,0007	Passed	0,0400	Passed
Cape Smokey Elementary School	Boiler Room	CSE-KS-BOIL	0,0010	Passed	0,0410	Passed
Cape Smokey Elementary School	Class	CSE-KS-CLASS	0,0000	Passed	0,0370	Passed
Cape Smokey Elementary School	Hallway	CSE-KS-HALL	0,0005	Passed	0,0650	Passed
Cape Smokey Elementary School	Kitchen	CSE-KS-KIT-1	0,0008	Passed	0,0590	Passed
Cape Smokey Elementary School	Kitchen	CSE-KS-KIT-2	0,0000	Passed	0,0460	Passed
Cape Smokey Elementary School	Kitchen	CSE-KS-KIT-3	0,0045	Passed	0,0810	Passed
Cape Smokey Elementary School	Main	CSE-MAIN	0,0040	Passed	0,0690	Passed
Coxheath Elementary School	Hall near washroom on 3rd floor	COX-DF-1	0,0000	Passed	0,0200	Passed
Coxheath Elementary School	Top of stairs to 3rd floor	COX-DF-2	0,0000	Passed	0,0720	Passed
Coxheath Elementary School	Hall near gym	COX-DF-3	0,0013	Passed	0,2500	Passed
Coxheath Elementary School	In room 200 pre primary	COX-DF-4-200	0,0020	Passed	0,3900	Passed
Coxheath Elementary School	Base of stairs	COX-DF-5	0,0000	Passed	0,0530	Passed
Coxheath Elementary School	Cafeteria	COX-KS-122	0,0000	Passed	0,4900	Passed
Coxheath Elementary School	Music room	COX-KS-124	0,0000	Passed	0,3100	Passed
Coxheath Elementary School	Room 201	COX-KS-201	0,0007	Passed	0,5300	Passed
Coxheath Elementary School	Room 227	COX-KS-227	0,0000	Passed	0,2200	Passed
Coxheath Elementary School	Work room in main office	COX-KS-234	0,0017	Passed	0,5200	Passed
Coxheath Elementary School	Staff room 310	COX-KS-310	0,0013	Passed	0,5800	Passed
Cusack School	Room 100	CUS-KS-100	0,0420	Exceeds Limit	1,3000	Passed
Cusack School	Room 101	CUS-KS-101	0,0047	Passed	0,5100	Passed
Cusack School	Room 102	CUS-KS-102	0,2900	Exceeds Limit	2,3000	Exceeds Limit
Cusack School	Room 103	CUS-KS-103	0,0440	Exceeds Limit	1,0000	Passed
Cusack School	Room 106	CUS-KS-106	0,0021	Passed	0,6300	Passed
Cusack School	Room 107	CUS-KS-107	0,0059	Exceeds Limit	0,7800	Passed
Cusack School	Room 108	CUS-KS-108	0,0018	Passed	0,3000	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cusack School	Room 109	CUS-KS-109	0,0000	Passed	0,5000	Passed
Cusack School	Room 110	CUS-KS-110	0,0000	Passed	0,6800	Passed
Cusack School	Room 111	CUS-KS-111	0,0010	Passed	0,5900	Passed
Cusack School	Room 112	CUS-KS-112	0,0000	Passed	0,5700	Passed
Cusack School	Room 113	CUS-KS-113	0,0000	Passed	0,5800	Passed
Cusack School	Room 114	CUS-KS-114	0,0000	Passed	0,5600	Passed
Cusack School	Room 216	CUS-KS-216	0,0000	Passed	0,4600	Passed
Cusack School	Art room	CUS-KS-ART	0,0370	Exceeds Limit	0,4700	Passed
Cusack School	Art room	CUS-KS-ART	0,0280	Exceeds Limit	1,4000	Passed
Cusack School	Kitchen in cafeteria	CUS-KS-CAF 1	0,0009	Passed	0,5500	Passed
Cusack School	Kitchen in cafeteria	CUS-KS-CAF 2	0,0012	Passed	0,3900	Passed
Cusack School	Kitchen in cafeteria	CUS-KS-CAF 3	0,0014	Passed	0,2500	Passed
Cusack School	Kitchen in cafeteria	CUS-KS-CAF 4	0,0000	Passed	0,4900	Passed
Cusack School	Classroom on 2nd floor next to room 214	CUS-KS-CLASS	0,0000	Passed	0,4200	Passed
Cusack School	Classroom on 2nd floor next to room 216	CUS-KS-CLASS 2	0,0000	Passed	0,5700	Passed
Cusack School	In classroom on 2nd floor	CUS-KS-CLASS 3	0,0000	Passed	0,6900	Passed
Cusack School	In learning centre beside room 106	CUS-KS-LC	0,0034	Passed	0,7300	Passed
Cusack School	Library	CUS-KS-LIB	0,1900	Exceeds Limit	0,7300	Passed
Cusack School	Music room	CUS-KS-MUSIC	0,0300	Exceeds Limit	0,8400	Passed
Cusack School	Staff room	CUS-KS-STAFF	0,0014	Passed	0,3900	Passed
Cusack School	Near main entrance in a storage/kitchen room	CUS-KS-STOR	0,0010	Passed	0,5100	Passed
Donkin School	Main	DON MAIN	0,0210	Exceeds Limit	0,0610	Passed
Donkin School	Fountain	DON-DF-1	0,0010	Passed	0,0430	Passed
Donkin School	Fountain	DON-DF-2	0,0000	Passed	0,1300	Passed
Donkin School	Fountain	DON-DF-3	0,0000	Passed	0,0340	Passed
Donkin School	Room 103	DON-KS-103	0,0000	Passed	0,0140	Passed
Donkin School	Art	DON-KS-ART-1	0,0250	Exceeds Limit	0,0590	Passed
Donkin School	Art	DON-KS-ART-1	0,0015	Passed	0,1300	Passed
Donkin School	Art	DON-KS-ART-2	0,0330	Exceeds Limit	0,0430	Passed
Donkin School	Art	DON-KS-ART-2	0,0260	Exceeds Limit	0,1200	Passed
Donkin School	Art	DON-KS-ART-3	0,0250	Exceeds Limit	0,0500	Passed
Donkin School	Art	DON-KS-ART-3	0,0056	Exceeds Limit	0,0960	Passed
Donkin School	Art	DON-KS-ART-4	0,0250	Exceeds Limit	0,0580	Passed
Donkin School	Art	DON-KS-ART-4	0,0089	Exceeds Limit	0,1000	Passed
Donkin School	Home Ec	DON-KS-HEC-1	0,0027	Passed	0,0470	Passed
Donkin School	Home Ec	DON-KS-HEC-2	0,0045	Passed	0,0410	Passed
Donkin School	Home Ec	DON-KS-HEC-3	0,0066	Exceeds Limit	0,0420	Passed
Donkin School	Home Ec	DON-KS-HEC-3	0,0000	Passed	0,0570	Passed
Donkin School	Home Ec	DON-KS-HEC-4	0,0110	Exceeds Limit	0,0400	Passed
Donkin School	Home Ec	DON-KS-HEC-4	0,0007	Passed	0,0850	Passed
Donkin School	Home Ec	DON-KS-HEC-5	0,0037	Passed	0,0370	Passed
Donkin School	Home Ec	DON-KS-HEC-6	0,0045	Passed	0,0540	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Donkin School	Kitchen	DON-KS-KITCHEN-1	0,0000	Passed	0,0610	Passed
Donkin School	Kitchen	DON-KS-KITCHEN-2	0,0000	Passed	0,0340	Passed
Donkin School	Music	DON-KS-MUSC	0,0010	Passed	0,1000	Passed
Donkin School	Staff	DON-KS-STAFF	0,0012	Passed	0,1500	Passed
Donkin School	Tech Room	DON-KS-WOOD	0,0015	Passed	0,0330	Passed
Dr. T.L. Sullivan School	Fountain	DTS-DF-1	0,0018	Passed	0,2000	Passed
Dr. T.L. Sullivan School	Fountain	DTS-DF-2	0,0000	Passed	0,1100	Passed
Dr. T.L. Sullivan School	Fountain	DTS-DF-3	0,0094	Exceeds Limit	0,1500	Passed
Dr. T.L. Sullivan School	Fountain	DTS-DF-3	0,0027	Passed	0,0300	Passed
Dr. T.L. Sullivan School	Fountain	DTS-DF-4	0,0019	Passed	0,2700	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207 (2)	0,0000	Passed	0,0250	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207 (3)	0,0930	Exceeds Limit	0,0430	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207 (4)	0,0007	Passed	0,0240	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207 (5)	0,0000	Passed	0,0220	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207 (6)	0,0000	Passed	0,0220	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207(1)	0,0039	Passed	0,0600	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207(2)	0,0130	Exceeds Limit	0,1000	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207(3)	0,3000	Exceeds Limit	0,1500	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207(4)	0,1100	Exceeds Limit	0,0920	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207(5)	0,0076	Exceeds Limit	0,0370	Passed
Dr. T.L. Sullivan School	Room 207	DTS-KS-207(6)	0,0090	Exceeds Limit	0,0620	Passed
Dr. T.L. Sullivan School	Art	DTS-KS-ART-1	0,0410	Exceeds Limit	0,2300	Passed
Dr. T.L. Sullivan School	Art 1	DTS-KS-ART-1	0,0030	Passed	0,0470	Passed
Dr. T.L. Sullivan School	Art	DTS-KS-ART-2	0,0140	Exceeds Limit	0,2900	Passed
Dr. T.L. Sullivan School	Art 2	DTS-KS-ART-2	0,0049	Passed	0,0830	Passed
Dr. T.L. Sullivan School	Multi purpose	DTS-KS-AV	0,0036	Passed	0,0740	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-1	0,0760	Exceeds Limit	0,3100	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-1	0,0096	Exceeds Limit	0,5500	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-2	0,0370	Exceeds Limit	0,3500	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-2	0,0042	Passed	0,4700	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-3	0,0037	Passed	0,0640	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-4	0,0092	Exceeds Limit	0,4100	Passed
Dr. T.L. Sullivan School	Cafeteria	DTS-KS-CAF-4	0,0069	Exceeds Limit	0,1200	Passed
Dr. T.L. Sullivan School	Cleaner Closet	DTS-KS-JAN	0,0110	Exceeds Limit	0,0770	Passed
Dr. T.L. Sullivan School	Cleaner Closet	DTS-KS-JAN	0,0000	Passed	0,0280	Passed
Dr. T.L. Sullivan School	Learning Center	DTS-KS-LC	0,0024	Passed	0,1700	Passed
Dr. T.L. Sullivan School	Music	DTS-KS-MUSC	0,0450	Exceeds Limit	0,2100	Passed
Dr. T.L. Sullivan School	Music	DTS-KS-MUSC	0,0012	Passed	0,0210	Passed
Dr. T.L. Sullivan School	Science	DTS-KS-SC1-1	0,1600	Exceeds Limit	0,6500	Passed
Dr. T.L. Sullivan School	Lab	DTS-KS-SC1-2	0,3100	Exceeds Limit	0,3500	Passed
Dr. T.L. Sullivan School	Lab	DTS-KS-SCI-1	0,0019	Passed	0,0520	Passed
Dr. T.L. Sullivan School	Lab	DTS-KS-SCI-2	0,0410	Exceeds Limit	0,4000	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dr. T.L. Sullivan School	Staff	DTS-KS-STAFF	0,0180	Exceeds Limit	0,2000	Passed
Dr. T.L. Sullivan School	Staff	DTS-KS-STAFF	0,0005	Passed	0,0660	Passed
Dr. T.L. Sullivan School	Storage	DTS-KS-STOR	0,1000	Exceeds Limit	0,2400	Passed
Dr. T.L. Sullivan School	Storage	DTS-KS-STOR	0,0016	Passed	0,0140	Passed
Dr. T.L. Sullivan School	Washroom	DTS-KS-SWR-1	0,0070	Exceeds Limit	0,2200	Passed
Dr. T.L. Sullivan School	Washroom	DTS-KS-SWR-1	0,0000	Passed	0,0730	Passed
Dr. T.L. Sullivan School	Washroom	DTS-KS-SWR-2	0,0410	Exceeds Limit	0,2700	Passed
Dr. T.L. Sullivan School	Washroom	DTS-KS-SWR-2	0,0006	Passed	0,0610	Passed
Dr. T.L. Sullivan School	Wood Shop	DTS-KS-WOOD	0,0100	Exceeds Limit	0,1100	Passed
Dr. T.L. Sullivan School	Tech Room	DTS-KS-WOOD	0,0012	Passed	0,0160	Passed
Dr. T.L. Sullivan School	Main	DTS-MAIN	0,0130	Exceeds Limit	0,0690	Passed
Dr. T.L. Sullivan School	Main	DTS-MAIN	0,0014	Passed	0,0068	Passed
Ferrisview Elementary School	In hall outside main office	FER-DF-1	0,0000	Passed	0,0310	Passed
Ferrisview Elementary School	In learning centre room 2201	FER-KS-2201	0,0000	Passed	0,0270	Passed
Ferrisview Elementary School	Room 2207	FER-KS-2207	0,0005	Passed	0,0600	Passed
Ferrisview Elementary School	Room 2211	FER-KS-2211	0,0005	Passed	0,0310	Passed
Ferrisview Elementary School	In room 2212	FER-KS-2212	0,0000	Passed	0,0180	Passed
Ferrisview Elementary School	In room 2214	FER-KS-2214	0,0009	Passed	0,0260	Passed
Ferrisview Elementary School	Cafeteria	FER-KS-CAF	0,0000	Passed	0,0850	Passed
Ferrisview Elementary School	In classroom by room 2207	FER-KS-CLASS	0,0000	Passed	0,0410	Passed
Ferrisview Elementary School	In classroom across from room 2212	FER-KS-CLASS	0,0009	Passed	0,0860	Passed
Ferrisview Elementary School	Kitchen in cafeteria	FER-KS-KIT (1)	0,0000	Passed	0,0290	Passed
Ferrisview Elementary School	Kitchen in cafeteria	FER-KS-KIT (2)	0,0011	Passed	0,0810	Passed
Ferrisview Elementary School	Music room	FER-KS-MUSIC	0,0000	Passed	0,0580	Passed
Ferrisview Elementary School	locker room in gym	FER-KS-PP1	0,0000	Passed	0,0630	Passed
Ferrisview Elementary School	Locker room in gym	FER-KS-PP2	0,0000	Passed	0,0810	Passed
Ferrisview Elementary School	In staff room 1105	FER-KS-STAFF	0,0000	Passed	0,0250	Passed
Ferrisview Elementary School	In mech room across from room 1105 on lower floor	FER-MAIN	0,0032	Passed	0,0820	Passed
Glace Bay Elementary School	In cafeteria	GBE-DF-1	0,0000	Passed	0,0660	Passed
Glace Bay Elementary School	First floor hallway near elevator	GBE-DF-2	0,0000	Passed	0,1700	Passed
Glace Bay Elementary School	2nd floor hallway across from fan room 1	GBE-DF-3	0,0000	Passed	0,0650	Passed
Glace Bay Elementary School	Room 101	GBE-KS-101	0,0000	Passed	0,3800	Passed
Glace Bay Elementary School	Room 102	GBE-KS-102	0,0000	Passed	0,3000	Passed
Glace Bay Elementary School	Room 103	GBE-KS-103	0,0013	Passed	0,3800	Passed
Glace Bay Elementary School	Room 104	GBE-KS-104	0,0000	Passed	0,2800	Passed
Glace Bay Elementary School	Pre primary room 106	GBE-KS-106-1	0,0000	Passed	0,1300	Passed
Glace Bay Elementary School	Pre primary room 106	GBE-KS-106-2	0,0000	Passed	0,1000	Passed
Glace Bay Elementary School	Room 111	GBE-KS-111	0,0000	Passed	0,2900	Passed
Glace Bay Elementary School	Room 112	GBE-KS-112	0,0000	Passed	0,2000	Passed
Glace Bay Elementary School	Room 213	GBE-KS-213	0,0000	Passed	0,4300	Passed
Glace Bay Elementary School	Room 214	GBE-KS-214	0,0000	Passed	0,3500	Passed
Glace Bay Elementary School	Kitchen in cafeteria	GBE-KS-KIT-1	0,0000	Passed	0,2000	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Glace Bay Elementary School	Kitchen in cafeteria	GBE-KS-KIT-2	0,0000	Passed	0,0220	Passed
Glace Bay Elementary School	Kitchen in cafeteria	GBE-KS-KIT-3	0,0008	Passed	0,2900	Passed
Glace Bay Elementary School	Kitchen in cafeteria	GBE-KS-KIT-4	0,0000	Passed	0,2300	Passed
Glace Bay Elementary School	Learning centre	GBE-KS-LC	0,0005	Passed	0,4200	Passed
Glace Bay Elementary School	Music room	GBE-KS-MUSIC	0,0200	Exceeds Limit	0,1700	Passed
Glace Bay Elementary School	Staff room	GBE-KS-STAFF	0,0000	Passed	0,0570	Passed
Glace Bay Elementary School	In boiler room near room 110	GBE-MAIN	0,0006	Passed	0,4100	Passed
Glace Bay High School	Fountain	GBH-DF-1	0,0000	Passed	0,1400	Passed
Glace Bay High School	Fountain	GBH-DF-2	0,0000	Passed	0,1200	Passed
Glace Bay High School	Fountain	GBH-DF-3	0,0000	Passed	0,1500	Passed
Glace Bay High School	Fountain	GBH-DF-4	0,0000	Passed	0,1800	Passed
Glace Bay High School	Fountain	GBH-KS-1STF	0,0000	Passed	0,0520	Passed
Glace Bay High School	Fountain	GBH-KS-2NDF	0,0010	Passed	0,0890	Passed
Glace Bay High School	Lab	GBH-KS-CHEM1	0,0036	Passed	0,0780	Passed
Glace Bay High School	Lab	GBH-KS-CHEM10	0,0560	Exceeds Limit	0,0660	Passed
Glace Bay High School	Lab	GBH-KS-CHEM2	0,0040	Passed	0,0750	Passed
Glace Bay High School	Lab	GBH-KS-CHEM3	0,0120	Exceeds Limit	0,0540	Passed
Glace Bay High School	Lab	GBH-KS-CHEM4	0,0039	Passed	0,1200	Passed
Glace Bay High School	Lab	GBH-KS-CHEM5	0,0006	Passed	0,0310	Passed
Glace Bay High School	Lab	GBH-KS-CHEM6	0,0048	Passed	0,1100	Passed
Glace Bay High School	Lab	GBH-KS-CHEM7	0,0031	Passed	0,1100	Passed
Glace Bay High School	Lab	GBH-KS-CHEM8	0,0031	Passed	0,1100	Passed
Glace Bay High School	Lab	GBH-KS-CHEM9	0,0026	Passed	0,0570	Passed
Glace Bay High School	Home Ec	GBH-KS-HEC1	0,0012	Passed	0,1300	Passed
Glace Bay High School	Home Ec	GBH-KS-HEC2	0,0024	Passed	0,2300	Passed
Glace Bay High School	Tech Room	GBH-KS-IND	0,0008	Passed	0,1700	Passed
Glace Bay High School	Kitchen	GBH-KS-KIT-1	0,0008	Passed	0,0560	Passed
Glace Bay High School	Kitchen	GBH-KS-KIT-2	0,0007	Passed	0,1700	Passed
Glace Bay High School	Lab	GBH-KS-PHYS	0,0310	Exceeds Limit	0,0880	Passed
Glace Bay High School	Main	GBH-MAIN	0,0000	Passed	0,0560	Passed
Greenfield Elementary School	Room 101	CLASSROOM 101	0,0000	Passed	0,1100	Passed
Greenfield Elementary School	Room 102	CLASSROOM 102	0,0000	Passed	0,1100	Passed
Greenfield Elementary School	Room 103	CLASSROOM 103	0,0000	Passed	0,1400	Passed
Greenfield Elementary School	Room 104	CLASSROOM 104	0,0000	Passed	0,3100	Passed
Greenfield Elementary School	Room 105	CLASSROOM 105	0,0007	Passed	0,2800	Passed
Greenfield Elementary School	Room 106	CLASSROOM 106	0,0000	Passed	0,2300	Passed
Greenfield Elementary School	Room 107	CLASSROOM 107	0,0000	Passed	0,1500	Passed
Greenfield Elementary School	Room 108	CLASSROOM 108	0,0000	Passed	0,2300	Passed
Greenfield Elementary School	Room 110	CLASSROOM 110	0,0000	Passed	0,0630	Passed
Greenfield Elementary School	Room 111	CLASSROOM 111	0,0000	Passed	0,0860	Passed
Greenfield Elementary School	Hall outside room 110	DRINKING FOUNTAIN 2	0,0000	Passed	0,0470	Passed
Greenfield Elementary School	In front of washrooms by cafeteria	DRINKING FOUNTAIN 3	0,0000	Passed	0,0530	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Greenfield Elementary School	In front of washrooms by cafeteria	DRINKING FOUNTAIN 4	0,0000	Passed	0,1500	Passed
Greenfield Elementary School	Hall next to room 123	GRN-DF-1	0,0000	Passed	0,0460	Passed
Greenfield Elementary School	Room 112	GRN-KS-112	0,0000	Passed	0,0660	Passed
Greenfield Elementary School	Room 114	GRN-KS-114	0,0000	Passed	0,2200	Passed
Greenfield Elementary School	Room 115	GRN-KS-115	0,0000	Passed	0,0850	Passed
Greenfield Elementary School	Room 116	GRN-KS-116	0,0000	Passed	0,0790	Passed
Greenfield Elementary School	Room 117	GRN-KS-117	0,0000	Passed	0,0900	Passed
Greenfield Elementary School	Room 118	GRN-KS-118	0,0000	Passed	0,0740	Passed
Greenfield Elementary School	Room 119	GRN-KS-119	0,0000	Passed	0,0810	Passed
Greenfield Elementary School	Room 120	GRN-KS-120	0,0000	Passed	0,1200	Passed
Greenfield Elementary School	Room 121	GRN-KS-121	0,0000	Passed	0,1100	Passed
Greenfield Elementary School	Room 123	GRN-KS-123	0,0000	Passed	0,0800	Passed
Greenfield Elementary School	Room 124	GRN-KS-124	0,0000	Passed	0,0790	Passed
Greenfield Elementary School	Art room	GRN-KS-135 (1)	0,0000	Passed	0,1200	Passed
Greenfield Elementary School	Art room	GRN-KS-135 (2)	0,0000	Passed	0,0630	Passed
Greenfield Elementary School	Art room	GRN-KS-135 (3)	0,0000	Passed	0,0630	Passed
Greenfield Elementary School	Music room	GRN-KS-165 (MUSIC)	0,0007	Passed	0,0480	Passed
Greenfield Elementary School	Library	GRN-KS-WORK (LIBRARY)	0,0010	Passed	0,0340	Passed
Greenfield Elementary School	Sick room	GRN-KS-WR (SICK ROOM)	0,0000	Passed	0,2300	Passed
Greenfield Elementary School	In kitchen	KITCHEN 1ST ON LEFT	0,0000	Passed	0,0410	Passed
Greenfield Elementary School	In kitchen	KITCHEN 2ND ON LEFT	0,0000	Passed	0,0400	Passed
Greenfield Elementary School	In kitchen	KITCHEN BACKWALL	0,0000	Passed	0,0870	Passed
Greenfield Elementary School	In kitchen	KITCHEN MIDDLE	0,0000	Passed	0,0380	Passed
Greenfield Elementary School	Staff room	KITCHEN STAFF ROOM	0,0000	Passed	0,0870	Passed
Greenfield Elementary School	Learning centre	LEARNING CENTER 1ST ON LEFT	0,0000	Passed	0,0740	Passed
Greenfield Elementary School	Learning centre	LEARNING CENTER 2ND BACKWALL	0,0000	Passed	0,0670	Passed
Greenfield Elementary School	In kitchen	UTILITY ROOM CAFETERIA	0,0000	Passed	0,1100	Passed
Greenfield Elementary School	In boiler room	WATER MAIN	0,0009	Passed	0,0750	Passed
Harbourside Elementary School	Hall by room 105	HAR-DF-1	0,0000	Passed	0,6700	Passed
Harbourside Elementary School	In cafeteria	HAR-DF-2	0,0020	Passed	0,7000	Passed
Harbourside Elementary School	In gym	HAR-DF-3	0,0000	Passed	0,8800	Passed
Harbourside Elementary School	Hall by room 116	HAR-DF-4	0,0000	Passed	0,7200	Passed
Harbourside Elementary School	Hall across from room 110	HAR-DF-5	0,0000	Passed	0,8700	Passed
Harbourside Elementary School	Hall across from room 205	HAR-DF-6	0,0000	Passed	0,8100	Passed
Harbourside Elementary School	In hall next to staff room	HAR-DF-7	0,0000	Passed	0,8300	Passed
Harbourside Elementary School	Hall next to french room 210	HAR-DF-8	0,0000	Passed	0,9100	Passed
Harbourside Elementary School	Hall across from room 212	HAR-DF-9	0,0000	Passed	0,8200	Passed
Harbourside Elementary School	Room 101	HAR-KS-101	0,0041	Passed	0,5300	Passed
Harbourside Elementary School	Room 102	HAR-KS-102	0,0011	Passed	0,6200	Passed
Harbourside Elementary School	Room 103	HAR-KS-103	0,0061	Exceeds Limit	0,4200	Passed
Harbourside Elementary School	Room 104	HAR-KS-104	0,0007	Passed	0,5800	Passed
Harbourside Elementary School	Room 105	HAR-KS-105	0,0000	Passed	0,6800	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Harbourside Elementary School	Room 107 learning centre	HAR-KS-107	0,0000	Passed	0,6100	Passed
Harbourside Elementary School	Room 109	HAR-KS-109	0,0008	Passed	0,5100	Passed
Harbourside Elementary School	Room 110	HAR-KS-110	0,0000	Passed	0,5300	Passed
Harbourside Elementary School	Room 113	HAR-KS-113	0,0015	Passed	0,6200	Passed
Harbourside Elementary School	Room 114	HAR-KS-114	0,0009	Passed	0,4400	Passed
Harbourside Elementary School	Room 115	HAR-KS-115	0,0000	Passed	0,5100	Passed
Harbourside Elementary School	Room 116	HAR-KS-116	0,0015	Passed	0,5700	Passed
Harbourside Elementary School	Room 201	HAR-KS-201	0,0021	Passed	0,3600	Passed
Harbourside Elementary School	Room 202	HAR-KS-202	0,0011	Passed	0,4900	Passed
Harbourside Elementary School	Room 203	HAR-KS-203	0,0006	Passed	0,5700	Passed
Harbourside Elementary School	Room 204	HAR-KS-204	0,0006	Passed	0,6100	Passed
Harbourside Elementary School	Room 205	HAR-KS-205	0,0011	Passed	0,5800	Passed
Harbourside Elementary School	Room 206	HAR-KS-206	0,0000	Passed	0,5000	Passed
Harbourside Elementary School	Room 207	HAR-KS-207	0,0019	Passed	0,2100	Passed
Harbourside Elementary School	Room 210	HAR-KS-210	0,0018	Passed	0,4700	Passed
Harbourside Elementary School	Room 211	HAR-KS-211	0,0009	Passed	0,5500	Passed
Harbourside Elementary School	Room 212	HAR-KS-212	0,0010	Passed	0,5300	Passed
Harbourside Elementary School	Room 213	HAR-KS-213	0,0008	Passed	0,5000	Passed
Harbourside Elementary School	Room 214	HAR-KS-214	0,0011	Passed	0,5100	Passed
Harbourside Elementary School	Room 215	HAR-KS-215	0,0020	Passed	0,7400	Passed
Harbourside Elementary School	Room 216	HAR-KS-216	0,0013	Passed	0,3800	Passed
Harbourside Elementary School	Room 217	HAR-KS-217	0,0230	Exceeds Limit	0,4000	Passed
Harbourside Elementary School	Room 218	HAR-KS-218	0,0016	Passed	0,5900	Passed
Harbourside Elementary School	Art room	HAR-KS-ART (1)	0,0008	Passed	0,2800	Passed
Harbourside Elementary School	Art room	HAR-KS-ART (2)	0,0007	Passed	0,2800	Passed
Harbourside Elementary School	Kitchen	HAR-KS-KITCHEN 1	0,0069	Exceeds Limit	0,3400	Passed
Harbourside Elementary School	Kitchen	HAR-KS-KITCHEN 2	0,0006	Passed	0,7000	Passed
Harbourside Elementary School	Kitchen	HAR-KS-KITCHEN 3	0,0007	Passed	0,5100	Passed
Harbourside Elementary School	Kitchen	HAR-KS-KITCHEN 4	0,0000	Passed	0,6200	Passed
Harbourside Elementary School	In boiler room	HAR-KS-MAIN	0,0780	Exceeds Limit	0,2700	Passed
Harbourside Elementary School	Music room	HAR-KS-MUSIC	0,0020	Passed	0,3700	Passed
Harbourside Elementary School	Music room storage	HAR-KS-MUSIC STORAGE	0,0280	Exceeds Limit	0,0450	Passed
Harbourside Elementary School	Sick room	HAR-KS-SICK	0,0000	Passed	0,6500	Passed
Harbourside Elementary School	Staff room	HAR-KS-STAFF	0,0000	Passed	0,4600	Passed
John Bernard Croak V.C. Memorial School	Fountain	JBC-DF-1	0,0500	Exceeds Limit	0,6500	Passed
John Bernard Croak V.C. Memorial School	Fountain	JBC-DF-2	0,0015	Passed	0,1300	Passed
John Bernard Croak V.C. Memorial School	Fountain	JBC-DF-3	0,0035	Passed	0,1800	Passed
John Bernard Croak V.C. Memorial School	Fountain	JBC-DF-4	0,0110	Exceeds Limit	0,6100	Passed
John Bernard Croak V.C. Memorial School	Room 101	JBC-KS-101	0,0033	Passed	0,1600	Passed
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-BWR-1ST-1	0,0520	Exceeds Limit	4,2000	Exceeds Limit
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-BWR-2ND-1	0,1700	Exceeds Limit	16,0000	Exceeds Limit
John Bernard Croak V.C. Memorial School	Cafeteria	JBC-KS-CAF	0,0036	Passed	0,2900	Passed



## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-GWR-1ST-1	0,0029	Passed	0,2800	Passed
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-GWR-2ND-1	0,0370	Exceeds Limit	0,9500	Passed
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-LWR	0,0012	Passed	0,1000	Passed
John Bernard Croak V.C. Memorial School	Office	JBC-KS-OFF-1	0,0000	Passed	0,0110	Passed
John Bernard Croak V.C. Memorial School	Office	JBC-KS-OFF-1 (DS)	0,0000	Passed	0,0950	Passed
John Bernard Croak V.C. Memorial School	Office	JBC-KS-OFF-2 (DS)	0,0010	Passed	0,1000	Passed
John Bernard Croak V.C. Memorial School	Office	JBC-KS-OFF-2 (UPSTAIRS)	0,0005	Passed	0,0410	Passed
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-OWR-1	0,0032	Passed	0,1300	Passed
John Bernard Croak V.C. Memorial School	Washroom	JBC-KS-OWR-2	0,0400	Exceeds Limit	0,3700	Passed
John Bernard Croak V.C. Memorial School	Staff	JBC-KS-STAFF	0,1800	Exceeds Limit	1,8000	Passed
John Bernard Croak V.C. Memorial School	Staff Room	JBC-KS-STAFF	0,0000	Passed	0,0240	Passed
John Bernard Croak V.C. Memorial School	Water Main	WATER MAIN	0,0009	Passed	0,0054	Passed
Jubilee Elementary School	In hallway across from art room	JUB-DF-1	0,0012	Passed	0,2400	Passed
Jubilee Elementary School	In washroom across from room 101	JUB-DF-2	0,0000	Passed	0,2700	Passed
Jubilee Elementary School	In washroom across from room 202	JUB-DF-3	0,0000	Passed	0,0960	Passed
Jubilee Elementary School	Room 101 pre primary	JUB-KS-101	0,0000	Passed	0,1900	Passed
Jubilee Elementary School	Room 102	JUB-KS-102	0,0010	Passed	0,3400	Passed
Jubilee Elementary School	Room 103	JUB-KS-103	0,0000	Passed	0,4000	Passed
Jubilee Elementary School	Room 105	JUB-KS-105	0,0006	Passed	0,2800	Passed
Jubilee Elementary School	Room 106	JUB-KS-106	0,0110	Exceeds Limit	0,7900	Passed
Jubilee Elementary School	Room 107	JUB-KS-107	0,0000	Passed	0,2300	Passed
Jubilee Elementary School	Room 108	JUB-KS-108	0,0000	Passed	0,2900	Passed
Jubilee Elementary School	Room 109 resource room	JUB-KS-109	0,0010	Passed	0,2100	Passed
Jubilee Elementary School	In kitchen in resource room	JUB-KS-109K	0,0028	Passed	0,1200	Passed
Jubilee Elementary School	Room 201	JUB-KS-201	0,0008	Passed	0,2800	Passed
Jubilee Elementary School	Room 202	JUB-KS-202	0,0000	Passed	0,2000	Passed
Jubilee Elementary School	Room 203	JUB-KS-203	0,0000	Passed	0,4000	Passed
Jubilee Elementary School	Room 204	JUB-KS-204	0,0000	Passed	0,2500	Passed
Jubilee Elementary School	Room 206	JUB-KS-206	0,0000	Passed	0,4800	Passed
Jubilee Elementary School	Room 207	JUB-KS-207	0,0010	Passed	0,4000	Passed
Jubilee Elementary School	Room 208	JUB-KS-208	0,0000	Passed	0,3900	Passed
Jubilee Elementary School	Room 209	JUB-KS-209	0,0000	Passed	0,2600	Passed
Jubilee Elementary School	Room 210	JUB-KS-210	0,0000	Passed	0,2300	Passed
Jubilee Elementary School	Music room	JUB-KS-212	0,0010	Passed	0,2100	Passed
Jubilee Elementary School	Room 2211	JUB-KS-221	0,0012	Passed	0,3000	Passed
Jubilee Elementary School	In early years centre	JUB-KS-EYC	0,0000	Passed	0,1800	Passed
Jubilee Elementary School	In kitchen	JUB-KS-KIT-1	0,0005	Passed	0,4900	Passed
Jubilee Elementary School	In kitchen	JUB-KS-KIT-2	0,0140	Exceeds Limit	0,3600	Passed
Jubilee Elementary School	In kitchen	JUB-KS-KIT-3	0,0000	Passed	0,3400	Passed
Jubilee Elementary School	Sick room	JUB-KS-SICK	0,0006	Passed	0,6800	Passed
Jubilee Elementary School	Staff room	JUB-KS-STAFF	0,0000	Passed	0,0130	Passed
Jubilee Elementary School	In art room	JUB-MAIN	0,0031	Passed	0,0095	Passed



## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Malcolm Munroe Middle School	Fountain	MMM-DF-1	0,0005	Passed	0,4600	Passed
Malcolm Munroe Middle School	Fountain	MMM-DF-2	0,0007	Passed	0,1800	Passed
Malcolm Munroe Middle School	Fountain	MMM-DF-3	0,0012	Passed	0,1300	Passed
Malcolm Munroe Middle School	Fountain	MMM-DF-4	0,0000	Passed	0,4000	Passed
Malcolm Munroe Middle School	Fountain	MMM-DF-5	0,0051	Exceeds Limit	0,4000	Passed
Malcolm Munroe Middle School	Fountain	MMM-DF-6	0,0010	Passed	0,3600	Passed
Malcolm Munroe Middle School	Room 114	MMM-KS-114	0,0013	Passed	0,3400	Passed
Malcolm Munroe Middle School	Room 116	MMM-KS-116	0,0010	Passed	0,5700	Passed
Malcolm Munroe Middle School	Room 219	MMM-KS-219(1)	0,0000	Passed	0,0490	Passed
Malcolm Munroe Middle School	Room 219	MMM-KS-219(2)	0,0000	Passed	0,0420	Passed
Malcolm Munroe Middle School	Room 220	MMM-KS-220	0,0089	Exceeds Limit	0,4300	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(1)	0,0006	Passed	0,5000	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(2)	0,0009	Passed	0,3500	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(3)	0,0013	Passed	0,3400	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(4)	0,0017	Passed	0,3200	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(5)	0,0030	Passed	0,4500	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(6)	0,0044	Passed	0,3000	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(7)	0,0007	Passed	0,2600	Passed
Malcolm Munroe Middle School	Room 222	MMM-KS-222(8)	0,0087	Exceeds Limit	0,3100	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(1)	0,0000	Passed	0,0490	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(10)	0,0019	Passed	0,0530	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(2)	0,0012	Passed	0,0710	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(3)	0,0008	Passed	0,0570	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(4)	0,0011	Passed	0,0610	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(5)	0,0320	Exceeds Limit	0,4300	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(6)	0,0000	Passed	0,0480	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(7)	0,0000	Passed	0,0460	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(8)	0,0008	Passed	0,0600	Passed
Malcolm Munroe Middle School	Room 223	MMM-KS-223(9)	0,0008	Passed	0,0580	Passed
Malcolm Munroe Middle School	Kitchen	MMM-KS-KITCHEN(1)	0,0000	Passed	0,0600	Passed
Malcolm Munroe Middle School	Kitchen	MMM-KS-KITCHEN(2)	0,0000	Passed	0,0630	Passed
Malcolm Munroe Middle School	Kitchen	MMM-KS-KITCHEN(3)	0,0000	Passed	0,0750	Passed
Malcolm Munroe Middle School	Music	MMM-KS-MUSIC	0,0000	Passed	0,1000	Passed
Malcolm Munroe Middle School	Staff	MMM-KS-STAFF	0,0000	Passed	0,1300	Passed
Malcolm Munroe Middle School	Main	MMM-MAIN	0,0016	Passed	0,0140	Passed
Marion Bridge School	Hall across from room 102	MBE-DF-1	0,0011	Passed	0,0440	Passed
Marion Bridge School	Staff room	MBE-KS-107	0,0000	Passed	0,0220	Passed
Marion Bridge School	Room 108	MBE-KS-108	0,0012	Passed	0,0150	Passed
Marion Bridge School	Room B08	MBE-KS-B08	0,0096	Exceeds Limit	0,6600	Passed
Marion Bridge School	In room B06	MBE-MAIN	0,0610	Exceeds Limit	0,0750	Passed
Memorial Composite High School	Fountain	MHS-DF-1	0,0078	Exceeds Limit	0,2200	Passed
Memorial Composite High School	Fountain	MHS-DF-1	0,0011	Passed	0,0170	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Memorial Composite High School	Fountain	MHS-DF-2	0,0024	Passed	0,1900	Passed
Memorial Composite High School	Fountain	MHS-DF-3	0,0019	Passed	0,1200	Passed
Memorial Composite High School	Fountain	MHS-DF-4	0,0580	Exceeds Limit	0,6100	Passed
Memorial Composite High School	Fountain	MHS-DF-4	0,0015	Passed	0,0530	Passed
Memorial Composite High School	Fountain	MHS-DF-5	0,0006	Passed	0,0200	Passed
Memorial Composite High School	Fountain	MHS-DF-6	0,1600	Exceeds Limit	7,2000	Exceeds Limit
Memorial Composite High School	Fountain	MHS-DF-6	0,0000	Passed	0,0100	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-1	0,0760	Exceeds Limit	0,4600	Passed
Memorial Composite High School	Room A313	MHS-KS-A313-1	0,0000	Passed	0,0057	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-2	0,0041	Passed	0,5100	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-3	0,0056	Exceeds Limit	0,5700	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-3	0,0000	Passed	0,0063	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-4	0,0022	Passed	0,0910	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-5	0,0014	Passed	0,0370	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-6	0,0011	Passed	0,0260	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-7	0,0010	Passed	0,0220	Passed
Memorial Composite High School	Room 313	MHS-KS-A313-8	0,0009	Passed	0,0200	Passed
Memorial Composite High School	Room 314	MHS-KS-A314-1	0,0012	Passed	0,0310	Passed
Memorial Composite High School	Room 314	MHS-KS-A314-2	0,0007	Passed	0,0190	Passed
Memorial Composite High School	Room 314	MHS-KS-A314-3	0,0006	Passed	0,0110	Passed
Memorial Composite High School	Lab	MHS-KS-ASTOR	0,0009	Passed	0,0180	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-1	0,0700	Exceeds Limit	0,7900	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-1	0,0012	Passed	0,0130	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-2	0,0560	Exceeds Limit	0,5200	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-2	0,0020	Passed	0,0220	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-3	0,0250	Exceeds Limit	0,3500	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-3	0,0012	Passed	0,0085	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-4	0,1200	Exceeds Limit	0,4600	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-4	0,0013	Passed	0,0087	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-5	0,0340	Exceeds Limit	0,7900	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-5	0,0012	Passed	0,0096	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-6	0,0280	Exceeds Limit	0,6700	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-6	0,0012	Passed	0,0083	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-8	0,0090	Exceeds Limit	0,1200	Passed
Memorial Composite High School	Lab	MHS-KS-BIO-8	0,0012	Passed	0,0092	Passed
Memorial Composite High School	Lab	MHS-KS-BSTOR	0,0090	Exceeds Limit	0,0380	Passed
Memorial Composite High School	Lab	MHS-KS-BSTOR	0,0033	Passed	0,1700	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-1	0,0110	Exceeds Limit	0,5600	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-1	0,0026	Passed	0,0290	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-10	0,0035	Passed	0,0460	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-11	0,0260	Exceeds Limit	0,1400	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-11	0,0023	Passed	0,0270	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Memorial Composite High School	Lab	MHS-KS-CHEM-2	0,1300	Exceeds Limit	0,2300	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-2	0,0024	Passed	0,0270	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-3	0,0044	Passed	0,2100	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-4	0,0250	Exceeds Limit	0,1800	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-4	0,0025	Passed	0,0280	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-5	0,0110	Exceeds Limit	0,1100	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-5	0,0024	Passed	0,0270	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-6	0,0290	Exceeds Limit	0,6900	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-6	0,0025	Passed	0,0320	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-7	0,0280	Exceeds Limit	0,3200	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-7	0,0026	Passed	0,0280	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-8	0,0078	Exceeds Limit	0,0870	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-8	0,0024	Passed	0,0270	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-9	0,0200	Exceeds Limit	0,9500	Passed
Memorial Composite High School	Lab	MHS-KS-CHEM-9	0,0024	Passed	0,0300	Passed
Memorial Composite High School	Lab	MHS-KS-CLOTH	0,0029	Passed	0,0170	Passed
Memorial Composite High School	Lab	MHS-KS-CSTOR	0,0200	Exceeds Limit	0,4500	Passed
Memorial Composite High School	Lab	MHS-KS-CSTOR	0,0025	Passed	0,0280	Passed
Memorial Composite High School	Food	MHS-KS-FOOD-1	0,0069	Exceeds Limit	0,0230	Passed
Memorial Composite High School	Food	MHS-KS-FOOD-1	0,0000	Passed	0,0067	Passed
Memorial Composite High School	Food	MHS-KS-FOOD-2	0,0021	Passed	0,0450	Passed
Memorial Composite High School	Food	MHS-KS-FOOD-3	0,0011	Passed	0,0230	Passed
Memorial Composite High School	Food	MHS-KS-FOOD-4	0,0011	Passed	0,0230	Passed
Memorial Composite High School	Lab	MHS-KS-GRAPH	0,0007	Passed	0,0450	Passed
Memorial Composite High School	Lab	MHS-KS-METAL	0,0000	Passed	0,0110	Passed
Memorial Composite High School	Lab	MHS-KS-PHYS-1	0,0430	Exceeds Limit	0,3600	Passed
Memorial Composite High School	Lab	MHS-KS-PHYS-1	0,0035	Passed	0,0270	Passed
Memorial Composite High School	Lab	MHS-KS-PHYS-2	0,0072	Exceeds Limit	0,2800	Passed
Memorial Composite High School	Lab	MHS-KS-PHYS-2	0,0033	Passed	0,0270	Passed
Memorial Composite High School	Lab	MHS-KS-PSTOR	0,1900	Exceeds Limit	0,6300	Passed
Memorial Composite High School	Storage	MHS-KS-PSTOR	0,0033	Passed	0,0280	Passed
Memorial Composite High School	Lab	MHS-KS-WOOD	0,0061	Exceeds Limit	0,2300	Passed
Memorial Composite High School	Lab	MHS-KS-WOOD	0,0000	Passed	0,0061	Passed
Memorial Composite High School	Main	MHS-MAIN	0,0110	Exceeds Limit	0,2300	Passed
Memorial Composite High School	Main	MHS-MAIN	0,0000	Passed	0,0057	Passed
Middle River Consolidated	Fountain	MID-DF	0,3200	Exceeds Limit	1,4000	Passed
Middle River Consolidated	Class	MID-KS-CLASS	0,0350	Exceeds Limit	0,2400	Passed
Middle River Consolidated	Hall	MID-KS-HALL	0,0710	Exceeds Limit	0,2900	Passed
Mountainview Elementary School	Fountain	MTV-DF-1	0,0000	Passed	0,0120	Passed
Mountainview Elementary School	Fountain	MTV-DF-2	0,0039	Passed	0,0500	Passed
Mountainview Elementary School	Fountain	MTV-DF-3	0,0020	Passed	0,0300	Passed
Mountainview Elementary School	Room 119	MTV-KS-119	0,0043	Passed	0,0980	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Mountainview Elementary School	Washroom	MTV-KS-119-WR	0,0000	Passed	0,0330	Passed
Mountainview Elementary School	Room 120	MTV-KS-120	0,0015	Passed	0,0240	Passed
Mountainview Elementary School	Washroom	MTV-KS-120-WR	0,0000	Passed	0,0400	Passed
Mountainview Elementary School	Room 121	MTV-KS-121	0,0041	Passed	0,0680	Passed
Mountainview Elementary School	Room 122	MTV-KS-122	0,0025	Passed	0,0910	Passed
Mountainview Elementary School	Room 142	MTV-KS-142	0,0025	Passed	0,0280	Passed
Mountainview Elementary School	Room 144	MTV-KS-144	0,0007	Passed	0,0083	Passed
Mountainview Elementary School	Room 157	MTV-KS-157(1)	0,0009	Passed	0,0210	Passed
Mountainview Elementary School	Room 157	MTV-KS-157(2)	0,0079	Exceeds Limit	0,0920	Passed
Mountainview Elementary School	Cafeteria	MTV-KS-CAF	0,0012	Passed	0,0440	Passed
Mountainview Elementary School	Learning Center	MTV-KS-LR-1	0,0025	Passed	0,0360	Passed
Mountainview Elementary School	Learning Center	MTV-KS-LR-2	0,0009	Passed	0,0060	Passed
Mountainview Elementary School	Music	MTV-KS-MUSIC	0,0068	Exceeds Limit	0,0560	Passed
Mountainview Elementary School	Staff	MTV-KS-STAFF	0,0008	Passed	0,0160	Passed
Mountainview Elementary School	Main	MTV-MAIN	0,0008	Passed	0,0050	Passed
North Highlands Elementary School	Room 107	NHL-KS-107	0,0012	Passed	1,4000	Passed
North Highlands Elementary School	Room 109	NHL-KS-109	0,0016	Passed	0,1900	Passed
North Highlands Elementary School	Room 117	NHL-KS-117	0,0014	Passed	1,7000	Passed
North Highlands Elementary School	Room 123	NHL-KS-123(1)	0,0006	Passed	0,6000	Passed
North Highlands Elementary School	Room 123	NHL-KS-123(2)	0,0067	Exceeds Limit	1,2000	Passed
North Highlands Elementary School	Room 124	NHL-KS-124	0,0094	Exceeds Limit	0,7300	Passed
North Highlands Elementary School	Room 130	NHL-KS-130	0,0081	Exceeds Limit	1,7000	Passed
North Highlands Elementary School	Room 144	NHL-KS-144	0,0035	Passed	0,9900	Passed
North Highlands Elementary School	Room 145	NHL-KS-145	0,0068	Exceeds Limit	0,6900	Passed
North Highlands Elementary School	Room 150	NHL-KS-150	0,0068	Exceeds Limit	0,7900	Passed
North Highlands Elementary School	Room 151	NHL-KS-151	0,0029	Passed	0,5400	Passed
North Highlands Elementary School	Room 174	NHL-KS-174	0,0093	Exceeds Limit	1,8000	Passed
North Highlands Elementary School	Boiler Room	NHL-KS-BOIL	0,0075	Exceeds Limit	0,6500	Passed
North Highlands Elementary School	Class	NHL-KS-CLASS	0,0027	Passed	0,8100	Passed
North Highlands Elementary School	Hall	NHL-KS-HALL	0,0081	Exceeds Limit	0,4400	Passed
North Highlands Elementary School	Kitchen	NHL-KS-KIT-1	0,0023	Passed	1,8000	Passed
North Highlands Elementary School	Kitchen	NHL-KS-KIT-2	0,0032	Passed	0,8200	Passed
North Highlands Elementary School	Kitchen	NHL-KS-KIT-3	0,0048	Passed	1,7000	Passed
Oceanview Education Centre	Art	OVEC-ART-1	0,0020	Passed	0,0640	Passed
Oceanview Education Centre	Art	OVEC-ART-2	0,0350	Exceeds Limit	0,2600	Passed
Oceanview Education Centre	Fountain	OVEC-DF-1	0,0019	Passed	0,2100	Passed
Oceanview Education Centre	Fountain	OVEC-DF-2	0,0000	Passed	0,4400	Passed
Oceanview Education Centre	Fountain	OVEC-DF-3	0,0000	Passed	0,1200	Passed
Oceanview Education Centre	Fountain	OVEC-DF-5	0,0011	Passed	0,1400	Passed
Oceanview Education Centre	Room 1108	OVEC-KS-1108	0,0000	Passed	0,0910	Passed
Oceanview Education Centre	Room 1126	OVEC-KS-1126	0,0560	Exceeds Limit	0,5000	Passed
Oceanview Education Centre	Room 1207	OVEC-KS-1207	0,0018	Passed	0,1500	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Oceanview Education Centre	Room 1301	OVEC-KS-1301	0,0000	Passed	0,0410	Passed
Oceanview Education Centre	Room 1311	OVEC-KS-1311	0,0000	Passed	0,0750	Passed
Oceanview Education Centre	Room 1324	OVEC-KS-1324	0,0000	Passed	0,0970	Passed
Oceanview Education Centre	Room 2329	OVEC-KS-2329	0,0093	Exceeds Limit	0,5600	Passed
Oceanview Education Centre	Lab	OVEC-KS-BIO-1	0,0097	Exceeds Limit	0,0500	Passed
Oceanview Education Centre	Lab	OVEC-KS-BIO-2	0,0097	Exceeds Limit	0,0920	Passed
Oceanview Education Centre	Lab	OVEC-KS-BIO-3	0,0120	Exceeds Limit	0,2700	Passed
Oceanview Education Centre	Lab	OVEC-KS-BIO-4	0,0260	Exceeds Limit	0,1800	Passed
Oceanview Education Centre	Family	OVEC-KS-FAM-1	0,0017	Passed	0,2300	Passed
Oceanview Education Centre	Family	OVEC-KS-FAM-2	0,0025	Passed	0,1900	Passed
Oceanview Education Centre	Family	OVEC-KS-FAM-3	0,0028	Passed	0,1800	Passed
Oceanview Education Centre	Family	OVEC-KS-FAM-4	0,0053	Exceeds Limit	0,2900	Passed
Oceanview Education Centre	Kitchen	OVEC-KS-KIT-1	0,0008	Passed	0,1500	Passed
Oceanview Education Centre	Kitchen	OVEC-KS-KIT-2	0,0000	Passed	0,0680	Passed
Oceanview Education Centre	Kitchen	OVEC-KS-KIT-3	0,0008	Passed	0,0970	Passed
Oceanview Education Centre	Kitchen	OVEC-KS-KIT-4	0,0000	Passed	0,1900	Passed
Oceanview Education Centre	Science	OVEC-KS-SCI-1	0,0120	Exceeds Limit	0,4600	Passed
Oceanview Education Centre	Science	OVEC-KS-SCI-2	0,0150	Exceeds Limit	0,5600	Passed
Oceanview Education Centre	Science	OVEC-KS-SCI-3	0,0020	Passed	0,1100	Passed
Oceanview Education Centre	Science	OVEC-KS-SCI-4	0,0036	Passed	0,2100	Passed
Oceanview Education Centre	Science	OVEC-KS-SCI-5	0,0045	Passed	0,5800	Passed
Oceanview Education Centre	Science	OVEC-KS-SCI-6	0,0014	Passed	0,2300	Passed
Oceanview Education Centre	Main	OVEC-MAIN	0,0076	Exceeds Limit	0,0059	Passed
Rankin School of the Narrows	Fountain	RAN-DF-1	0,0000	Passed	0,2800	Passed
Rankin School of the Narrows	Fountain	RAN-DF-2	0,0000	Passed	0,1200	Passed
Rankin School of the Narrows	Room 104	RAN-KS-104	0,0009	Passed	0,1400	Passed
Rankin School of the Narrows	Room 109	RAN-KS-109-1	0,0040	Passed	0,1200	Passed
Rankin School of the Narrows	Room 109	RAN-KS-109-2	0,0006	Passed	0,1400	Passed
Rankin School of the Narrows	Room 109	RAN-KS-109-3	0,0034	Passed	0,0880	Passed
Rankin School of the Narrows	Room 109	RAN-KS-109-4	0,0120	Exceeds Limit	0,1200	Passed
Rankin School of the Narrows	Room 110	RAN-KS-110	0,0041	Passed	0,1000	Passed
Rankin School of the Narrows	Room 118	RAN-KS-118	0,0100	Exceeds Limit	0,1100	Passed
Rankin School of the Narrows	Room 120	RAN-KS-120-1	0,0054	Exceeds Limit	0,1700	Passed
Rankin School of the Narrows	Room 120	RAN-KS-120-2	0,0026	Passed	0,0880	Passed
Rankin School of the Narrows	Room 120	RAN-KS-120-3	0,0036	Passed	0,0840	Passed
Rankin School of the Narrows	Room 128	RAN-KS-128	0,0028	Passed	0,0680	Passed
Rankin School of the Narrows	Room 136	RAN-KS-136-1	0,0014	Passed	0,1800	Passed
Rankin School of the Narrows	Room 136	RAN-KS-136-2	0,0033	Passed	0,1100	Passed
Rankin School of the Narrows	Room 140	RAN-KS-140	0,0005	Passed	0,0910	Passed
Rankin School of the Narrows	Room 150	RAN-KS-150-1	0,0013	Passed	0,1000	Passed
Rankin School of the Narrows	Room 150	RAN-KS-150-2	0,0021	Passed	0,0750	Passed
Rankin School of the Narrows	Room 150	RAN-KS-150-3	0,0044	Passed	0,2000	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Rankin School of the Narrows	Room 153	RAN-KS-153	0,0038	Passed	0,0660	Passed
Rankin School of the Narrows	Room 156	RAN-KS-156	0,0059	Exceeds Limit	0,1100	Passed
Rankin School of the Narrows	Room 163	RAN-KS-163	0,0028	Passed	0,0700	Passed
Rankin School of the Narrows	Room 164	RAN-KS-164	0,0036	Passed	0,0960	Passed
Rankin School of the Narrows	Main	RAN-MAIN	0,0000	Passed	0,0480	Passed
Rankin School of the Narrows	Washroom	RAN-MAIN-GIRLS WR	0,0044	Passed	0,1500	Passed
Rankin School of the Narrows	Washroom	RAN-MAIN-MENS WR	0,0044	Passed	0,1900	Passed
Riverside School	Hallway near room 109	RVS-DF-1	0,0000	Passed	0,0540	Passed
Riverside School	Hallway near room 118	RVS-DF-2	0,0008	Passed	0,1000	Passed
Riverside School	Hallway near room 104	RVS-DF-3	0,0000	Passed	0,2100	Passed
Riverside School	Hallway near library	RVS-DF-4	0,0000	Passed	0,0084	Passed
Riverside School	Room 102	RVS-KS-102	0,0025	Passed	0,1400	Passed
Riverside School	Room 103	RVS-KS-103	0,0041	Passed	0,0520	Passed
Riverside School	Room 104	RVS-KS-104	0,0020	Passed	0,0480	Passed
Riverside School	Room 105	RVS-KS-105	0,0014	Passed	0,0460	Passed
Riverside School	Room 108	RVS-KS-108	0,0017	Passed	0,0790	Passed
Riverside School	Resource room	RVS-KS-109	0,0023	Passed	0,0530	Passed
Riverside School	Room 110	RVS-KS-110	0,0006	Passed	0,0550	Passed
Riverside School	Small group room near resource	RVS-KS-111	0,0530	Exceeds Limit	0,2500	Passed
Riverside School	Learning centre	RVS-KS-112 (1)	0,0028	Passed	0,0470	Passed
Riverside School	Learning centre	RVS-KS-112 (2)	0,0016	Passed	0,0510	Passed
Riverside School	Room 113	RVS-KS-113	0,0010	Passed	0,0480	Passed
Riverside School	Room 114	RVS-KS-114	0,0014	Passed	0,0560	Passed
Riverside School	Room 115	RVS-KS-115	0,0005	Passed	0,0550	Passed
Riverside School	Room 116	RVS-KS-116	0,0000	Passed	0,0620	Passed
Riverside School	Art room	RVS-KS-117 (3)	0,0009	Passed	0,0500	Passed
Riverside School	Art room	RVS-KS-117(1)	0,0000	Passed	0,0530	Passed
Riverside School	Art room	RVS-KS-117(2)	0,0000	Passed	0,0900	Passed
Riverside School	Art room	RVS-KS-117(4)	0,0015	Passed	0,0450	Passed
Riverside School	Room 118	RVS-KS-118	0,0008	Passed	0,0460	Passed
Riverside School	In kitchen	RVS-KS-KITCHEN (1)	0,0000	Passed	0,0350	Passed
Riverside School	In kitchen	RVS-KS-KITCHEN (2)	0,0000	Passed	0,0260	Passed
Riverside School	In kitchen	RVS-KS-KITCHEN (3)	0,0000	Passed	0,0200	Passed
Riverside School	In kitchen	RVS-KS-KITCHEN (4)	0,0610	Exceeds Limit	1,3000	Passed
Riverside School	In pre primary room	RVS-KS-PREC	0,0006	Passed	0,0350	Passed
Riverside School	In recycling room near cafeteria	RVS-KS-REC	0,0012	Passed	0,0860	Passed
Riverside School	In sick room	RVS-KS-SICK	0,0009	Passed	0,1100	Passed
Riverside School	Staff room	RVS-KS-STAFF	0,0022	Passed	0,0330	Passed
Riverside School	In boiler room next to recycling room	RVS-MAIN	0,0042	Passed	0,0850	Passed
Riverview High School	Fountain	RHS-DF-1	0,0037	Passed	0,2700	Passed
Riverview High School	Room 2	RHS-DF-2	0,0014	Passed	0,0790	Passed
Riverview High School	Room 4	RHS-DF-4	0,0000	Passed	0,1100	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Riverview High School	Room 5	RHS-DF-5	0,0010	Passed	0,0490	Passed
Riverview High School	Room 6	RHS-DF-6	0,0036	Passed	0,1400	Passed
Riverview High School	Room 11	RHS-KS-B11A-1	0,0062	Exceeds Limit	0,5800	Passed
Riverview High School	Room 11	RHS-KS-B11A-1	0,0008	Passed	0,1000	Passed
Riverview High School	Room 11	RHS-KS-B11A-2	0,0061	Exceeds Limit	0,2000	Passed
Riverview High School	Room 11	RHS-KS-B11A-2	0,0007	Passed	0,1300	Passed
Riverview High School	Room 11	RHS-KS-B11A-3	0,0060	Exceeds Limit	0,5000	Passed
Riverview High School	Room 11	RHS-KS-B11A-3	0,0016	Passed	0,1300	Passed
Riverview High School	Room 11	RHS-KS-B11A-4	0,0062	Exceeds Limit	0,2200	Passed
Riverview High School	Room 11	RHS-KS-B11A-4	0,0024	Passed	0,1400	Passed
Riverview High School	Room 11	RHS-KS-B11A-5	0,0031	Passed	0,1900	Passed
Riverview High School	Room 11	RHS-KS-B11A-6	0,0037	Passed	0,2200	Passed
Riverview High School	Room 12	RHS-KS-B12-1	0,0640	Exceeds Limit	0,4200	Passed
Riverview High School	Room 12	RHS-KS-B12-1	0,0042	Passed	0,4700	Passed
Riverview High School	Room 12	RHS-KS-B12-2	0,0810	Exceeds Limit	1,1000	Passed
Riverview High School	Room 12	RHS-KS-B12-2	0,0069	Exceeds Limit	0,7400	Passed
Riverview High School	Room 14	RHS-KS-B14-1	0,0300	Exceeds Limit	0,5900	Passed
Riverview High School	Room 14	RHS-KS-B14-1	0,0044	Passed	0,7000	Passed
Riverview High School	Room 14	RHS-KS-B14-2	0,0240	Exceeds Limit	0,3900	Passed
Riverview High School	Room 14	RHS-KS-B14-2	0,0031	Passed	0,5400	Passed
Riverview High School	Kitchen	RHS-KS-B16-KITCHEN	0,0021	Passed	0,2300	Passed
Riverview High School	Room 17	RHS-KS-B17-1	0,0071	Exceeds Limit	0,2100	Passed
Riverview High School	Room 17	RHS-KS-B17-1	0,0007	Passed	0,4200	Passed
Riverview High School	Room 17	RHS-KS-B17-2	0,0009	Passed	0,1400	Passed
Riverview High School	Room 17	RHS-KS-B17-3	0,0037	Passed	0,1900	Passed
Riverview High School	Room 17	RHS-KS-B17-4	0,0021	Passed	0,1700	Passed
Riverview High School	Room 2329	RHS-KS-B23-1	0,0031	Passed	0,1900	Passed
Riverview High School	Room 2329	RHS-KS-B23-2	0,0220	Exceeds Limit	0,8200	Passed
Riverview High School	Room B23	RHS-KS-B23-2	0,0015	Passed	0,3800	Passed
Riverview High School	Room 25	RHS-KS-B25-1	0,0021	Passed	0,2600	Passed
Riverview High School	Room 25	RHS-KS-B25-2	0,0031	Passed	0,2200	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-1	0,0240	Exceeds Limit	1,3000	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-1	0,0009	Passed	0,5600	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-2	0,0570	Exceeds Limit	0,5600	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-2	0,0081	Exceeds Limit	0,5500	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-3	0,0330	Exceeds Limit	0,8500	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-3	0,0027	Passed	0,2200	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-4	0,1200	Exceeds Limit	0,5500	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-4	0,0027	Passed	0,1100	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-5	0,2200	Exceeds Limit	0,5700	Passed
Riverview High School	Cafeteria	RHS-KS-CAF-5	0,0240	Exceeds Limit	0,1500	Passed
Riverview High School	Lab	RHS-KS-CHEM 28-1	0,1300	Exceeds Limit	0,6400	Passed



## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Riverview High School	Lab	RHS-KS-CHEM 28-10	1,3000	Exceeds Limit	8,7000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-12	0,7000	Exceeds Limit	1,4000	Passed
Riverview High School	Lab	RHS-KS-CHEM 28-13	0,1500	Exceeds Limit	1,3000	Passed
Riverview High School	Lab	RHS-KS-CHEM 28-2	1,1000	Exceeds Limit	18,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-3	0,7200	Exceeds Limit	4,8000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-4	1,8000	Exceeds Limit	15,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-5	1,2000	Exceeds Limit	13,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-6	0,6200	Exceeds Limit	4,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-8	0,5700	Exceeds Limit	7,6000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 28-9	0,8600	Exceeds Limit	4,5000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM 29-1	0,0950	Exceeds Limit	0,4900	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-10	0,0690	Exceeds Limit	0,9300	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-2	0,1600	Exceeds Limit	1,1000	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-3	0,1400	Exceeds Limit	0,9600	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-5	0,0680	Exceeds Limit	1,0000	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-6	0,0340	Exceeds Limit	1,1000	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-7	0,1500	Exceeds Limit	0,7700	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-8	0,1000	Exceeds Limit	1,0000	Passed
Riverview High School	Lab	RHS-KS-CHEM 29-9	0,1000	Exceeds Limit	1,1000	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-1	0,2100	Exceeds Limit	1,5000	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-10	0,1900	Exceeds Limit	1,5000	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-12	0,2000	Exceeds Limit	1,3000	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-13	0,0530	Exceeds Limit	2,1000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM-28-2	0,1900	Exceeds Limit	4,9000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM-28-3	0,1600	Exceeds Limit	1,8000	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-4	0,7100	Exceeds Limit	6,7000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM-28-5	1,3000	Exceeds Limit	8,5000	Exceeds Limit
Riverview High School	Lab	RHS-KS-CHEM-28-6	0,0390	Exceeds Limit	0,9400	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-8	0,0780	Exceeds Limit	0,9500	Passed
Riverview High School	Lab	RHS-KS-CHEM-28-9	0,0930	Exceeds Limit	1,3000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-1	0,0220	Exceeds Limit	1,6000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-10	0,0041	Passed	0,3500	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-2	0,0150	Exceeds Limit	1,7000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-3	0,0290	Exceeds Limit	1,7000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-5	0,0310	Exceeds Limit	1,2000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-6	0,0110	Exceeds Limit	0,7700	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-7	0,0140	Exceeds Limit	1,0000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-8	0,0130	Exceeds Limit	1,3000	Passed
Riverview High School	Lab	RHS-KS-CHEM-29-9	0,0087	Exceeds Limit	0,4100	Passed
Riverview High School	Health	RHS-KS-HEALTH	0,0008	Passed	0,1700	Passed
Riverview High School	Lab	RHS-KS-PHYS-1	0,5200	Exceeds Limit	0,6700	Passed
Riverview High School	Lab	RHS-KS-PHYS-1	0,1100	Exceeds Limit	0,2700	Passed



## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Riverview High School	Lab	RHS-KS-PHYS-10	9,1000	Exceeds Limit	15,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-10	0,4000	Exceeds Limit	1,9000	Passed
Riverview High School	Lab	RHS-KS-PHYS-11	1,1000	Exceeds Limit	5,8000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-11	0,1100	Exceeds Limit	1,1000	Passed
Riverview High School	Lab	RHS-KS-PHYS-12	4,7000	Exceeds Limit	3,3000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-12	0,5200	Exceeds Limit	2,2000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-2	1,5000	Exceeds Limit	2,6000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-2	0,1200	Exceeds Limit	1,6000	Passed
Riverview High School	Lab	RHS-KS-PHYS-3	0,4700	Exceeds Limit	1,0000	Passed
Riverview High School	Lab	RHS-KS-PHYS-3	0,2300	Exceeds Limit	2,2000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-4	1,4000	Exceeds Limit	3,6000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-4	0,8700	Exceeds Limit	1,6000	Passed
Riverview High School	Lab	RHS-KS-PHYS-5	2,2000	Exceeds Limit	2,5000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-5	0,1900	Exceeds Limit	0,4500	Passed
Riverview High School	Lab	RHS-KS-PHYS-6	2,1000	Exceeds Limit	4,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-6	0,1200	Exceeds Limit	0,4400	Passed
Riverview High School	Lab	RHS-KS-PHYS-7	1,5000	Exceeds Limit	4,4000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-7	0,5200	Exceeds Limit	1,1000	Passed
Riverview High School	Lab	RHS-KS-PHYS-8	0,6300	Exceeds Limit	0,5100	Passed
Riverview High School	Lab	RHS-KS-PHYS-8	1,3000	Exceeds Limit	18,0000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-9	1,4000	Exceeds Limit	4,2000	Exceeds Limit
Riverview High School	Lab	RHS-KS-PHYS-9	0,4100	Exceeds Limit	1,8000	Passed
Riverview High School	Staff	RHS-KS-STAFF	0,0750	Exceeds Limit	0,8000	Passed
Riverview High School	Staff	RHS-KS-STAFF	0,0036	Passed	0,5000	Passed
Riverview High School	Main	RHS-MAIN	0,2800	Exceeds Limit	2,6000	Exceeds Limit
Riverview High School	Main	RHS-MAIN	0,0017	Passed	0,0210	Passed
Robin Foote Elementary School	Fountain	RFE-DF-1	0,0000	Passed	0,2100	Passed
Robin Foote Elementary School	Fountain	RFE-DF-2	0,0050	Passed	0,1800	Passed
Robin Foote Elementary School	Room 1	RFE-KS-1	0,0000	Passed	0,2900	Passed
Robin Foote Elementary School	Staff	RFE-KS-STAFF	0,0000	Passed	0,0930	Passed
Robin Foote Elementary School	Washroom	RFE-KS-WR1	0,0000	Passed	0,1100	Passed
Robin Foote Elementary School	Main	RFE-MAIN	0,0008	Passed	0,0082	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-1	0,0000	Passed	0,6600	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-2	0,0000	Passed	0,5900	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-3	0,0007	Passed	0,5500	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-4	0,0000	Passed	0,5900	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-5	0,0022	Passed	0,5500	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-6	0,0000	Passed	0,4800	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-7	0,0000	Passed	0,5500	Passed
Sherwood Park Education Centre	Fountain	SPEC-DF-8	0,0000	Passed	0,6500	Passed
Sherwood Park Education Centre	Room 101	SPEC-KS-101	0,0048	Passed	0,5600	Passed
Sherwood Park Education Centre	Room 103	SPEC-KS-103	0,0026	Passed	0,4700	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sherwood Park Education Centre	Room 105	SPEC-KS-105	0,0015	Passed	0,8900	Passed
Sherwood Park Education Centre	Room 107	SPEC-KS-107	0,0097	Exceeds Limit	1,1000	Passed
Sherwood Park Education Centre	Room 110	SPEC-KS-110	0,0034	Passed	0,5400	Passed
Sherwood Park Education Centre	Room 112	SPEC-KS-112	0,0046	Passed	0,6700	Passed
Sherwood Park Education Centre	Room 114	SPEC-KS-114	0,0055	Exceeds Limit	0,4800	Passed
Sherwood Park Education Centre	Room 200	SPEC-KS-200	0,0022	Passed	0,5600	Passed
Sherwood Park Education Centre	Room 201	SPEC-KS-201	0,0052	Exceeds Limit	0,4800	Passed
Sherwood Park Education Centre	Room 203	SPEC-KS-203	0,0039	Passed	0,4500	Passed
Sherwood Park Education Centre	Room 205	SPEC-KS-205	0,0018	Passed	0,8000	Passed
Sherwood Park Education Centre	Room 206	SPEC-KS-206	0,0046	Passed	0,5400	Passed
Sherwood Park Education Centre	Room 210	SPEC-KS-210	0,0022	Passed	0,5100	Passed
Sherwood Park Education Centre	Room 212	SPEC-KS-212	0,0072	Exceeds Limit	0,7500	Passed
Sherwood Park Education Centre	Room 214	SPEC-KS-214	0,0029	Passed	0,5100	Passed
Sherwood Park Education Centre	Art	SPEC-KS-ART-1	0,0024	Passed	0,6200	Passed
Sherwood Park Education Centre	Art	SPEC-KS-ART-2	0,0010	Passed	0,4500	Passed
Sherwood Park Education Centre	Art	SPEC-KS-ART-3	0,0690	Exceeds Limit	3,1000	Exceeds Limit
Sherwood Park Education Centre	Cook	SPEC-KS-COOK-1	0,0030	Passed	0,5100	Passed
Sherwood Park Education Centre	Cook	SPEC-KS-COOK-2	0,0018	Passed	0,4300	Passed
Sherwood Park Education Centre	Cook	SPEC-KS-COOK-3	0,0013	Passed	0,5200	Passed
Sherwood Park Education Centre	Cook	SPEC-KS-COOK-4	0,0016	Passed	0,4200	Passed
Sherwood Park Education Centre	Cook	SPEC-KS-COOK-5	0,0015	Passed	0,4800	Passed
Sherwood Park Education Centre	Hospitality	SPEC-KS-HOSP	0,0034	Passed	0,4500	Passed
Sherwood Park Education Centre	Kitchen	SPEC-KS-KIT-1	0,0016	Passed	0,5800	Passed
Sherwood Park Education Centre	Kitchen	SPEC-KS-KIT-2	0,0006	Passed	0,4000	Passed
Sherwood Park Education Centre	Kitchen	SPEC-KS-KIT-3	0,0061	Exceeds Limit	0,6600	Passed
Sherwood Park Education Centre	Lab	SPEC-KS-LAB-1	2,3000	Exceeds Limit	1,3000	Passed
Sherwood Park Education Centre	Lab	SPEC-KS-LAB109-1	0,0230	Exceeds Limit	0,5500	Passed
Sherwood Park Education Centre	Lab	SPEC-KS-LAB109-2	12,0000	Exceeds Limit	2,4000	Exceeds Limit
Sherwood Park Education Centre	Lab	SPEC-KS-LAB109-3	0,7600	Exceeds Limit	3,8000	Exceeds Limit
Sherwood Park Education Centre	Lab	SPEC-KS-LAB-2	0,0160	Exceeds Limit	0,6800	Passed
Sherwood Park Education Centre	Lab	SPEC-KS-LAB-3	0,0240	Exceeds Limit	0,6400	Passed
Sherwood Park Education Centre	Learning Center	SPEC-KS-LC208-1	0,0077	Exceeds Limit	0,6800	Passed
Sherwood Park Education Centre	Learning Center	SPEC-KS-LC208-2	0,0021	Passed	0,4900	Passed
Sherwood Park Education Centre	Learning Center	SPEC-KS-LC214-1	0,0022	Passed	0,3900	Passed
Sherwood Park Education Centre	Learning Center	SPEC-KS-LC214-2	0,0033	Passed	0,4800	Passed
Sherwood Park Education Centre	Library	SPEC-KS-LIB	0,0067	Exceeds Limit	0,8200	Passed
Sherwood Park Education Centre	Office	SPEC-KS-OFFICE	0,0045	Passed	0,5400	Passed
Sherwood Park Education Centre	Science	SPEC-KS-SCI-1	0,0390	Exceeds Limit	0,5500	Passed
Sherwood Park Education Centre	Science	SPEC-KS-SCI-2	0,2600	Exceeds Limit	6,4000	Exceeds Limit
Sherwood Park Education Centre	Science	SPEC-KS-SCI-3	0,1400	Exceeds Limit	1,3000	Passed
Sherwood Park Education Centre	Science	SPEC-KS-SCI-4	0,5000	Exceeds Limit	11,0000	Exceeds Limit
Sherwood Park Education Centre	Science	SPEC-KS-SCI-5	0,0120	Exceeds Limit	0,4700	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sherwood Park Education Centre	Tech Room	SPEC-KS-TECH-1	0,1900	Exceeds Limit	1,6000	Passed
Sherwood Park Education Centre	Tech Room	SPEC-KS-TECH-2	0,0052	Exceeds Limit	0,6400	Passed
Shipyard Elementary School	In hall near office	SHP-DF-1	0,0000	Passed	0,1100	Passed
Shipyard Elementary School	By entrance to gym across from main entrance	SHP-DF-2	0,0000	Passed	0,1100	Passed
Shipyard Elementary School	Room 107	SHP-KS-107	0,0019	Passed	0,2100	Passed
Shipyard Elementary School	Room 108	SHP-KS-108	0,0017	Passed	0,2500	Passed
Shipyard Elementary School	Room 109	SHP-KS-109	0,0023	Passed	0,2500	Passed
Shipyard Elementary School	Room 111	SHP-KS-111	0,0000	Passed	0,2100	Passed
Shipyard Elementary School	Room 112	SHP-KS-112	0,0007	Passed	0,2700	Passed
Shipyard Elementary School	Room 113	SHP-KS-113	0,0009	Passed	0,1900	Passed
Shipyard Elementary School	Room 114	SHP-KS-114	0,0013	Passed	0,2300	Passed
Shipyard Elementary School	Room 116	SHP-KS-116	0,0011	Passed	0,2000	Passed
Shipyard Elementary School	Room 117	SHP-KS-117	0,0009	Passed	0,1600	Passed
Shipyard Elementary School	Art room	SHP-KS-127-1	0,0009	Passed	0,1700	Passed
Shipyard Elementary School	Art room	SHP-KS-127-2	0,0015	Passed	0,0980	Passed
Shipyard Elementary School	Room 147	SHP-KS-147	0,0012	Passed	0,1800	Passed
Shipyard Elementary School	Room 148	SHP-KS-148	0,0009	Passed	0,1600	Passed
Shipyard Elementary School	Room 150	SHP-KS-150	0,0006	Passed	0,2100	Passed
Shipyard Elementary School	Room 152	SHP-KS-152	0,0020	Passed	0,1900	Passed
Shipyard Elementary School	Room 153	SHP-KS-153	0,0000	Passed	0,2500	Passed
Shipyard Elementary School	Room 155	SHP-KS-155	0,0000	Passed	0,2200	Passed
Shipyard Elementary School	Rom 158	SHP-KS-158	0,0008	Passed	0,1700	Passed
Shipyard Elementary School	Music room	SHP-KS-MUSIC	0,0120	Exceeds Limit	0,5500	Passed
Shipyard Elementary School	Recycle room 136	SHP-KS-REC	0,0000	Passed	0,2200	Passed
Shipyard Elementary School	Staff room	SHP-KS-STAFF	0,0000	Passed	0,2100	Passed
St. Anne's Elementary School	Hall across from art room	STA-DF-1	0,0000	Passed	0,0860	Passed
St. Anne's Elementary School	Hall across from room 111	STA-DF-2	0,0000	Passed	0,1200	Passed
St. Anne's Elementary School	Room 206	STA-DF-206	0,0000	Passed	0,2400	Passed
St. Anne's Elementary School	Hall across from room 221 offices	STA-DF-3	0,0016	Passed	0,0770	Passed
St. Anne's Elementary School	Hall next to room 210	STA-DF-4	0,0000	Passed	0,0620	Passed
St. Anne's Elementary School	Room 106	STA-KS-106	0,0000	Passed	0,0550	Passed
St. Anne's Elementary School	Art room	STA-KS-119 (1)	0,0017	Passed	0,4100	Passed
St. Anne's Elementary School	Art room	STA-KS-119 (2)	0,0015	Passed	0,3200	Passed
St. Anne's Elementary School	Music room	STA-KS-122	0,0015	Passed	0,1100	Passed
St. Anne's Elementary School	Recycle room 125	STA-KS-125	0,0000	Passed	0,2100	Passed
St. Anne's Elementary School	Office	STA-KS-126	0,0000	Passed	0,0820	Passed
St. Anne's Elementary School	Kitchen	STA-KS-127	0,0000	Passed	0,1300	Passed
St. Anne's Elementary School	Room 202	STA-KS-202	0,0000	Passed	0,3700	Passed
St. Anne's Elementary School	Room 207	STA-KS-207	0,0000	Passed	0,1300	Passed
St. Anne's Elementary School	Room 208	STA-KS-208	0,0000	Passed	0,0190	Passed
St. Anne's Elementary School	Room 209	STA-KS-209	0,0030	Passed	0,0340	Passed
St. Anne's Elementary School	Room 211	STA-KS-211	0,0000	Passed	0,0870	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Anne's Elementary School	Staff room	STA-KS-STAFF	0,0000	Passed	0,0190	Passed
St. Anne's Elementary School	Staff room	STA-KS-STAFF #1	0,0000	Passed	0,2200	Passed
Sydney Academy	Fountain	SA-DF-1	0,0000	Passed	0,3900	Passed
Sydney Academy	Fountain	SA-DF-2	0,0000	Passed	0,2700	Passed
Sydney Academy	Fountain	SA-DF-3	0,0050	Passed	0,7400	Passed
Sydney Academy	Fountain	SA-DF-3	0,0000	Passed	0,3700	Passed
Sydney Academy	Fountain	SA-DF-4	0,0000	Passed	0,3200	Passed
Sydney Academy	Art	SA-KS-ART	0,0000	Passed	0,6500	Passed
Sydney Academy	Room 106	SA-KS-C106	0,0007	Passed	0,0310	Passed
Sydney Academy	Room 107	SA-KS-C107	0,0000	Passed	0,0350	Passed
Sydney Academy	Lab	SA-KS-PHY	0,0012	Passed	0,7400	Passed
Sydney Academy	Quiet Room	SA-KS-QUIET	0,0007	Passed	0,0850	Passed
Sydney Academy	Room 214	SA-KS-S214 (1)	0,0150	Exceeds Limit	1,3000	Passed
Sydney Academy	Room 214	SA-KS-S214 (10)	0,0170	Exceeds Limit	0,8300	Passed
Sydney Academy	Room 214	SA-KS-S214 (11)	0,0000	Passed	0,5300	Passed
Sydney Academy	Room 214	SA-KS-S214 (2)	0,0140	Exceeds Limit	0,6600	Passed
Sydney Academy	Room 214	SA-KS-S214 (3)	0,0086	Exceeds Limit	0,8700	Passed
Sydney Academy	Room 214	SA-KS-S214 (4)	0,0058	Exceeds Limit	1,1000	Passed
Sydney Academy	Room 214	SA-KS-S214 (5)	0,0190	Exceeds Limit	1,0000	Passed
Sydney Academy	Room 214	SA-KS-S214 (6)	0,0160	Exceeds Limit	0,9400	Passed
Sydney Academy	Room 214	SA-KS-S214 (7)	0,0120	Exceeds Limit	0,6900	Passed
Sydney Academy	Room 214	SA-KS-S214 (8)	0,0370	Exceeds Limit	0,8100	Passed
Sydney Academy	Room 214	SA-KS-S214 (9)	0,0160	Exceeds Limit	0,7100	Passed
Sydney Academy	Room 214	SA-KS-S214-1	0,0043	Passed	0,5500	Passed
Sydney Academy	Room 214	SA-KS-S214-10	0,0000	Passed	0,2100	Passed
Sydney Academy	Room 214	SA-KS-S214-2	0,0000	Passed	0,3400	Passed
Sydney Academy	Room 214	SA-KS-S214-3	0,0097	Exceeds Limit	0,4100	Passed
Sydney Academy	Room 214	SA-KS-S214-4	0,0040	Passed	0,3600	Passed
Sydney Academy	Room 214	SA-KS-S214-5	0,0000	Passed	0,2900	Passed
Sydney Academy	Room 214	SA-KS-S214-6	0,0015	Passed	0,2900	Passed
Sydney Academy	Room 214	SA-KS-S214-7	0,0140	Exceeds Limit	0,3400	Passed
Sydney Academy	Room 214	SA-KS-S214-8	0,0000	Passed	0,2200	Passed
Sydney Academy	Room 214	SA-KS-S214-9	0,0021	Passed	0,2200	Passed
Sydney Academy	Room 215	SA-KS-S215	0,0120	Exceeds Limit	1,5000	Passed
Sydney Academy	Room 215	SA-KS-S215	0,0023	Passed	1,1000	Passed
Sydney Academy	Room 216	SA-KS-S216	0,0008	Passed	0,5700	Passed
Sydney Academy	Room 217	SA-KS-S217 (1)	0,0130	Exceeds Limit	0,9000	Passed
Sydney Academy	Room 217	SA-KS-S217 (10)	0,0077	Exceeds Limit	0,4800	Passed
Sydney Academy	Room 217	SA-KS-S217 (2)	0,0067	Exceeds Limit	0,4800	Passed
Sydney Academy	Room 217	SA-KS-S217 (3)	0,0075	Exceeds Limit	0,5200	Passed
Sydney Academy	Room 217	SA-KS-S217 (4)	0,0120	Exceeds Limit	1,3000	Passed
Sydney Academy	Room 217	SA-KS-S217 (5)	0,0079	Exceeds Limit	0,6100	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sydney Academy	Room 217	SA-KS-S217 (6)	0,0500	Exceeds Limit	1,1000	Passed
Sydney Academy	Room 217	SA-KS-S217 (7)	0,0074	Exceeds Limit	0,7000	Passed
Sydney Academy	Room 217	SA-KS-S217 (8)	0,0091	Exceeds Limit	0,6600	Passed
Sydney Academy	Room 217	SA-KS-S217 (9)	0,0065	Exceeds Limit	0,4300	Passed
Sydney Academy	Room 217	SA-KS-S217-1	0,0010	Passed	0,5100	Passed
Sydney Academy	Room 217	SA-KS-S217-10	0,0009	Passed	0,3900	Passed
Sydney Academy	Room 217	SA-KS-S217-2	0,0013	Passed	0,4500	Passed
Sydney Academy	Room 217	SA-KS-S217-3	0,0011	Passed	0,4600	Passed
Sydney Academy	Room 217	SA-KS-S217-4	0,0000	Passed	0,4000	Passed
Sydney Academy	Room 217	SA-KS-S217-5	0,0000	Passed	0,4200	Passed
Sydney Academy	Room 217	SA-KS-S217-6	0,0000	Passed	0,4000	Passed
Sydney Academy	Room 217	SA-KS-S217-7	0,0000	Passed	0,4700	Passed
Sydney Academy	Room 217	SA-KS-S217-8	0,0012	Passed	0,4300	Passed
Sydney Academy	Room 217	SA-KS-S217-9	0,0000	Passed	0,4000	Passed
Sydney Academy	Staff	SA-KS-STAFF 1	0,0080	Exceeds Limit	0,8500	Passed
Sydney Academy	Staff	SA-KS-STAFF 2	0,0007	Passed	0,7000	Passed
Sydney Academy	Staff	SA-KS-STAFF 3	0,0000	Passed	0,5200	Passed
Sydney Academy	Staff	SA-KS-STAFF 4	0,0000	Passed	0,2500	Passed
Sydney Academy	Staff	SA-KS-STAFF1	0,0008	Passed	0,4500	Passed
Sydney Mines Middle School	Fountain	SMM-DF-1	0,0011	Passed	0,0560	Passed
Sydney Mines Middle School	Fountain	SMM-DF-2	0,0000	Passed	0,1300	Passed
Sydney Mines Middle School	Fountain	SMM-DF-3	0,0000	Passed	0,0440	Passed
Sydney Mines Middle School	Fountain	SMM-DF-4	0,0011	Passed	0,0900	Passed
Sydney Mines Middle School	Fountain	SMM-KS-112	0,0000	Passed	0,0230	Passed
Sydney Mines Middle School	Room 206	SMM-KS-206 (1)	0,0000	Passed	0,0750	Passed
Sydney Mines Middle School	Room 206	SMM-KS-206 (2)	0,0000	Passed	0,0850	Passed
Sydney Mines Middle School	Room 206	SMM-KS-206 (3)	0,0000	Passed	0,0820	Passed
Sydney Mines Middle School	Room 206	SMM-KS-206 (4)	0,0008	Passed	0,1400	Passed
Sydney Mines Middle School	Room 206	SMM-KS-206 (5)	0,0000	Passed	0,1000	Passed
Sydney Mines Middle School	Staff	SMM-KS-STAFF	0,0000	Passed	0,0490	Passed
Sydney River Elementary School	Hall near music room	SRE-DF-1	0,0023	Passed	0,0480	Passed
Sydney River Elementary School	Hall near library	SRE-DF-3	0,0000	Passed	0,0120	Passed
Sydney River Elementary School	Hall near learning centre	SRE-DF-4	0,0018	Passed	0,0420	Passed
Sydney River Elementary School	Upstaris near washrooms	SRE-DF-5	0,0007	Passed	0,0260	Passed
Sydney River Elementary School	In library office	SRE-DF-LIB	0,0440	Exceeds Limit	3,5000	Exceeds Limit
Sydney River Elementary School	Music room	SRE-KS-105	0,0390	Exceeds Limit	0,2100	Passed
Sydney River Elementary School	Room 122	SRE-KS-122	0,0160	Exceeds Limit	0,0170	Passed
Sydney River Elementary School	Room 131	SRE-KS-131-1	0,0098	Exceeds Limit	0,0740	Passed
Sydney River Elementary School	Room 132	SRE-KS-132-0	0,0130	Exceeds Limit	0,1000	Passed
Sydney River Elementary School	Room 133	SRE-KS-133	0,0160	Exceeds Limit	0,0270	Passed
Sydney River Elementary School	Learning centre	SRE-KS-139	0,0027	Passed	0,0230	Passed
Sydney River Elementary School	Art room	SRE-KS-ART-0	0,0050	Passed	0,0240	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sydney River Elementary School	Art room	SRE-KS-ART-1	0,0069	Exceeds Limit	0,0330	Passed
Sydney River Elementary School	Cafeteria	SRE-KS-CAF	0,0180	Exceeds Limit	0,0540	Passed
Sydney River Elementary School	Health room	SRE-KS-HEALTH	0,3300	Exceeds Limit	1,2000	Passed
Sydney River Elementary School	Staff room	SRE-KS-STAFF	0,0006	Passed	0,0100	Passed
Sydney River Elementary School	In mechanical room across from main office	SRE-MAIN	0,0000	Passed	0,1000	Passed
Tompkins Memorial Elementary School	Across from room 3	TMP-DF-1	0,0012	Passed	0,3000	Passed
Tompkins Memorial Elementary School	Across from room 16	TMP-DF-2	0,0028	Passed	0,2300	Passed
Tompkins Memorial Elementary School	Room 2 guidance	TMP-KS-2	0,0021	Passed	0,0570	Passed
Tompkins Memorial Elementary School	Staff room	TMP-KS-22	0,0027	Passed	0,2500	Passed
Tompkins Memorial Elementary School	Room 5 pre-k	TMP-KS-5	0,0000	Passed	0,0740	Passed
Whitney Pier Memorial Middle School	Fountain	DRINKING FOUNTAIN BY 102	0,0000	Passed	0,0310	Passed
Whitney Pier Memorial Middle School	Locker Room	GYM LOCKER RM	0,0000	Passed	0,0039	Passed
Whitney Pier Memorial Middle School	Food Lab	SECOND FLOOR FOOD LAB	0,0000	Passed	0,0520	Passed
Whitney Pier Memorial Middle School	Washroom	WPM-BWR-1ST-1	0,0000	Passed	0,0110	Passed
Whitney Pier Memorial Middle School	Washroom	WPM-BWR-3RD-1	0,0000	Passed	0,0180	Passed
Whitney Pier Memorial Middle School	Fountain	WPM-DF-1	0,0000	Passed	0,4400	Passed
Whitney Pier Memorial Middle School	Fountain	WPM-DF-2	0,0012	Passed	0,9300	Passed
Whitney Pier Memorial Middle School	Fountain	WPM-DF-3	0,0023	Passed	0,7600	Passed
Whitney Pier Memorial Middle School	Fountain	WPM-DF-3	0,0000	Passed	0,0450	Passed
Whitney Pier Memorial Middle School	Fountain	WPM-DF-4	0,0012	Passed	0,3200	Passed
Whitney Pier Memorial Middle School	Fountain	WPM-DF-5	0,0008	Passed	0,3900	Passed
Whitney Pier Memorial Middle School	Washroom	WPM-GWR-1ST-1	0,0000	Passed	0,1100	Passed
Whitney Pier Memorial Middle School	Room 102	WPM-KS-102	0,0420	Exceeds Limit	0,6500	Passed
Whitney Pier Memorial Middle School	Room 102	WPM-KS-102	0,0006	Passed	0,5200	Passed
Whitney Pier Memorial Middle School	Room 310	WPM-KS-310-1	0,0006	Passed	0,4700	Passed
Whitney Pier Memorial Middle School	Room 310	WPM-KS-310-2	0,0009	Passed	0,5000	Passed
Whitney Pier Memorial Middle School	Room 311	WPM-KS-311-1	0,0007	Passed	0,4900	Passed
Whitney Pier Memorial Middle School	Room 311	WPM-KS-311-2	0,0007	Passed	0,2600	Passed
Whitney Pier Memorial Middle School	Room 411	WPM-KS-411-1	0,0000	Passed	0,0510	Passed
Whitney Pier Memorial Middle School	Art Room	WPM-KS-ART-1	0,2400	Exceeds Limit	0,6000	Passed
Whitney Pier Memorial Middle School	Art	WPM-KS-ART-1	0,0000	Passed	0,0650	Passed
Whitney Pier Memorial Middle School	Art Room	WPM-KS-ART-2	0,0300	Exceeds Limit	1,8000	Passed
Whitney Pier Memorial Middle School	Art	WPM-KS-ART-2	0,0000	Passed	0,0600	Passed
Whitney Pier Memorial Middle School	Music	WPM-KS-BAND	0,0007	Passed	0,1900	Passed
Whitney Pier Memorial Middle School	Washroom	WPM-KS-BWR-1ST-2	0,0000	Passed	0,0210	Passed
Whitney Pier Memorial Middle School	Canteen	WPM-KS-CAN	0,0000	Passed	0,6200	Passed
Whitney Pier Memorial Middle School	Canteen	WPM-KS-CAN	0,0000	Passed	0,0088	Passed
Whitney Pier Memorial Middle School	Art Room	WPM-KS-CER	0,0100	Exceeds Limit	0,1500	Passed
Whitney Pier Memorial Middle School	Art Room	WPM-KS-CER	0,0000	Passed	0,0620	Passed
Whitney Pier Memorial Middle School	Family Room	WPM-KS-FAM	0,0034	Passed	0,6900	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-1	0,0150	Exceeds Limit	1,3000	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-1	0,0000	Passed	0,0440	Passed

## Cape Breton — Victoria Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-2	0,0150	Exceeds Limit	0,5200	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-2	0,0037	Passed	0,0620	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-3	0,0130	Exceeds Limit	0,6900	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-3	0,0000	Passed	0,0430	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-4	0,0150	Exceeds Limit	0,6400	Passed
Whitney Pier Memorial Middle School	Food	WPM-KS-FOOD-5	0,0170	Exceeds Limit	0,6000	Passed
Whitney Pier Memorial Middle School	Home Ec	WPM-KS-FS-1	0,0000	Passed	0,9500	Passed
Whitney Pier Memorial Middle School	Home Ec	WPM-KS-FS-1	0,0000	Passed	0,5200	Passed
Whitney Pier Memorial Middle School	Home Ec	WPM-KS-FS-2	0,0000	Passed	0,5600	Passed
Whitney Pier Memorial Middle School	Home Ec	WPM-KS-FS-2	0,0000	Passed	0,0630	Passed
Whitney Pier Memorial Middle School	Room 208	WPM-KS-L208-1	0,0530	Exceeds Limit	0,1100	Passed
Whitney Pier Memorial Middle School	Room 208	WPM-KS-L208-1	0,0000	Passed	0,0590	Passed
Whitney Pier Memorial Middle School	Room 208	WPM-KS-L208-2	0,2500	Exceeds Limit	0,1200	Passed
Whitney Pier Memorial Middle School	Room 208	WPM-KS-L208-3	0,2800	Exceeds Limit	0,0670	Passed
Whitney Pier Memorial Middle School	Room 208	WPM-KS-L208-3	0,0008	Passed	0,1800	Passed
Whitney Pier Memorial Middle School	Room 208	WPM-KS-L208-4	0,1300	Exceeds Limit	0,9500	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-1	0,0230	Exceeds Limit	0,7700	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-1	0,0047	Passed	0,9100	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-2	0,0062	Exceeds Limit	0,0660	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-3	4,6000	Exceeds Limit	6,0000	Exceeds Limit
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-3	0,0000	Passed	0,0320	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-4	0,0053	Exceeds Limit	1,2000	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-5	0,0020	Passed	0,1400	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-6	0,0015	Passed	0,1100	Passed
Whitney Pier Memorial Middle School	Room 215	WPM-KS-L215-7	0,0016	Passed	0,1200	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-1	0,0800	Exceeds Limit	0,2800	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-1	0,0000	Passed	0,0098	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-2	0,0320	Exceeds Limit	0,2700	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-2	0,0000	Passed	0,0630	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-3	0,0280	Exceeds Limit	0,8400	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-3	0,0000	Passed	0,0550	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-4	0,0990	Exceeds Limit	0,2300	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-4	0,0000	Passed	0,0550	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-5	0,0340	Exceeds Limit	1,5000	Passed
Whitney Pier Memorial Middle School	Room 217	WPM-KS-L217-5	0,0000	Passed	0,1500	Passed
Whitney Pier Memorial Middle School	Office	WPM-KS-OFF-1	0,0000	Passed	0,0110	Passed
Whitney Pier Memorial Middle School	Office	WPM-KS-OFF-2	0,0000	Passed	0,0170	Passed
Whitney Pier Memorial Middle School	Prep Room	WPM-KS-PREP	0,0000	Passed	0,5600	Passed
Whitney Pier Memorial Middle School	Resource	WPM-KS-RES	0,0000	Passed	0,0320	Passed
Whitney Pier Memorial Middle School	Sewing Room	WPM-KS-SEW	0,0059	Exceeds Limit	0,7100	Passed
Whitney Pier Memorial Middle School	Staff	WPM-KS-STAFF	0,0000	Passed	0,7100	Passed
Whitney Pier Memorial Middle School	Main	WPM-MAIN	0,0000	Passed	0,0710	Passed