

# Water Test Results

Chignecto Central Regional Centre for Education



## Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate remediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

## Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

## Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

[www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html](http://www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html)

Copper:

[www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3](http://www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3)

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
A. G. Baillie Memorial School	Source-Municipal	MSG804	0,0017	Passed	0,0490	Passed
A. G. Baillie Memorial School	Fountain Gym Entrance	MSG805	0,0000	Passed	0,8700	Passed
A. G. Baillie Memorial School	Fountain 1st Floor North Wing	MSG806	0,0016	Passed	0,1300	Passed
A. G. Baillie Memorial School	Room 124	MSG807	0,0022	Passed	0,2400	Passed
A. G. Baillie Memorial School	Room 122	MSG808	0,0210	Exceeds Limit	0,4300	Passed
A. G. Baillie Memorial School	Room 130	MSG809	0,0000	Passed	0,0760	Passed
A. G. Baillie Memorial School	Room 130 Laundry Sink	MSG810	0,0000	Passed	0,6400	Passed
A. G. Baillie Memorial School	Room 133	MSG811	0,0008	Passed	0,0670	Passed
A. G. Baillie Memorial School	Room 134, Sink A	MSG812	0,0021	Passed	0,0750	Passed
A. G. Baillie Memorial School	Room 134, Sink B	MSG813	0,0025	Passed	0,0490	Passed
A. G. Baillie Memorial School	Room 137	MSG814	0,0021	Passed	0,0670	Passed
A. G. Baillie Memorial School	Room 155	MSG815	0,0000	Passed	0,5200	Passed
A. G. Baillie Memorial School	Room 156	MSG816	0,0007	Passed	0,0039	Passed
A. G. Baillie Memorial School	Principal's Office Sink	MSG817	0,0018	Passed	0,0910	Passed
A. G. Baillie Memorial School	Cafeteria Kitchen Sink	MSG818	0,0026	Passed	0,0510	Passed
A. G. Baillie Memorial School	Kitchen Handwashing Sink	MSG819	0,0009	Passed	0,0850	Passed
A. G. Baillie Memorial School	Room 205	MSG820	0,0012	Passed	0,0770	Passed
A. G. Baillie Memorial School	Room 207	MSG821	0,0014	Passed	0,0810	Passed
A. G. Baillie Memorial School	Room 208	MSG822	0,0053	Exceeds Limit	0,0790	Passed
A. G. Baillie Memorial School	Room 209	MSG823	0,0023	Passed	0,0900	Passed
A. G. Baillie Memorial School	Fountain 2nd Floor Main Wing	MSG824	0,0000	Passed	0,3600	Passed
A. G. Baillie Memorial School	Fountain 2nd Floor North Wing	MSG825	0,0023	Passed	0,1100	Passed
A. G. Baillie Memorial School	005 Room 124 Washroom	NFR465	0,0054	Exceeds Limit	0,1700	Passed
A. G. Baillie Memorial School	008 Room 130 Washroom	NFR466	0,0052	Exceeds Limit	0,1300	Passed
A. G. Baillie Memorial School	011 Room 133 Washroom	NFR467	0,0005	Passed	0,0420	Passed
A. G. Baillie Memorial School	015 Room 137 Washroom	NFR468	0,0012	Passed	0,0400	Passed
A. G. Baillie Memorial School	027 Main Level Staff Washroom A	NFR469	0,0023	Passed	0,1600	Passed
A. G. Baillie Memorial School	028 Main Level Staff Washroom B	NFR470	0,0021	Passed	0,1900	Passed
A. G. Baillie Memorial School	029 Gym Office Washroom	NFR471	0,0056	Exceeds Limit	0,0780	Passed
A. G. Baillie Memorial School	030 Gym Washroom Girls	NFR472	0,0031	Passed	0,0440	Passed
A. G. Baillie Memorial School	031 Gym Washroom Boys	NFR473	0,0079	Exceeds Limit	0,0840	Passed
A. G. Baillie Memorial School	032 Bottom Floor Washroom Girls A	NFR474	0,0460	Exceeds Limit	0,2700	Passed
A. G. Baillie Memorial School	033 Bottom Floor Washroom Girls B	NFR475	0,0059	Exceeds Limit	0,0850	Passed
A. G. Baillie Memorial School	034 Bottom Floor Washroom Girls C	NFR476	0,0190	Exceeds Limit	0,1100	Passed
A. G. Baillie Memorial School	035 Bottom Floor Washroom Girls D	NFR477	0,0390	Exceeds Limit	0,1300	Passed
A. G. Baillie Memorial School	036 Bottom Floor Washroom Girls E	NFR478	0,0220	Exceeds Limit	0,2000	Passed
A. G. Baillie Memorial School	037 Bottom Floor Washroom Boys A	NFR479	0,0220	Exceeds Limit	0,2000	Passed
A. G. Baillie Memorial School	038 Bottom Floor Washroom Boys B	NFR480	0,0130	Exceeds Limit	0,1200	Passed
A. G. Baillie Memorial School	039 Bottom Floor Washroom Boys C	NFR481	0,0130	Exceeds Limit	0,1300	Passed
A. G. Baillie Memorial School	040 Bottom Floor Washroom Boys D	NFR482	0,0120	Exceeds Limit	0,1800	Passed
A. G. Baillie Memorial School	041 Main Floor Washroom Girls	NFR483	0,0006	Passed	0,0490	Passed
A. G. Baillie Memorial School	042 Main Floor Washroom Boys	NFR484	0,0000	Passed	0,0250	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
A. G. Baillie Memorial School	043 Bottom Floor Custodial Closet	NFR485	0,0130	Exceeds Limit	0,1300	Passed
A. G. Baillie Memorial School	044 Main Floor Custodial Closet	NFR486	0,0000	Passed	0,0110	Passed
A. G. Baillie Memorial School	045 2nd Floor Custodial Closet	NFR487	0,0014	Passed	0,0430	Passed
A. G. Baillie Memorial School	046 2nd Floor Washroom Girls A	NFR488	0,0008	Passed	0,0480	Passed
A. G. Baillie Memorial School	047 2nd Floor Washroom Girls B	NFR489	0,0014	Passed	0,0450	Passed
A. G. Baillie Memorial School	048 2nd Floor Washroom B	NFR490	0,0012	Passed	0,0590	Passed
A. G. Baillie Memorial School	049 2nd Floor Washroom Boys B	NFR491	0,0012	Passed	0,0790	Passed
Advocate District School	Tap #1	LDD605	0,0012	Passed	0,1600	Passed
Advocate District School	Tap #2	LDD606	0,0025	Passed	0,1500	Passed
Advocate District School	Tap #3	LDD607	0,0013	Passed	0,1600	Passed
Advocate District School	Tap #4	LDD608	0,0580	Exceeds Limit	0,7000	Passed
Advocate District School	Tap #5	LDD609	0,0010	Passed	0,6700	Passed
Advocate District School	Drinking Fountain #1	LDD610	0,0020	Passed	0,1100	Passed
Advocate District School	Drinking Fountain #2	LDD611	0,0000	Passed	0,3600	Passed
Advocate District School	Water Source	LDD612	0,0028	Passed	0,0250	Passed
Advocate District School	Boiler Room	NDQ901	0,0000	Passed	0,0400	Passed
Advocate District School	Boys Locker Room	NDQ902	0,0008	Passed	0,0850	Passed
Advocate District School	Girls Locker Room	NDQ903	0,0007	Passed	0,1100	Passed
Advocate District School	Main Office Washroom	NDQ904	0,0007	Passed	0,0600	Passed
Advocate District School	Staff #1	NDQ905	0,0000	Passed	0,0700	Passed
Advocate District School	Staff #2	NDQ906	0,0000	Passed	0,4900	Passed
Advocate District School	Boys #1	NDQ907	0,0011	Passed	0,0730	Passed
Advocate District School	Boys #2	NDQ908	0,0018	Passed	0,0700	Passed
Advocate District School	Boys #3	NDQ909	0,0011	Passed	0,0650	Passed
Advocate District School	Boys #4	NDQ910	0,0000	Passed	0,0510	Passed
Advocate District School	Custodial Closet	NDQ911	0,0000	Passed	0,0410	Passed
Advocate District School	Girls #1	NDQ912	0,0008	Passed	0,0840	Passed
Advocate District School	Girls #2	NDQ913	0,0000	Passed	0,0500	Passed
Advocate District School	Girls #3	NDQ914	0,0000	Passed	0,0430	Passed
Advocate District School	Girls #4	NDQ915	0,0000	Passed	0,0410	Passed
Amherst Regional High School	Cafeteria #1	MVN551	0,0009	Passed	0,0460	Passed
Amherst Regional High School	Cafeteria #2	MVN552	0,0220	Exceeds Limit	0,7500	Passed
Amherst Regional High School	Room 140	MVN553	0,0000	Passed	0,0480	Passed
Amherst Regional High School	Fountain by Locker Rooms	MVN554	0,0013	Passed	0,2300	Passed
Amherst Regional High School	Fountain in Cafeteria	MVN555	0,0010	Passed	0,0770	Passed
Amherst Regional High School	Room 130	MVN556	0,0026	Passed	0,0440	Passed
Amherst Regional High School	Room 143	MVN557	0,0000	Passed	0,0370	Passed
Amherst Regional High School	Fountain by Music Room	MVN558	0,0016	Passed	0,2100	Passed
Amherst Regional High School	Room 128	MVN559	0,0029	Passed	0,0580	Passed
Amherst Regional High School	Room 139	MVN560	0,0540	Exceeds Limit	0,8300	Passed
Amherst Regional High School	Guidance Office	MVN561	0,0000	Passed	0,0520	Passed
Amherst Regional High School	Main Office Photo Room	MVN562	0,0000	Passed	0,0640	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Amherst Regional High School	Fountain by Main Office	MVN563	0,0017	Passed	0,2000	Passed
Amherst Regional High School	Fountain in Atrium	MVN564	0,0009	Passed	0,0800	Passed
Amherst Regional High School	Library	MVN565	0,0009	Passed	0,0740	Passed
Amherst Regional High School	Fountain in Blue Wing	MVN566	0,0100	Exceeds Limit	1,1000	Passed
Amherst Regional High School	Room 131	MVN567	0,0390	Exceeds Limit	0,5900	Passed
Amherst Regional High School	Room 130	MVN568	0,0086	Exceeds Limit	0,4100	Passed
Amherst Regional High School	Room 127	MVN569	0,0250	Exceeds Limit	0,4400	Passed
Amherst Regional High School	Room 125	MVN570	0,0140	Exceeds Limit	0,4400	Passed
Amherst Regional High School	Room 123 #1	MVN571	0,0019	Passed	0,9400	Passed
Amherst Regional High School	Room 123 #2	MVN572	0,0009	Passed	0,6700	Passed
Amherst Regional High School	Room 123 #3	MVN573	0,0026	Passed	0,6300	Passed
Amherst Regional High School	Room 123 #4	MVN574	0,0034	Passed	0,8500	Passed
Amherst Regional High School	Room 123 #5	MVN575	0,0330	Exceeds Limit	1,6000	Passed
Amherst Regional High School	Room 121	MVN576	0,0340	Exceeds Limit	1,1000	Passed
Amherst Regional High School	Room 112	MVN577	0,0043	Passed	0,3600	Passed
Amherst Regional High School	Room 110	MVN578	0,0053	Exceeds Limit	0,5800	Passed
Amherst Regional High School	Room 108	MVN579	0,0014	Passed	0,3700	Passed
Amherst Regional High School	Room 111	MVN580	0,0074	Exceeds Limit	0,5000	Passed
Amherst Regional High School	Room 109	MVN581	0,0095	Exceeds Limit	0,2800	Passed
Amherst Regional High School	Room 107	MVN582	0,0046	Passed	0,3700	Passed
Amherst Regional High School	Room 105	MVN583	0,0068	Exceeds Limit	0,3300	Passed
Amherst Regional High School	Room 103	MVN584	0,0022	Passed	0,3200	Passed
Amherst Regional High School	Room 101 #1	MVN585	0,0050	Passed	0,5300	Passed
Amherst Regional High School	Room 101 #2	MVN586	0,0110	Exceeds Limit	0,6600	Passed
Amherst Regional High School	Fountain in Green Wing	MVN587	0,0070	Exceeds Limit	0,3900	Passed
Amherst Regional High School	Fountain in Trades Building	MVN588	0,0007	Passed	0,6200	Passed
Amherst Regional High School	Room 224 #1	MVN589	0,0180	Exceeds Limit	0,6000	Passed
Amherst Regional High School	Room 224 #2	MVN590	0,0092	Exceeds Limit	0,5700	Passed
Amherst Regional High School	Room 224 #3	MVN591	0,0024	Passed	0,4000	Passed
Amherst Regional High School	Room 224 #4	MVN592	0,0240	Exceeds Limit	0,9500	Passed
Amherst Regional High School	Fountain in Yellow Wing	MVN593	0,0013	Passed	0,1400	Passed
Amherst Regional High School	Room 231	MVN594	0,0063	Exceeds Limit	0,4200	Passed
Amherst Regional High School	Room 229	MVN595	0,0530	Exceeds Limit	0,8300	Passed
Amherst Regional High School	Room 227	MVN596	0,0078	Exceeds Limit	0,3400	Passed
Amherst Regional High School	Room 225	MVN597	0,0140	Exceeds Limit	0,4200	Passed
Amherst Regional High School	Room 223	MVN598	0,0062	Exceeds Limit	0,8000	Passed
Amherst Regional High School	Room 221	MVN599	0,0160	Exceeds Limit	0,9300	Passed
Amherst Regional High School	Room 216	MVN600	0,0200	Exceeds Limit	0,1800	Passed
Amherst Regional High School	Room 222	MVN601	0,0037	Passed	0,4600	Passed
Amherst Regional High School	Room 204	MVN602	0,0180	Exceeds Limit	0,5300	Passed
Amherst Regional High School	Room 208	MVN603	0,0028	Passed	0,4100	Passed
Amherst Regional High School	Room 206	MVN604	0,0078	Exceeds Limit	0,2500	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Amherst Regional High School	Room 209	MVN605	0,0007	Passed	0,2500	Passed
Amherst Regional High School	Fountain in Red Wing	MVN606	0,0013	Passed	0,4200	Passed
Amherst Regional High School	Room 201	MVN607	0,0110	Exceeds Limit	0,8100	Passed
Amherst Regional High School	Room 203	MVN608	0,0040	Passed	0,3300	Passed
Amherst Regional High School	Room 205	MVN609	0,0041	Passed	0,3200	Passed
Amherst Regional High School	Room 207	MVN610	0,0067	Exceeds Limit	0,4900	Passed
Amherst Regional High School	Room 202	MVN611	0,0390	Exceeds Limit	0,7800	Passed
Amherst Regional High School	Room 211	MVN612	0,0063	Exceeds Limit	0,3800	Passed
Amherst Regional High School	Room 3001	MVN613	0,0021	Passed	0,2300	Passed
Amherst Regional High School	Mech Gym	MVN614	0,0016	Passed	0,2400	Passed
Amherst Regional High School	Room 2500	MVN615	0,0005	Passed	0,0620	Passed
Amherst Regional High School	Girls Green Sink #2	NFR329	0,0014	Passed	0,2600	Passed
Amherst Regional High School	Girls Green Sink #1	NFR330	0,0034	Passed	0,4000	Passed
Amherst Regional High School	Girls Green Sink #4	NFR331	0,0021	Passed	0,2200	Passed
Amherst Regional High School	Girls Green Sink #3	NFR332	0,0023	Passed	0,2300	Passed
Amherst Regional High School	Teacher Green Sink	NFR333	0,0017	Passed	0,2800	Passed
Amherst Regional High School	Janitor Sink Yellow Section	NFR334	0,0020	Passed	0,2000	Passed
Amherst Regional High School	Trans Gen Sink by Office	NFR335	0,0006	Passed	0,1400	Passed
Amherst Regional High School	Nurse Office Sink	NFR336	0,0000	Passed	0,0510	Passed
Amherst Regional High School	Boys Blue Sink #1	NFR337	0,0008	Passed	0,0600	Passed
Amherst Regional High School	Boys Blue Sink #2	NFR338	0,0008	Passed	0,0560	Passed
Amherst Regional High School	Girls Blue Sink #3	NFR339	0,0000	Passed	0,0490	Passed
Amherst Regional High School	Girls Blue Sink #4	NFR340	0,0005	Passed	0,0880	Passed
Amherst Regional High School	Girls Blue Sink #2	NFR341	0,0005	Passed	0,0530	Passed
Amherst Regional High School	Girls Blue Sink #1	NFR342	0,0006	Passed	0,0580	Passed
Amherst Regional High School	Teach 115 Blue	NFR343	0,0008	Passed	0,2100	Passed
Amherst Regional High School	Main Office Bathroom Sink	NFR344	0,0005	Passed	0,0940	Passed
Amherst Regional High School	Stage Washroom	NFR345	0,0010	Passed	0,0480	Passed
Amherst Regional High School	Café Boys Sink #3	NFR346	0,0000	Passed	0,0290	Passed
Amherst Regional High School	Café Boys Sink #1	NFR347	0,0005	Passed	0,0360	Passed
Amherst Regional High School	Café Boys Sink #2	NFR348	0,0000	Passed	0,0320	Passed
Amherst Regional High School	Boys Change Room A	NFR349	0,0005	Passed	0,0480	Passed
Amherst Regional High School	Boys Change Room B	NFR350	0,0000	Passed	0,0370	Passed
Amherst Regional High School	Café Girls #1	NFR351	0,0026	Passed	0,0880	Passed
Amherst Regional High School	Café Girls #2	NFR352	0,0007	Passed	0,0570	Passed
Amherst Regional High School	Café Girls #3	NFR353	0,0007	Passed	0,0530	Passed
Amherst Regional High School	Stage Prep #1	NFR354	0,0000	Passed	0,0370	Passed
Amherst Regional High School	Stage Prep #2	NFR355	0,0000	Passed	0,0310	Passed
Amherst Regional High School	Janitor Sink Blue	NFR356	0,0022	Passed	0,2600	Passed
Amherst Regional High School	Special Needs Sink	NFR357	0,0011	Passed	0,4300	Passed
Amherst Regional High School	Staff Blue Sink #1	NFR358	0,0030	Passed	0,1800	Passed
Amherst Regional High School	Boys Blue Sink #3	NFR359	0,0008	Passed	0,0560	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Amherst Regional High School	Boys Blue Sink #4	NFR360	0,0006	Passed	0,0540	Passed
Amherst Regional High School	Janitor Sink Tess Room	NFR361	0,0000	Passed	0,0340	Passed
Amherst Regional High School	Room 142	NFR362	0,0011	Passed	0,0810	Passed
Amherst Regional High School	Café Worker Sink	NFR363	0,0006	Passed	0,0690	Passed
Amherst Regional High School	Café Hand Sink	NFR364	0,0006	Passed	0,0520	Passed
Amherst Regional High School	Maintenance Washroom Sink	NFR365	0,0005	Passed	0,0420	Passed
Amherst Regional High School	Room 144	NFR366	0,0006	Passed	0,0520	Passed
Amherst Regional High School	Girls Locker Sink	NFR367	0,0016	Passed	0,1100	Passed
Amherst Regional High School	Girls Locker Sink B	NFR368	0,0051	Exceeds Limit	0,3700	Passed
Amherst Regional High School	Staff Blue Sink #2	NFR369	0,0031	Passed	0,1600	Passed
Amherst Regional High School	Boys Green Bath Sink #1	NFR370	0,0025	Passed	0,2400	Passed
Amherst Regional High School	Boys Green Bath Sink #2	NFR371	0,0020	Passed	0,2200	Passed
Amherst Regional High School	Boys Green Bath Sink #3	NFR372	0,0020	Passed	0,2300	Passed
Amherst Regional High School	Boys Green Bath Sink #4	NFR373	0,0018	Passed	0,2200	Passed
Amherst Regional High School	Guidance Sink	NFR374	0,0006	Passed	0,0680	Passed
Amherst Regional High School	Custodial/Office	NFR375	0,0006	Passed	0,0910	Passed
Amherst Regional High School	2102 Sink #1	NHD717	0,0029	Passed	0,2400	Passed
Amherst Regional High School	2102 Sink #2	NHD718	0,0031	Passed	0,2300	Passed
Amherst Regional High School	2102 Sink #3	NHD719	0,0029	Passed	0,2300	Passed
Amherst Regional High School	2102 Sink #4	NHD720	0,0028	Passed	0,2300	Passed
Amherst Regional High School	2104 Sink #1	NHD721	0,0028	Passed	0,2400	Passed
Amherst Regional High School	2104 Sink #2	NHD722	0,0027	Passed	0,2300	Passed
Amherst Regional High School	2104 Sink #3	NHD723	0,0028	Passed	0,2300	Passed
Amherst Regional High School	2104 Sink #4	NHD724	0,0029	Passed	0,2300	Passed
Amherst Regional High School	2320	NHD725	0,0028	Passed	0,2300	Passed
Amherst Regional High School	2311	NHD726	0,0028	Passed	0,2400	Passed
Amherst Regional High School	2304 Sink #1	NHD727	0,0033	Passed	0,1800	Passed
Amherst Regional High School	2304 Sink #2	NHD728	0,0033	Passed	0,1700	Passed
Amherst Regional High School	2304 Sink #3	NHD729	0,0030	Passed	0,1700	Passed
Amherst Regional High School	2304 Sink #4	NHD730	0,0030	Passed	0,1700	Passed
Amherst Regional High School	2302 Sink #1	NHD731	0,0029	Passed	0,1700	Passed
Amherst Regional High School	2302 Sink #2	NHD732	0,0030	Passed	0,1700	Passed
Amherst Regional High School	2302 Sink #3	NHD733	0,0031	Passed	0,1700	Passed
Amherst Regional High School	2302 Sink #4	NHD734	0,0035	Passed	0,1800	Passed
Amherst Regional High School	2110	NHD735	0,0028	Passed	0,3100	Passed
Amherst Regional High School	2011	NHD736	0,0029	Passed	0,2300	Passed
Amherst Regional High School	Trades Building Janitor Sink	NHD737	0,0017	Passed	0,4500	Passed
Amherst Regional High School	Trades Building Bathroom Sink	NHD738	0,0015	Passed	0,4000	Passed
Bible Hill Consolidated	Kitchen Tray Washing Tap, T5	MQE325	0,0015	Passed	0,2000	Passed
Bible Hill Consolidated	Kitchen Main Sink, T7	MQE326	0,0000	Passed	0,2200	Passed
Bible Hill Consolidated	Recycle Room 108 Tap, T11	MQE327	0,0000	Passed	0,2300	Passed
Bible Hill Consolidated	Fountain by Wash Area 112, F1	MQE328	0,0000	Passed	0,1900	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bible Hill Consolidated	Learning Centre Room 116 Tap, T17	MQE329	0,0000	Passed	0,1500	Passed
Bible Hill Consolidated	Staff Room 119 Tap, T18	MQE330	0,0000	Passed	0,1100	Passed
Bible Hill Consolidated	Classroom 120 Tap, T21	MQE331	0,0000	Passed	0,1400	Passed
Bible Hill Consolidated	Classroom 124 Tap, T22	MQE332	0,0000	Passed	0,1400	Passed
Bible Hill Consolidated	Classroom 123 Tap, T35	MQE333	0,0000	Passed	0,1800	Passed
Bible Hill Consolidated	Classroom 127 Tap, T36	MQE334	0,0000	Passed	0,2000	Passed
Bible Hill Consolidated	Classroom 132 Tap 27	MQE335	0,0000	Passed	0,2300	Passed
Bible Hill Consolidated	Classroom 131 Tap, T29	MQE336	0,0000	Passed	0,2200	Passed
Bible Hill Consolidated	Classroom 136 Tap, T28	MQE337	0,0000	Passed	0,1800	Passed
Bible Hill Consolidated	Classroom 135 Tap, T30	MQE338	0,0000	Passed	0,2600	Passed
Bible Hill Consolidated	Classroom 144 Tap, T37	MQE339	0,0000	Passed	0,2300	Passed
Bible Hill Consolidated	Classroom Room 148 Tap, T38	MQE340	0,0000	Passed	0,2500	Passed
Bible Hill Consolidated	Classroom 143 Tap, T33	MQE341	0,0005	Passed	0,1900	Passed
Bible Hill Consolidated	Classroom 147 Tap, T34	MQE342	0,0006	Passed	0,2300	Passed
Bible Hill Junior High School	Metal Shop (BM), F7	MOY682	0,0200	Exceeds Limit	0,4300	Passed
Bible Hill Junior High School	Cafeteria, F2	MOY684	0,0086	Exceeds Limit	0,7900	Passed
Bible Hill Junior High School	Main Kitchen Sink, T14	MOY685	0,1400	Exceeds Limit	0,3700	Passed
Bible Hill Junior High School	Kitchen Sink near Dishwasher, T15	MOY686	0,0059	Exceeds Limit	0,7600	Passed
Bible Hill Junior High School	Main Fl. Across from Room 103, F3	MOY687	0,0000	Passed	0,2000	Passed
Bible Hill Junior High School	Upper FS Room 210 Hall Wall, T29	MOY688	0,0100	Exceeds Limit	0,6100	Passed
Bible Hill Junior High School	Upper FS Room 210 Far Left, T28	MOY689	0,0120	Exceeds Limit	0,6400	Passed
Bible Hill Junior High School	Upper FS Room 210, Mid Left, T30	MOY690	0,0110	Exceeds Limit	0,5000	Passed
Bible Hill Junior High School	Upper FS Room 210, Mid Right, T31	MOY691	0,0092	Exceeds Limit	0,6900	Passed
Bible Hill Junior High School	Upper FS Room 210, Far Right, T32	MOY692	0,1500	Exceeds Limit	0,3100	Passed
Bible Hill Junior High School	Near FS Upstairs 210, F4	MOY693	0,0000	Passed	0,4100	Passed
Bible Hill Junior High School	Kitchen Room 209, T34	MOY694	0,0460	Exceeds Limit	0,6000	Passed
Bible Hill Junior High School	Across from Rm 203, F5	MOY695	0,0024	Passed	1,2000	Passed
Bible Hill Junior High School	Staff Room Kitchen Upstairs, T51	MOY696	0,0140	Exceeds Limit	0,8300	Passed
Bible Hill Junior High School	Main Floor by Rm 110, F1	MVN616	0,0150	Exceeds Limit	1,1000	Passed
Brookfield Elementary School	Room 5 Kitchen T5	MOP210	0,0570	Exceeds Limit	1,3000	Passed
Brookfield Elementary School	Sink, T4	MOP211	0,0720	Exceeds Limit	2,9000	Exceeds Limit
Brookfield Elementary School	Cafeteria (for BP), T7	MOP212	0,0290	Exceeds Limit	2,1000	Exceeds Limit
Brookfield Elementary School	Staff Rm Kitchen, T17	MOP213	0,0140	Exceeds Limit	3,6000	Exceeds Limit
Brookfield Elementary School	New Fountain by Gym, F2	MOP214	0,0009	Passed	0,8600	Passed
Brookfield Elementary School	New Fountain Upstairs, F3	MOP215	0,0000	Passed	0,7000	Passed
Brookfield Elementary School	LC Room 32 Sink on Left, T27	MOP216	0,3400	Exceeds Limit	3,4000	Exceeds Limit
Brookfield Elementary School	LC Room 32 Sink in Mid, T28	MOP217	0,1700	Exceeds Limit	3,6000	Exceeds Limit
Brookfield Elementary School	LC Room 32 Kitchen RT Wall, T29	MOP218	0,0680	Exceeds Limit	2,5000	Exceeds Limit
Brookfield Elementary School	LC Room 32 Kitchen by Dr RM 33, T30	MOP219	0,2700	Exceeds Limit	3,4000	Exceeds Limit
Central Colchester Junior High School	Room 48 Kit Tap Back of Tech Shop, T2	MVH514	0,0160	Exceeds Limit	0,2000	Passed
Central Colchester Junior High School	Kitchen Main Sink Tap, T9	MVH515	0,0074	Exceeds Limit	0,4800	Passed
Central Colchester Junior High School	Kit Three Compartment Sink Tap, T11	MVH516	0,0290	Exceeds Limit	0,4800	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Central Colchester Junior High School	Kitchen Single Sink Tap, T12	MVH517	0,0190	Exceeds Limit	0,7900	Passed
Central Colchester Junior High School	Cooking Lab Tap on Left, T14	MVH518	0,0011	Passed	0,3600	Passed
Central Colchester Junior High School	Cooking Lab Tap on Right, T15	MVH519	0,0075	Exceeds Limit	0,3300	Passed
Central Colchester Junior High School	Sewing Lab Tap on Wall, T16	MVH520	0,0200	Exceeds Limit	0,3100	Passed
Central Colchester Junior High School	Sewing Lab Tap by Washer, T57	MVH521	0,0045	Passed	0,2200	Passed
Central Colchester Junior High School	Kit Tap Off of Library, T20	MVH522	0,0410	Exceeds Limit	0,3900	Passed
Central Colchester Junior High School	Fountain by Main Office, F1	MVH523	0,0100	Exceeds Limit	0,5700	Passed
Central Colchester Junior High School	Room 22 Learning Centre Kit Tap, T27	MVH524	0,0069	Exceeds Limit	0,4700	Passed
Central Colchester Junior High School	Staff Room Kitchen Tap on Right, T31	MVH525	0,0140	Exceeds Limit	0,4100	Passed
Central Colchester Junior High School	Staff Room Kitchen Tap on Left, T32	MVH526	0,0250	Exceeds Limit	0,4500	Passed
Central Colchester Junior High School	Fountain Low Floor By Boys Washroom, F2	MVH527	0,0140	Exceeds Limit	0,2400	Passed
Central Colchester Junior High School	Fountain Upper Floor by Boys Washroom, F3	MVH528	0,0300	Exceeds Limit	0,3400	Passed
Chiganois Elementary School	Staff Rm Kitchen, T1	MOP470	0,0100	Exceeds Limit	0,0960	Passed
Chiganois Elementary School	Learning Centre Kitchen Sink, T2	MOP471	0,0098	Exceeds Limit	0,1900	Passed
Chiganois Elementary School	Pre-Primary Kitchen Sink, T5	MOP472	0,0100	Exceeds Limit	0,3200	Passed
Chiganois Elementary School	Kitchen Sink to Left, T6	MOP473	0,0038	Passed	0,1200	Passed
Chiganois Elementary School	Kitchen Sink in Middle, T7	MOP474	0,0060	Exceeds Limit	0,1700	Passed
Chiganois Elementary School	Kitchen Sink to Right, T8	MOP475	0,0092	Exceeds Limit	0,0890	Passed
Chiganois Elementary School	Fountain by Boys Washroom, F1	MOP476	0,0013	Passed	0,9900	Passed
Chiganois Elementary School	Fountain by Girls Washroom, F2	MOP477	0,0250	Exceeds Limit	0,5900	Passed
Cobequid Consolidated Elementary School	Staff Rm Kitchen Sink, T2	MRG577	0,0067	Exceeds Limit	0,4900	Passed
Cobequid Consolidated Elementary School	Fountain, F1	MRG578	0,0014	Passed	0,3400	Passed
Cobequid Consolidated Elementary School	Kitchen Sink, T6	MRG579	0,0088	Exceeds Limit	0,3800	Passed
Cobequid District Elementary School	Janitors Room Sink, T10	LDZ920	0,0620	Exceeds Limit	0,1200	Passed
Cobequid District Elementary School	Girls Washroom Downstairs 1st, T13	LDZ921	0,0200	Exceeds Limit	0,1600	Passed
Cobequid District Elementary School	Girls Washroom Downstairs 2nd, T12	LDZ922	0,0110	Exceeds Limit	0,2200	Passed
Cobequid District Elementary School	Girls Washroom Downstairs 3rd, T11	LDZ923	0,0190	Exceeds Limit	0,2400	Passed
Cobequid District Elementary School	Fountain Downstairs by Girls Washroom, F2	LDZ924	0,0088	Exceeds Limit	0,1700	Passed
Cobequid District Elementary School	Boys Washroom Downstairs 1st, T14	LDZ925	0,0210	Exceeds Limit	0,1800	Passed
Cobequid District Elementary School	Boys Washroom Downstairs 2nd, T15	LDZ926	0,0170	Exceeds Limit	0,1700	Passed
Cobequid District Elementary School	Boys Washroom Downstairs 3rd, T16	LDZ927	0,0220	Exceeds Limit	0,2000	Passed
Cobequid District Elementary School	Fountain in Room 114, F3	LDZ928	0,0110	Exceeds Limit	0,2600	Passed
Cobequid District Elementary School	Tap in Room 114, T17	LDZ929	0,0050	Passed	0,1800	Passed
Cobequid District Elementary School	Handicap Washroom Downstairs, T18	LDZ930	0,0037	Passed	0,7100	Passed
Cobequid District Elementary School	Pre-Primary Kitchen Tap Rm 119, T19	LDZ931	0,0007	Passed	0,3200	Passed
Cobequid District Elementary School	Kitchen Tap in Principals Office, T20	LDZ932	0,1000	Exceeds Limit	0,2600	Passed
Cobequid District Elementary School	Staff Washroom Tap Upstairs, T9	LDZ933	0,0029	Passed	0,0970	Passed
Cobequid District Elementary School	Girls Washroom Upstairs 1st, T3	LDZ934	0,0095	Exceeds Limit	0,1400	Passed
Cobequid District Elementary School	Girls Washroom Upstairs 2nd, T4	LDZ935	0,0200	Exceeds Limit	0,1300	Passed
Cobequid District Elementary School	Girls Washroom Upstairs 3rd, T5	LDZ936	0,0490	Exceeds Limit	0,1400	Passed
Cobequid District Elementary School	Boys Washroom Upstairs 1st, T6	LDZ937	0,0110	Exceeds Limit	0,2000	Passed
Cobequid District Elementary School	Boys Washroom Upstairs 2nd, T7	LDZ938	0,0150	Exceeds Limit	0,2300	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cobequid District Elementary School	Boys Washroom Upstairs 3rd, T8	LDZ939	0,0590	Exceeds Limit	0,3300	Passed
Cobequid District Elementary School	New Fountain Upstairs, F1	LDZ9441	0,0000	Passed	0,2200	Passed
Cobequid District Elementary School	Staff Room Kitchen Tap, T1	LDZ945	0,0068	Exceeds Limit	0,1500	Passed
Cobequid District Elementary School	Handicap Washroom Upstairs, F1	LDZ946	0,0032	Passed	0,5800	Passed
Cobequid District Elementary School	Raw Water in Boiler Room	LDZ947	0,0000	Passed	0,0020	Passed
Cobequid District Elementary School	Room 114 Kitchen Tap, T17	NBU134	0,0035	Passed	0,1100	Passed
Cobequid Educational Centre	Main Office by Kitchen Tap MFP1, T4	MXS676	0,0016	Passed	0,1500	Passed
Cobequid Educational Centre	Fountain by Room 1 MFP1, F1	MXS677	0,0110	Exceeds Limit	0,2600	Passed
Cobequid Educational Centre	Fountain by Room 6 MFP1, F1	MXS678	0,0000	Passed	0,0900	Passed
Cobequid Educational Centre	Fountain by Room 10 MFP1, F3	MXS679	0,0017	Passed	0,3700	Passed
Cobequid Educational Centre	Special Needs Room 11 Kitchen Tap MFP1, T28	MXS680	0,0000	Passed	0,0930	Passed
Cobequid Educational Centre	Nurses Station Kitchen Tap MFP1, T33	MXS681	0,0020	Passed	0,3100	Passed
Cobequid Educational Centre	Fountain by Room 24 MFP1, F4	MXS682	0,0000	Passed	0,1900	Passed
Cobequid Educational Centre	Fountain by Room 20 MFP1, F5	MXS683	0,0000	Passed	0,2100	Passed
Cobequid Educational Centre	Music Room 97 Kitchen Sink MFP1, T45	MXS684	0,0019	Passed	0,3200	Passed
Cobequid Educational Centre	Lab Storage MFP1, T25	MXS685	0,0042	Passed	0,2200	Passed
Cobequid Educational Centre	Fountain MY Room 15 MFP1, F6	MXS686	0,0028	Passed	1,1000	Passed
Cobequid Educational Centre	CEP Kitchen Double Sink Tap MFP1, T49	MXS687	0,0260	Exceeds Limit	1,6000	Passed
Cobequid Educational Centre	CEP Kitchen Tap by Sprayer MFP1, T50	MXS688	0,0010	Passed	0,1900	Passed
Cobequid Educational Centre	CEP Kitchen Island Sink Tap MFP1, T51	MXS689	0,0000	Passed	0,1300	Passed
Cobequid Educational Centre	CEP Kitchen Pot Fill by Stove MFP1, T53	MXS690	0,0026	Passed	0,2900	Passed
Cobequid Educational Centre	Café Rm 13 Count Sink Tap MFP, T52	MXS691	0,0009	Passed	0,0790	Passed
Cobequid Educational Centre	Library Kitchen Sink in Office TFP1, T64	MXS863	0,0045	Passed	0,6600	Passed
Cobequid Educational Centre	Fountain by Room 25, TPF1, F7	MXS864	0,0000	Passed	0,1000	Passed
Cobequid Educational Centre	2nd Flr, Fountain by Stud. Coun. FTP1, F8	MXS865	0,0015	Passed	0,3100	Passed
Cobequid Educational Centre	Room 255 Office Sink TFP1, T95	MXS866	0,0720	Exceeds Limit	0,2500	Passed
Cobequid Educational Centre	Fountain by Room 34, TFP1, T9	MXS867	0,0000	Passed	0,0780	Passed
Cobequid Educational Centre	Fountain by Room 48, TFP1, F10	MXS868	0,0000	Passed	0,1000	Passed
Cobequid Educational Centre	Fountain by Room 44B TFP1, F11	MXS869	0,0000	Passed	0,1900	Passed
Cobequid Educational Centre	Fountain by Rom 39 TFP1, F12	MXS870	0,0023	Passed	0,9800	Passed
Cobequid Educational Centre	Room 236 T185	MXS871	0,0036	Passed	0,1100	Passed
Cobequid Educational Centre	Fountain by Room 104 LFP2, F13	MXS892	0,0007	Passed	0,1200	Passed
Cobequid Educational Centre	Room 108 Kitchen Tap LFP2, T198	MXS893	0,0045	Passed	0,1800	Passed
Cobequid Educational Centre	Room 111 Corner Tap LFP2, T200	MXS894	0,0550	Exceeds Limit	0,1500	Passed
Cobequid Educational Centre	Fountain by Room 112, LFP2, F14	MXS895	0,0000	Passed	0,2100	Passed
Cobequid Educational Centre	Room 140 by Gym Bar Tap LFP2, T209	MXS896	0,0031	Passed	0,4200	Passed
Cobequid Educational Centre	Fountain by Room 140 LFP2, F15	MXS897	0,0000	Passed	0,2900	Passed
Cobequid Educational Centre	Room 212 Old Staff Room Kit.Tap UFP2, T12	MXT072	0,0060	Exceeds Limit	0,1300	Passed
Cobequid Educational Centre	Room 207 News Room Kit Tap UFP2, T215	MXT073	0,0200	Exceeds Limit	0,2700	Passed
Cobequid Educational Centre	Fountain across from Cougar Cage UFP2, F16	MXT074	0,0037	Passed	0,1700	Passed
Cobequid Educational Centre	Room 216 Family Study, 1st on Lt Tap UFP2, T216	MXT075	0,0043	Passed	0,1600	Passed
Cobequid Educational Centre	Room 216 Family Study 2nd on Lt Tap UFP2, T217	MXT076	0,0014	Passed	0,1800	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cobequid Educational Centre	Room 216 Family Study 3rd on Lt Tap UFP2, T218	MXT077	0,0017	Passed	0,2100	Passed
Cobequid Educational Centre	Room 216 Family Study 4th on Lt Tap UFP2, T219	MXT078	0,0025	Passed	0,2400	Passed
Cobequid Educational Centre	Room 216 Family Study Last Tap on Rt UFP2, T220	MXT079	0,0022	Passed	0,2400	Passed
Cobequid Educational Centre	Room 231 Staff Room Kitchen Tap UFP2, T221	MXT080	0,0230	Exceeds Limit	0,1500	Passed
Cobequid Educational Centre	Room 219 Kitchen Tap UFP2, T222	MXT081	0,0170	Exceeds Limit	0,1900	Passed
Cobequid Educational Centre	Fountain by Room 223, UFP2, F17	MXT082	0,0020	Passed	0,2800	Passed
Cobequid Educational Centre	Room 223 Kitchen Tap UFP2, T223	MXT083	0,0300	Exceeds Limit	0,2000	Passed
Cobequid Educational Centre	Art Room 228 Front Kitchen Tap UFP2, T225	MXT084	0,0380	Exceeds Limit	0,2400	Passed
Cobequid Educational Centre	Art Room 228 1st on Lt Kitchen Tap, UFP2, T226	MXT085	0,2700	Exceeds Limit	0,1800	Passed
Cobequid Educational Centre	Art Room 228 2nd on Lt Kitchen Tap UFP2, T227	MXT086	0,0260	Exceeds Limit	0,1500	Passed
Cobequid Educational Centre	Art Room 228 Kitchen Tap on Rt UFP2, T228	MXT087	0,0077	Exceeds Limit	0,2300	Passed
Cobequid Educational Centre	Cafeteria Canteen UFP2, T229	MXT088	0,0270	Exceeds Limit	0,2900	Passed
Cobequid Educational Centre	Cafeteria Kitchen Tap on Lt UFP2, T230	MXT089	0,0033	Passed	0,1200	Passed
Cobequid Educational Centre	Cafeteria Kitchen Tap on Rt UFP2, T231	MXT090	0,0016	Passed	0,0960	Passed
Cobequid Educational Centre	Fountain by Girls Washroom LFP3, F18	MXT247	0,0006	Passed	0,2800	Passed
Cobequid Educational Centre	Fountain by Room 255, UFP3, F19	MXT290	0,0000	Passed	0,3700	Passed
Cobequid Educational Centre	Room 256 Lunch Room UFP3, T241	MXT291	0,0032	Passed	0,2400	Passed
Cumberland North Academy	Fountain by Gym	MVZ174	0,0000	Passed	0,0800	Passed
Cyrus Eaton Elementary School	Cafeteria Sink	MOP499	0,0041	Passed	0,0520	Passed
Cyrus Eaton Elementary School	Fountain - Gym	MOP500	0,0044	Passed	0,0750	Passed
Cyrus Eaton Elementary School	Principal's Office	MOP501	0,0023	Passed	0,0480	Passed
Cyrus Eaton Elementary School	Fountain by Washrooms	MOP502	0,0009	Passed	0,0700	Passed
Cyrus Eaton Elementary School	Staff Room	MOP503	0,0010	Passed	0,0390	Passed
Cyrus Eaton Elementary School	Room #14	MOP504	0,0310	Exceeds Limit	0,0690	Passed
Cyrus Eaton Elementary School	Room #2	MOP505	0,0019	Passed	0,0550	Passed
Cyrus Eaton Elementary School	Room #3	MOP506	0,0051	Exceeds Limit	0,0460	Passed
Cyrus Eaton Elementary School	Room #6	MOP507	0,0018	Passed	0,0480	Passed
Cyrus Eaton Elementary School	Room #7	MOP508	0,0014	Passed	0,0580	Passed
Cyrus Eaton Elementary School	Fountain - Upper Hall	MOP509	0,0026	Passed	0,0630	Passed
Cyrus Eaton Elementary School	Girls Locker Room	NFC496	0,0041	Passed	0,0620	Passed
Cyrus Eaton Elementary School	Boys Locker Room	NFC497	0,0008	Passed	0,0390	Passed
Cyrus Eaton Elementary School	Kitchen	NFC498	0,0054	Exceeds Limit	0,0810	Passed
Cyrus Eaton Elementary School	Custodial	NFC499	0,0000	Passed	0,0440	Passed
Cyrus Eaton Elementary School	Principals #1	NFC500	0,0014	Passed	0,0490	Passed
Cyrus Eaton Elementary School	Room #8 Sink #1	NFC501	0,0006	Passed	0,0460	Passed
Cyrus Eaton Elementary School	Boys #1	NFC502	0,0010	Passed	0,0480	Passed
Cyrus Eaton Elementary School	Boys #2	NFC503	0,0000	Passed	0,0410	Passed
Cyrus Eaton Elementary School	Girls #1	NFC504	0,0012	Passed	0,0690	Passed
Cyrus Eaton Elementary School	Girls #2	NFC505	0,0007	Passed	0,0430	Passed
Cyrus Eaton Elementary School	Staff Room	NFC506	0,0006	Passed	0,0430	Passed
Cyrus Eaton Elementary School	Room #8 Sink #2	NFC507	0,0000	Passed	0,0410	Passed
Cyrus Eaton Elementary School	Room 4	NFC508	0,0022	Passed	0,0600	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cyrus Eaton Elementary School	Room 5	NFC509	0,0013	Passed	0,0550	Passed
Cyrus Eaton Elementary School	Room 9	NFC510	0,0010	Passed	0,0550	Passed
Debert Elementary School	Staff Room 2nd Floor	LDD577	0,0009	Passed	0,0590	Passed
Debert Elementary School	Fountain In Lower Level	LDD579	0,0008	Passed	0,1200	Passed
Debert Elementary School	Fountain 2nd Floor	LDD580	0,0000	Passed	0,0730	Passed
Debert Elementary School	Fountain by Gym	LDD581	0,0023	Passed	0,2000	Passed
Debert Elementary School	Kitchen Tap	LDD582	0,0075	Exceeds Limit	0,1500	Passed
Debert Elementary School	Kitchen Handwashing Tap	LDD583	0,0680	Exceeds Limit	0,1200	Passed
Debert Elementary School	Pre-Primary Kitchen Tap	MVZ210	0,0087	Exceeds Limit	0,0490	Passed
Dr. W.A. MacLeod Consolidated School	Room 104 Classroom Sink A	MOY849	0,0210	Exceeds Limit	0,1900	Passed
Dr. W.A. MacLeod Consolidated School	Room 104 Classroom Sink B	MOY850	0,1500	Exceeds Limit	1,3000	Passed
Dr. W.A. MacLeod Consolidated School	Office Washroom	MOY851	0,0000	Passed	0,1200	Passed
Dr. W.A. MacLeod Consolidated School	Kitchen Sprayer	MOY852	0,0018	Passed	0,0750	Passed
Dr. W.A. MacLeod Consolidated School	Kitchen Sink A	MOY853	0,0920	Exceeds Limit	0,0110	Passed
Dr. W.A. MacLeod Consolidated School	Kitchen Sink B	MOY854	0,0130	Exceeds Limit	0,1600	Passed
Dr. W.A. MacLeod Consolidated School	Rm 107 Washroom Sink	MOY855	0,0012	Passed	0,1200	Passed
Dr. W.A. MacLeod Consolidated School	Rm 109 Washroom Sink A	MOY856	0,0280	Exceeds Limit	0,2600	Passed
Dr. W.A. MacLeod Consolidated School	Rm 109 Washroom Sink B	MOY857	0,0006	Passed	0,2800	Passed
Dr. W.A. MacLeod Consolidated School	Rm 110 Washroom Sink	MOY858	0,0000	Passed	0,0750	Passed
Dr. W.A. MacLeod Consolidated School	Rm 110 Sink	MOY859	0,0000	Passed	0,0600	Passed
Dr. W.A. MacLeod Consolidated School	Industrial Arts Rm	MOY860	0,0000	Passed	0,0750	Passed
Dr. W.A. MacLeod Consolidated School	Rm 215 Sink A	MOY861	0,1500	Exceeds Limit	2,5000	Exceeds Limit
Dr. W.A. MacLeod Consolidated School	Rm 215 Sink B	MOY862	0,1400	Exceeds Limit	1,9000	Passed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink A	MOY863	0,0000	Passed	0,0280	Passed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink B	MOY864	0,0000	Passed	0,1000	Passed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink C	MOY865	0,0000	Passed	0,1200	Passed
Dr. W.A. MacLeod Consolidated School	Family Studies Sink D	MOY866	0,0000	Passed	0,0930	Passed
Dr. W.A. MacLeod Consolidated School	Family Studies Class Sink	MOY867	0,0000	Passed	0,0840	Passed
Dr. W.A. MacLeod Consolidated School	Rm 207 Sink	MOY868	0,0009	Passed	0,2700	Passed
Dr. W.A. MacLeod Consolidated School	Staff Kitchen Sink	MOY869	0,0007	Passed	0,3000	Passed
Dr. W.A. MacLeod Consolidated School	Staff Washroom Sink A	MOY870	0,0000	Passed	0,0810	Passed
Dr. W.A. MacLeod Consolidated School	Staff Washroom Sink B	MOY871	0,0000	Passed	0,0860	Passed
Dr. W.A. MacLeod Consolidated School	Rm 204 Sink A	MOY872	0,2400	Exceeds Limit	0,3000	Passed
Dr. W.A. MacLeod Consolidated School	Rm 204 Sink B	MOY873	0,0520	Exceeds Limit	0,2700	Passed
Dr. W.A. MacLeod Consolidated School	Rm 203 Sink A	MOY874	0,0380	Exceeds Limit	0,5400	Passed
Dr. W.A. MacLeod Consolidated School	Rm 203 Sink B	MOY875	0,0550	Exceeds Limit	0,7000	Passed
Dr. W.A. MacLeod Consolidated School	Counsel Rm Washroom	MOY876	0,0073	Exceeds Limit	0,3100	Passed
Dr. W.A. MacLeod Consolidated School	Gym Girls Locker Room A	NFD447	0,0015	Passed	0,3300	Passed
Dr. W.A. MacLeod Consolidated School	Gym Girls Locker Room B	NFD448	0,0034	Passed	0,2900	Passed
Dr. W.A. MacLeod Consolidated School	Gym Boys Locker Room A	NFD449	0,0200	Exceeds Limit	0,4100	Passed
Dr. W.A. MacLeod Consolidated School	Gym Boys Locker Room B	NFD450	0,0170	Exceeds Limit	0,5000	Passed
Dr. W.A. MacLeod Consolidated School	1st Floor Girls Washroom A	NFD451	0,0000	Passed	0,0710	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dr. W.A. MacLeod Consolidated School	1st Floor Girls Washroom B	NFD452	0,0000	Passed	0,0690	Passed
Dr. W.A. MacLeod Consolidated School	1st Floor Girls Washroom C	NFD453	0,0000	Passed	0,0720	Passed
Dr. W.A. MacLeod Consolidated School	1st Floor Boys Washroom A	NFD454	0,0000	Passed	0,0700	Passed
Dr. W.A. MacLeod Consolidated School	1st Floor Boys Washroom B	NFD455	0,0000	Passed	0,0630	Passed
Dr. W.A. MacLeod Consolidated School	1st Floor Boys Washroom C	NFD456	0,0000	Passed	0,0730	Passed
Dr. W.A. MacLeod Consolidated School	Gym Girls Locker Room A	NFD457	0,0000	Passed	0,0740	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Girls Washroom A	NFD458	0,0000	Passed	0,0420	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Girls Washroom B	NFD459	0,0000	Passed	0,0390	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Girls Washroom C	NFD460	0,0000	Passed	0,0420	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom A	NFD461	0,0000	Passed	0,0340	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom B	NFD462	0,0000	Passed	0,0770	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom C	NFD463	0,0000	Passed	0,0460	Passed
Dr. W.A. MacLeod Consolidated School	2nd Floor Boys Washroom D	NFD464	0,0000	Passed	0,0590	Passed
Dr. W.A. MacLeod Consolidated School	Fountain Across from Rm 104	NFD465	0,0000	Passed	0,1400	Passed
Dr. W.A. MacLeod Consolidated School	Fountain Top Floor Beside Staff Room	NFD466	0,0000	Passed	0,1100	Passed
E. B. Chandler Junior High School	Wood Shop Sink #1	MPQ187	0,0000	Passed	0,4200	Passed
E. B. Chandler Junior High School	Wood Shop Sink #2	MPQ188	0,0110	Exceeds Limit	0,6000	Passed
E. B. Chandler Junior High School	Food Lab Sink #1	MPQ189	0,0020	Passed	0,5700	Passed
E. B. Chandler Junior High School	Food Lab Sink #2	MPQ190	0,0350	Exceeds Limit	0,5300	Passed
E. B. Chandler Junior High School	Food Lab Sink #3	MPQ191	0,0009	Passed	0,3700	Passed
E. B. Chandler Junior High School	Food Lab Sink #4	MPQ192	0,0560	Exceeds Limit	0,4600	Passed
E. B. Chandler Junior High School	Food Lab Sink #5	MPQ193	0,0006	Passed	0,4000	Passed
E. B. Chandler Junior High School	Food Lab Sink #6	MPQ194	0,0000	Passed	0,5100	Passed
E. B. Chandler Junior High School	Learning Centre	MPQ195	0,0000	Passed	0,2000	Passed
E. B. Chandler Junior High School	Cafeteria Sink #1	MPQ196	0,0000	Passed	0,0450	Passed
E. B. Chandler Junior High School	Cafeteria Sink #2	MPQ197	0,0008	Passed	0,0970	Passed
E. B. Chandler Junior High School	Staff Room	MPQ198	0,0006	Passed	0,3900	Passed
E. B. Chandler Junior High School	Fountain by Gym	MPQ199	0,0052	Exceeds Limit	0,2900	Passed
E. B. Chandler Junior High School	Music Room	MPQ200	0,0073	Exceeds Limit	0,4700	Passed
E. B. Chandler Junior High School	Fountain in Front Lobby	MPQ201	0,0042	Passed	0,3900	Passed
E. B. Chandler Junior High School	Art Room #1	MPQ202	0,0130	Exceeds Limit	0,4000	Passed
E. B. Chandler Junior High School	Art Room #2	MPQ203	0,0110	Exceeds Limit	0,3000	Passed
E. B. Chandler Junior High School	Fountain 2nd Floor	MPQ204	0,0073	Exceeds Limit	0,2900	Passed
E. B. Chandler Junior High School	Boys Locker #1	NEF548	0,0011	Passed	0,0970	Passed
E. B. Chandler Junior High School	Boys Locker #2	NEF549	0,0015	Passed	0,2100	Passed
E. B. Chandler Junior High School	Gym Office	NEF550	0,0000	Passed	0,0240	Passed
E. B. Chandler Junior High School	Girls Locker #1	NEF551	0,0000	Passed	0,0300	Passed
E. B. Chandler Junior High School	Girls Locker #2	NEF552	0,0000	Passed	0,0290	Passed
E. B. Chandler Junior High School	Room 122	NEF553	0,0043	Passed	0,0630	Passed
E. B. Chandler Junior High School	Room 123	NEF554	0,0007	Passed	0,0930	Passed
E. B. Chandler Junior High School	Learning Centre #1	NEF555	0,0000	Passed	0,0190	Passed
E. B. Chandler Junior High School	Learning Centre #2	NEF556	0,0000	Passed	0,0230	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
E. B. Chandler Junior High School	Staff #1	NEF557	0,0000	Passed	0,0240	Passed
E. B. Chandler Junior High School	Staff #2	NEF558	0,0000	Passed	0,0210	Passed
E. B. Chandler Junior High School	Lower Boys #1	NEF559	0,0000	Passed	0,0330	Passed
E. B. Chandler Junior High School	Lower Boys #2	NEF560	0,0000	Passed	0,0330	Passed
E. B. Chandler Junior High School	Lower Boys #3	NEF561	0,0000	Passed	0,0320	Passed
E. B. Chandler Junior High School	Lower Girls #1	NEF562	0,0000	Passed	0,0400	Passed
E. B. Chandler Junior High School	Lower Girls #2	NEF563	0,0000	Passed	0,0380	Passed
E. B. Chandler Junior High School	Lower Girls #3	NEF564	0,0000	Passed	0,0370	Passed
E. B. Chandler Junior High School	Lower Custodial	NEF565	0,0000	Passed	0,0290	Passed
E. B. Chandler Junior High School	Upper Boys #1	NEF566	0,0000	Passed	0,0330	Passed
E. B. Chandler Junior High School	Upper Boys #2	NEF567	0,0000	Passed	0,0620	Passed
E. B. Chandler Junior High School	Upper Boys #3	NEF568	0,0000	Passed	0,0340	Passed
E. B. Chandler Junior High School	Upper Girls #1	NEF569	0,0000	Passed	0,0370	Passed
E. B. Chandler Junior High School	Upper Girls #2	NEF570	0,0000	Passed	0,0370	Passed
E. B. Chandler Junior High School	Upper Girls #3	NEF571	0,0007	Passed	0,0500	Passed
E. B. Chandler Junior High School	Upper Custodial	NEF572	0,0000	Passed	0,0280	Passed
Elmsdale District Elementary School	Kitchen Sink Closer to Island	MSH296	0,0036	Passed	0,1400	Passed
Elmsdale District Elementary School	Kitchen Sink in Corner, T3	MSH297	0,0180	Exceeds Limit	0,1500	Passed
Elmsdale District Elementary School	Recycle Rm 136, T9	MSH298	0,0000	Passed	0,1100	Passed
Elmsdale District Elementary School	Fountain by Recycle Rm, F1	MSH299	0,0000	Passed	0,5400	Passed
Elmsdale District Elementary School	Rm 1451 Kitchen Tap, T14	MSH300	0,0010	Passed	0,0960	Passed
Elmsdale District Elementary School	Fountain by Main Entrance, F2	MSH301	0,0000	Passed	0,0850	Passed
Elmsdale District Elementary School	Rm 128 Kitchen Tap by Hall, T18	MSH302	0,0016	Passed	0,1000	Passed
Elmsdale District Elementary School	Rm 128 Tap in Kitchen, T19	MSH303	0,0012	Passed	0,1400	Passed
Elmsdale District Elementary School	Music Rm 129 Kitchen Tap, T16	MSH304	0,0013	Passed	0,0760	Passed
Elmsdale District Elementary School	Rm 111 Kitchen Tap, T17	MSH305	0,0016	Passed	0,1100	Passed
Elmsdale District Elementary School	Rm 114, Kitchen Tap, T22	MSH306	0,0009	Passed	0,1000	Passed
Elmsdale District Elementary School	Rm 113, Kitchen Tap 121	MSH307	0,0014	Passed	0,1100	Passed
Elmsdale District Elementary School	Rm 116, Kitchen Tap, T25	MSH308	0,0007	Passed	0,1000	Passed
Elmsdale District Elementary School	Rm 115, Kitchen Tap, T26	MSH309	0,0110	Exceeds Limit	0,1600	Passed
Elmsdale District Elementary School	Fountain Near Rm 115, F3	MSH310	0,0000	Passed	0,1500	Passed
Elmsdale District Elementary School	Rm 117, Kitchen Tap, T27	MSH311	0,0009	Passed	0,0830	Passed
Elmsdale District Elementary School	Rm 118, Kitchen Tap, T34	MSH312	0,0008	Passed	0,1800	Passed
Elmsdale District Elementary School	Rm 119, Kitchen Tap, T35	MSH313	0,0012	Passed	0,1100	Passed
Elmsdale District Elementary School	Rm 133, Kitchen Tap, T36	MSH314	0,0130	Exceeds Limit	0,6500	Passed
Elmsdale District Elementary School	Rm 112, Kitchen Tap, T37	MSH315	0,0000	Passed	0,0660	Passed
Elmsdale District Elementary School	Rm 109, Kitchen Tap, T39	MSH316	0,0013	Passed	0,1000	Passed
Elmsdale District Elementary School	Rm 107, Kitchen Tap, T41	MSH317	0,0007	Passed	0,0790	Passed
Elmsdale District Elementary School	Rm 110, Kitchen Tap, T43	MSH318	0,0000	Passed	0,0730	Passed
Elmsdale District Elementary School	Rm 105, Kitchen Tap, T45	MSH319	0,0019	Passed	0,0920	Passed
Elmsdale District Elementary School	Rm 108, Kitchen Tap, T46	MSH320	0,0012	Passed	0,0870	Passed
Elmsdale District Elementary School	Rm 103, Kitchen Tap, T48	MSH321	0,0068	Exceeds Limit	0,0880	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Elmsdale District Elementary School	Rm 106, Kitchen Tap, T47	MSH322	0,0013	Passed	0,0810	Passed
Elmsdale District Elementary School	Fountain Near Rm 103, F4	MSH323	0,0000	Passed	0,1400	Passed
Elmsdale District Elementary School	Rm 104, Kitchen Tap, T57	MSH324	0,0010	Passed	0,1000	Passed
Elmsdale District Elementary School	Rm 102, Kitchen Tap, T58	MSH325	0,0007	Passed	0,1500	Passed
Elmsdale District Elementary School	Rm 101, Kitchen Tap, T59	MSH326	0,0019	Passed	0,2000	Passed
Elmsdale District Elementary School	Learning Support Washroom 128.1, T20	NFR1000	0,0006	Passed	0,1200	Passed
Elmsdale District Elementary School	Custodial 114.2 Cust Floor Sink, T23	NFR1001	0,1800	Exceeds Limit	3,2000	Exceeds Limit
Elmsdale District Elementary School	Everyone Washroom 150.5, T24	NFR1002	0,0028	Passed	0,1400	Passed
Elmsdale District Elementary School	Boys Washroom Across from Class 117 Left Tap, T28	NFR1003	0,0007	Passed	0,1500	Passed
Elmsdale District Elementary School	Boys Washroom Across from Class 117 Mid Tap, T29	NFR1004	0,0007	Passed	0,1400	Passed
Elmsdale District Elementary School	Boys Washroom Across from Class 117 Right Tap, T30	NFR1005	0,0015	Passed	0,1500	Passed
Elmsdale District Elementary School	Girls Washroom Across From Class 117 Left Tap, T31	NFR1006	0,0007	Passed	0,1300	Passed
Elmsdale District Elementary School	Girls Washroom Across From Class 117 Mid Tap, T32	NFR1007	0,0006	Passed	0,1400	Passed
Elmsdale District Elementary School	Girls Washroom Across From Class 117 Right Tap, T33	NFR1008	0,0008	Passed	0,1400	Passed
Elmsdale District Elementary School	Staff Room 133, T36	NFR1009	0,0013	Passed	0,1500	Passed
Elmsdale District Elementary School	Staff Washroom, T36A	NFR1010	0,0000	Passed	0,1600	Passed
Elmsdale District Elementary School	Washroom 112.1, In Class 112 T38	NFR1011	0,0150	Exceeds Limit	0,2200	Passed
Elmsdale District Elementary School	Washroom 109.1 In Class 109, T40	NFR1012	0,0067	Exceeds Limit	0,1600	Passed
Elmsdale District Elementary School	Washroom 107.1 In Class 107, T42	NFR1013	0,0009	Passed	0,1100	Passed
Elmsdale District Elementary School	Washroom 110.1 In Class 110, T44	NFR1014	0,0009	Passed	0,0570	Passed
Elmsdale District Elementary School	Custodial Room by Class 103, T49	NFR1015	0,0013	Passed	0,1700	Passed
Elmsdale District Elementary School	Boys Washroom by Staff Washroom 157, Left Tap T50	NFR1016	0,0000	Passed	0,0950	Passed
Elmsdale District Elementary School	Boys Washroom by Staff Washroom 157, Left Tap T51	NFR1017	0,0005	Passed	0,1000	Passed
Elmsdale District Elementary School	Boys Washroom by Staff Washroom 157, Right Tap, T52	NFR1018	0,0019	Passed	0,1900	Passed
Elmsdale District Elementary School	Staff Washroom 157, T53	NFR1019	0,0000	Passed	0,1200	Passed
Elmsdale District Elementary School	Girls Washroom by Staff Washroom 157, Left Tap, T54	NFR1020	0,0012	Passed	0,1700	Passed
Elmsdale District Elementary School	Girls Washroom by Staff Washroom 157, Mid Tap, T55	NFR1021	0,0000	Passed	0,1300	Passed
Elmsdale District Elementary School	Girls Washroom by Staff Washroom 157, Right Tap, T56	NFR1022	0,0000	Passed	0,1100	Passed
Elmsdale District Elementary School	Kitchen Sprayer Sink, T4	NFR989	0,0580	Exceeds Limit	0,8500	Passed
Elmsdale District Elementary School	Kitchen Handwash Sink, T5	NFR990	0,0098	Exceeds Limit	0,1700	Passed
Elmsdale District Elementary School	Gym Office 135.8 ER, T6	NFR991	0,0077	Exceeds Limit	0,1700	Passed
Elmsdale District Elementary School	Girls Locker Room Washroom, T7	NFR992	0,0000	Passed	0,1300	Passed
Elmsdale District Elementary School	Boys Locker Room Washroom T8	NFR993	0,0000	Passed	0,1500	Passed
Elmsdale District Elementary School	Girls Washroom by Recycle Room Left Tap, T10	NFR994	0,0007	Passed	0,0990	Passed
Elmsdale District Elementary School	Girls Washroom by Recycle Room Right Tap, T11	NFR995	0,0012	Passed	0,1300	Passed
Elmsdale District Elementary School	Boys Washroom by Recycle Room Left Tap, T12	NFR996	0,0018	Passed	0,1000	Passed
Elmsdale District Elementary School	Boys Washroom by Recycle Room Left Tap, T13	NFR997	0,0005	Passed	0,1000	Passed
Elmsdale District Elementary School	Administrative 150 Washroom, T15	NFR998	0,0000	Passed	0,1800	Passed
Elmsdale District Elementary School	Music Room 129, T16	NFR999	0,0019	Passed	0,1000	Passed
Elmsdale District Elementary School	Kitchen Sink in Island, T1	NSH295	0,0008	Passed	0,0870	Passed
Enfield District Elementary	Janitor Room 144, T1	NNA793	0,0140	Exceeds Limit	0,3200	Passed
Enfield District Elementary	Staff Washroom, 142.3 - T2	NNA794	0,0081	Exceeds Limit	0,3500	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Enfield District Elementary	Washroom 142.4 - T3	NNA795	0,0081	Exceeds Limit	0,3400	Passed
Enfield District Elementary	Staff Room Kitchen Tap, Room 142 - T4	NNA796	0,0000	Passed	0,1100	Passed
Enfield District Elementary	Recycle Rm 147 - T5	NNA797	0,0180	Exceeds Limit	0,6400	Passed
Enfield District Elementary	Music Room 118 - T6	NNA798	0,0013	Passed	0,3800	Passed
Enfield District Elementary	Female Washroom off Gym Room 119.8 - T7	NNA799	0,7000	Exceeds Limit	6,2000	Exceeds Limit
Enfield District Elementary	Gym Teachers Office Washroom 119.2 - T9	NNA800	0,0032	Passed	0,3300	Passed
Enfield District Elementary	Fountain by Gym #1	NNA801	0,0076	Exceeds Limit	4,0000	Exceeds Limit
Enfield District Elementary	Classroom 116 Kitchen Tap, T10	NNA802	0,0057	Exceeds Limit	0,8500	Passed
Enfield District Elementary	Boys Washroom 145 Left Tap - T11	NNA803	0,0007	Passed	0,0820	Passed
Enfield District Elementary	Girls Washroom 143 Left Tap - T13	NNA804	0,0012	Passed	0,0810	Passed
Enfield District Elementary	Girls Washroom 143 Right Tap - T14	NNA805	0,0011	Passed	0,0760	Passed
Enfield District Elementary	Kitchen Room 115.1 Kitchen Tap - T15	NNA806	0,0005	Passed	0,0570	Passed
Enfield District Elementary	Kitchen Room 115.1 Handwash Tap - T16	NNA807	0,0038	Passed	0,3100	Passed
Enfield District Elementary	Kitchen Room 115.1 Double Sink Tap - T17	NNA808	0,0068	Exceeds Limit	0,0730	Passed
Enfield District Elementary	Kitchen Room 115.1 Sprayer - T18	NNA809	0,6600	Exceeds Limit	1,1000	Passed
Enfield District Elementary	Fountain in Cafeteria - F2	NNA810	0,0000	Passed	0,4800	Passed
Enfield District Elementary	Custodian Room 135 Tap - T19	NNA811	0,0013	Passed	0,1600	Passed
Enfield District Elementary	Sick Room Tap 130.3 - Tap - T20	NNA812	0,0024	Passed	0,3300	Passed
Enfield District Elementary	Office Washroom 130.4 Tap - T22	NNA813	0,0025	Passed	0,4400	Passed
Enfield District Elementary	Classroom 107 Kitchen Tap - T23	NNA814	0,0061	Exceeds Limit	0,7000	Passed
Enfield District Elementary	Classroom 108 Kitchen Tap - T24	NNA815	0,0026	Passed	0,2700	Passed
Enfield District Elementary	Classroom 109 - T25	NNA816	0,0068	Exceeds Limit	3,0000	Exceeds Limit
Enfield District Elementary	Classroom 110 - T26	NNA817	0,0019	Passed	0,4900	Passed
Enfield District Elementary	Washroom 137 - T27	NNA818	0,0800	Exceeds Limit	0,7000	Passed
Enfield District Elementary	Female Washroom 134 Left Tap - T28	NNA819	0,0011	Passed	0,1100	Passed
Enfield District Elementary	Female Washroom 134 Middle Tap - T29	NNA820	0,0000	Passed	0,0850	Passed
Enfield District Elementary	Female Washroom 134 Right Tap - T30	NNA821	0,0022	Passed	0,1300	Passed
Enfield District Elementary	Male Washroom 135 Left Tap - T31	NNA822	0,0010	Passed	0,1400	Passed
Enfield District Elementary	Male Washroom 135 Middle Tap - T32	NNA823	0,0059	Exceeds Limit	0,2800	Passed
Enfield District Elementary	Male Washroom 135 Right Tap - T33	NNA824	0,0015	Passed	0,1300	Passed
Enfield District Elementary	Fountain by Washroom 135 - F3	NNA825	0,0009	Passed	0,3800	Passed
Enfield District Elementary	Classroom 112 Kitchen Tap - T34	NNA826	0,0065	Exceeds Limit	0,7800	Passed
Enfield District Elementary	Classroom 114 Kitchen Tap - T35	NNA827	0,0380	Exceeds Limit	0,8800	Passed
Enfield District Elementary	Classroom 113 Kitchen Tap - T36	NNA828	0,0055	Exceeds Limit	1,2000	Passed
Enfield District Elementary	Classroom 111 Kitchen Tap - T37	NNA829	0,0079	Exceeds Limit	1,3000	Passed
Enfield District Elementary	Work Room 121.1 off Library Tap - T38	NNA830	0,0051	Exceeds Limit	0,2000	Passed
Enfield District Elementary	Special Needs Kitchen Tap Room 120 - T39	NNA831	0,0036	Passed	0,4400	Passed
Enfield District Elementary	Washroom 122.2 Tap - T40	NNA832	0,0031	Passed	0,5300	Passed
Enfield District Elementary	51 Room Classroom 122 Kitchen Tap - T41	NNA833	0,0078	Exceeds Limit	0,6900	Passed
Enfield District Elementary	Custodian Room 127 - Tap - 42	NNA834	0,0024	Passed	0,2700	Passed
Enfield District Elementary	Classroom 101 Tap - T43	NNA835	0,0042	Passed	0,5500	Passed
Enfield District Elementary	Classroom Washroom 101.1 Tap - T46	NNA836	0,0043	Passed	0,3600	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Enfield District Elementary	Classroom 102 Kitchen Tap - T44	NNA837	0,0029	Passed	0,3500	Passed
Enfield District Elementary	Classroom Washroom 103.1 Tap - 45	NNA838	0,0032	Passed	0,5700	Passed
Enfield District Elementary	Classroom 104 - Tap - T47	NNA839	0,0220	Exceeds Limit	0,6100	Passed
Enfield District Elementary	Fountain by Washroom - F4	NNA840	0,0079	Exceeds Limit	0,8100	Passed
Enfield District Elementary	Female Washroom 124 Left Tap - T48	NNA841	0,0010	Passed	0,1900	Passed
Enfield District Elementary	Female Washroom 124 Middle Tap - T49	NNA842	0,0031	Passed	0,1900	Passed
Enfield District Elementary	Female Washroom Right Tap - T50	NNA843	0,0017	Passed	0,2000	Passed
Enfield District Elementary	Male Washroom 126 Left Tap - T51	NNA844	0,0015	Passed	0,1500	Passed
Enfield District Elementary	Male Washroom 126 Middle Tap - T52	NNA845	0,0022	Passed	0,1400	Passed
Enfield District Elementary	Male Washroom 126 Right Tap - T53	NNA846	0,0018	Passed	0,1400	Passed
Enfield District Elementary	Classroom 106 Kitchen Tap - T54	NNA847	0,0028	Passed	0,2900	Passed
Enfield District Elementary	Classroom 105 Kitchen Tap - T55	NNA848	0,0090	Exceeds Limit	0,5200	Passed
Enfield District Elementary	Washroom 129 - T56	NNA849	0,0057	Exceeds Limit	0,3500	Passed
Enfield District Elementary	Classroom 103 Kitchen - T57	NNA850	0,0024	Passed	0,3300	Passed
F.H. MacDonald Academy	007 Fountain A	MYX915	0,0006	Passed	0,3000	Passed
F.H. MacDonald Academy	008 Room 112	MYX916	0,0180	Exceeds Limit	0,0290	Passed
F.H. MacDonald Academy	010 Room 116	MYX917	0,0240	Exceeds Limit	0,0430	Passed
F.H. MacDonald Academy	012 Room 118	MYX918	0,0120	Exceeds Limit	0,0300	Passed
F.H. MacDonald Academy	014 Room 120	MYX919	0,0160	Exceeds Limit	0,0420	Passed
F.H. MacDonald Academy	015 Room 121	MYX920	0,0120	Exceeds Limit	0,0180	Passed
F.H. MacDonald Academy	017 Room 150 Left Sink	MYX921	0,0160	Exceeds Limit	0,3200	Passed
F.H. MacDonald Academy	018 Room 150 Right Sink	MYX922	0,0300	Exceeds Limit	0,5500	Passed
F.H. MacDonald Academy	019 Kitchen Handwash Sink	MYX923	0,0140	Exceeds Limit	0,2400	Passed
F.H. MacDonald Academy	021 Kitchen Dish Spray Sink	MYX924	0,0200	Exceeds Limit	1,0000	Passed
F.H. MacDonald Academy	028 Fountain B	MYX925	0,0000	Passed	0,2800	Passed
F.H. MacDonald Academy	030 Room 159	MYX926	0,0400	Exceeds Limit	0,0086	Passed
F.H. MacDonald Academy	032 Family Studies Sink B	MYX927	0,0350	Exceeds Limit	0,1100	Passed
F.H. MacDonald Academy	033 Family Studies Sink C	MYX928	0,0190	Exceeds Limit	0,0610	Passed
F.H. MacDonald Academy	034 Family Studies Sink D	MYX929	0,0230	Exceeds Limit	0,3000	Passed
F.H. MacDonald Academy	035 Family Studies Sink E	MYX930	0,0250	Exceeds Limit	0,2500	Passed
F.H. MacDonald Academy	036 Family Studies Sink F	MYX931	0,0440	Exceeds Limit	0,0160	Passed
F.H. MacDonald Academy	037 Family Studies Sink G	MYX932	0,0390	Exceeds Limit	0,0320	Passed
F.H. MacDonald Academy	041 Arts/Science Sink A	MYX933	0,0057	Exceeds Limit	0,0210	Passed
F.H. MacDonald Academy	042 Arts/Science Sink B	MYX934	0,0500	Exceeds Limit	0,0110	Passed
F.H. MacDonald Academy	043 Arts/Science Sink C	MYX935	0,0430	Exceeds Limit	0,0360	Passed
F.H. MacDonald Academy	044 Arts/Science Sink D	MYX936	0,0340	Exceeds Limit	0,0460	Passed
F.H. MacDonald Academy	045 Room 212	MYX937	0,0230	Exceeds Limit	0,0150	Passed
F.H. MacDonald Academy	046 Room 204	MYX938	0,0220	Exceeds Limit	0,0240	Passed
F.H. MacDonald Academy	047 Room 204A	MYX939	0,0260	Exceeds Limit	0,0170	Passed
F.H. MacDonald Academy	048 Room 204B	MYX940	0,0210	Exceeds Limit	0,0100	Passed
F.H. MacDonald Academy	049 Fountain C	MYX941	0,0000	Passed	0,3500	Passed
F.H. MacDonald Academy	053 Room 208	MYX942	0,0210	Exceeds Limit	0,0530	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
F.H. MacDonald Academy	054 Room 208A	MYX943	0,0290	Exceeds Limit	0,0150	Passed
F.H. MacDonald Academy	055 Room 208B	MYX944	0,0180	Exceeds Limit	0,0100	Passed
F.H. MacDonald Academy	056 Room 227	MYX945	0,0230	Exceeds Limit	0,0310	Passed
F.H. MacDonald Academy	058 Room 225	MYX946	0,0460	Exceeds Limit	0,0120	Passed
F.H. MacDonald Academy	060 Room 237	MYX947	0,0270	Exceeds Limit	0,0460	Passed
F.H. MacDonald Academy	061 Room 237A	MYX948	0,0220	Exceeds Limit	0,0220	Passed
F.H. MacDonald Academy	062 Room 215	MYX949	0,0280	Exceeds Limit	0,0360	Passed
F.H. MacDonald Academy	065 Fountain D	MYX950	0,0016	Passed	0,7400	Passed
F.H. MacDonald Academy	066 Room 237B	MYX951	0,0170	Exceeds Limit	0,0120	Passed
F.H. MacDonald Academy	071 Room 231	MYX952	0,0400	Exceeds Limit	0,0320	Passed
F.H. MacDonald Academy	072 Room 240	MYX953	0,0360	Exceeds Limit	0,0360	Passed
F.H. MacDonald Academy	073 Room 240A	MYX954	0,0210	Exceeds Limit	0,0360	Passed
F.H. MacDonald Academy	074 Room 241	MYX955	0,0360	Exceeds Limit	0,0073	Passed
F.H. MacDonald Academy	Back Water Room, T1	NFK561	0,0090	Exceeds Limit	0,0510	Passed
F.H. MacDonald Academy	Back Water Room 2nd Test, T1A	NFK562	0,0093	Exceeds Limit	0,0290	Passed
G.R. Saunders Elementary School	Fountain Main Entry	LDE229	0,0000	Passed	0,0120	Passed
G.R. Saunders Elementary School	Kitchen Rm 126	LDE230	0,0000	Passed	0,0150	Passed
G.R. Saunders Elementary School	Kitchen Sink	LDE231	0,0000	Passed	0,0190	Passed
G.R. Saunders Elementary School	Fountain 1st Floor	LDE232	0,0000	Passed	0,0330	Passed
G.R. Saunders Elementary School	Rm 007	LDE233	0,0000	Passed	0,1100	Passed
G.R. Saunders Elementary School	Rm 114	LDE234	0,0034	Passed	0,4000	Passed
G.R. Saunders Elementary School	Rm 006	LDE235	0,0006	Passed	0,2000	Passed
G.R. Saunders Elementary School	Rm 004	LDE236	0,0000	Passed	0,0990	Passed
G.R. Saunders Elementary School	Rm 003	LDE237	0,0005	Passed	0,1500	Passed
G.R. Saunders Elementary School	Rm 005	LDE238	0,0088	Exceeds Limit	0,1600	Passed
G.R. Saunders Elementary School	Fountain 2nd Floor	LDE239	0,0000	Passed	0,0460	Passed
G.R. Saunders Elementary School	Rm 215	LDE240	0,0000	Passed	0,0370	Passed
G.R. Saunders Elementary School	Source Sample	LDE241	0,0011	Passed	0,0630	Passed
G.R. Saunders Elementary School	Gym Room 116 Girls Bathroom Sink	NFD706	0,0013	Passed	0,0750	Passed
G.R. Saunders Elementary School	Gym Room 116 Boys Bathroom Sink	NFD707	0,0000	Passed	0,0090	Passed
G.R. Saunders Elementary School	Office Sink	NFD708	0,0000	Passed	0,0620	Passed
G.R. Saunders Elementary School	Downstairs Girls Bathroom A	NFD709	0,0000	Passed	0,0310	Passed
G.R. Saunders Elementary School	Downstairs Girls Bathroom B	NFD710	0,0000	Passed	0,0370	Passed
G.R. Saunders Elementary School	Downstairs Girls Bathroom C	NFD711	0,0010	Passed	0,0790	Passed
G.R. Saunders Elementary School	Downstairs Boys Bathroom A	NFD712	0,0000	Passed	0,0390	Passed
G.R. Saunders Elementary School	Downstairs Boys Bathroom B	NFD713	0,0000	Passed	0,0240	Passed
G.R. Saunders Elementary School	Downstairs Boys Bathroom C	NFD714	0,0032	Passed	0,2100	Passed
G.R. Saunders Elementary School	Downstairs Boys Bathroom D	NFD715	0,0000	Passed	0,0930	Passed
G.R. Saunders Elementary School	Custodial Closet Sink	NFD716	0,0006	Passed	0,0380	Passed
G.R. Saunders Elementary School	Upstairs Girls Bathroom A	NFD717	0,0006	Passed	0,0960	Passed
G.R. Saunders Elementary School	Upstairs Girls Bathroom B	NFD718	0,0000	Passed	0,0220	Passed
G.R. Saunders Elementary School	Upstairs Girls Bathroom C	NFD719	0,0010	Passed	0,0360	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
G.R. Saunders Elementary School	Upstairs Girls Bathroom D	NFD720	0,0000	Passed	0,0100	Passed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink A	NFD721	0,0000	Passed	0,0270	Passed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink B	NFD722	0,0000	Passed	0,0140	Passed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink C	NFD723	0,0000	Passed	0,0110	Passed
G.R. Saunders Elementary School	Upstairs Boys Bathroom Sink D	NFD724	0,0000	Passed	0,0099	Passed
G.R. Saunders Elementary School	Mechanical Room Sink	NFD725	0,0000	Passed	0,0083	Passed
G.R. Saunders Elementary School	Custodial Closet Sink	NFD726	0,0000	Passed	0,0120	Passed
Great Village Elementary School	Fountain Main Floor	LCP291	0,1200	Exceeds Limit	0,7200	Passed
Great Village Elementary School	Fountain Second Floor	LCP292	0,0780	Exceeds Limit	0,3100	Passed
Great Village Elementary School	Kitchen Tap Staff Room	LCP293	0,0290	Exceeds Limit	0,8200	Passed
Great Village Elementary School	Fountain by Gym	LCP294	0,0830	Exceeds Limit	1,3000	Passed
Great Village Elementary School	Tap Gym Kitchen	LCP295	0,5400	Exceeds Limit	0,6700	Passed
Great Village Elementary School	Raw Water Basement	LCP296	0,0006	Passed	0,0037	Passed
Hants East Rural High School	Room 205 (Old Music Room) Kit. Tap T9	MUL356	0,0420	Exceeds Limit	0,1100	Passed
Hants East Rural High School	Cafeteria Main Kitchen Tap, T11	MUL357	0,0037	Passed	0,0580	Passed
Hants East Rural High School	Room 211 Special Needs Kit. Tap, T21	MUL358	0,0063	Exceeds Limit	0,1100	Passed
Hants East Rural High School	Fountain by Health Room, F1	MUL359	0,0000	Passed	0,0330	Passed
Hants East Rural High School	Art Room 225 Kit. Tap on Right, T41	MUL360	0,0750	Exceeds Limit	0,1600	Passed
Hants East Rural High School	Art Room 225 Kit. Tap on Left, T42	MUL361	0,0330	Exceeds Limit	0,1300	Passed
Hants East Rural High School	Art Room 227 Kit. Tap, T44	MUL362	0,0210	Exceeds Limit	0,0870	Passed
Hants East Rural High School	Fountain Across from Room 227, F2	MUL363	0,0000	Passed	0,0740	Passed
Hants East Rural High School	CEP Kit. First Row Tap on Left, T46	MUL364	0,0760	Exceeds Limit	0,2400	Passed
Hants East Rural High School	CEP Kit. First Row Tap on Right, T47	MUL365	0,0072	Exceeds Limit	0,0660	Passed
Hants East Rural High School	CEP Kit. 2nd Row Tap by Window, T48	MUL366	0,1600	Exceeds Limit	0,2500	Passed
Hants East Rural High School	Staff Room Kitchen Tap, T70	MUL367	0,0028	Passed	0,0490	Passed
Hants East Rural High School	Fountain by Room 317, F4	MUL368	0,0009	Passed	0,0790	Passed
Hants East Rural High School	Fountain in Upstairs Foyer, F5	MUL369	0,0000	Passed	0,0820	Passed
Hants East Rural High School	Schools Plus Kitchen Tap, T92	MUL370	0,0120	Exceeds Limit	0,0950	Passed
Hants North Rural High School	New Fountain Main Gym, F7	LEK492	0,0000	Passed	0,1200	Passed
Hants North Rural High School	Large Sink by Door in HE Rm 123, T72	LEK493	0,0190	Exceeds Limit	0,3800	Passed
Hants North Rural High School	Sink on Left in HE Room 123, T73	LEK494	0,0027	Passed	0,1800	Passed
Hants North Rural High School	Sink on Left Centre in HE Rm 123, T74	LEK495	0,0045	Passed	0,2800	Passed
Hants North Rural High School	Sink on Right Centre in HE Rm 123, T75	LEK496	0,0055	Exceeds Limit	0,1100	Passed
Hants North Rural High School	Sink on Right in HE Rm 123, T76	LEK497	0,0066	Exceeds Limit	0,1700	Passed
Hants North Rural High School	Main Kitchen Sink Room 124, T77	LEK498	0,0140	Exceeds Limit	0,0880	Passed
Hants North Rural High School	Kitchen Hand Washing Sink Rm 124, T78	LEK499	0,0270	Exceeds Limit	0,0750	Passed
Hants North Rural High School	Kitchen Sink Rm 121, T43	LEK551	0,0220	Exceeds Limit	0,3100	Passed
Hants North Rural High School	Fountain by Sprinkler Room 119, Rm F6	LEK552	0,0040	Passed	0,1100	Passed
Hants North Rural High School	Sink in Primary Room 109, T36	LEK553	0,0027	Passed	0,1800	Passed
Hants North Rural High School	Sink in Lunch Room 116, T35	LEK554	0,0100	Exceeds Limit	0,1800	Passed
Hants North Rural High School	Sink in Room 110, T34	LEK555	0,0066	Exceeds Limit	0,1600	Passed
Hants North Rural High School	Sink in Room 115, T38	LEK556	0,0044	Passed	0,1300	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Hants North Rural High School	Fountain in Room 115, F5	LEK557	0,0240	Exceeds Limit	0,0750	Passed
Hants North Rural High School	Fountain Outside Staff Room 114, F4	LEK558	0,0035	Passed	0,2100	Passed
Hants North Rural High School	Staff Room Elementary 114, T33	LEK559	0,0100	Exceeds Limit	0,0980	Passed
Hants North Rural High School	Staff Room Upstairs 230, T9	LEK560	0,0250	Exceeds Limit	1,3000	Passed
Hants North Rural High School	Fountain Upstairs by Room 235, F1	LEK563	0,0051	Exceeds Limit	0,1200	Passed
Hants North Rural High School	Fountain Upstairs by GW Rm 222, F2	LEK564	0,0019	Passed	0,0640	Passed
Hants North Rural High School	New Fountain by Room 212, F3	LEK565	0,0000	Passed	0,0580	Passed
Hants North Rural High School	Raw Water Boiler Rm Old Well	LEK566	0,1600	Exceeds Limit	3,6000	Exceeds Limit
Harmony Heights Elementary School	Music Room 129, T2	MQE345	0,0032	Passed	0,1600	Passed
Harmony Heights Elementary School	Room 127 First Tap on Right, T3	MQE346	0,0010	Passed	0,1600	Passed
Harmony Heights Elementary School	Room 127 Second Tap on Right, T4	MQE347	0,0000	Passed	0,1400	Passed
Harmony Heights Elementary School	Staff Room Kitchen Tap on Left, T22	MQE348	0,0000	Passed	0,1500	Passed
Harmony Heights Elementary School	Fountain Near Staff Room, F2	MQE349	0,0000	Passed	0,0950	Passed
Harmony Heights Elementary School	Room 117 Tap Behind Sliding Wall, T24	MQE350	0,0010	Passed	0,1600	Passed
Harmony Heights Elementary School	Room 117 Kitchen Tap on Left, T25	MQE351	0,0086	Exceeds Limit	0,0970	Passed
Harmony Heights Elementary School	Library Room 105 Kitchen Tap, T12	MQE352	0,0046	Passed	0,1500	Passed
Harmony Heights Elementary School	Fountain by Gym Entrance, F1	MQE353	0,0000	Passed	0,1200	Passed
Harmony Heights Elementary School	Recycle Room 136 Tap, T26	MQE354	0,0007	Passed	0,2000	Passed
Harmony Heights Elementary School	Main Kitchen Sink on Right, T28	MQE355	0,0006	Passed	0,1900	Passed
Harmony Heights Elementary School	Main Kitchen Sink in Island, T29	MQE356	0,0008	Passed	0,2000	Passed
Harmony Heights Elementary School	Fountain Near Office North Wing, F3	MQE357	0,0000	Passed	0,1500	Passed
Harmony Heights Elementary School	Room 147, Kitchen Sink, T41	MQE358	0,0000	Passed	0,1000	Passed
Harmony Heights Elementary School	Room 159, Kitchen Sink, T39	MQE359	0,0010	Passed	0,1100	Passed
Harmony Heights Elementary School	Room 148, Kitchen Sink, T42	MQE360	0,0044	Passed	0,1000	Passed
Harmony Heights Elementary School	Room 158, Kitchen Sink, T43	MQE361	0,0009	Passed	0,1400	Passed
Harmony Heights Elementary School	Room 150, Kitchen Sink, T45	MQE362	0,0008	Passed	0,1000	Passed
Harmony Heights Elementary School	Room 155, Kitchen Sink, T47	MQE363	0,0007	Passed	0,1200	Passed
Harmony Heights Elementary School	Room 152, Kitchen Sink, T48	MQE364	0,0010	Passed	0,1100	Passed
Harmony Heights Elementary School	Room 153, Kitchen Sink, T49	MQE365	0,0006	Passed	0,1500	Passed
Hilden Elementary School	Staff Rm Kitchen Sink , T1	MQS978	0,0052	Exceeds Limit	0,0320	Passed
Hilden Elementary School	Learning Centre Sink, T17	MQS979	0,0340	Exceeds Limit	0,0840	Passed
Hilden Elementary School	Fountain by LC, F1	MQS980	0,0045	Passed	0,0870	Passed
Hilden Elementary School	Sink in Room 107, T9	MQS981	0,0170	Exceeds Limit	0,0490	Passed
Hilden Elementary School	Sink in Room 106, T10	MQS982	0,0160	Exceeds Limit	0,0800	Passed
Hilden Elementary School	Sink in Room 105, T11	MQS983	0,0370	Exceeds Limit	0,0880	Passed
Hilden Elementary School	Fountain by Room 135, F2	MQS984	0,0045	Passed	0,1100	Passed
Hilden Elementary School	Kitchen Sink, T13	MQS985	0,0034	Passed	0,0850	Passed
Junction Road Elementary School	Hallway Fountain	LEU319	0,0021	Passed	0,4300	Passed
Junction Road Elementary School	Raw Water Source	LEU320	0,5000	Exceeds Limit	1,7000	Passed
Junction Road Elementary School	Staff Room Tap	LEU321	0,0014	Passed	0,4000	Passed
Junction Road Elementary School	Girls #1	NEE675	0,0000	Passed	0,0270	Passed
Junction Road Elementary School	Girls #2	NEE676	0,0000	Passed	0,0290	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Junction Road Elementary School	Girls #3	NEE677	0,0000	Passed	0,0270	Passed
Junction Road Elementary School	Custodial by Office	NEE678	0,0000	Passed	0,0270	Passed
Junction Road Elementary School	Boys #1	NEE679	0,0000	Passed	0,0370	Passed
Junction Road Elementary School	Boys #2	NEE680	0,0000	Passed	0,0360	Passed
Junction Road Elementary School	Boys #3	NEE681	0,0000	Passed	0,0330	Passed
Junction Road Elementary School	Boys #4	NEE682	0,0000	Passed	0,0320	Passed
Junction Road Elementary School	Staff #1	NEE683	0,0011	Passed	0,0300	Passed
Junction Road Elementary School	Staff #2	NEE684	0,0000	Passed	0,0330	Passed
Junction Road Elementary School	Washroom #1	NEE685	0,0000	Passed	0,1500	Passed
Junction Road Elementary School	Washroom #2	NEE686	0,0000	Passed	0,1500	Passed
Junction Road Elementary School	Custodial by Library	NEE687	0,0000	Passed	0,1300	Passed
Kennetcook District Elementary School	Resource Room 118, T37	LEK666	0,0052	Exceeds Limit	0,3200	Passed
Kennetcook District Elementary School	Janitor Washroom Rm 219 T25	LEK667	0,0099	Exceeds Limit	0,8100	Passed
Kennetcook District Elementary School	Raw Water Boiler Rm New Well	LEK668	0,9100	Exceeds Limit	0,1300	Passed
Maple Ridge Elementary School	Rm 152 Kitchen Tap, T1	MRG529	0,0097	Exceeds Limit	0,0740	Passed
Maple Ridge Elementary School	Outside Music Room, F1	MRG530	0,0028	Passed	0,0920	Passed
Maple Ridge Elementary School	Music Rm 148, Kitchen Tap, T12	MRG531	0,0190	Exceeds Limit	0,2100	Passed
Maple Ridge Elementary School	Art Room 145, T14	MRG532	0,0043	Passed	0,2700	Passed
Maple Ridge Elementary School	Kitchen Dishwashing Tap, T15	MRG533	0,1100	Exceeds Limit	0,2700	Passed
Maple Ridge Elementary School	Kitchen Handwashing Tap, T16	MRG534	0,0049	Passed	0,0930	Passed
Maple Ridge Elementary School	Kitchen Main Tap, T17	MRG535	0,0026	Passed	0,0610	Passed
Maple Ridge Elementary School	Staff Room, Kitchen Tap, T23	MRG536	0,0025	Passed	0,1200	Passed
Maple Ridge Elementary School	Room A-1/206 Kitchen Tap, T33	MRG537	0,0093	Exceeds Limit	0,1900	Passed
Maple Ridge Elementary School	Room A-2/203 Kitchen Tap, T36	MRG538	0,0035	Passed	0,1700	Passed
Maple Ridge Elementary School	Room A-3/201 Kitchen Tap, T42	MRG539	0,0029	Passed	0,1800	Passed
Maple Ridge Elementary School	Room A-4/198 Kitchen Tap, T44	MRG540	0,0048	Passed	0,1800	Passed
Maple Ridge Elementary School	LC Room A-8/189, Kitchen Tap, T37	MRG541	0,0048	Passed	0,2000	Passed
Maple Ridge Elementary School	Room A-7/191 Kitchen Tap T38	MRG542	0,0130	Exceeds Limit	0,1200	Passed
Maple Ridge Elementary School	Room A-6/193 Kitchen Tap, T40	MRG543	0,0013	Passed	0,0920	Passed
Maple Ridge Elementary School	Room A-5/196 Kitchen Tap, T41	MRG544	0,0065	Exceeds Limit	0,3000	Passed
Maple Ridge Elementary School	By Girls Washroom, 142, F2	MRG545	0,0000	Passed	0,0880	Passed
Maple Ridge Elementary School	Room A-1/206 F3	MSH256	0,0000	Passed	0,1100	Passed
Maple Ridge Elementary School	Room A-2/203 F4	MSH257	0,0000	Passed	0,0930	Passed
Maple Ridge Elementary School	Room A-3/201, F8	MSH258	0,0005	Passed	0,0910	Passed
Maple Ridge Elementary School	Room A-4/198, F6	MSH259	0,0000	Passed	0,1100	Passed
Maple Ridge Elementary School	Room A-8/189 F5	MSH260	0,0008	Passed	0,2000	Passed
Maple Ridge Elementary School	Room A-7/191, F6	MSH261	0,0000	Passed	0,0600	Passed
Maple Ridge Elementary School	Room A-6/193 F7	MSH262	0,0000	Passed	0,0580	Passed
Maple Ridge Elementary School	Room A-5/196 F10	MSH263	0,0007	Passed	0,1900	Passed
Maple Ridge Elementary School	North Change Room 156 Left Tap, T2	NGT279	0,0380	Exceeds Limit	0,1100	Passed
Maple Ridge Elementary School	North Change Room 156 Right Tap, T3	NGT280	0,0490	Exceeds Limit	0,4700	Passed
Maple Ridge Elementary School	South Change Room 157, Left Tap, T4	NGT281	0,0350	Exceeds Limit	0,0960	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Maple Ridge Elementary School	South Change Room 157, Right Tap, T5	NGT282	0,0340	Exceeds Limit	0,2100	Passed
Maple Ridge Elementary School	Maintenance Storage 158, T6	NGT283	0,0022	Passed	0,1700	Passed
Maple Ridge Elementary School	Boy's Change Room 160, Left Tap, T7	NGT284	0,0048	Passed	0,1900	Passed
Maple Ridge Elementary School	Boy's Change Room 160, Right Tap, T8	NGT285	0,0150	Exceeds Limit	0,2100	Passed
Maple Ridge Elementary School	Girl's Change Room 161, Left Tap, T9	NGT286	0,0051	Exceeds Limit	0,1900	Passed
Maple Ridge Elementary School	Girl's Change Room 161, Right Tap, T10	NGT287	0,0180	Exceeds Limit	0,1400	Passed
Maple Ridge Elementary School	Gym Office 162, T11	NGT288	0,0039	Passed	0,1900	Passed
Maple Ridge Elementary School	Janitors Closet 147 Cust. Floor Sink, T13	NGT289	0,0018	Passed	0,1000	Passed
Maple Ridge Elementary School	Boys Washroom 143 Left Tap, T18	NGT290	0,0023	Passed	0,1700	Passed
Maple Ridge Elementary School	Boys Washroom 143 Right Tap, T19	NGT291	0,0100	Exceeds Limit	0,1700	Passed
Maple Ridge Elementary School	Girls Washroom 142 Left Tap, T20	NGT292	0,0061	Exceeds Limit	0,1100	Passed
Maple Ridge Elementary School	Girls Washroom 142 Right Tap, T20A	NGT293	0,0037	Passed	0,1700	Passed
Maple Ridge Elementary School	Staff Room Washroom 116, T21	NGT294	0,0075	Exceeds Limit	0,2000	Passed
Maple Ridge Elementary School	Staff Room Washroom 115, T22	NGT295	0,0062	Exceeds Limit	0,2100	Passed
Maple Ridge Elementary School	Washroom 109 Main Office T24	NGT296	0,0060	Exceeds Limit	0,1300	Passed
Maple Ridge Elementary School	Sick Room Main Office, T25	NGT297	0,0091	Exceeds Limit	0,2800	Passed
Maple Ridge Elementary School	Wash Up Room 118, T26	NGT298	0,0370	Exceeds Limit	0,2700	Passed
Maple Ridge Elementary School	Girls Washroom 179 Left Tap, T27	NGT299	0,0110	Exceeds Limit	0,2400	Passed
Maple Ridge Elementary School	Girls Washroom 179 Right Tap, T28	NGT300	0,0081	Exceeds Limit	0,2000	Passed
Maple Ridge Elementary School	Boys Washroom 180 Left Tap, T29	NGT301	0,0035	Passed	0,1100	Passed
Maple Ridge Elementary School	Boys Washroom 180 Right Tap, T30	NGT302	0,0019	Passed	0,1300	Passed
Maple Ridge Elementary School	Everyone Washroom 183, T31	NGT303	0,0077	Exceeds Limit	0,1400	Passed
Maple Ridge Elementary School	Janitors Closet 182, T32	NGT304	0,0037	Passed	0,0970	Passed
Maple Ridge Elementary School	Washroom 207 Classroom A-1/206, T34	NGT305	0,0065	Exceeds Limit	0,1200	Passed
Maple Ridge Elementary School	Washroom 204 Classroom A-2/203, T35	NGT306	0,0037	Passed	0,1300	Passed
Maple Ridge Elementary School	Washroom 192 Classroom A-7/191, T39	NGT307	0,0033	Passed	0,1200	Passed
Maple Ridge Elementary School	Washroom 194 Classroom A-6/193, T40A	NGT308	0,0026	Passed	0,1200	Passed
Maple Ridge Elementary School	Washroom 202 Classroom A-3/201, T43	NGT309	0,0013	Passed	0,0730	Passed
Maple Ridge Elementary School	Washroom 199 Classroom A-4/198, T45	NGT310	0,0059	Exceeds Limit	0,1300	Passed
Maple Ridge Elementary School	Wash Up/Storage 197, T46	NGT311	0,0390	Exceeds Limit	0,0870	Passed
McCulloch Education Centre	Rm 1016 Sick Rm Sink	NNH543	0,0410	Exceeds Limit	0,1500	Passed
McCulloch Education Centre	Rm 1019 Admin Washroom Sink	NNH544	0,0230	Exceeds Limit	0,2500	Passed
McCulloch Education Centre	Kitchen Double Sink	NNH545	0,0250	Exceeds Limit	0,1800	Passed
McCulloch Education Centre	Kitchen Sprayer	NNH546	0,0031	Passed	0,1000	Passed
McCulloch Education Centre	Kitchen Handwash Sink	NNH547	0,0150	Exceeds Limit	0,1900	Passed
McCulloch Education Centre	Boys Washroom Sink A	NNH548	0,0190	Exceeds Limit	0,1300	Passed
McCulloch Education Centre	Boys Washroom Sink B	NNH549	0,0160	Exceeds Limit	0,1300	Passed
McCulloch Education Centre	Boys Washroom Sink C	NNH550	0,0270	Exceeds Limit	0,1400	Passed
McCulloch Education Centre	Rm 1025 Girls Washroom Sink A	NNH551	0,0430	Exceeds Limit	0,3300	Passed
McCulloch Education Centre	Rm 1025 Girls Washroom Sink B	NNH552	0,0360	Exceeds Limit	0,2600	Passed
McCulloch Education Centre	Rm 1025 Girls Washroom Sink C	NNH553	0,0360	Exceeds Limit	0,2000	Passed
McCulloch Education Centre	Library Sink	NNH554	0,0370	Exceeds Limit	0,2200	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
McCulloch Education Centre	Rm 1028 Boys Washroom Sink A	NNH555	0,0210	Exceeds Limit	0,1800	Passed
McCulloch Education Centre	Rm 1028 Boys Washroom Sink B	NNH556	0,0250	Exceeds Limit	0,4500	Passed
McCulloch Education Centre	Gym Office Sink	NNH557	0,0820	Exceeds Limit	0,4900	Passed
McCulloch Education Centre	Male Change Rm Sink	NNH558	0,0260	Exceeds Limit	0,3800	Passed
McCulloch Education Centre	Female Change Rm Sink	NNH559	0,0480	Exceeds Limit	0,2500	Passed
McCulloch Education Centre	Rm 1037 Custodial Closet Sink	NNH560	0,2700	Exceeds Limit	0,3800	Passed
McCulloch Education Centre	Rm 1038 Recycle Rm Sink	NNH561	0,0025	Passed	0,1900	Passed
McCulloch Education Centre	Rm 1047 Music Rm Sink	NNH562	0,0610	Exceeds Limit	0,2100	Passed
McCulloch Education Centre	Rm 1050 Staff Rm Kitchen Sink	NNH563	0,0040	Passed	0,1700	Passed
McCulloch Education Centre	Rm 1052 Staff Washroom Sink	NNH564	0,0077	Exceeds Limit	0,1500	Passed
McCulloch Education Centre	Rm 1053 Staff Washroom Sink	NNH565	0,0055	Exceeds Limit	0,1800	Passed
McCulloch Education Centre	Rm 1054 Classroom Sink	NNH566	0,0083	Exceeds Limit	0,2200	Passed
McCulloch Education Centre	Rm 1057 Classroom Sink	NNH567	0,0200	Exceeds Limit	0,1700	Passed
McCulloch Education Centre	Rm 1061 Classroom Sink	NNH568	0,0045	Passed	0,1900	Passed
McCulloch Education Centre	Rm 1062 Classroom Sink	NNH569	0,0930	Exceeds Limit	1,2000	Passed
McCulloch Education Centre	Rm 1063 Lab Sink	NNH570	0,0150	Exceeds Limit	0,5200	Passed
McCulloch Education Centre	Rm 1064 Classroom Sink	NNH571	0,0240	Exceeds Limit	0,5200	Passed
McCulloch Education Centre	Rm 1065 Learning Ctr Kitchen Sink	NNH572	0,0250	Exceeds Limit	0,1800	Passed
McCulloch Education Centre	Rm 1069 Learning Ctr Bathroom Sink	NNH573	0,0290	Exceeds Limit	0,2000	Passed
McCulloch Education Centre	Rm 1070 Comm Rm Sink	NNH574	0,0310	Exceeds Limit	0,3600	Passed
McCulloch Education Centre	Rm 1071 Vestibule Sink	NNH575	0,0060	Exceeds Limit	0,1500	Passed
McCulloch Education Centre	Rm 1072 Classroom Sink	NNH576	0,0330	Exceeds Limit	0,5100	Passed
McCulloch Education Centre	Rm 1073 Classroom Sink	NNH577	0,0320	Exceeds Limit	0,3500	Passed
McCulloch Education Centre	Rm 1080 Classroom Sink	NNH578	0,0088	Exceeds Limit	0,1400	Passed
McCulloch Education Centre	Rm 1081 Washroom Sink A	NNH579	0,0110	Exceeds Limit	0,1700	Passed
McCulloch Education Centre	Rm 1081 Washroom Sink B	NNH580	0,0390	Exceeds Limit	0,9500	Passed
McCulloch Education Centre	Rm 1082 Classroom Lab1 Handwash Sink	NNH581	0,0220	Exceeds Limit	0,6800	Passed
McCulloch Education Centre	Rm 1082 Classroom CS1 Utility Sink	NNH582	0,0082	Exceeds Limit	0,1500	Passed
McCulloch Education Centre	Rm 1090 Mechanical Rm Sink	NNH583	0,0200	Exceeds Limit	0,2100	Passed
McCulloch Education Centre	Fountain Corridor 1008	NNH584	0,0082	Exceeds Limit	0,0960	Passed
McCulloch Education Centre	Fountain Corridor 1006	NNH585	0,0061	Exceeds Limit	0,2000	Passed
New Glasgow Academy	Room 112 Sink A	MYY893	0,0000	Passed	0,0890	Passed
New Glasgow Academy	Room 113 Sink A	MYY894	0,0000	Passed	0,0630	Passed
New Glasgow Academy	Room 115 PP Sink A	MYY895	0,0000	Passed	0,0330	Passed
New Glasgow Academy	Room 124 Sink A	MYY896	0,0000	Passed	0,3500	Passed
New Glasgow Academy	Room 124 Sink B	MYY897	0,0053	Exceeds Limit	0,5700	Passed
New Glasgow Academy	Room 125 Sink A	MYY898	0,0000	Passed	0,0920	Passed
New Glasgow Academy	Room 126 Sink A	MYY899	0,0000	Passed	0,0610	Passed
New Glasgow Academy	Kitchen Sink	MYY900	0,0031	Passed	0,1000	Passed
New Glasgow Academy	Hand Sink 2	MYY901	0,0007	Passed	0,1600	Passed
New Glasgow Academy	Family Studies Sink	MYY902	0,0000	Passed	0,1000	Passed
New Glasgow Academy	Nutrition Lab Sink A	MYY903	0,0000	Passed	0,1200	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
New Glasgow Academy	Nutrition Lab Sink B	MYY904	0,0000	Passed	0,0700	Passed
New Glasgow Academy	Nutrition Lab Sink C	MYY905	0,0000	Passed	0,0410	Passed
New Glasgow Academy	Nutrition Lab Sink D	MYY906	0,0000	Passed	0,3200	Passed
New Glasgow Academy	Nutrition Lab Sink E	MYY907	0,0000	Passed	0,3100	Passed
New Glasgow Academy	Staff Room Kitchen Sink	MYY908	0,0000	Passed	0,1300	Passed
New Glasgow Academy	Fountain A	MYY909	0,0000	Passed	0,2300	Passed
New Glasgow Academy	Fountain B	MYY910	0,0000	Passed	0,3900	Passed
New Glasgow Academy	Dish Sink	MYY911	0,0007	Passed	0,6100	Passed
New Glasgow Academy	Cafeteria Sink	MYY912	0,0000	Passed	0,1100	Passed
New Glasgow Academy	Cafeteria Kitchen Sink	MYY913	0,0000	Passed	0,3200	Passed
New Glasgow Academy	Music Room Sink	MYY914	0,0000	Passed	0,1400	Passed
New Glasgow Academy	Room 230 Sink A	MYY915	0,0013	Passed	0,1400	Passed
New Glasgow Academy	Room 230 Sink B	MYY916	0,0010	Passed	0,1700	Passed
New Glasgow Academy	Room 231 Sink A	MYY917	0,0000	Passed	0,6900	Passed
New Glasgow Academy	Room 238 Sink	MYY918	0,0013	Passed	0,0910	Passed
New Glasgow Academy	Room 239 Sink	MYY919	0,0000	Passed	0,0850	Passed
New Glasgow Academy	Fountain C	MYY920	0,0000	Passed	0,5700	Passed
New Glasgow Academy	Room 303 Sink	MYY921	0,0000	Passed	0,2900	Passed
New Glasgow Academy	Room 304 Sink	MYY922	0,0000	Passed	0,1900	Passed
New Glasgow Academy	Fountain E	MYY923	0,0000	Passed	0,3400	Passed
New Glasgow Academy	1st Floor Staff Room Washroom Sink	NU503	0,0000	Passed	0,0600	Passed
New Glasgow Academy	1st Floor Boys Washroom Sink A	NU504	0,0000	Passed	0,4100	Passed
New Glasgow Academy	1st Floor Boys Washrom Sink B	NU505	0,0000	Passed	0,5200	Passed
New Glasgow Academy	1st Floor Girls Washroom Sink A	NU506	0,0017	Passed	0,2100	Passed
New Glasgow Academy	1st Floor Girls Washroom Sink B	NU507	0,0012	Passed	0,1600	Passed
New Glasgow Academy	1st Floor Custodial Closet Sink	NU508	0,0011	Passed	0,0530	Passed
New Glasgow Academy	Boiler Room Sink	NU509	0,0006	Passed	0,0530	Passed
New Glasgow Academy	2nd Floor Boys Washroom Sink A	NU510	0,0000	Passed	0,0570	Passed
New Glasgow Academy	2nd Floor Boys Washroom Sink B	NU511	0,0000	Passed	0,0580	Passed
New Glasgow Academy	2nd Floor Girls Washroom Sink A	NU512	0,0000	Passed	0,0690	Passed
New Glasgow Academy	2nd Floor Girls Washroom Sink B	NU513	0,0000	Passed	0,0580	Passed
New Glasgow Academy	2nd Floor Custodial Closet Sink	NU514	0,0010	Passed	0,1100	Passed
New Glasgow Academy	3rd Floor Staff Washroom Sink	NU515	0,0000	Passed	0,0880	Passed
New Glasgow Academy	3rd Floor Boys Washroom Sink A	NU516	0,0000	Passed	0,0730	Passed
New Glasgow Academy	3rd Floor Boys Washroom Sink B	NU517	0,0000	Passed	0,0680	Passed
New Glasgow Academy	3rd Floor Girls Washroom Sink A	NU518	0,0000	Passed	0,0540	Passed
New Glasgow Academy	3rd Floor Girls Washroom Sink B	NU519	0,0010	Passed	0,1100	Passed
New Glasgow Academy	3rd Floor Custodial Closet Sink	NU520	0,0005	Passed	0,0590	Passed
New Glasgow Academy	Mechanical Room Sink	NU521	0,0000	Passed	0,0780	Passed
New Glasgow Academy	Room 116 Washroom Sink	NU522	0,0000	Passed	0,0750	Passed
New Glasgow Academy	Room 119 Washroom Sink	NU523	0,0008	Passed	0,1300	Passed
New Glasgow Academy	Room 241 Staff Room Sink A	NU524	0,0000	Passed	0,0920	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
New Glasgow Academy	Room 241 Staff Room Sink B	NU525	0,0000	Passed	0,0890	Passed
New Glasgow Academy	Gym Locker Room Girls Sink A	NU526	0,0006	Passed	0,1300	Passed
New Glasgow Academy	Gym Locker Room Girls Sink B	NU527	0,0017	Passed	0,2800	Passed
New Glasgow Academy	Gym Locker Room Boys Sink A	NU528	0,0007	Passed	0,1000	Passed
New Glasgow Academy	Gym Locker Room Boys Sink B	NU529	0,0000	Passed	0,0580	Passed
New Glasgow Academy	Girls Washroom Sink C	NU530	0,0009	Passed	0,1300	Passed
North Nova Education Centre	C2006 Staff Room Sink	MXT540	0,0000	Passed	0,2700	Passed
North Nova Education Centre	C2007 Kitchen Class (Sink A)	MXT541	0,0016	Passed	0,4500	Passed
North Nova Education Centre	C2007 Kitchen Class (Sink B)	MXT542	0,0024	Passed	0,3100	Passed
North Nova Education Centre	C2007 Kitchen Class (Sink C)	MXT543	0,0009	Passed	0,2300	Passed
North Nova Education Centre	C2010 Tentile Class (Sink D)	MXT544	0,0006	Passed	0,2600	Passed
North Nova Education Centre	C2010 Tentile Class (Sink)	MXT545	0,0006	Passed	0,1800	Passed
North Nova Education Centre	A2180 Classroom (Sink)	MXT546	0,0029	Passed	1,0000	Passed
North Nova Education Centre	083 Fountain A-2nd FL SW	MXT547	0,0000	Passed	1,2000	Passed
North Nova Education Centre	084 Fountain C-2nd FL NW	MXT548	0,0000	Passed	0,5900	Passed
North Nova Education Centre	085 Fountain D-2nd FL NE	MXT549	0,0000	Passed	0,2700	Passed
North Nova Education Centre	086 Fountain E-1st FL SW	MXT550	0,0014	Passed	1,5000	Passed
North Nova Education Centre	087 Fountain F-1st FL SE	MXT551	0,0000	Passed	0,9300	Passed
North Nova Education Centre	088 Fountain G - 1st FL NW	MXT552	0,0000	Passed	0,4200	Passed
North Nova Education Centre	089 Fountain H-1st FL NE	MXT553	0,0000	Passed	0,3300	Passed
North Nova Education Centre	090 Fountain 1-1st FL by Gym	MXT554	0,0000	Passed	1,2000	Passed
North Nova Education Centre	091 Library (Sink)	MXT555	0,0011	Passed	0,1900	Passed
North Nova Education Centre	092 1052 Learning CTR (Sink)	MXT556	0,0006	Passed	0,1600	Passed
North Nova Education Centre	095 C1005 Main Office	MXT557	0,0000	Passed	0,1100	Passed
North Nova Education Centre	098 B1112 CAF Kitchen (Prep Sink A)	MXT558	0,0070	Exceeds Limit	0,1600	Passed
North Nova Education Centre	099 B1112 CAF Kitchen (Prep Sink B)	MXT559	0,0000	Passed	0,0860	Passed
North Nova Education Centre	100 B1112 CAF Kitchen (Hand Sink)	MXT560	0,0059	Exceeds Limit	0,6400	Passed
North Nova Education Centre	101 B1112 CAF Kitchen (Sprayer)	MXT561	0,2800	Exceeds Limit	0,6800	Passed
North Nova Education Centre	103 B1111 Music Room (Sink)	MXT562	0,0007	Passed	0,1700	Passed
North Nova Education Centre	104 B1117 FS Kitchen (Hand Sink)	MXT563	0,0000	Passed	0,0860	Passed
North Nova Education Centre	105 B1117 FS Kitchen (Sprayer)	MXT564	0,0000	Passed	0,0620	Passed
North Nova Education Centre	123 Gym Office #1 (Sink)	MXT565	0,0000	Passed	0,1600	Passed
North Nova Education Centre	125 Gym Office #2 (Sink)	MXT566	0,0000	Passed	0,1300	Passed
North Nova Education Centre	135 C1065 Visual Arts (Sink A)	MXT567	0,0006	Passed	0,0980	Passed
North Nova Education Centre	136 C1065 Visual Arts (Sink B)	MXT568	0,0082	Exceeds Limit	0,1100	Passed
North Nova Education Centre	137 C1067 Visual Arts (Sink A)	MXT569	0,0006	Passed	0,1600	Passed
North Nova Education Centre	138 C1067 Visual Arts (Sink B)	MXT570	0,0012	Passed	0,0930	Passed
North Nova Education Centre	A1194 Boys Washroom A	NHC555	0,0007	Passed	0,1200	Passed
North Nova Education Centre	A1194 Boys Washroom B	NHC556	0,0011	Passed	0,0910	Passed
North Nova Education Centre	A1194 Boys Washroom C	NHC557	0,0056	Exceeds Limit	0,7900	Passed
North Nova Education Centre	A1196 Girls Washroom A	NHC558	0,0057	Exceeds Limit	0,7900	Passed
North Nova Education Centre	A1196 Girls Washroom B	NHC559	0,0024	Passed	0,2100	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
North Nova Education Centre	A1196 Girls Washroom C	NHC560	0,0040	Passed	0,7600	Passed
North Nova Education Centre	Custodial Closet Floor Sink	NHC561	0,0000	Passed	0,0810	Passed
North Nova Education Centre	C2006 Staff Washroom A	NHC562	0,0016	Passed	0,1600	Passed
North Nova Education Centre	C2006 Staff Washroom B	NHC563	0,0030	Passed	0,3500	Passed
North Nova Education Centre	C2012 Biology Lab A	NHC564	0,0150	Exceeds Limit	0,4900	Passed
North Nova Education Centre	C2012 Biology Lab B	NHC565	0,0140	Exceeds Limit	0,7600	Passed
North Nova Education Centre	C2012 Biology Lab C	NHC566	0,0180	Exceeds Limit	0,6300	Passed
North Nova Education Centre	C2012 Biology Lab D	NHC567	0,0110	Exceeds Limit	0,3300	Passed
North Nova Education Centre	C2012 Biology Lab E	NHC568	0,0200	Exceeds Limit	0,5400	Passed
North Nova Education Centre	C2021 Science Lab A	NHC569	0,0058	Exceeds Limit	0,1000	Passed
North Nova Education Centre	C2021 Science Lab B	NHC570	0,0053	Exceeds Limit	0,1100	Passed
North Nova Education Centre	C2021 Science Lab C	NHC571	0,0076	Exceeds Limit	0,2900	Passed
North Nova Education Centre	C2021 Science Lab D	NHC572	0,0041	Passed	0,2000	Passed
North Nova Education Centre	C2022 Science Lab A	NHC573	0,0180	Exceeds Limit	0,2000	Passed
North Nova Education Centre	C2022 Science Lab B	NHC574	0,0130	Exceeds Limit	0,1800	Passed
North Nova Education Centre	C2022 Science Lab C	NHC575	0,0160	Exceeds Limit	0,9100	Passed
North Nova Education Centre	C2022 Science Lab D	NHC576	0,0110	Exceeds Limit	0,1800	Passed
North Nova Education Centre	C2022 Science Lab E	NHC577	0,0092	Exceeds Limit	0,1600	Passed
North Nova Education Centre	C2013 Science Lab A	NHC578	0,0022	Passed	0,2700	Passed
North Nova Education Centre	C2013 Science Lab B	NHC579	0,0130	Exceeds Limit	0,5800	Passed
North Nova Education Centre	C2013 Science Lab C	NHC580	0,0063	Exceeds Limit	0,4500	Passed
North Nova Education Centre	C2013 Science Lab D	NHC581	0,0120	Exceeds Limit	0,5700	Passed
North Nova Education Centre	C2020 Science Lab A	NHC582	0,0024	Passed	0,1700	Passed
North Nova Education Centre	C2020 Science Lab B	NHC583	0,0074	Exceeds Limit	0,9100	Passed
North Nova Education Centre	C2020 Science Lab C	NHC584	0,0058	Exceeds Limit	0,2600	Passed
North Nova Education Centre	C2020 Science Lab D	NHC585	0,0140	Exceeds Limit	0,6500	Passed
North Nova Education Centre	C2019 Science Lab A	NHC586	0,0019	Passed	0,1800	Passed
North Nova Education Centre	C2019 Science Lab B	NHC587	0,0099	Exceeds Limit	0,1300	Passed
North Nova Education Centre	C2019 Science Lab C	NHC588	0,0180	Exceeds Limit	0,3500	Passed
North Nova Education Centre	C2019 Science Lab D	NHC589	0,0140	Exceeds Limit	0,1000	Passed
North Nova Education Centre	C2019 Science Lab E	NHC590	0,0090	Exceeds Limit	0,3100	Passed
North Nova Education Centre	C2017 Science Lab A	NHC591	0,0042	Passed	0,1000	Passed
North Nova Education Centre	C2017 Science Lab B	NHC592	0,0064	Exceeds Limit	0,2100	Passed
North Nova Education Centre	C2017 Science Lab C	NHC593	0,0089	Exceeds Limit	0,1500	Passed
North Nova Education Centre	C2017 Science Lab D	NHC594	0,0094	Exceeds Limit	0,3100	Passed
North Nova Education Centre	C2017 Science Lab E	NHC595	0,0037	Passed	0,0830	Passed
North Nova Education Centre	C2017 Science Lab F	NHC596	0,0063	Exceeds Limit	0,1200	Passed
North Nova Education Centre	C2017 Science Lab G	NHC597	0,0084	Exceeds Limit	0,2200	Passed
North Nova Education Centre	C2017 Science Lab H	NHC598	0,0055	Exceeds Limit	0,1100	Passed
North Nova Education Centre	C2017 Science Lab 1	NHC599	0,0017	Passed	0,2500	Passed
North Nova Education Centre	A2194 Boys Washroom A	NHC600	0,0034	Passed	0,3500	Passed
North Nova Education Centre	A2194 Boys Washroom B	NHC601	0,0036	Passed	0,4300	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
North Nova Education Centre	A2194 Boys Washroom C	NHC602	0,0025	Passed	0,4400	Passed
North Nova Education Centre	A2196 Girls Washroom A	NHC603	0,0018	Passed	0,1600	Passed
North Nova Education Centre	Custodial Closet Science Pod	NHC604	0,0020	Passed	0,1100	Passed
North Nova Education Centre	Staff Washroom Science Pod	NHC605	0,0022	Passed	0,4500	Passed
North Nova Education Centre	A2174 Boys Washroom A	NHC606	0,0029	Passed	0,1600	Passed
North Nova Education Centre	A2174 Boys Washroom B	NHC607	0,0000	Passed	0,1400	Passed
North Nova Education Centre	A2176 Girls Washroom A	NHC608	0,0012	Passed	0,1800	Passed
North Nova Education Centre	A2176 Girls Washroom B	NHC609	0,0015	Passed	0,2400	Passed
North Nova Education Centre	A2176 Girls Washroom C	NHC610	0,0017	Passed	0,2500	Passed
North Nova Education Centre	2014 Biology Storage	NHC611	0,0010	Passed	0,2200	Passed
North Nova Education Centre	2023 Chemistry Storage	NHC612	0,0017	Passed	0,2300	Passed
North Nova Education Centre	Custodial Closet SS Pod Floor	NHC613	0,0007	Passed	0,0710	Passed
North Nova Education Centre	Custodial Closet FR Pod Floor	NHC614	0,0012	Passed	0,2400	Passed
North Nova Education Centre	Staff Washroom SS Pod	NHC615	0,0008	Passed	0,1700	Passed
North Nova Education Centre	B2040 Ventilation Room	NHC616	0,0021	Passed	0,1000	Passed
North Nova Education Centre	Boys Washroom FR Pod 8	NHC617	0,0011	Passed	0,1400	Passed
North Nova Education Centre	Boys Washroom FR Pod C	NHC618	0,0022	Passed	0,1100	Passed
North Nova Education Centre	Girls Washroom FR Pod A	NHC619	0,0010	Passed	0,1500	Passed
North Nova Education Centre	Girls Washroom FR Pod B	NHC620	0,0027	Passed	0,4100	Passed
North Nova Education Centre	Girls Washroom FR Pod C	NHC621	0,0019	Passed	0,1800	Passed
North Nova Education Centre	Girls Washroom FR Pod D	NHC622	0,0027	Passed	0,1700	Passed
North Nova Education Centre	2nd Floor Custodial Closet Utility	NHC623	0,0010	Passed	0,0580	Passed
North Nova Education Centre	1052 Learning Centre Washroom	NHC624	0,0037	Passed	0,3900	Passed
North Nova Education Centre	C1005 Main Office Washroom	NHC625	0,0000	Passed	0,1200	Passed
North Nova Education Centre	C1019 Student SRS Washroom	NHC626	0,0022	Passed	0,2100	Passed
North Nova Education Centre	B1114 Cafeteria Recycle Floor	NHC627	0,0095	Exceeds Limit	0,1700	Passed
North Nova Education Centre	Staff Washroom CEP	NHC628	0,0084	Exceeds Limit	0,9000	Passed
North Nova Education Centre	B1121 Tec Prod Lab Eyewash Station	NHC629	0,0089	Exceeds Limit	0,5300	Passed
North Nova Education Centre	B1124 Auto Lab Eyewash Station	NHC630	0,0027	Passed	0,2900	Passed
North Nova Education Centre	B1128 Recycle Storage	NHC631	0,0067	Exceeds Limit	0,1600	Passed
North Nova Education Centre	Boiler Room Utility sink	NHC632	0,0030	Passed	0,1300	Passed
North Nova Education Centre	Gym Locker Room #1	NHC633	0,0025	Passed	0,2700	Passed
North Nova Education Centre	Gym Locker Room #2	NHC634	0,0022	Passed	0,2200	Passed
North Nova Education Centre	Gym Locker Room #3	NHC635	0,0021	Passed	0,2400	Passed
North Nova Education Centre	Gym Locker Room #4	NHC636	0,0022	Passed	0,1600	Passed
North Nova Education Centre	C1062 Boys Washroom A	NHC637	0,0110	Exceeds Limit	0,5500	Passed
North Nova Education Centre	C1062 Boys Washroom B	NHC638	0,0590	Exceeds Limit	6,3000	Exceeds Limit
North Nova Education Centre	C1062 Boys Washroom C	NHC639	0,0480	Exceeds Limit	5,8000	Exceeds Limit
North Nova Education Centre	C1063 Girls Washroom A	NHC640	0,0073	Exceeds Limit	0,8800	Passed
North Nova Education Centre	C1063 Girls Washroom B	NHC641	0,0058	Exceeds Limit	0,5700	Passed
North Nova Education Centre	C1063 Girls Washroom C	NHC642	0,0044	Passed	0,2600	Passed
North Nova Education Centre	C1063 Girls Washroom D	NHC643	0,0083	Exceeds Limit	0,8100	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
North Nova Education Centre	Custodial Closet Floor	NHC644	0,0028	Passed	0,1100	Passed
North Nova Education Centre	A1176 Boys Washroom A	NHC645	0,0010	Passed	0,1000	Passed
North Nova Education Centre	A1176 Boys Washroom B	NHC646	0,0007	Passed	0,1000	Passed
North Nova Education Centre	A1176 Boys Washroom C	NHC647	0,0013	Passed	0,1400	Passed
North Nova Education Centre	A1174 Girls Washroom A	NHC648	0,0170	Exceeds Limit	2,6000	Exceeds Limit
North Nova Education Centre	A1174 Girls Washroom B	NHC649	0,0110	Exceeds Limit	1,7000	Passed
North Nova Education Centre	A1174 Girls Washroom C	NHC650	0,0099	Exceeds Limit	1,2000	Passed
North Nova Education Centre	Custodial Closet Floor	NHC651	0,0064	Exceeds Limit	0,2100	Passed
North Nova Education Centre	Staff Washroom English Pod	NHC652	0,0015	Passed	0,2300	Passed
North Nova Education Centre	Staff Washroom Math Pod	NHC653	0,0014	Passed	0,2400	Passed
North Nova Education Centre	B1112 Cafeteria Kitchen Sink with Sprayer	NIU620	0,0019	Passed	0,1300	Passed
North Nova Education Centre	C1065 Visual Arts Sink B	NIU621	0,0044	Passed	0,1300	Passed
North River Elementary School	Fountain Outside of Gym F1	LET625	0,0000	Passed	0,1800	Passed
North River Elementary School	Staff Room Sink T11	LET629	0,0008	Passed	0,1500	Passed
North River Elementary School	Kitchen Hand Washing Sink T14	LET630	0,0078	Exceeds Limit	0,2700	Passed
North River Elementary School	Dishwasher Sprayer T15	LET631	0,0180	Exceeds Limit	0,3000	Passed
North River Elementary School	Main Kitchen Sink T16	LET632	0,0037	Passed	0,2700	Passed
North River Elementary School	Kitchen Sink by Fridge	LET633	0,0023	Passed	0,2900	Passed
North River Elementary School	First Fountain by Boys Washroom F2	LET634	0,0000	Passed	0,4000	Passed
North River Elementary School	Fountain in between Washroom F3	LET635	0,0000	Passed	0,4200	Passed
North River Elementary School	Raw Water Entering Building	LET636	0,0610	Exceeds Limit	0,1800	Passed
Northport Consolidated Elementary School	Fountain by Gym	MPQ227	0,0000	Passed	0,2500	Passed
Northport Consolidated Elementary School	Staff Room	MPQ228	0,0000	Passed	0,0470	Passed
Northport Consolidated Elementary School	Fountain in Classroom Wing	MPQ229	0,0015	Passed	0,1400	Passed
Northport Consolidated Elementary School	Room 5	NHD505	0,0000	Passed	0,0230	Passed
Northport Consolidated Elementary School	Room 5	NHD505	0,0000	Passed	0,0230	Passed
Northport Consolidated Elementary School	Room 1	NHD506	0,0000	Passed	0,0220	Passed
Northport Consolidated Elementary School	Room 1	NHD506	0,0000	Passed	0,0220	Passed
Northport Consolidated Elementary School	Staff Room	NHD507	0,0000	Passed	0,0088	Passed
Northport Consolidated Elementary School	Staff Room	NHD507	0,0000	Passed	0,0088	Passed
Northport Consolidated Elementary School	Boys #1	NHD508	0,0000	Passed	0,0100	Passed
Northport Consolidated Elementary School	Boys #1	NHD508	0,0000	Passed	0,0100	Passed
Northport Consolidated Elementary School	Boys #2	NHD509	0,0000	Passed	0,0076	Passed
Northport Consolidated Elementary School	Boys #2	NHD509	0,0000	Passed	0,0076	Passed
Northport Consolidated Elementary School	Boys #3	NHD510	0,0000	Passed	0,0071	Passed
Northport Consolidated Elementary School	Boys #3	NHD510	0,0000	Passed	0,0071	Passed
Northport Consolidated Elementary School	Boys #4	NHD511	0,0000	Passed	0,0081	Passed
Northport Consolidated Elementary School	Boys #4	NHD511	0,0000	Passed	0,0081	Passed
Northport Consolidated Elementary School	Custodial	NHD512	0,0000	Passed	0,0055	Passed
Northport Consolidated Elementary School	Custodial	NHD512	0,0000	Passed	0,0055	Passed
Northport Consolidated Elementary School	Girls #1	NHD513	0,0000	Passed	0,0100	Passed
Northport Consolidated Elementary School	Girls #1	NHD513	0,0000	Passed	0,0100	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Northport Consolidated Elementary School	Girls #2	NHD514	0,0000	Passed	0,0100	Passed
Northport Consolidated Elementary School	Girls #2	NHD514	0,0000	Passed	0,0100	Passed
Northport Consolidated Elementary School	Girls #3	NHD515	0,0000	Passed	0,0096	Passed
Northport Consolidated Elementary School	Girls #3	NHD515	0,0000	Passed	0,0096	Passed
Northport Consolidated Elementary School	Girls #4	NHD516	0,0000	Passed	0,0093	Passed
Northport Consolidated Elementary School	Girls #4	NHD516	0,0000	Passed	0,0093	Passed
Northumberland Regional High School	A1072 Library Sink	MYH270	0,0022	Passed	0,0830	Passed
Northumberland Regional High School	A1077 Sink	MYH271	0,0016	Passed	0,1400	Passed
Northumberland Regional High School	A1086 Kitchen A	MYH272	0,0010	Passed	0,1500	Passed
Northumberland Regional High School	A1086 Kitchen Sink B	MYH273	0,0000	Passed	0,0570	Passed
Northumberland Regional High School	A1086 Kitchen Sink C	MYH274	0,0006	Passed	0,0650	Passed
Northumberland Regional High School	A1086 Kitchen Sink D	MYH275	0,0005	Passed	0,0810	Passed
Northumberland Regional High School	A1089 Sink	MYH276	0,0042	Passed	0,0550	Passed
Northumberland Regional High School	A1083 Sink A	MYH277	0,0040	Passed	0,3700	Passed
Northumberland Regional High School	A1083 Sink B	MYH278	0,0020	Passed	0,1800	Passed
Northumberland Regional High School	A1084 Sink A	MYH279	0,0011	Passed	0,2200	Passed
Northumberland Regional High School	A1084 Sink B	MYH280	0,0021	Passed	0,1300	Passed
Northumberland Regional High School	CEP Kitchen Sink A	MYH281	0,0190	Exceeds Limit	0,1000	Passed
Northumberland Regional High School	CEP Kitchen Sink B	MYH282	0,0023	Passed	0,2600	Passed
Northumberland Regional High School	CEP Kitchen Handwash	MYH283	0,0065	Exceeds Limit	0,0890	Passed
Northumberland Regional High School	Fountain A	MYH284	0,0000	Passed	0,8800	Passed
Northumberland Regional High School	Fountain B	MYH285	0,0005	Passed	0,2500	Passed
Northumberland Regional High School	Fountain C	MYH286	0,0000	Passed	0,5600	Passed
Northumberland Regional High School	Fountain D	MYH287	0,0000	Passed	0,1600	Passed
Northumberland Regional High School	Fountain E	MYH288	0,0000	Passed	0,1100	Passed
Northumberland Regional High School	1122 in Music Room Sink	MYH289	0,0032	Passed	0,0690	Passed
Northumberland Regional High School	Kitchen Handwash	MYH290	0,0009	Passed	0,0970	Passed
Northumberland Regional High School	Kitchen Dishwash Sink A	MYH291	0,0019	Passed	0,0570	Passed
Northumberland Regional High School	Kitchen Dishwash Sink B	MYH292	0,0038	Passed	0,1500	Passed
Northumberland Regional High School	Kitchen Dishwash Sink C	MYH293	0,0006	Passed	0,0750	Passed
Northumberland Regional High School	Kitchen Dishwash Sink D	MYH294	0,0000	Passed	0,0890	Passed
Northumberland Regional High School	Kitchen Sprayer	MYH295	0,0160	Exceeds Limit	0,1500	Passed
Northumberland Regional High School	Room 2044	MYH296	0,0005	Passed	0,1300	Passed
Northumberland Regional High School	Fountain F	MYH297	0,0000	Passed	0,1100	Passed
Northumberland Regional High School	Fountain G	MYH298	0,0000	Passed	0,3000	Passed
Northumberland Regional High School	Fountain H	MYH299	0,0000	Passed	0,2200	Passed
Northumberland Regional High School	Fountain I	MYH300	0,0000	Passed	0,2800	Passed
Northumberland Regional High School	A2059	MYH301	0,0160	Exceeds Limit	0,2300	Passed
Northumberland Regional High School	A2060 Sink A	MYH302	0,0079	Exceeds Limit	0,0490	Passed
Northumberland Regional High School	A2060 Sink B	MYH303	0,0008	Passed	0,2300	Passed
Northumberland Regional High School	A2060 Sink C	MYH304	0,0055	Exceeds Limit	0,1500	Passed
Northumberland Regional High School	Kitchen Sprayer	NIU713	0,0022	Passed	0,0570	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Oxford Regional Education Centre	Wood Tech Shop	MSG858	0,0010	Passed	0,4000	Passed
Oxford Regional Education Centre	Mechanical Room	MSG859	0,0000	Passed	0,4300	Passed
Oxford Regional Education Centre	Fountain 1st Floor	MSG860	0,0000	Passed	0,1600	Passed
Oxford Regional Education Centre	Room 110	MSG861	0,0000	Passed	0,7100	Passed
Oxford Regional Education Centre	Room 206	MSG862	0,0013	Passed	0,6100	Passed
Oxford Regional Education Centre	Room 207	MSG863	0,0006	Passed	0,4700	Passed
Oxford Regional Education Centre	Room 208	MSG864	0,0000	Passed	0,5000	Passed
Oxford Regional Education Centre	Room 215	MSG865	0,0000	Passed	0,4500	Passed
Oxford Regional Education Centre	Room 216	MSG866	0,0067	Exceeds Limit	0,6400	Passed
Oxford Regional Education Centre	Room 217	MSG867	0,0000	Passed	0,5200	Passed
Oxford Regional Education Centre	Library	MSG868	0,0045	Passed	1,5000	Passed
Oxford Regional Education Centre	Fountain 2nd by Café	MSG869	0,0000	Passed	0,2800	Passed
Oxford Regional Education Centre	Cafeteria #1	MSG870	0,0011	Passed	0,4900	Passed
Oxford Regional Education Centre	Cafeteria #2	MSG871	0,0019	Passed	0,4000	Passed
Oxford Regional Education Centre	Visual Art #1	MSG872	0,0005	Passed	0,4400	Passed
Oxford Regional Education Centre	Visual Art #2	MSG873	0,0021	Passed	0,4500	Passed
Oxford Regional Education Centre	Fountain by Gym	MSG874	0,0005	Passed	0,8400	Passed
Oxford Regional Education Centre	Staff Room 3rd Floor	MSG875	0,0005	Passed	0,5000	Passed
Oxford Regional Education Centre	Fountain 3rd Floor	MSG876	0,0000	Passed	0,2400	Passed
Oxford Regional Education Centre	Nutrition #1	MSG877	0,0006	Passed	0,5300	Passed
Oxford Regional Education Centre	Nutrition #2	MSG878	0,0012	Passed	0,5400	Passed
Oxford Regional Education Centre	Nutrition #3	MSG879	0,0008	Passed	0,5300	Passed
Oxford Regional Education Centre	Nutrition #4	MSG880	0,0000	Passed	0,5500	Passed
Oxford Regional Education Centre	Nutrition #5	MSG881	0,0022	Passed	0,6900	Passed
Oxford Regional Education Centre	Music Room	MSG882	0,0000	Passed	0,4900	Passed
Oxford Regional Education Centre	Room 216	NU567	0,0000	Passed	0,3500	Passed
Parrsboro Regional Elementary School	Staff Room	MOZ014	0,0018	Passed	6,1000	Exceeds Limit
Parrsboro Regional Elementary School	Fountain Upper Hall	MOZ015	0,0072	Exceeds Limit	4,5000	Exceeds Limit
Parrsboro Regional Elementary School	Room 202	MOZ016	0,0058	Exceeds Limit	4,0000	Exceeds Limit
Parrsboro Regional Elementary School	Room 204	MOZ017	0,0210	Exceeds Limit	2,3000	Exceeds Limit
Parrsboro Regional Elementary School	Room 206	MOZ018	0,0070	Exceeds Limit	1,3000	Passed
Parrsboro Regional Elementary School	Room 208	MOZ019	0,0020	Passed	3,9000	Exceeds Limit
Parrsboro Regional Elementary School	Gym Office	MOZ020	0,1300	Exceeds Limit	6,0000	Exceeds Limit
Parrsboro Regional Elementary School	Library	MOZ021	0,1800	Exceeds Limit	1,8000	Passed
Parrsboro Regional Elementary School	Fountain Lower Hall	MPQ252	0,0013	Passed	5,2000	Exceeds Limit
Parrsboro Regional High School	Staff Room	MOZ162	0,0060	Exceeds Limit	3,2000	Exceeds Limit
Parrsboro Regional High School	Room 112	MOZ163	0,0034	Passed	1,1000	Passed
Parrsboro Regional High School	Fountain Lower Hall	MOZ164	0,0039	Passed	1,4000	Passed
Parrsboro Regional High School	Room 107 Sink #1	MOZ165	0,2200	Exceeds Limit	0,4000	Passed
Parrsboro Regional High School	Room 107 Sink #2	MOZ166	0,4000	Exceeds Limit	0,3900	Passed
Parrsboro Regional High School	Room 108 Sink #1	MOZ167	0,0200	Exceeds Limit	3,8000	Exceeds Limit
Parrsboro Regional High School	Room 108 Sink #2	MOZ168	0,0110	Exceeds Limit	3,4000	Exceeds Limit



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Parrsboro Regional High School	Room 108 Sink #3	MOZ169	0,0090	Exceeds Limit	2,6000	Exceeds Limit
Parrsboro Regional High School	Cafeteria Sink #1	MOZ170	0,0400	Exceeds Limit	1,9000	Passed
Parrsboro Regional High School	Cafeteria Sink #2	MOZ171	0,0660	Exceeds Limit	1,4000	Passed
Parrsboro Regional High School	Cafeteria Laundry Sink	MOZ172	0,0034	Passed	0,6700	Passed
Parrsboro Regional High School	Food Lab #1	MOZ173	0,0048	Passed	2,0000	Passed
Parrsboro Regional High School	Food Lab #2	MOZ174	0,0087	Exceeds Limit	1,3000	Passed
Parrsboro Regional High School	Food Lab #3	MOZ175	0,0044	Passed	2,3000	Exceeds Limit
Parrsboro Regional High School	Food Lab #4	MOZ176	0,0180	Exceeds Limit	1,2000	Passed
Parrsboro Regional High School	Fountain Front Lobby	MOZ177	0,0018	Passed	2,1000	Exceeds Limit
Parrsboro Regional High School	Fountain Upper Hall	MOZ178	0,0055	Exceeds Limit	1,4000	Passed
Parrsboro Regional High School	Room 202	MOZ179	0,0500	Exceeds Limit	0,2100	Passed
Parrsboro Regional High School	Boiler Room	MOZ180	0,0008	Passed	4,7000	Exceeds Limit
Parrsboro Regional High School	Gym Office	NCP513	0,0006	Passed	0,6100	Passed
Parrsboro Regional High School	Boys Locker #1	NCP514	0,0014	Passed	5,2000	Exceeds Limit
Parrsboro Regional High School	Boys Locker #2	NCP515	0,0013	Passed	5,3000	Exceeds Limit
Parrsboro Regional High School	Girl Locker #1	NCP516	0,0013	Passed	5,3000	Exceeds Limit
Parrsboro Regional High School	Girl Locker #2	NCP517	0,0014	Passed	5,4000	Exceeds Limit
Parrsboro Regional High School	Lower Custodial Sink	NCP518	0,0021	Passed	1,9000	Passed
Parrsboro Regional High School	Staff #1	NCP519	0,0016	Passed	2,4000	Exceeds Limit
Parrsboro Regional High School	Staff #2	NCP520	0,0020	Passed	1,5000	Passed
Parrsboro Regional High School	Room 214 #1	NCP521	0,0000	Passed	0,2600	Passed
Parrsboro Regional High School	Room 214 #2	NCP522	0,0000	Passed	0,2900	Passed
Parrsboro Regional High School	Room 214 #3	NCP523	0,0000	Passed	0,3100	Passed
Parrsboro Regional High School	Room 214 #4	NCP524	0,0006	Passed	0,3000	Passed
Parrsboro Regional High School	Room 213 #1	NCP525	0,0008	Passed	0,4400	Passed
Parrsboro Regional High School	Room 213 #2	NCP526	0,0000	Passed	0,2900	Passed
Parrsboro Regional High School	Room 213 #3	NCP527	0,0000	Passed	0,2700	Passed
Parrsboro Regional High School	Room 213 #4	NCP528	0,0012	Passed	0,3600	Passed
Parrsboro Regional High School	Upper Custodial	NCP529	0,0013	Passed	0,5200	Passed
Pictou Academy	Source - Municipal	MTG917	0,0028	Passed	0,1200	Passed
Pictou Academy	Staff Room Kitchen Taps	MTG918	0,0017	Passed	0,2100	Passed
Pictou Academy	Fountain 1st Floor	MTG919	0,0010	Passed	0,3500	Passed
Pictou Academy	Room 104	MTG920	0,0039	Passed	0,0840	Passed
Pictou Academy	Room 105	MTH055	0,0052	Exceeds Limit	0,0230	Passed
Pictou Academy	Family Studies, Sink A	MTH056	0,3200	Exceeds Limit	0,8700	Passed
Pictou Academy	Family Studies, Sink B	MTH057	0,0068	Exceeds Limit	0,0360	Passed
Pictou Academy	Family Studies, Sink C	MTH058	0,0180	Exceeds Limit	0,1700	Passed
Pictou Academy	Family Studies, Sink D	MTH059	0,0017	Passed	0,0190	Passed
Pictou Academy	Family Studies, Sink E	MTH060	0,0011	Passed	0,0130	Passed
Pictou Academy	Fountain 2nd Floor	MTH061	0,0230	Exceeds Limit	0,0980	Passed
Pictou Academy	Photocopy Room Sink	MTH062	0,0008	Passed	0,0130	Passed
Pugwash District High School	Cafeteria Sink #1	MOP845	0,0006	Passed	0,0950	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Pugwash District High School	Cafeteria Sink #2	MOP846	0,0000	Passed	0,0990	Passed
Pugwash District High School	Fountain - Cafeteria	MOP847	0,0000	Passed	0,0330	Passed
Pugwash District High School	Fountain - Gym	MOP848	0,0005	Passed	0,1700	Passed
Pugwash District High School	Fountain - Lower Lobby	MOP849	0,0000	Passed	0,3000	Passed
Pugwash District High School	Music Room	MOP850	0,0017	Passed	0,0680	Passed
Pugwash District High School	Learning Centre	MOP851	0,0000	Passed	0,0860	Passed
Pugwash District High School	Staff Room	MOP852	0,0000	Passed	0,0980	Passed
Pugwash District High School	Room #109 Lab	MOP853	0,0030	Passed	0,0950	Passed
Pugwash District High School	Room #122	MOP854	0,0014	Passed	0,1000	Passed
Pugwash District High School	Main Office	MOP855	0,0054	Exceeds Limit	0,1300	Passed
Pugwash District High School	Fountain by Office	MOP856	0,0000	Passed	0,5200	Passed
Pugwash District High School	Food Lab Sink #1	MOP857	0,0013	Passed	0,0750	Passed
Pugwash District High School	Food Lab Sink #2	MOP858	0,0028	Passed	0,0990	Passed
Pugwash District High School	Food Lab Sink #3	MOP859	0,0019	Passed	0,0820	Passed
Pugwash District High School	Food Lab Sink #4	MOP860	0,0013	Passed	0,0800	Passed
Pugwash District High School	Room 102 Sink	MOP861	0,0013	Passed	0,0960	Passed
Pugwash District High School	Fountain Junior Wing	MOP862	0,0000	Passed	1,2000	Passed
Pugwash District High School	Library Storage Room Sink	MOP863	0,0022	Passed	0,0920	Passed
Pugwash District High School	Fountain Upper Circle	MOP864	0,0015	Passed	0,5000	Passed
Pugwash District High School	Art Lab Sink #1	MOP865	0,0055	Exceeds Limit	0,0810	Passed
Pugwash District High School	Art Lab Sink #2	MOP866	0,0016	Passed	0,1200	Passed
Pugwash District High School	Room J	NIK935	0,0000	Passed	0,0760	Passed
Pugwash District High School	Café Hand Sink	NU597	0,0013	Passed	0,0880	Passed
Pugwash District High School	Girls Locker #1	NU598	0,0000	Passed	0,0800	Passed
Pugwash District High School	Girls Locker #2	NU599	0,0000	Passed	0,0730	Passed
Pugwash District High School	Girls Locker #3	NU600	0,0000	Passed	0,0730	Passed
Pugwash District High School	Boys Locker #1	NU601	0,0000	Passed	0,1100	Passed
Pugwash District High School	Boys Locker #2	NU602	0,0000	Passed	0,1100	Passed
Pugwash District High School	Boys Locker #3	NU603	0,0000	Passed	0,1200	Passed
Pugwash District High School	Gym #1	NU604	0,0008	Passed	0,1200	Passed
Pugwash District High School	Gym #2	NU605	0,0007	Passed	0,0920	Passed
Pugwash District High School	Lobby Girls #1	NU606	0,0006	Passed	0,0380	Passed
Pugwash District High School	Lobby Girls #3	NU607	0,0000	Passed	0,0400	Passed
Pugwash District High School	Lobby Boys #1	NU608	0,0000	Passed	0,0400	Passed
Pugwash District High School	Lobby Boys #3	NU610	0,0000	Passed	0,0400	Passed
Pugwash District High School	Lower Lobby Custodial	NU611	0,0000	Passed	0,0380	Passed
Pugwash District High School	Room 145 #1	NU612	0,0000	Passed	0,0230	Passed
Pugwash District High School	Room 145 #2	NU613	0,0000	Passed	0,0270	Passed
Pugwash District High School	Room 131 #2	NU615	0,0000	Passed	0,0490	Passed
Pugwash District High School	Staff #1	NU616	0,0000	Passed	0,1700	Passed
Pugwash District High School	Staff #2	NU617	0,0000	Passed	0,1700	Passed
Pugwash District High School	Room 129	NU618	0,0009	Passed	0,1100	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Pugwash District High School	Main Office	NU619	0,0012	Passed	0,1100	Passed
Pugwash District High School	Room 119 #1	NU620	0,0006	Passed	0,0750	Passed
Pugwash District High School	Room 119 #2	NU621	0,0000	Passed	0,0750	Passed
Pugwash District High School	Room 118 #1	NU622	0,0006	Passed	0,0750	Passed
Pugwash District High School	Room 118 #2	NU623	0,0005	Passed	0,0770	Passed
Pugwash District High School	Room 118 #3	NU624	0,0019	Passed	0,0760	Passed
Pugwash District High School	Room 118 #4	NU625	0,0007	Passed	0,0810	Passed
Pugwash District High School	Lower Circle Custodial	NU626	0,0008	Passed	0,0820	Passed
Pugwash District High School	Room 221	NU627	0,0015	Passed	0,1200	Passed
Pugwash District High School	Room 220	NU628	0,0006	Passed	0,0930	Passed
Pugwash District High School	Upper Circle Custodial	NU629	0,0009	Passed	0,0810	Passed
Pugwash District High School	Upper Girls #1	NU630	0,0006	Passed	0,0740	Passed
Pugwash District High School	Upper Girls #2	NU631	0,0000	Passed	0,0720	Passed
Pugwash District High School	Upper Girls #3	NU632	0,0000	Passed	0,0730	Passed
Pugwash District High School	Upper Girls #4	NU633	0,0000	Passed	0,0710	Passed
Pugwash District High School	Upper Boys #1	NU634	0,0000	Passed	0,0760	Passed
Pugwash District High School	Upper Boys #2	NU635	0,0000	Passed	0,0730	Passed
Pugwash District High School	Upper Boys #3	NU636	0,0000	Passed	0,0720	Passed
Rawdon District Elementary School	Fountain Main Level	LCP155	0,0200	Exceeds Limit	0,2000	Passed
Rawdon District Elementary School	Main Tap in Kitchen	LCP156	0,0470	Exceeds Limit	0,1400	Passed
Rawdon District Elementary School	Hand Washing Tap Kitchen	LCP157	0,0630	Exceeds Limit	0,6600	Passed
Rawdon District Elementary School	New Fountain Upstairs	LCP158	0,0044	Passed	0,1800	Passed
Rawdon District Elementary School	Staff Room Tap Upstairs	LCP159	0,1000	Exceeds Limit	0,6200	Passed
Rawdon District Elementary School	Raw Water on Pressure Tank	LCP160	0,0021	Passed	0,0130	Passed
Redcliff Middle School	Boiler Room, T1	MOY814	0,0150	Exceeds Limit	0,1700	Passed
Redcliff Middle School	Tap on Left in Music Room, T2	MOY815	0,0016	Passed	0,1700	Passed
Redcliff Middle School	Tap on Right in Music Room, T3	MOY816	0,0026	Passed	0,1900	Passed
Redcliff Middle School	Tech Ed Room, T4	MOY817	0,0015	Passed	0,1700	Passed
Redcliff Middle School	Against wall in Family Studies, T7	MOY818	0,0024	Passed	0,3200	Passed
Redcliff Middle School	Tap 1st one to right in Family Studies, T9	MOY819	0,0033	Passed	0,3700	Passed
Redcliff Middle School	Tap 2nd to right in Family Studies, T6	MOY820	0,0150	Exceeds Limit	0,2300	Passed
Redcliff Middle School	Tap 1st one to left in Family Studies, T8	MOY821	0,0220	Exceeds Limit	0,2200	Passed
Redcliff Middle School	Tap 2nd one to left in Family Studies, T5	MOY822	0,0080	Exceeds Limit	0,4200	Passed
Redcliff Middle School	Tap in Library Office, T13	MOY823	0,0012	Passed	0,4000	Passed
Redcliff Middle School	Tap on Island in Kitchen, T21	MOY824	0,0038	Passed	0,3200	Passed
Redcliff Middle School	Main Tap in Kitchen, T23	MOY825	0,0009	Passed	0,3200	Passed
Redcliff Middle School	Fountain outside Custodian Room, F1	MOY826	0,0000	Passed	0,0670	Passed
Redcliff Middle School	Fountain across from Room 1055, F2	MOY827	0,0000	Passed	0,2000	Passed
Redcliff Middle School	Fountain across from Room 1060, F3	MOY828	0,0000	Passed	0,1900	Passed
Redcliff Middle School	Staff Room Tap to the Left, T40	MOY829	0,0029	Passed	0,3600	Passed
Redcliff Middle School	Staff Room Tap to the Right, T39	MOY830	0,0000	Passed	0,4500	Passed
Redcliff Middle School	Learning Centre Tap on Hallway Wall, T41	MOY831	0,0006	Passed	0,4000	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Redcliff Middle School	Learning Centre to the Left, T43	MOY832	0,0025	Passed	0,1500	Passed
Redcliff Middle School	Fountain across from Room 1080, F4	MOY833	0,0000	Passed	0,3800	Passed
Redcliff Middle School	Art Room Tap first on right, T52	MOY834	0,0007	Passed	0,5300	Passed
Redcliff Middle School	Art Room Tap 2nd on right, T53	MOY835	0,0012	Passed	0,6400	Passed
Redcliff Middle School	Cafeteria Kit. 1008A, Dish Spray Sink, T24	NDR343	0,0061	Exceeds Limit	0,2300	Passed
Redcliff Middle School	Custodial 1003A Floor Sink, T25	NDR344	0,0024	Passed	0,5600	Passed
Redcliff Middle School	Boys Washroom 1044, Left Tap, T26	NDR345	0,0014	Passed	0,1900	Passed
Redcliff Middle School	Boys Washroom 1044, Middle Tap, T27	NDR346	0,0017	Passed	0,2700	Passed
Redcliff Middle School	Boys Washroom 1044 Right Tap, T28	NDR347	0,0016	Passed	0,1500	Passed
Redcliff Middle School	Girls Washroom 1045, Left Tap, T29	NDR348	0,0013	Passed	0,3700	Passed
Redcliff Middle School	Girls Washroom 1045, Middle Tap, T30	NDR349	0,0015	Passed	0,2300	Passed
Redcliff Middle School	Girls Washroom 1045, Right Tap, T31	NDR350	0,0010	Passed	0,2200	Passed
Redcliff Middle School	Science Lab 1052 Counter Sink, T33	NDR351	0,0120	Exceeds Limit	0,0590	Passed
Redcliff Middle School	Boys Washroom 1018 Left Tap, T10	NDR352	0,0007	Passed	0,1200	Passed
Redcliff Middle School	Boys Washroom 1018 Middle Tap, T11	NDR353	0,0024	Passed	0,2300	Passed
Redcliff Middle School	Boys Washroom 1018 Right Tap, T12	NDR354	0,0012	Passed	0,1300	Passed
Redcliff Middle School	Girls Washroom 1017 Left Tap, T14	NDR355	0,0007	Passed	0,1800	Passed
Redcliff Middle School	Girls Washroom 1017 Middle Tap, T15	NDR356	0,0016	Passed	0,2000	Passed
Redcliff Middle School	Girls Washroom 1017, Right Tap, T16	NDR357	0,0010	Passed	0,0740	Passed
Redcliff Middle School	Girls Locker 1014, T17	NDR358	0,0016	Passed	0,1200	Passed
Redcliff Middle School	Gym Office 1015, T18	NDR359	0,0018	Passed	0,3600	Passed
Redcliff Middle School	Gym Office 1012, T19	NDR360	0,0021	Passed	0,2600	Passed
Redcliff Middle School	Boys Locker 1011, T20	NDR361	0,0007	Passed	0,2200	Passed
Redcliff Middle School	Science Lab 1052 Counter Sink, Left Tap, T34	NDR362	0,0120	Exceeds Limit	0,0470	Passed
Redcliff Middle School	Staff Washroom 1100, T35	NDR363	0,0043	Passed	0,2900	Passed
Redcliff Middle School	Sick Room 1-1097 Hand Wash Sink, T36	NDR364	0,0031	Passed	0,5200	Passed
Redcliff Middle School	Sick Room 2 -1096 Hand Wash Sink, T37	NDR365	0,0018	Passed	0,6300	Passed
Redcliff Middle School	Staff Washroom 1099, T38	NDR366	0,0025	Passed	0,2900	Passed
Redcliff Middle School	Resource Washroom 1085, T44	NDR367	0,0010	Passed	0,2800	Passed
Redcliff Middle School	Boys Washroom 1083, Left Tap, T45	NDR368	0,0012	Passed	0,2200	Passed
Redcliff Middle School	Boys Washroom 1083 Middle Tap, T46	NDR369	0,0016	Passed	0,1800	Passed
Redcliff Middle School	Boys Washroom 1083 Right Tap, T47	NDR370	0,0015	Passed	0,1500	Passed
Redcliff Middle School	Girls Washroom Left Tap, T48	NDR371	0,0011	Passed	0,1600	Passed
Redcliff Middle School	Girls Washroom Middle Tap, T49	NDR372	0,0017	Passed	0,3100	Passed
Redcliff Middle School	Girls Washroom Right Tap, T50	NDR373	0,0010	Passed	0,3300	Passed
Redcliff Middle School	Custodial 1068A Floor Sink, T51	NDR374	0,0072	Exceeds Limit	0,4600	Passed
Redcliff Middle School	Cafeteria Kitchen Hand Sink	NDR375	0,0012	Passed	0,3200	Passed
River Hebert District School	Food Lab #1	LKO206	0,0024	Passed	0,0150	Passed
River Hebert District School	Food Lab #2	LKO207	0,0059	Exceeds Limit	0,1700	Passed
River Hebert District School	Café #2	LKO208	0,0000	Passed	0,0006	Passed
River Hebert District School	Science Room Sink	LKO209	0,0007	Passed	0,0250	Passed
River Hebert District School	Source	LKO210	0,0070	Exceeds Limit	0,1200	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
River Hebert District School	Custodial Closet Lower Hall	NDQ960	0,0000	Passed	0,0200	Passed
River Hebert District School	Youth Health	NDQ961	0,0018	Passed	3,0000	Exceeds Limit
River Hebert District School	Lower Girls #1	NDQ962	0,0006	Passed	0,0250	Passed
River Hebert District School	Lower Girls #2	NDQ963	0,0037	Passed	0,1900	Passed
River Hebert District School	Lower Girls #3	NDQ964	0,0000	Passed	0,1100	Passed
River Hebert District School	Lower Boys #1	NDQ965	0,0220	Exceeds Limit	0,4800	Passed
River Hebert District School	Lower Boys #2	NDQ966	0,0000	Passed	0,0390	Passed
River Hebert District School	Lower Boys #3	NDQ967	0,0020	Passed	0,0920	Passed
River Hebert District School	Boys Locker Room	NDQ968	0,0006	Passed	0,1400	Passed
River Hebert District School	Girls Locker Room	NDQ969	0,0000	Passed	0,0120	Passed
River Hebert District School	Learning Centre	NDQ970	0,0000	Passed	0,0047	Passed
River Hebert District School	Primary Washroom	NDQ971	0,0000	Passed	0,0200	Passed
River Hebert District School	Main Boys #1	NDQ972	0,0000	Passed	0,0052	Passed
River Hebert District School	Main Boys #2	NDQ973	0,0000	Passed	0,0043	Passed
River Hebert District School	Main Girls #1	NDQ974	0,0000	Passed	0,0054	Passed
River Hebert District School	Main Girls #2	NDQ975	0,0000	Passed	0,0045	Passed
River Hebert District School	Custodial Closet By Gym	NDQ976	0,0007	Passed	0,0051	Passed
River Hebert District School	Main Office	NDQ977	0,0000	Passed	0,0014	Passed
River Hebert District School	Upper Girls #1	NDQ978	0,0085	Exceeds Limit	0,2500	Passed
River Hebert District School	Upper Girls #2	NDQ979	0,0099	Exceeds Limit	0,2100	Passed
River Hebert District School	Upper Girls #3	NDQ980	0,0060	Exceeds Limit	0,2100	Passed
River Hebert District School	Upper Boys #1	NDQ981	0,0014	Passed	0,0420	Passed
River Hebert District School	Upper Boys #2	NDQ982	0,0010	Passed	0,0300	Passed
River Hebert District School	Upper Boys #3	NDQ983	0,0014	Passed	0,0340	Passed
River Hebert District School	Upper Custodial Closet	NDQ984	0,0006	Passed	0,0040	Passed
River Hebert District School	Washroom By Elevator	NDQ985	0,0000	Passed	0,2600	Passed
River Hebert District School	Staff Washroom	NDQ986	0,0000	Passed	0,0110	Passed
Riverside Education Centre	Left Fountain by Room 1166, F1	MSH580	0,0005	Passed	0,0640	Passed
Riverside Education Centre	Left Fountain by Room 1161, F2	MSH581	0,0000	Passed	0,0640	Passed
Riverside Education Centre	Kitchen Tap, Room 1161, T14	MSH582	0,0150	Exceeds Limit	0,2400	Passed
Riverside Education Centre	Kitchen Tap, Room 1164, T15	MSH583	0,0140	Exceeds Limit	0,1100	Passed
Riverside Education Centre	Design & Tech Rm Kitchen, T17	MSH584	0,0140	Exceeds Limit	0,2400	Passed
Riverside Education Centre	Fountain by Room 1136, F3	MSH585	0,0000	Passed	0,0680	Passed
Riverside Education Centre	Fountain by Room 1131, F4	MSH586	0,0020	Passed	0,0710	Passed
Riverside Education Centre	Room 1136, Kitchen Tap, T25	MSH587	0,0050	Passed	0,0880	Passed
Riverside Education Centre	Room 1133, Kitchen Tap, T32	MSH588	0,0140	Exceeds Limit	0,1200	Passed
Riverside Education Centre	Kitchen Main Sink Tap, T36	MSH589	0,0024	Passed	0,1700	Passed
Riverside Education Centre	Kitchen Island Sink Tap, T35	MSH590	0,0024	Passed	0,0800	Passed
Riverside Education Centre	Special Needs Kitchen Tap, T39	MSH591	0,0018	Passed	0,0960	Passed
Riverside Education Centre	Special Needs Tap by Washer, T42	MSH592	0,0170	Exceeds Limit	0,1300	Passed
Riverside Education Centre	Fountain by Room 2166, F5	MSH593	0,0006	Passed	0,0880	Passed
Riverside Education Centre	Fountain by Room 2161, F6	MSH594	0,0000	Passed	0,0780	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Riverside Education Centre	Kitchen Tap, Room 2161, T54	MSH595	0,0094	Exceeds Limit	0,1200	Passed
Riverside Education Centre	Kitchen Tap, Room 2164, T56	MSH596	0,0110	Exceeds Limit	0,1600	Passed
Riverside Education Centre	Family Studies 1st Kitchen Tap by Entrance, T57	MSH597	0,0120	Exceeds Limit	0,3600	Passed
Riverside Education Centre	Family Studies 1st Kitchen Tap on Left, T59	MSH598	0,0120	Exceeds Limit	0,2000	Passed
Riverside Education Centre	Family Studies 2nd Kitchen Tap on Left, T61	MSH599	0,0130	Exceeds Limit	0,2000	Passed
Riverside Education Centre	Family Studies 1st Kitchen Tap on Right, T60	MSH600	0,0090	Exceeds Limit	0,1700	Passed
Riverside Education Centre	Family Studies 2nd Kitchen Tap on Right, T62	MSH601	0,0094	Exceeds Limit	0,1900	Passed
Riverside Education Centre	Family Studies Kitchen Tap on Far Wall, T58	MSH602	0,0100	Exceeds Limit	0,1100	Passed
Riverside Education Centre	IGS Room, T64	MSH603	0,0110	Exceeds Limit	0,2300	Passed
Riverside Education Centre	Room off Library Kitchen Tap, T63	MSH604	0,0230	Exceeds Limit	0,1800	Passed
Riverside Education Centre	Fountain Outside of Staff Room, F7	MSH605	0,0000	Passed	0,0840	Passed
Riverside Education Centre	Staff Room Kitchen Tap, T67	MSH606	0,0008	Passed	0,1300	Passed
Riverside Education Centre	Tap in WashRoom, T68	MSH607	0,0210	Exceeds Limit	0,1200	Passed
Riverside Education Centre	Fountain by Room 2136, F8	MSH608	0,0012	Passed	0,0850	Passed
Riverside Education Centre	Fountain by Room 2131, F9	MSH609	0,0010	Passed	0,0730	Passed
Riverside Education Centre	Kitchen Tap, Room 2136, T77	MSH610	0,0110	Exceeds Limit	0,1300	Passed
Riverside Education Centre	Kitchen Tap, Room 2133, T84	MSH611	0,0110	Exceeds Limit	0,0990	Passed
Riverside Education Centre	Main Office Kitchen Tap, T86	MSH612	0,0098	Exceeds Limit	0,1400	Passed
Riverside Education Centre	Fountain Outside Music Room, F10	MSH613	0,0000	Passed	0,1100	Passed
Riverside Education Centre	Room off Music Room Kitchen Tap, T96	MSH614	0,0340	Exceeds Limit	0,1500	Passed
Riverside Education Centre	Fountain by Boys Locker Room, F11	MSH615	0,0022	Passed	0,1100	Passed
Riverside Education Centre	Fountain by Girls Locker Room, F12	MSH616	0,0008	Passed	0,1200	Passed
Salt Springs Elementary School	Source - Well	MOQ041	0,0120	Exceeds Limit	0,1200	Passed
Salt Springs Elementary School	Office 001 Principal's Office Sink	MOQ042	0,0450	Exceeds Limit	0,0830	Passed
Salt Springs Elementary School	Office 019 Staff Rm Sink	MOQ043	0,0066	Exceeds Limit	0,0490	Passed
Salt Springs Elementary School	Kitchen Sink A	MOQ044	0,0012	Passed	0,0330	Passed
Salt Springs Elementary School	Kitchen Sink B	MOQ045	0,0021	Passed	0,0630	Passed
Salt Springs Elementary School	Classroom 010	MOQ046	0,0170	Exceeds Limit	0,0560	Passed
Salt Springs Elementary School	Classroom 012	MOQ047	0,0067	Exceeds Limit	0,0470	Passed
Salt Springs Elementary School	Classroom 014	MOQ048	0,0096	Exceeds Limit	0,0540	Passed
Salt Springs Elementary School	Classroom 015	MOQ049	0,0043	Passed	0,0650	Passed
Salt Springs Elementary School	Classroom 016	MOQ050	0,0230	Exceeds Limit	0,0330	Passed
Salt Springs Elementary School	Classroom 017	MOQ051	0,0051	Exceeds Limit	0,0560	Passed
Salt Springs Elementary School	Classroom 013	MOQ052	0,0073	Exceeds Limit	0,0570	Passed
Salt Springs Elementary School	Classroom 011	MOQ053	0,0031	Passed	0,0520	Passed
Salt Springs Elementary School	Fountain in Entry Way	MOQ054	0,0020	Passed	0,0290	Passed
Salt Springs Elementary School	Fountain Classroom Hallway	MOQ055	0,0000	Passed	0,2300	Passed
Salt Springs Elementary School	Fountain in Gym	MOQ056	0,0033	Passed	0,0420	Passed
Salt Springs Elementary School	Custodial Closet	NKE372	0,1300	Exceeds Limit	0,4300	Passed
Salt Springs Elementary School	Gym Washroom Girls	NKE373	0,0150	Exceeds Limit	0,3500	Passed
Salt Springs Elementary School	Gym Washroom Boys	NKE374	0,0009	Passed	0,0360	Passed
Salt Springs Elementary School	Staff Washroom Hall	NKE375	0,0019	Passed	0,0380	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Salt Springs Elementary School	Staff Washroom Office	NKE376	0,0110	Exceeds Limit	0,1100	Passed
Salt Springs Elementary School	Washroom Girls 1 Sink A	NKE377	0,0017	Passed	0,0370	Passed
Salt Springs Elementary School	Washroom Girls 1 Sink B	NKE378	0,0030	Passed	0,0540	Passed
Salt Springs Elementary School	Washroom Girls 1 Sink C	NKE379	0,0042	Passed	0,0510	Passed
Salt Springs Elementary School	Hall Janitor Closet	NKE380	0,0074	Exceeds Limit	0,0630	Passed
Salt Springs Elementary School	Washroom Boys 1 Sink A	NKE381	0,0061	Exceeds Limit	0,0420	Passed
Salt Springs Elementary School	Washroom Boys 1 Sink B	NKE382	0,0071	Exceeds Limit	0,0690	Passed
Salt Springs Elementary School	Washroom Boys 1 Sink C	NKE383	0,0056	Exceeds Limit	0,0570	Passed
Salt Springs Elementary School	Washroom PP Girls Sink	NKE384	0,0031	Passed	0,0430	Passed
Salt Springs Elementary School	Washroom PP Boys Sink	NKE385	0,0019	Passed	0,0340	Passed
Scotsburn Elementary School	Rm 107 Office Treatment Rm	LCP053	0,0021	Passed	0,1600	Passed
Scotsburn Elementary School	Rm 109 Staff Rm	LCP054	0,0240	Exceeds Limit	0,0940	Passed
Scotsburn Elementary School	Rm 110 Classroom	LCP055	0,0190	Exceeds Limit	0,1100	Passed
Scotsburn Elementary School	Rm 154 Sprinkler Rm	LCP056	0,0009	Passed	0,1100	Passed
Scotsburn Elementary School	Rm 154 Sprinkler Rm	LCP057	0,0110	Exceeds Limit	0,0260	Passed
Scotsburn Elementary School	Rm 124 Classroom	LCP058	0,0027	Passed	0,1200	Passed
Scotsburn Elementary School	Rm 125 Classroom	LCP059	0,0019	Passed	0,1100	Passed
Scotsburn Elementary School	Rm 135 Kitchen Sink A	LCP060	0,0013	Passed	0,0670	Passed
Scotsburn Elementary School	Rm 135 Kitchen Sink B	LCP061	0,0017	Passed	0,0950	Passed
Scotsburn Elementary School	Rm 142 Preprimary	LCP062	0,0230	Exceeds Limit	0,0830	Passed
Scotsburn Elementary School	Corridor 2 Hallway Fountain	LCP065	0,0000	Passed	0,3200	Passed
Shubenacadie District Elementary School	Fountain Across from Room 152, F1	MSW132	0,0063	Exceeds Limit	0,8200	Passed
Shubenacadie District Elementary School	Room 156, Kitchen Tap, T8	MSW133	0,0033	Passed	0,5400	Passed
Shubenacadie District Elementary School	Fountain By Office, F3	MSW134	0,0160	Exceeds Limit	1,3000	Passed
Shubenacadie District Elementary School	Room 138 Kitchen Tap, T38	MSW135	0,0270	Exceeds Limit	0,9600	Passed
Shubenacadie District Elementary School	Room 139, Kitchen Tap, T37	MSW136	0,0270	Exceeds Limit	0,5400	Passed
Shubenacadie District Elementary School	Main Kitchen Double Sink Left Hand Tap, T34	MSW137	0,0097	Exceeds Limit	1,4000	Passed
Shubenacadie District Elementary School	Fountain Across from Room 146, F4	MSW138	0,0055	Exceeds Limit	1,1000	Passed
Shubenacadie District Elementary School	Staff Room 132 Kitchen Tap, T20	MSW139	0,0056	Exceeds Limit	0,9600	Passed
Shubenacadie District Elementary School	Fountain Across from Staff Room, F5	MSW140	0,0014	Passed	0,5300	Passed
Shubenacadie District Elementary School	Main Kitchen Double Sink Right Hand Tap, T35	MSW141	0,0390	Exceeds Limit	1,2000	Passed
Shubenacadie District Elementary School	Main Kitchen Single Sink Tap, T36	MSW142	0,0420	Exceeds Limit	1,8000	Passed
Shubenacadie District Elementary School	Fountain by Main Kitchen, F6	MSW143	0,0071	Exceeds Limit	0,9100	Passed
South Colchester Academy	Gym Fountain, F1	MUG095	0,0000	Passed	1,0000	Passed
South Colchester Academy	Fountain Outside Cust. 1391, F2	MUG096	0,0029	Passed	4,2000	Exceeds Limit
South Colchester Academy	Sink 1(R) Classroom 1640, T19	MUG097	0,0091	Exceeds Limit	0,5800	Passed
South Colchester Academy	Sink 2(2) Classroom 1640, T20	MUG098	0,0052	Exceeds Limit	0,4800	Passed
South Colchester Academy	Sink 3(L) Classroom 1640, T21	MUG099	0,0095	Exceeds Limit	0,7300	Passed
South Colchester Academy	Sink 4(L) Classroom 1640, T22	MUG100	0,0110	Exceeds Limit	0,6600	Passed
South Colchester Academy	Tap, Classroom 1630M T23	MUG101	0,0230	Exceeds Limit	0,9200	Passed
South Colchester Academy	Tap, Classroom 1650, T25	MUG102	0,0051	Exceeds Limit	0,5000	Passed
South Colchester Academy	Tap, Office Library 1261, T26	MUG103	0,0340	Exceeds Limit	1,9000	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
South Colchester Academy	Fountain Outside 1550, F3	MUG104	0,0025	Passed	1,3000	Passed
South Colchester Academy	Fountain Beside 1321, F4	MUG105	0,0013	Passed	1,6000	Passed
South Colchester Academy	Tap, Classroom 1460, T37	MUG106	0,0058	Exceeds Limit	1,2000	Passed
South Colchester Academy	Tap, Kitchen by Stove, T39	MUG107	0,0071	Exceeds Limit	0,9300	Passed
South Colchester Academy	Tap, Kitchen by Freezer, T40	MUG108	0,0026	Passed	0,9900	Passed
South Colchester Academy	Tap, Tray Washing Right, T42	MUG109	0,0160	Exceeds Limit	1,5000	Passed
South Colchester Academy	Tap, Tray Washing Left, T43	MUG110	0,0150	Exceeds Limit	1,4000	Passed
South Colchester Academy	Fountain Beside 2393, F5	MUG111	0,0016	Passed	3,9000	Exceeds Limit
South Colchester Academy	Tap, Room 2650 Graphic Lab, T54	MUG112	0,0053	Exceeds Limit	0,7000	Passed
South Colchester Academy	Fountain Beside 2550, F6	MUG113	0,0007	Passed	1,6000	Passed
South Colchester Academy	Tap Staff Room 2330, T56	MUG114	0,0036	Passed	0,9500	Passed
South Colchester Academy	Fountain Beside 2321 Cust. Room, F7	MUG115	0,0010	Passed	1,2000	Passed
South Colchester Academy	Tap 2460 Classroom, T65	MUG116	0,0160	Exceeds Limit	1,5000	Passed
South Colchester Academy	Tap (R) 2110 Visual Arts, T66	MUG117	0,0069	Exceeds Limit	0,7200	Passed
South Colchester Academy	Tap (L) 2110 Visual Arts, T67	MUG118	0,0055	Exceeds Limit	0,6900	Passed
Spring Street Academy	Library	MRN205	0,0000	Passed	0,5300	Passed
Spring Street Academy	Music Room	MRN206	0,0000	Passed	0,4500	Passed
Spring Street Academy	Recycling Room	MRN207	0,0000	Passed	0,5400	Passed
Spring Street Academy	Cafeteria #1	MRN208	0,0000	Passed	0,4800	Passed
Spring Street Academy	Cafeteria #2	MRN209	0,0000	Passed	0,5300	Passed
Spring Street Academy	Cafeteria #3	MRN210	0,0040	Passed	0,2500	Passed
Spring Street Academy	Cafeteria #4	MRN211	0,0005	Passed	0,6000	Passed
Spring Street Academy	Stage	MRN212	0,0006	Passed	0,5200	Passed
Spring Street Academy	Fountain by Gym	MRN213	0,0010	Passed	0,2800	Passed
Spring Street Academy	Fountain Lower Hall	MRN214	0,0015	Passed	0,2400	Passed
Spring Street Academy	Room 104	MRN215	0,0010	Passed	0,3100	Passed
Spring Street Academy	Room 103	MRN216	0,0000	Passed	0,4400	Passed
Spring Street Academy	Room 102	MRN217	0,0000	Passed	0,3800	Passed
Spring Street Academy	Room 101	MRN218	0,0000	Passed	0,4700	Passed
Spring Street Academy	Room 155	MRN219	0,0000	Passed	0,4700	Passed
Spring Street Academy	Room 154	MRN220	0,0000	Passed	0,4400	Passed
Spring Street Academy	Room 153	MRN221	0,0000	Passed	0,4500	Passed
Spring Street Academy	Room 152	MRN222	0,0000	Passed	0,4900	Passed
Spring Street Academy	Room 151 Sink #1	MRN223	0,0021	Passed	0,3500	Passed
Spring Street Academy	Room 151 Sink #2	MRN224	0,0000	Passed	0,5100	Passed
Spring Street Academy	Staff Room	MRN225	0,0000	Passed	0,3900	Passed
Spring Street Academy	Room 211	MRN226	0,0009	Passed	0,2900	Passed
Spring Street Academy	Room 213	MRN227	0,0009	Passed	0,3500	Passed
Spring Street Academy	Room 214	MRN228	0,0010	Passed	0,2800	Passed
Spring Street Academy	Room 216	MRN229	0,0012	Passed	0,2200	Passed
Spring Street Academy	Room 217	MRN230	0,0016	Passed	0,0950	Passed
Spring Street Academy	Room 220	MRN231	0,0013	Passed	0,1800	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Spring Street Academy	Room 221	MRN232	0,0011	Passed	0,2500	Passed
Spring Street Academy	Room 223	MRN233	0,0009	Passed	0,3400	Passed
Spring Street Academy	Room 224	MRN234	0,0010	Passed	0,3400	Passed
Spring Street Academy	Room 227	MRN237	0,0000	Passed	0,4600	Passed
Spring Street Academy	Fountain Upper Hall	MRN238	0,0000	Passed	0,1600	Passed
Springhill Jr/Sr High School	Board Office Kitchen	MVZ098	0,0006	Passed	0,4900	Passed
Springhill Jr/Sr High School	Warehouse	MVZ099	0,0036	Passed	0,4500	Passed
Springhill Jr/Sr High School	Fountain by Cafeteria	MVZ100	0,0025	Passed	0,1500	Passed
Springhill Jr/Sr High School	Wood Shop	MVZ101	0,0037	Passed	0,9500	Passed
Springhill Jr/Sr High School	Cafeteria	MVZ102	0,0098	Exceeds Limit	0,5500	Passed
Springhill Jr/Sr High School	1st Staff Room	MVZ103	0,0006	Passed	0,1800	Passed
Springhill Jr/Sr High School	Room 196 Learning Centre	MVZ104	0,0006	Passed	0,2800	Passed
Springhill Jr/Sr High School	Fountain by Main Office	MVZ105	0,0000	Passed	0,1800	Passed
Springhill Jr/Sr High School	Fountain 2nd Junior Wing	MVZ106	0,0017	Passed	0,1600	Passed
Springhill Jr/Sr High School	Room 253 Lab	MVZ107	0,0018	Passed	0,2200	Passed
Springhill Jr/Sr High School	Food Lab #1	MVZ108	0,0074	Exceeds Limit	0,6300	Passed
Springhill Jr/Sr High School	Food Lab #2	MVZ109	0,0140	Exceeds Limit	0,6600	Passed
Springhill Jr/Sr High School	Food Lab #3	MVZ110	0,0026	Passed	0,4200	Passed
Springhill Jr/Sr High School	Food Lab #4	MVZ111	0,0000	Passed	0,1800	Passed
Springhill Jr/Sr High School	Fountain by Gym	MVZ112	0,0008	Passed	0,2800	Passed
Springhill Jr/Sr High School	Room 212	MVZ113	0,0075	Exceeds Limit	0,6900	Passed
Springhill Jr/Sr High School	Café #2	MVZ114	0,0000	Passed	0,1500	Passed
Tatamagouche Regional Academy	001 - Source	MRN075	0,0000	Passed	0,6000	Passed
Tatamagouche Regional Academy	002 - Room 118	MRN076	0,0000	Passed	0,0950	Passed
Tatamagouche Regional Academy	004 - Room 119	MRN077	0,0000	Passed	0,1700	Passed
Tatamagouche Regional Academy	005 - Room 121	MRN078	0,0000	Passed	0,2900	Passed
Tatamagouche Regional Academy	006 - Room 124 Kitchen Tap	MRN079	0,0000	Passed	0,2800	Passed
Tatamagouche Regional Academy	007 - Room 124 Upper Fountain	MRN080	0,0000	Passed	0,0830	Passed
Tatamagouche Regional Academy	008 - Room 124 Lower Fountain	MRN081	0,0000	Passed	0,0800	Passed
Tatamagouche Regional Academy	009 - Room 129	MRN082	0,0000	Passed	0,1900	Passed
Tatamagouche Regional Academy	011 - Room 130	MRN083	0,0000	Passed	0,1600	Passed
Tatamagouche Regional Academy	017 - Outside Gym - Upper Fountain	MRN084	0,0000	Passed	0,1500	Passed
Tatamagouche Regional Academy	018 - Outside Gym - Lower Fountain	MRN085	0,0000	Passed	0,0700	Passed
Tatamagouche Regional Academy	023 - 216 Lower Fountain	MRN086	0,0000	Passed	0,1900	Passed
Tatamagouche Regional Academy	024 - 216 Upper Fountain	MRN087	0,0000	Passed	0,1000	Passed
Tatamagouche Regional Academy	025 - 141 A - Sink A	MRN088	0,0024	Passed	0,0450	Passed
Tatamagouche Regional Academy	026 - 141 A - Sprayer A	MRN089	0,0016	Passed	0,1100	Passed
Tatamagouche Regional Academy	027 - 141 A - Sink B	MRN090	0,0000	Passed	0,1100	Passed
Tatamagouche Regional Academy	028 - 141 A - Sink C	MRN091	0,0035	Passed	0,1900	Passed
Tatamagouche Regional Academy	034 - 200 C	MRN092	0,0000	Passed	0,0590	Passed
Tatamagouche Regional Academy	035 - 200 C - Upper Fountain	MRN093	0,0000	Passed	0,1400	Passed
Tatamagouche Regional Academy	036 - 200 C - Lower Fountain	MRN094	0,0000	Passed	0,0380	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Tatamagouche Regional Academy	039 - 238 - Sink A	MRN095	0,0000	Passed	0,1600	Passed
Tatamagouche Regional Academy	040 - 238 - Sink B	MRN096	0,0000	Passed	0,2000	Passed
Tatamagouche Regional Academy	041 - 238 - Sink C	MRN097	0,0000	Passed	0,1100	Passed
Tatamagouche Regional Academy	042 - 238 - Sink D	MRN098	0,0000	Passed	0,1500	Passed
Tatamagouche Regional Academy	044 - 238	MRN099	0,0000	Passed	0,1100	Passed
Tatamagouche Regional Academy	054 - 216	MRN100	0,0000	Passed	0,3300	Passed
Tatamagouche Regional Academy	055 - 218	MRN101	0,0000	Passed	0,2100	Passed
Tatamagouche Regional Academy	080 - 222 Sink A	MRN102	0,0000	Passed	0,1500	Passed
Tatamagouche Regional Academy	081 - 222 Sink B	MRN103	0,0018	Passed	0,0940	Passed
Thorburn Consolidated School	Source-Well	MUN075	0,0024	Passed	0,0200	Passed
Thorburn Consolidated School	Room 112 - Sink	MUN079	0,0700	Exceeds Limit	0,1400	Passed
Thorburn Consolidated School	Room 303 Kitchen Sink	MUN080	0,0380	Exceeds Limit	0,3000	Passed
Thorburn Consolidated School	Gym Office Sink	MUN081	0,0640	Exceeds Limit	0,3200	Passed
Thorburn Consolidated School	Gym Wall Fountain A	MUN082	0,0120	Exceeds Limit	0,0900	Passed
Thorburn Consolidated School	Kitchen Sink	MUN083	0,0027	Passed	0,1600	Passed
Thorburn Consolidated School	Room 111 - Sink	MUN084	0,0420	Exceeds Limit	0,2100	Passed
Thorburn Consolidated School	Hall Fountain B	MUN085	0,0560	Exceeds Limit	0,3300	Passed
Thorburn Consolidated School	Hall Fountain C	MUN086	0,0067	Exceeds Limit	0,0910	Passed
Thorburn Consolidated School	Room 106 Sink	MUN087	0,0630	Exceeds Limit	0,0940	Passed
Thorburn Consolidated School	Room 106 Tech Room Hall Sink	MUN088	0,1600	Exceeds Limit	0,4900	Passed
Thorburn Consolidated School	Room 107 Sink	MUN089	0,0120	Exceeds Limit	0,1400	Passed
Thorburn Consolidated School	Staff Kitchen Sink	MUN090	0,0078	Exceeds Limit	0,0510	Passed
Thorburn Consolidated School	Room 105 Sink	MUN091	0,0042	Passed	0,0870	Passed
Thorburn Consolidated School	Wall Fountain D	MUN092	0,0260	Exceeds Limit	0,1000	Passed
Thorburn Consolidated School	Room 100 Kitchenette Sink	MUN093	0,0170	Exceeds Limit	0,0560	Passed
Thorburn Consolidated School	Room 203 Sink	MUN094	0,0073	Exceeds Limit	0,1700	Passed
Thorburn Consolidated School	Room 204 Sink	MUN095	0,0097	Exceeds Limit	0,1700	Passed
Thorburn Consolidated School	Room 207	MUN096	0,0130	Exceeds Limit	0,0870	Passed
Thorburn Consolidated School	Wall Fountain E	MUN097	0,0340	Exceeds Limit	0,2100	Passed
Thorburn Consolidated School	Wall Fountain F	MUN098	0,0380	Exceeds Limit	0,1600	Passed
Thorburn Consolidated School	Room 206 Sink	MUN099	0,0130	Exceeds Limit	0,1600	Passed
Thorburn Consolidated School	Room 209 Sink	MUN100	0,1200	Exceeds Limit	0,5900	Passed
Thorburn Consolidated School	Wall Fountain G	MUN101	0,0100	Exceeds Limit	0,1300	Passed
Thorburn Consolidated School	Room 213 Sink	MUN102	0,0150	Exceeds Limit	0,1600	Passed
Thorburn Consolidated School	Room 217 Sink	MUN103	0,0110	Exceeds Limit	0,1400	Passed
Thorburn Consolidated School	004 Room 303 Washroom	NEE711	0,0000	Passed	0,0270	Passed
Thorburn Consolidated School	005 Office Area Washroom Sink A	NEE712	0,0013	Passed	0,0320	Passed
Thorburn Consolidated School	006 Office Area Washroom Sink B	NEE713	0,0008	Passed	0,0330	Passed
Thorburn Consolidated School	008 Washroom Gym Office Sink A	NEE714	0,0420	Exceeds Limit	0,1800	Passed
Thorburn Consolidated School	009 Washroom Gym Office Sink B	NEE715	0,0360	Exceeds Limit	0,1000	Passed
Thorburn Consolidated School	011 Locker Room Boys A	NEE716	0,0770	Exceeds Limit	0,3000	Passed
Thorburn Consolidated School	012 Locker Room Boys B	NEE717	0,0810	Exceeds Limit	0,3900	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Thorburn Consolidated School	013 Locker Room Girls A	NEE718	0,1600	Exceeds Limit	0,4500	Passed
Thorburn Consolidated School	014 Locker Room Girls B	NEE719	0,0770	Exceeds Limit	0,3800	Passed
Thorburn Consolidated School	016 Kitchen Washroom Sink	NEE720	0,0460	Exceeds Limit	0,4300	Passed
Thorburn Consolidated School	018 Room 114 Janitors Room	NEE721	0,0059	Exceeds Limit	0,0860	Passed
Thorburn Consolidated School	020 Washroom 2/3 Boys Sink A	NEE722	0,0160	Exceeds Limit	0,2200	Passed
Thorburn Consolidated School	021 Washroom 2/3 Boys Sink B	NEE723	0,0035	Passed	0,1400	Passed
Thorburn Consolidated School	022 Washroom 2/3 Boys Sink C	NEE724	0,0180	Exceeds Limit	0,2100	Passed
Thorburn Consolidated School	023 Washroom 2/3 Girls Sink A	NEE725	0,0130	Exceeds Limit	0,4600	Passed
Thorburn Consolidated School	024 Washroom 2/3 Girls Sink B	NEE726	0,0130	Exceeds Limit	0,3200	Passed
Thorburn Consolidated School	025 Washroom 2/3 Girls Sink C	NEE727	0,0160	Exceeds Limit	0,4400	Passed
Thorburn Consolidated School	027 Laundry Sink Room	NEE728	0,0031	Passed	0,0760	Passed
Thorburn Consolidated School	030 Room 106 Washroom Sink	NEE729	0,0160	Exceeds Limit	0,1100	Passed
Thorburn Consolidated School	032 Washroom Primary Boys Sink	NEE730	0,0015	Passed	0,0750	Passed
Thorburn Consolidated School	033 Washroom Primary Girls A	NEE731	0,0290	Exceeds Limit	0,2000	Passed
Thorburn Consolidated School	034 Washroom Primary Girls B	NEE732	0,0018	Passed	0,1200	Passed
Thorburn Consolidated School	036 Staff Washroom Sink	NEE733	0,0049	Passed	0,1100	Passed
Thorburn Consolidated School	045 Washroom 3/4 Boys A	NEE734	0,0210	Exceeds Limit	0,1700	Passed
Thorburn Consolidated School	046 Washroom 3/4 Boys B	NEE735	0,0210	Exceeds Limit	0,1800	Passed
Thorburn Consolidated School	047 Washroom 3/4 Boys C	NEE736	0,0460	Exceeds Limit	0,1700	Passed
Thorburn Consolidated School	048 Washroom 3/4 Girls Sink A	NEE737	0,0310	Exceeds Limit	0,4100	Passed
Thorburn Consolidated School	049 Washroom 3/4 Girls Sink B	NEE738	0,0250	Exceeds Limit	0,3500	Passed
Thorburn Consolidated School	050 Washroom 3/4 Girls Sink C	NEE739	0,0290	Exceeds Limit	0,4700	Passed
Thorburn Consolidated School	054 Janitors Room Sink	NEE740	0,0100	Exceeds Limit	0,1700	Passed
Thorburn Consolidated School	055 Washroom Junior High Boys A	NEE741	0,0068	Exceeds Limit	0,0730	Passed
Thorburn Consolidated School	056 Washroom Junior High Boys B	NEE742	0,0140	Exceeds Limit	0,1500	Passed
Thorburn Consolidated School	058 Washroom Junior High Girls A	NEE744	0,0350	Exceeds Limit	0,6100	Passed
Thorburn Consolidated School	059 Washroom Junior High Girls B	NEE745	0,0190	Exceeds Limit	0,2400	Passed
Thorburn Consolidated School	060 Washroom Junior High Girls C	NEE746	0,0240	Exceeds Limit	0,1900	Passed
Thorburn Consolidated School	061 Library Washroom	NEE747	0,0140	Exceeds Limit	0,1500	Passed
Thorburn Consolidated School	063 Janitors Room Sink	NEE748	0,0530	Exceeds Limit	0,2900	Passed
Trenton Elementary School	001 Room 240 Classroom	LES833	0,0011	Passed	0,7000	Passed
Trenton Elementary School	002 Floor Hallway (Fountain)	LES834	0,0015	Passed	0,4500	Passed
Trenton Elementary School	003 Room 247 (Staff Room)	LES835	0,0009	Passed	0,5600	Passed
Trenton Elementary School	004 1st Hallway (Fountain Mid Hallway)	LES836	0,0013	Passed	0,3000	Passed
Trenton Elementary School	005 1st Floor Hallway (Fountain by Gym)	LES837	0,0000	Passed	0,5500	Passed
Trenton Elementary School	006 Kitchen (Kitchen Off of Gym, Sink)	LES838	0,0009	Passed	0,7500	Passed
Trenton Elementary School	007 Utility Room (Source Sample)	LES839	0,0023	Passed	0,3800	Passed
Trenton Elementary School	008 Room 147 Main Room Sink	NGT237	0,0017	Passed	0,0960	Passed
Trenton Elementary School	009 Room 149 Girls Washroom Sink A	NGT238	0,0098	Exceeds Limit	0,4300	Passed
Trenton Elementary School	010 Room 149 Girls Washroom Sink B	NGT239	0,0190	Exceeds Limit	0,2000	Passed
Trenton Elementary School	011 Room 149 Girls Washroom Sink C	NGT240	0,0020	Passed	0,1800	Passed
Trenton Elementary School	012 Room 149 Girls Washroom Sink D	NGT241	0,0040	Passed	0,2300	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Trenton Elementary School	013 Room 146 Boys Washroom Sink A	NGT242	0,0064	Exceeds Limit	0,2300	Passed
Trenton Elementary School	014 Room 146 Boys Washroom Sink B	NGT243	0,0045	Passed	0,2500	Passed
Trenton Elementary School	015 Room 146 Boys Washroom Sink C	NGT244	0,0024	Passed	0,2000	Passed
Trenton Elementary School	016 Room 146 Boys Washroom Sink D	NGT245	0,0036	Passed	0,2400	Passed
Trenton Middle School	017 Room 114	MVY968	0,0085	Exceeds Limit	0,1800	Passed
Trenton Middle School	021 Room 116	MVY969	0,0580	Exceeds Limit	0,1500	Passed
Trenton Middle School	022 Room 117	MVY970	0,0100	Exceeds Limit	0,4600	Passed
Trenton Middle School	024 Room 122 Sink A	MVY971	0,0041	Passed	0,1300	Passed
Trenton Middle School	025 Room 122 Sink B	MVY972	0,0030	Passed	0,0830	Passed
Trenton Middle School	026 Room 122 Sink C	MVY973	0,0019	Passed	0,1900	Passed
Trenton Middle School	030 Room 211	MVY974	0,0014	Passed	0,8300	Passed
Trenton Middle School	031 Room 212 Sink A	MVY975	0,0290	Exceeds Limit	0,5200	Passed
Trenton Middle School	032 Room 212 Sink B	MVY976	0,0100	Exceeds Limit	0,2900	Passed
Trenton Middle School	033 Room 213 Sink A	MVY977	0,0045	Passed	0,3500	Passed
Trenton Middle School	034 Room 213 Sink B	MVY978	0,0170	Exceeds Limit	1,1000	Passed
Trenton Middle School	035 Room 213 Sink C	MVY979	0,0097	Exceeds Limit	0,8400	Passed
Trenton Middle School	036 Room 213 Sink D	MVY980	0,0024	Passed	0,0670	Passed
Trenton Middle School	037 Room 214	MVY981	0,0021	Passed	0,6700	Passed
Trenton Middle School	040 Room 217	MVY982	0,0029	Passed	0,5200	Passed
Trenton Middle School	043 Room 222	MVY983	0,0009	Passed	0,6000	Passed
Trenton Middle School	045 Room E103	MVY984	0,0100	Exceeds Limit	0,2900	Passed
Trenton Middle School	055 Room E200	MVY985	0,0018	Passed	0,3100	Passed
Trenton Middle School	059 Room E110 Sink A	MVY986	0,0038	Passed	0,2800	Passed
Trenton Middle School	060 Room E110 Sink B	MVY987	0,0120	Exceeds Limit	0,1500	Passed
Trenton Middle School	061 Room E115	MVY988	0,0270	Exceeds Limit	0,0460	Passed
Trenton Middle School	062 Room E116	MVY989	0,0140	Exceeds Limit	0,0870	Passed
Trenton Middle School	063 Room 207	MVY990	0,0010	Passed	0,5000	Passed
Trenton Middle School	072 Room 307	MVY991	0,0039	Passed	0,4100	Passed
Truro Elementary School	Fountain Outside Gym, F1	MPQ440	0,0000	Passed	0,1000	Passed
Truro Elementary School	Room 1052 Kitchen Tap,T7	MPQ441	0,0000	Passed	0,3700	Passed
Truro Elementary School	Kitchen Main Tap by Door, T8	MPQ442	0,0190	Exceeds Limit	0,3600	Passed
Truro Elementary School	Kitchen Tap in Island, T11	MPQ443	0,0018	Passed	0,2100	Passed
Truro Elementary School	High Fountain by Main Floor W/R F2	MPQ444	0,0000	Passed	0,1400	Passed
Truro Elementary School	Low Fountain by Main Floor W/R F3	MPQ445	0,0000	Passed	0,1900	Passed
Truro Elementary School	Room 1030, Kitchen Tap, T24	MPQ446	0,0000	Passed	0,2300	Passed
Truro Elementary School	Room 1028, Kitchen Tap, T25	MPQ447	0,0007	Passed	0,2100	Passed
Truro Elementary School	Room 1026, Kitchen Tap, T26	MPQ448	0,0000	Passed	0,2300	Passed
Truro Elementary School	Room 1021, Kitchen Tap, T30	MPQ449	0,0000	Passed	0,3200	Passed
Truro Elementary School	Room 1018, Kitchen Tap, T33	MPQ450	0,0000	Passed	0,1800	Passed
Truro Elementary School	Room 1023, Kitchen Tap, T29	MPQ451	0,0000	Passed	0,2400	Passed
Truro Elementary School	Room 1017, Kitchen Tap, T34	MPQ452	0,0007	Passed	0,3500	Passed
Truro Elementary School	Room 1014, Kitchen Tap, T36	MPQ453	0,0000	Passed	0,2600	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Truro Elementary School	Room 1013, Kitchen Tap, T35	MPQ454	0,0000	Passed	0,1900	Passed
Truro Elementary School	Room 1010, Kitchen Tap, T37	MPQ455	0,0007	Passed	0,2400	Passed
Truro Elementary School	Room 1009, Kitchen Tap, T38	MPQ456	0,0005	Passed	0,2200	Passed
Truro Elementary School	Room 1006, Kitchen Tap, T40	MPQ457	0,0000	Passed	0,3100	Passed
Truro Elementary School	Room 1005, Kitchen Tap, T39	MPQ458	0,0000	Passed	0,2800	Passed
Truro Elementary School	Room 1002, Kitchen Tap, T41	MPQ459	0,0000	Passed	0,3600	Passed
Truro Elementary School	Staff Room 2039, Kitchen Tap, T57	MPQ460	0,0000	Passed	0,1400	Passed
Truro Elementary School	Upstairs by Washroom, F4	MPQ461	0,0000	Passed	0,1300	Passed
Truro Elementary School	Room 2031, Kitchen Tap, T54	MPQ462	0,0010	Passed	0,4000	Passed
Truro Junior High School	Fountain across from Tech. Ed., F1	MPQ754	0,0000	Passed	0,0490	Passed
Truro Junior High School	Fountain near Girls Washroom Main Floor, F2	MPQ755	0,0000	Passed	0,1500	Passed
Truro Junior High School	Room 37 Kitchen Sink, T17	MPQ756	0,0050	Passed	0,2600	Passed
Truro Junior High School	Room 006, Kitchen Sink, T18	MPQ757	0,0006	Passed	0,1100	Passed
Truro Junior High School	Fountain near Staff Room Entrance, F3	MPQ758	0,0000	Passed	0,0870	Passed
Truro Junior High School	Fountain near Gym , F4	MPQ759	0,0000	Passed	0,0800	Passed
Truro Junior High School	Staff Rm Kitchen Tap, T19	MPQ760	0,0000	Passed	0,1300	Passed
Truro Junior High School	Recycle Rm Kitchen Tap, T25	MPQ761	0,0022	Passed	0,2400	Passed
Truro Junior High School	Single Tap in Kitchen, T28	MPQ762	0,0060	Exceeds Limit	0,9500	Passed
Truro Junior High School	Double Sink Tap on Right, T30	MPQ763	0,0054	Exceeds Limit	0,2000	Passed
Truro Junior High School	Double Sink Tap on Left, T29	MPQ764	0,0038	Passed	0,1800	Passed
Truro Junior High School	Fountain upstairs by Room 227, F5	MPQ765	0,0000	Passed	0,1100	Passed
Truro Junior High School	Fountain upstairs by Room 209, F6	MPQ766	0,0000	Passed	0,1200	Passed
Truro Junior High School	Family Studies RM 222 Sink on Left, T58	MPQ767	0,0049	Passed	0,2100	Passed
Truro Junior High School	Family Studies RM 222 Sink on Right, T59	MPQ768	0,0036	Passed	0,2200	Passed
Truro Junior High School	Family Studies RM 222 Sink on Left, T60	MPQ769	0,0090	Exceeds Limit	0,1900	Passed
Truro Junior High School	Family Studies RM 222 Sink on Right, T61	MPQ770	0,0018	Passed	0,2100	Passed
Truro Junior High School	RM 203, Kitchen Sink on Left, T52	MPQ771	0,0012	Passed	0,1000	Passed
Truro Junior High School	RM 203, Kitchen Sink on Right, T53	MPQ772	0,0018	Passed	0,1600	Passed
Uniacke District School	Kitchen Sink in Main Office, T27	LDD281	0,0027	Passed	0,2000	Passed
Uniacke District School	Fountain Near Room 252, F5	LDD282	0,0087	Exceeds Limit	0,0860	Passed
Uniacke District School	Fountain Near Room 132, Basement, F4	LDD283	0,0016	Passed	0,1000	Passed
Uniacke District School	Fountain Near Room 202, F3	LDD284	0,0006	Passed	0,2400	Passed
Uniacke District School	Fountain Near Room 201, F2	LDD285	0,0082	Exceeds Limit	0,0770	Passed
Uniacke District School	Tap in Classroom 208, T13	LDD286	0,0029	Passed	0,3300	Passed
Uniacke District School	Fountain by Library, F1	LDD287	0,0045	Passed	0,0680	Passed
Uniacke District School	Learning Centre Tap, T6	LDD288	0,0110	Exceeds Limit	0,1900	Passed
Uniacke District School	Kitchen Sink on Left, T9	LDD289	0,0110	Exceeds Limit	0,0790	Passed
Uniacke District School	Kitchen Sink on Right, T10	LDD290	0,0150	Exceeds Limit	0,1400	Passed
Uniacke District School	Kitchen Sprayer, T11	LDD299	0,0079	Exceeds Limit	0,1400	Passed
Uniacke District School	Kitchen Hand Washing Sink, T12	LDD300	0,0250	Exceeds Limit	0,1500	Passed
Uniacke District School	Fountain by Boiler Room Door, F8	LDD301	0,0095	Exceeds Limit	0,1300	Passed
Uniacke District School	Sink in Staff Room 115, T68	LDD302	0,0082	Exceeds Limit	0,1100	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Uniacke District School	Fountain by Music Room, F10	LDD303	0,0049	Passed	0,1200	Passed
Uniacke District School	Fountain Near Room 243, F6	LDD304	0,0006	Passed	0,4400	Passed
Uniacke District School	Fountain Near Room 326, F9	LDD305	0,0027	Passed	0,1400	Passed
Uniacke District School	Double Sink by Ent. In Home Ec, T53	LDD306	0,0120	Exceeds Limit	0,2600	Passed
Uniacke District School	Single Sink on Island in Home Ec, T54	LDD307	0,0120	Exceeds Limit	0,1700	Passed
Uniacke District School	Double Sink by White Board Home Ec, T52	LDD308	0,2300	Exceeds Limit	6,3000	Exceeds Limit
Uniacke District School	Sink by Fridge in Home Ec, T55	LDD368	1,2000	Exceeds Limit	2,2000	Exceeds Limit
Uniacke District School	Sink by Dishwasher in Home Ec, T50	LDD369	0,0250	Exceeds Limit	0,2100	Passed
Uniacke District School	Laundry Sink in Home Ec, T51	LDD370	0,0660	Exceeds Limit	0,2200	Passed
Uniacke District School	Fountain by Room 319, F7	LDD371	0,0012	Passed	0,1000	Passed
Uniacke District School	Sink in Room 132, T22	LDD372	0,0051	Exceeds Limit	0,1100	Passed
Uniacke District School	Raw Water by Main Valve	LDD373	0,0027	Passed	0,0130	Passed
Upper Stewiacke Elementary School	Kitchen Sink on Left, T8	MOP511	0,0340	Exceeds Limit	0,3700	Passed
Upper Stewiacke Elementary School	Kitchen Sink on Right, T9	MOP512	0,0069	Exceeds Limit	0,4400	Passed
Upper Stewiacke Elementary School	Staff Kitchen Sink, T6	MOP513	0,0210	Exceeds Limit	0,4200	Passed
Upper Stewiacke Elementary School	Fountain, F1	MOP514	0,0000	Passed	0,1600	Passed
Upper Stewiacke Elementary School	Girls Washroom Left Tap, T1	NJX628	0,0130	Exceeds Limit	0,9400	Passed
Upper Stewiacke Elementary School	Girls Washroom Right Tap, T2	NJX629	0,0050	Passed	0,5500	Passed
Upper Stewiacke Elementary School	Boys Washroom Left Tap, T5	NJX630	0,0032	Passed	0,4400	Passed
Upper Stewiacke Elementary School	Boys Washroom Left Tap, T4	NJX631	0,0056	Exceeds Limit	0,5800	Passed
Upper Stewiacke Elementary School	Staff Washroom Tap, T3	NJX632	0,0310	Exceeds Limit	0,5800	Passed
Valley Elementary School	Fountain Bottom Floor Reading Recovery F1	LEK589	0,0067	Exceeds Limit	1,4000	Passed
Valley Elementary School	Fountain Bottom Floor by Room 105 F2	LEK590	0,0064	Exceeds Limit	0,5200	Passed
Valley Elementary School	Fountain by Office F3	LEK591	0,0007	Passed	0,7700	Passed
Valley Elementary School	Staff Room Upstairs T6	LEK592	0,0060	Exceeds Limit	0,7500	Passed
Valley Elementary School	Fountain by Room 202	LEK593	0,0088	Exceeds Limit	0,6500	Passed
Valley Elementary School	Kitchen Sink Room #105	LEK594	0,0190	Exceeds Limit	1,2000	Passed
Valley Elementary School	New Fountain by Gym F4	LEK595	0,0000	Passed	0,8300	Passed
Valley Elementary School	Kitchen Sink Right Side T20	LEK596	0,0290	Exceeds Limit	0,3300	Passed
Valley Elementary School	Kitchen Sink Left Side T21	LEK597	0,0041	Passed	0,3400	Passed
Valley Elementary School	Hand Washing Sink Kitchen T19	LEK598	0,1100	Exceeds Limit	1,7000	Passed
Valley Elementary School	Raw Water Entering Building	LEK599	0,0160	Exceeds Limit	0,1000	Passed
Wallace Consolidated Elementary School	Kitchen #1	LKO357	0,0080	Exceeds Limit	0,1200	Passed
Wallace Consolidated Elementary School	Kitchen #2	LKO358	0,0039	Passed	0,0290	Passed
Wallace Consolidated Elementary School	1st Floor Washroom	NFC704	0,0029	Passed	0,0310	Passed
Wallace Consolidated Elementary School	Primary Room	NFC705	0,0000	Passed	0,0012	Passed
Wallace Consolidated Elementary School	Library	NFC706	0,0000	Passed	0,0008	Passed
Wallace Consolidated Elementary School	Girls #3	NFC709	0,0000	Passed	0,0057	Passed
Wallace Consolidated Elementary School	Boys #1	NFC710	0,0008	Passed	0,0050	Passed
Wallace Consolidated Elementary School	Boys #2	NFC711	0,0000	Passed	0,0017	Passed
Wallace Consolidated Elementary School	Boys #3	NFC712	0,0000	Passed	0,1100	Passed
Wallace Consolidated Elementary School	2nd Floor Custodial	NFC713	0,0000	Passed	0,0045	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Wallace Consolidated Elementary School	Grade 4/5 Room	NFC714	0,0016	Passed	0,0110	Passed
Wallace Consolidated Elementary School	Grade 5/6 Room	NFC715	0,0000	Passed	0,0000	Passed
Wallace Consolidated Elementary School	3rd Floor Custodial	NFC716	0,0000	Passed	0,0008	Passed
Wallace Consolidated Elementary School	Staff Room	NFC717	0,0000	Passed	0,0029	Passed
Wallace Consolidated Elementary School	Principals Office	NFC718	0,0012	Passed	0,0056	Passed
Walter Duggan Consolidated School	001 Supply	MPP900	0,0450	Exceeds Limit	0,0660	Passed
Walter Duggan Consolidated School	002 Room 170	MPP901	0,0000	Passed	0,0410	Passed
Walter Duggan Consolidated School	007 Room 157	MPP902	0,0020	Passed	0,0110	Passed
Walter Duggan Consolidated School	008 Room 161A - Sink A	MPP903	0,0024	Passed	0,2100	Passed
Walter Duggan Consolidated School	009 Room 161A - Sink B	MPP904	0,0017	Passed	0,3100	Passed
Walter Duggan Consolidated School	010 Room 159 - Sink A	MPP905	0,0016	Passed	0,1500	Passed
Walter Duggan Consolidated School	011 Room 159A - Sink B	MPP906	0,0039	Passed	0,1600	Passed
Walter Duggan Consolidated School	012 Room 102	MPP907	0,0035	Passed	0,0740	Passed
Walter Duggan Consolidated School	013 Room 103	MPP908	0,0011	Passed	0,1100	Passed
Walter Duggan Consolidated School	015 Room 128	MPP909	0,0011	Passed	0,0700	Passed
Walter Duggan Consolidated School	016 Room 121	MPP910	0,0006	Passed	0,0720	Passed
Walter Duggan Consolidated School	019 Room 119	MPP911	0,0010	Passed	0,0760	Passed
Walter Duggan Consolidated School	021 Room 114	MPP912	0,0012	Passed	0,0890	Passed
Walter Duggan Consolidated School	022 Room 115	MPP913	0,0000	Passed	0,0890	Passed
Walter Duggan Consolidated School	023 Room 117	MPP914	0,0008	Passed	0,0580	Passed
Walter Duggan Consolidated School	024 Room 118	MPP915	0,0000	Passed	0,0690	Passed
Walter Duggan Consolidated School	025 Room 113	MPP916	0,0015	Passed	0,1100	Passed
Walter Duggan Consolidated School	026 Room 147	MPP917	0,0084	Exceeds Limit	0,1200	Passed
Walter Duggan Consolidated School	027 Room 136	MPP918	0,0120	Exceeds Limit	0,1300	Passed
Walter Duggan Consolidated School	028 Room 146	MPP919	0,0047	Passed	0,1300	Passed
Walter Duggan Consolidated School	042 Fountain by Gym	MPP920	0,0000	Passed	0,0250	Passed
Walter Duggan Consolidated School	043 Fountain Down Main Hall	MPP921	0,0000	Passed	0,0800	Passed
Walter Duggan Consolidated School	044 Fountain Up Main Hall	MPP922	0,0000	Passed	0,0860	Passed
Walter Duggan Consolidated School	Boys Washroom Caf Sink A	NFE358	0,0000	Passed	0,0059	Passed
Walter Duggan Consolidated School	Boys Washroom Caf Sink B	NFE359	0,0023	Passed	0,0071	Passed
Walter Duggan Consolidated School	Girls Washroom Caf Sink A	NFE360	0,0000	Passed	0,0066	Passed
Walter Duggan Consolidated School	Girls Washroom Caf Sink B	NFE361	0,0000	Passed	0,0031	Passed
Walter Duggan Consolidated School	Room 106 Janitors Room Sink	NFE362	0,0000	Passed	0,0047	Passed
Walter Duggan Consolidated School	Room 121 Girls Washroom Sink	NFE363	0,0000	Passed	0,0230	Passed
Walter Duggan Consolidated School	Room 121 Boys Washroom Sink	NFE364	0,0000	Passed	0,0410	Passed
Walter Duggan Consolidated School	Room 119 Washroom Sink	NFE365	0,0000	Passed	0,0270	Passed
Walter Duggan Consolidated School	Room 147 Sink	NFE366	0,0000	Passed	0,0180	Passed
Walter Duggan Consolidated School	Downstairs Girls Washroom A	NFE368	0,0000	Passed	0,0270	Passed
Walter Duggan Consolidated School	Downstairs Girls Washroom B	NFE369	0,0000	Passed	0,0180	Passed
Walter Duggan Consolidated School	Downstairs Girls Washroom C	NFE370	0,0000	Passed	0,0160	Passed
Walter Duggan Consolidated School	Downstairs Boys Washroom A	NFE371	0,0000	Passed	0,0160	Passed
Walter Duggan Consolidated School	Downstairs Boys Washroom B	NFE372	0,0007	Passed	0,0210	Passed



## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Walter Duggan Consolidated School	Downstairs Boys Washroom C	NFE373	0,0000	Passed	0,0170	Passed
Walter Duggan Consolidated School	Room 202 Janitors Room Sink	NFE374	0,0000	Passed	0,0270	Passed
Walter Duggan Consolidated School	Upstairs Washroom Girls A	NFE375	0,0000	Passed	0,0200	Passed
Walter Duggan Consolidated School	Upstairs Washroom Girls B	NFE376	0,0000	Passed	0,0220	Passed
Walter Duggan Consolidated School	Upstairs Washroom Girls C	NFE377	0,0000	Passed	0,0190	Passed
Walter Duggan Consolidated School	Upstairs Boys Washroom A	NFE378	0,0000	Passed	0,0230	Passed
Walter Duggan Consolidated School	Upstairs Boys Washroom B	NFE379	0,0000	Passed	0,0170	Passed
Walter Duggan Consolidated School	Upstairs Boys Washroom C	NFE380	0,0000	Passed	0,0170	Passed
Walter Duggan Consolidated School	Supply	NIU564	0,1200	Exceeds Limit	0,0780	Passed
West Colchester Consolidated School	Staff Room Kitchen Sink T2	MOP095	0,0240	Exceeds Limit	1,4000	Passed
West Colchester Consolidated School	Bottom Floor, F1	MOP096	0,0510	Exceeds Limit	0,0160	Passed
West Colchester Consolidated School	Pre-Primary Kitchen Sink T6	MOP097	0,0120	Exceeds Limit	0,0900	Passed
West Colchester Consolidated School	Fountain Outside Office, F3	MOP098	0,0120	Exceeds Limit	0,0380	Passed
West Colchester Consolidated School	Kitchen Sink of Left T20	MOP099	0,1700	Exceeds Limit	0,4100	Passed
West Colchester Consolidated School	Kitchen Sink of Right T21	MOP100	0,3800	Exceeds Limit	0,8400	Passed
West Colchester Consolidated School	Laundry Sink in Home Ec T22	MOP101	0,0990	Exceeds Limit	0,6900	Passed
West Colchester Consolidated School	Kitchen Sink on Right T23	MOP102	0,0690	Exceeds Limit	1,2000	Passed
West Colchester Consolidated School	Kitchen Sink in Middle T24	MOP103	0,0720	Exceeds Limit	1,6000	Passed
West Colchester Consolidated School	Kitchen Sink on Left T25	MOP104	0,4000	Exceeds Limit	0,8400	Passed
West Colchester Consolidated School	Upstairs Fountain F2	MOP105	0,0130	Exceeds Limit	0,0098	Passed
West End Memorial School	Boiler Room #2	LET808	0,0010	Passed	0,1200	Passed
West End Memorial School	Pre Primary Sink	LET809	0,0038	Passed	0,2700	Passed
West End Memorial School	Staff Room Sink	LET811	0,0010	Passed	0,2400	Passed
West End Memorial School	Classroom #1 Sink	LET813	0,0010	Passed	0,3000	Passed
West End Memorial School	Classroom #3 Sink Fountain - Removed	LET815	0,0100	Exceeds Limit	0,4500	Passed
West End Memorial School	Pre Primary Fountain	LET816	0,0034	Passed	0,5100	Passed
West End Memorial School	Class #3 Sink Tap	LLP090	0,0010	Passed	0,1500	Passed
West End Memorial School	Class #2 Sink Tap	LLP091	0,0000	Passed	0,0710	Passed
West End Memorial School	Girls #1	NEF090	0,0000	Passed	0,0370	Passed
West End Memorial School	Girls #2	NEF091	0,0000	Passed	0,0450	Passed
West End Memorial School	Custodial by Staff Room	NEF092	0,0000	Passed	0,0530	Passed
West End Memorial School	Boys #1	NEF093	0,0000	Passed	0,1400	Passed
West End Memorial School	Boys #2	NEF094	0,0000	Passed	0,1300	Passed
West End Memorial School	Boys #3	NEF095	0,0000	Passed	0,0800	Passed
West End Memorial School	Staff Room	NEF096	0,0000	Passed	0,1100	Passed
West End Memorial School	Custodial in Lower End	NEF097	0,0000	Passed	0,0210	Passed
West End Memorial School	Staff in Lower End	NEF098	0,0000	Passed	0,0230	Passed
West Highlands Elementary School	Boiler Room	MTG944	0,0038	Passed	0,9100	Passed
West Highlands Elementary School	Cafeteria #1	MTG945	0,0009	Passed	0,8900	Passed
West Highlands Elementary School	Cafeteria #2	MTG946	0,0006	Passed	0,1700	Passed
West Highlands Elementary School	Cafeteria #3	MTG947	0,0016	Passed	0,7300	Passed
West Highlands Elementary School	Breakfast Program Room	MTG948	0,0006	Passed	0,5900	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
West Highlands Elementary School	Fountain by Gym	MTG949	0,0031	Passed	0,4500	Passed
West Highlands Elementary School	Music Room	MTG950	0,0014	Passed	1,4000	Passed
West Highlands Elementary School	Fountain Lower Hall	MTG951	0,0021	Passed	0,7400	Passed
West Highlands Elementary School	Learning Centre	MTG952	0,0005	Passed	0,5300	Passed
West Highlands Elementary School	Room 116	MTG953	0,0010	Passed	0,5500	Passed
West Highlands Elementary School	Room 124	MTG954	0,0000	Passed	0,5600	Passed
West Highlands Elementary School	Room 121	MTG955	0,0000	Passed	0,6600	Passed
West Highlands Elementary School	Room 118	MTG956	0,0000	Passed	0,5000	Passed
West Highlands Elementary School	Mechanical Room	MTG957	0,0000	Passed	0,0600	Passed
West Highlands Elementary School	Staff Room	MTG958	0,0000	Passed	0,4800	Passed
West Highlands Elementary School	Fountain Upper Hall	MTG959	0,0005	Passed	0,3700	Passed
West Highlands Elementary School	Visual Art #1	MTG960	0,0000	Passed	0,1400	Passed
West Highlands Elementary School	Visual Art #2	MTG961	0,0008	Passed	0,1700	Passed
West Highlands Elementary School	Room 215	MTG962	0,0000	Passed	0,6000	Passed
West Pictou Consolidated School	Room 109 Custodial Closet Sink	NGT250	0,0280	Exceeds Limit	0,0970	Passed
West Pictou Consolidated School	Room 147 Custodial Closet Sink	NGT251	0,1200	Exceeds Limit	0,5100	Passed
West Pictou Consolidated School	Room 219 Custodial Closet Sink A	NGT252	0,0120	Exceeds Limit	0,1700	Passed
West Pictou Consolidated School	Room 219 Custodial Closet Sink B	NGT253	0,0800	Exceeds Limit	0,1900	Passed
West Pictou Consolidated School	Main Hall Boys Washroom Sink A	NGT254	0,0110	Exceeds Limit	0,0690	Passed
West Pictou Consolidated School	Main Hall Boys Washroom Sink B	NGT255	0,0090	Exceeds Limit	0,0320	Passed
West Pictou Consolidated School	Main Hall Boys Washroom Sink C	NGT256	0,0140	Exceeds Limit	0,1400	Passed
West Pictou Consolidated School	Main Hall Boys Washroom Sink D	NGT257	0,0190	Exceeds Limit	0,4700	Passed
West Pictou Consolidated School	Main Hall Girls Washroom Sink A	NGT258	0,0580	Exceeds Limit	0,5000	Passed
West Pictou Consolidated School	Main Hall Girls Washroom Sink B	NGT259	0,0110	Exceeds Limit	0,1200	Passed
West Pictou Consolidated School	Main Hall Girls Washroom Sink C	NGT260	0,0090	Exceeds Limit	0,0690	Passed
West Pictou Consolidated School	Main Hall Girls Washroom Sink D	NGT261	0,0130	Exceeds Limit	0,1900	Passed
West Pictou Consolidated School	Gym Locker Room Boys Sink	NGT262	0,0400	Exceeds Limit	0,0520	Passed
West Pictou Consolidated School	Gym Locker Room Girls Sink	NGT263	0,0081	Exceeds Limit	0,0760	Passed
West Pictou Consolidated School	Primary End Boys Washroom Sink	NGT264	0,0088	Exceeds Limit	0,0570	Passed
West Pictou Consolidated School	Primary End Girls Washroom Sink	NGT265	0,0180	Exceeds Limit	0,4000	Passed
West Pictou Consolidated School	Room 161 Learning Centre Washroom Sink	NGT266	0,0130	Exceeds Limit	0,5300	Passed
West Pictou Consolidated School	2nd Floor Boys Washroom Sink A	NGT267	0,0170	Exceeds Limit	0,1200	Passed
West Pictou Consolidated School	2nd Floor Boys Washroom Sink B	NGT268	0,0110	Exceeds Limit	0,0910	Passed
West Pictou Consolidated School	2nd Floor Boys Washroom Sink C	NGT269	0,0140	Exceeds Limit	0,1000	Passed
West Pictou Consolidated School	2nd Floor Boys Washroom Sink D	NGT270	0,0270	Exceeds Limit	0,4400	Passed
West Pictou Consolidated School	2nd Floor Girls Washroom Sink A	NGT271	0,0110	Exceeds Limit	0,1700	Passed
West Pictou Consolidated School	2nd Floor Girls Washroom Sink B	NGT272	0,0110	Exceeds Limit	0,0580	Passed
West Pictou Consolidated School	2nd Floor Girls Washroom Sink C	NGT273	0,0100	Exceeds Limit	0,0960	Passed
West Pictou Consolidated School	2nd Floor Girls Washroom Sink D	NGT274	0,0063	Exceeds Limit	0,1100	Passed
Winding River Consolidated School	Library Room 106, Kitchen, Tap-T1	MSW778	0,0044	Passed	0,4900	Passed
Winding River Consolidated School	Fountain Across from Library, F1	MSW779	0,0000	Passed	0,1800	Passed
Winding River Consolidated School	Staff Room 161 Kitchen, Tap, T13	MSW780	0,0008	Passed	0,4000	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Winding River Consolidated School	Learning Centre Room 162, Kitchen Tap, T15	MSW781	0,0013	Passed	0,5600	Passed
Winding River Consolidated School	Visual Arts Room 154 Tap on Right, T42	MSW782	0,0055	Exceeds Limit	0,2000	Passed
Winding River Consolidated School	Visual Arts Room 154 Tap on Right, T41	MSW783	0,0061	Exceeds Limit	0,2400	Passed
Winding River Consolidated School	Fountain by Recycle Room, F3	MSW784	0,0000	Passed	0,2300	Passed
Winding River Consolidated School	Recycle Room, 133, T33	MSW785	0,0012	Passed	0,4500	Passed
Winding River Consolidated School	Main Kitchen Tap, T39	MSW786	0,0009	Passed	0,2200	Passed
Winding River Consolidated School	Fountain by Reading Recovery Room, F2	MSW787	0,0008	Passed	0,3100	Passed
Winding River Consolidated School	Room 188, Kitchen Tap, T25	MSW788	0,0030	Passed	0,2900	Passed
Winding River Consolidated School	Room 185 Kitchen Tap, T28	MSW789	0,0018	Passed	0,2500	Passed
Winding River Consolidated School	Room 175, Kitchen Tap, T23	MSW790	0,0032	Passed	0,7000	Passed
Winding River Consolidated School	Room 177, Kitchen Tap, T24	MSW791	0,0018	Passed	0,5400	Passed
Winding River Consolidated School	Room 184, Kitchen Tap, T29	MSW792	0,0016	Passed	0,4000	Passed
Winding River Consolidated School	Room 182, Kitchen Tap, T30	MSW793	0,0025	Passed	0,3700	Passed
Winding River Consolidated School	Room 178, Kitchen Tap, T31	MSW794	0,0020	Passed	0,5400	Passed
Winding River Consolidated School	Room 180, Kitchen Tap, T32	MSW795	0,0072	Exceeds Limit	0,3800	Passed
Winding River Consolidated School	Music Room 150, T2	NHI331	0,0037	Passed	0,8800	Passed
Winding River Consolidated School	Boys Washroom Across from Library (Push on Taps) Lft Tap, T3	NHI332	0,0065	Exceeds Limit	0,7100	Passed
Winding River Consolidated School	Boys Washroom Across from Library (Push on Taps) Mid Tap, T4	NHI333	0,0035	Passed	0,5200	Passed
Winding River Consolidated School	Boys Washroom Across from Library (Push on Taps) Rgt Tap, T5	NHI334	0,0032	Passed	0,5600	Passed
Winding River Consolidated School	Custodial Room Across from Library Cust Fir Sink, T6	NHI335	0,0014	Passed	0,1100	Passed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps), Lft Tap, T7	NHI336	0,0026	Passed	0,5200	Passed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps), 2nd Lft Tap, T8	NHI337	0,0041	Passed	1,0000	Passed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps) 3rd Lft Tap, T9	NHI338	0,0058	Exceeds Limit	0,6700	Passed
Winding River Consolidated School	Girls Washroom Across from Library (Push on Taps) 4th Lft Tap, T10	NHI339	0,0057	Exceeds Limit	0,9300	Passed
Winding River Consolidated School	Staff Female Washroom in Staff Room (Push on Taps), T11	NHI340	0,0021	Passed	0,6500	Passed
Winding River Consolidated School	Staff Male Washroom in Staff Room, T12	NHI341	0,0045	Passed	0,9200	Passed
Winding River Consolidated School	Everyone Washroom By Learning Centre 162, T14	NHI342	0,0013	Passed	0,6400	Passed
Winding River Consolidated School	Main Office Washroom (Push on Tap), T16	NHI343	0,0027	Passed	0,8600	Passed
Winding River Consolidated School	Boys Washroom Across from Main Office (Push on Tap) Left Tap, T17	NHI344	0,0052	Exceeds Limit	0,4800	Passed
Winding River Consolidated School	Boys Washroom Across From Main Office (Push on Tap) Mid Tap, T18	NHI345	0,0036	Passed	0,4800	Passed
Winding River Consolidated School	Boys Washroom Across From Main Office (Push on Tap) Rgt Tap, T19	NHI346	0,0034	Passed	0,4000	Passed
Winding River Consolidated School	Custodian Room Across from Custodial Floor Sink, T20	NHI347	0,0015	Passed	0,7300	Passed
Winding River Consolidated School	Girls Washroom Across from Off (Push on Taps) Lft Tap, T21	NHI348	0,0130	Exceeds Limit	0,7400	Passed
Winding River Consolidated School	Girls Washroom Across from Off (Push on Taps) Lft Tap, T22	NHI349	0,0029	Passed	0,5100	Passed
Winding River Consolidated School	Girls Washroom Across from Off (Push on Taps) Rgt Tap, T22A	NHI350	0,0031	Passed	0,4300	Passed
Winding River Consolidated School	Classroom 188 Washroom (Push on Tap), T26	NHI351	0,0067	Exceeds Limit	1,3000	Passed
Winding River Consolidated School	Classroom 185 Washroom (Push on Tap), T27	NHI352	0,0040	Passed	0,8600	Passed
Winding River Consolidated School	Boys Change Room (Push on Taps), Lft Tap, T34	NHI353	0,0054	Exceeds Limit	1,7000	Passed
Winding River Consolidated School	Boys Change Room (Push on Taps), Rgt Tap, T35	NHI354	0,0076	Exceeds Limit	0,8400	Passed
Winding River Consolidated School	Gym Office Washroom, T36	NHI355	0,0070	Exceeds Limit	0,9300	Passed
Winding River Consolidated School	Girls Change Room (Push on Taps), Lft Tap, T37	NHI356	0,0060	Exceeds Limit	0,6100	Passed
Winding River Consolidated School	Girls Change Room (Push on Taps), Rgt Tap, T38	NHI357	0,0057	Exceeds Limit	0,5100	Passed

## Chignecto-Central Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Winding River Consolidated School	Kitchen 135 Main Sink Handwash Sink, T40	NHI358	0,0032	Passed	0,7600	Passed
Winding River Consolidated School	Boiler Room 155, T43	NHI359	0,0040	Passed	2,5000	Exceeds Limit
Winding River Consolidated School	Kitchen Cust Floor Sink	NHI360	0,0230	Exceeds Limit	0,4100	Passed