

Water Test Results

Halifax Regional Centre for Education



Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate mediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html

Copper:

www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
A. J. Smeltzer Junior High School	1st floor Girls WR tap 1	MPX522	0.0032	Passed	0.4100	Passed
A. J. Smeltzer Junior High School	1st floor Girls WR tap 2	MPX523	0.0010	Passed	0.0610	Passed
A. J. Smeltzer Junior High School	1st floor Girls WR tap 3	MPX524	0.0074	Exceeds Limit	0.0580	Passed
A. J. Smeltzer Junior High School	1st floor Girls WR tap 4	MPX525	0.0066	Exceeds Limit	0.1600	Passed
A. J. Smeltzer Junior High School	1st floor fountain by JC	MPX526	0.0000	Passed	0.5700	Passed
A. J. Smeltzer Junior High School	1st floor JC tap	MPX527	0.0220	Exceeds Limit	0.1100	Passed
A. J. Smeltzer Junior High School	1st floor boys WR tap 1	MPX528	0.0330	Exceeds Limit	0.0670	Passed
A. J. Smeltzer Junior High School	1st floor boys WR tap 2	MPX529	0.0010	Passed	0.0840	Passed
A. J. Smeltzer Junior High School	1st floor boys WR tap 3	MPX530	0.0009	Passed	0.0700	Passed
A. J. Smeltzer Junior High School	1st floor boys WR tap 4	MPX531	0.0022	Passed	0.4500	Passed
A. J. Smeltzer Junior High School	Fountain by room 16	MPX532	0.0260	Exceeds Limit	0.1400	Passed
A. J. Smeltzer Junior High School	Wood shop tap 1	MPX533	0.0120	Exceeds Limit	0.1400	Passed
A. J. Smeltzer Junior High School	Wood shop tap 2	MPX534	0.0200	Exceeds Limit	0.1400	Passed
A. J. Smeltzer Junior High School	Kitchen WR tap	MPX535	0.0072	Exceeds Limit	0.0490	Passed
A. J. Smeltzer Junior High School	Kitchen sink 1 tap 1	NND038	0.0009	Passed	0.0130	Passed
A. J. Smeltzer Junior High School	Kitchen sink 2 tap 1	MPX537	0.0009	Passed	0.2600	Passed
A. J. Smeltzer Junior High School	Kitchen sink 2 tap 2	NND039	0.0009	Passed	0.0150	Passed
A. J. Smeltzer Junior High School	CR tap room 115	MPX539	0.0950	Exceeds Limit	0.4300	Passed
A. J. Smeltzer Junior High School	CR WR tap room 115	MPX540	0.0120	Exceeds Limit	0.2000	Passed
A. J. Smeltzer Junior High School	Guidance room WR tap	MPX541	0.0013	Passed	0.0880	Passed
A. J. Smeltzer Junior High School	Main office WR tap	MPX542	0.0000	Passed	0.0590	Passed
A. J. Smeltzer Junior High School	2nd floor girls WR tap 1	MPX543	0.0530	Exceeds Limit	0.3300	Passed
A. J. Smeltzer Junior High School	2nd floor girls WR tap 2	MPX544	0.0018	Passed	0.1300	Passed
A. J. Smeltzer Junior High School	2nd floor girls WR tap 3	MPX545	0.0023	Passed	0.1500	Passed
A. J. Smeltzer Junior High School	2nd floor girls WR tap 4	MPX546	0.0020	Passed	0.1200	Passed
A. J. Smeltzer Junior High School	Fountain by 2nd floor JC	MPX547	0.0023	Passed	0.1200	Passed
A. J. Smeltzer Junior High School	2nd floor JC tap	MPX548	0.0022	Passed	0.0420	Passed
A. J. Smeltzer Junior High School	2nd floor boys WR tap 1	MPX549	0.0055	Exceeds Limit	0.0210	Passed
A. J. Smeltzer Junior High School	2nd floor boys WR tap 2	MPX550	0.0015	Passed	0.0590	Passed
A. J. Smeltzer Junior High School	2nd floor boys WR tap 3	MPX551	0.0000	Passed	0.0067	Passed
A. J. Smeltzer Junior High School	2nd floor boys WR tap 4	MPX552	0.0006	Passed	0.0084	Passed
A. J. Smeltzer Junior High School	CR tap room 222	MPX553	0.0012	Passed	0.0250	Passed
A. J. Smeltzer Junior High School	Family living CR tap	MPX554	0.2900	Exceeds Limit	0.1300	Passed
A. J. Smeltzer Junior High School	Food lab WR tap	MPX555	0.0600	Exceeds Limit	0.1300	Passed
A. J. Smeltzer Junior High School	Food lab sink tap	NND040	0.0016	Passed	0.0180	Passed
A. J. Smeltzer Junior High School	Food lab washtub tap	NND041	0.0007	Passed	0.0130	Passed
A. J. Smeltzer Junior High School	Food lab kitchen tap 1	NND042	0.0014	Passed	0.0160	Passed
A. J. Smeltzer Junior High School	Food lab kitchen tap 2	NND043	0.0007	Passed	0.0120	Passed
A. J. Smeltzer Junior High School	Food lab kitchen tap 3	NND044	0.0110	Exceeds Limit	0.0160	Passed
A. J. Smeltzer Junior High School	Food lab kitchen tap 4	NND045	0.0012	Passed	0.0130	Passed
A. J. Smeltzer Junior High School	Library tap room 43A	MPX562	0.0150	Exceeds Limit	0.7000	Passed
A. J. Smeltzer Junior High School	CR tap room 227	MPX563	0.0010	Passed	0.0530	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
A. J. Smeltzer Junior High School	CR tap room 26	MPX564	0.0140	Exceeds Limit	0.4700	Passed
A. J. Smeltzer Junior High School	Staff WR tap room 27A	MPX565	0.0036	Passed	0.0280	Passed
A. J. Smeltzer Junior High School	Staff kitchen tap room 27	MPX566	0.0013	Passed	0.0350	Passed
A. J. Smeltzer Junior High School	Staff WR tap 27B	MPX567	0.0600	Exceeds Limit	0.0520	Passed
Admiral Westphal Elementary School	Fountain by room 16	MYH081	0.0049	Passed	0.8500	Passed
Admiral Westphal Elementary School	JC by girls WR	MYH082	0.0000	Passed	0.0670	Passed
Admiral Westphal Elementary School	Special needs WR tap by room 19	MYH083	0.0014	Passed	0.1600	Passed
Admiral Westphal Elementary School	CR tap 1 room 24	MYH084	0.0100	Exceeds Limit	0.7700	Passed
Admiral Westphal Elementary School	CR tap 2 room 24	MYH085	0.0300	Exceeds Limit	0.4100	Passed
Admiral Westphal Elementary School	Hand washing tap room 23	MYH086	0.0045	Passed	0.2700	Passed
Admiral Westphal Elementary School	Fountain by room 21	NLJ916	0.0041	Passed	0.0870	Passed
Admiral Westphal Elementary School	CR tap room 16	MYH088	0.0031	Passed	0.5300	Passed
Admiral Westphal Elementary School	Girls WR tap 1 by room 12	MYH089	0.0380	Exceeds Limit	0.1600	Passed
Admiral Westphal Elementary School	Girls WR tap 2 by room 12	MYH090	0.0540	Exceeds Limit	0.1200	Passed
Admiral Westphal Elementary School	Girls WR tap 3 by room 12	MYH092	0.0094	Exceeds Limit	0.1300	Passed
Admiral Westphal Elementary School	Girls WR tap 4 by room 12	MYH093	0.0130	Exceeds Limit	0.1200	Passed
Admiral Westphal Elementary School	WR tap in room 10	MYH094	0.0660	Exceeds Limit	1.2000	Passed
Admiral Westphal Elementary School	Boys WR tap 1 by room 12	MYH095	0.0590	Exceeds Limit	0.1300	Passed
Admiral Westphal Elementary School	Boys WR tap 2 by room 12	MYH096	0.0073	Exceeds Limit	0.0850	Passed
Admiral Westphal Elementary School	Boys WR tap 3 by room 12	MYH097	0.0520	Exceeds Limit	0.3600	Passed
Admiral Westphal Elementary School	Boys WR tap 4 by room 12	MYH098	0.0170	Exceeds Limit	0.1600	Passed
Admiral Westphal Elementary School	JC tap near room 12	MYH099	0.0140	Exceeds Limit	0.1800	Passed
Admiral Westphal Elementary School	Fountain by JC tap	MYH100	0.0020	Passed	0.1900	Passed
Admiral Westphal Elementary School	CR tap room 5	MYH101	0.0100	Exceeds Limit	1.3000	Passed
Admiral Westphal Elementary School	GN WR tap between room 4 + 5	MYH102	0.0074	Exceeds Limit	0.4300	Passed
Admiral Westphal Elementary School	JC tap between room 4 + 5	MYH103	0.0300	Exceeds Limit	0.2700	Passed
Admiral Westphal Elementary School	CR tap room 4	MYH104	0.0058	Exceeds Limit	0.1800	Passed
Admiral Westphal Elementary School	CR WR tap in room 3	MYH105	0.0120	Exceeds Limit	0.1500	Passed
Admiral Westphal Elementary School	CR tap in room 3	MYH106	0.0100	Exceeds Limit	0.1300	Passed
Admiral Westphal Elementary School	Staff room female WR tap 1	MYH107	0.0055	Exceeds Limit	0.0640	Passed
Admiral Westphal Elementary School	Staff room female WR tap 2	MYH108	0.0120	Exceeds Limit	0.3300	Passed
Admiral Westphal Elementary School	Staff room male WR tap 1	MYH109	0.0029	Passed	0.0780	Passed
Admiral Westphal Elementary School	Staff room kitchen sink tap	MYH110	0.0039	Passed	0.4600	Passed
Admiral Westphal Elementary School	Principal office WR tap	MYH111	0.0230	Exceeds Limit	0.2100	Passed
Alderney Elementary School	Staff WR tap by front door	NAN882	0.0040	Passed	0.1200	Passed
Alderney Elementary School	JC tap in sprinkler room	NAN883	0.0030	Passed	0.1800	Passed
Alderney Elementary School	1st floor Girls WR tap 1	NAN884	0.1600	Exceeds Limit	1.1000	Passed
Alderney Elementary School	1st floor Girls WR tap 2	NAN885	0.0240	Exceeds Limit	0.5600	Passed
Alderney Elementary School	Fountain by front door	NAN886	0.0021	Passed	0.2400	Passed
Alderney Elementary School	1st floor boys WR tap 1	NAN887	0.1200	Exceeds Limit	1.6000	Passed
Alderney Elementary School	1st floor boys WR tap 2	NAN888	0.0140	Exceeds Limit	0.4900	Passed
Alderney Elementary School	Basement JC tap room 109	NAN889	0.0008	Passed	0.0790	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Alderney Elementary School	Basement female WR tap 1	NAN890	0.1400	Exceeds Limit	0.4600	Passed
Alderney Elementary School	Basement female WR tap 2	NAN891	0.2400	Exceeds Limit	0.3000	Passed
Alderney Elementary School	Basement female WR tap 3	NAN892	0.3500	Exceeds Limit	0.7300	Passed
Alderney Elementary School	Basement male WR tap 1	NAN893	0.0760	Exceeds Limit	0.5400	Passed
Alderney Elementary School	Basement male WR tap 2	NAN894	0.3000	Exceeds Limit	0.7400	Passed
Alderney Elementary School	Basement male WR tap 3	NAN895	0.7200	Exceeds Limit	0.7400	Passed
Alderney Elementary School	Basement Fountain by WR's	NAN896	0.1300	Exceeds Limit	3.5000	Exceeds Limit
Alderney Elementary School	Basement staff room kitchen tap	NAN897	0.0050	Passed	0.0830	Passed
Ash Lee Jefferson Elementary School	CR tap room 207	MVG462	0.0000	Passed	0.4200	Passed
Ash Lee Jefferson Elementary School	Staff room tap	MVG463	0.0009	Passed	0.2100	Passed
Ash Lee Jefferson Elementary School	GN WR tap room 214	MVG464	0.0009	Passed	0.4400	Passed
Ash Lee Jefferson Elementary School	Kitchen tap 1 room 219	MVG465	0.0000	Passed	0.2100	Passed
Ash Lee Jefferson Elementary School	Kitchen tap 2 room 219	MVG466	0.0006	Passed	0.8100	Passed
Ash Lee Jefferson Elementary School	Kitchen tap 3 room 219	MVG467	0.0140	Exceeds Limit	0.1800	Passed
Ash Lee Jefferson Elementary School	Kitchen tap 4 room 219	MVG468	0.0017	Passed	0.1200	Passed
Ash Lee Jefferson Elementary School	Gym office tap room 231	MVG469	0.0029	Passed	1.6000	Passed
Ash Lee Jefferson Elementary School	Girls change room tap	MVG470	0.0005	Passed	0.2200	Passed
Ash Lee Jefferson Elementary School	Fountain in gym	MVG471	0.0011	Passed	0.4300	Passed
Ash Lee Jefferson Elementary School	Boys locker room tap	MVG472	0.0000	Passed	0.2200	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 1 (by boys locker room)	MVG473	0.0006	Passed	0.1400	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 2 (by boys locker room)	MVG474	0.0024	Passed	0.1100	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 3 (by boys locker room)	MVG475	0.0190	Exceeds Limit	0.5200	Passed
Ash Lee Jefferson Elementary School	JC tap	MVG476	0.0000	Passed	0.3000	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 1	MVG477	0.0048	Passed	0.4800	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 2	MVG478	0.0010	Passed	0.3100	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 3	MVG479	0.0010	Passed	0.0610	Passed
Ash Lee Jefferson Elementary School	Fountain by boys WR	MVG480	0.0061	Exceeds Limit	1.9000	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 1 by room 271	MVG481	0.0000	Passed	0.3100	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 2 by room 271	MVG482	0.0000	Passed	0.1200	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 3 by room 271	MVG483	0.0000	Passed	0.1100	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 4 by room 271	MVG484	0.0000	Passed	0.1100	Passed
Ash Lee Jefferson Elementary School	Fountain by room 271	MVG485	0.0000	Passed	1.5000	Passed
Ash Lee Jefferson Elementary School	JC tap	MVG486	0.0000	Passed	0.4200	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 1 by room 281	MVG487	0.0000	Passed	0.1200	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 2 by room 281	MVG488	0.0017	Passed	0.5900	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 3 by room 281	MVG489	0.0009	Passed	0.3000	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 4 by room 281	MVG490	0.0009	Passed	0.2700	Passed
Ash Lee Jefferson Elementary School	CR tap room 281	MVG491	0.0022	Passed	0.2400	Passed
Ash Lee Jefferson Elementary School	GN WR tap room 284	MVG492	0.0008	Passed	0.4400	Passed
Ash Lee Jefferson Elementary School	CR tap room 287	MVG493	0.0024	Passed	0.8200	Passed
Ash Lee Jefferson Elementary School	CR tap room 256	MVG494	0.0000	Passed	0.0630	Passed
Ash Lee Jefferson Elementary School	CR tap room 258	MVG495	0.0130	Exceeds Limit	0.9000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Ash Lee Jefferson Elementary School	CR tap room 260	MVG496	0.0000	Passed	0.5000	Passed
Ash Lee Jefferson Elementary School	Fountain beside room 127	MVG497	0.0036	Passed	0.7400	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 1 room 128	MVG498	0.0080	Exceeds Limit	0.2500	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 2 room 128	MVG499	0.0025	Passed	0.2600	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 3 room 128	MVG500	0.0034	Passed	0.1000	Passed
Ash Lee Jefferson Elementary School	JC tap room 127	MVG501	0.0006	Passed	0.2800	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 1 room 126	MVG502	0.0530	Exceeds Limit	0.5700	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 2 room 126	MVG503	0.0010	Passed	0.1500	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 3 room 126	MVG504	0.0035	Passed	0.1200	Passed
Ash Lee Jefferson Elementary School	Girls WR tap 2 room 126	MVG505	0.0005	Passed	0.5900	Passed
Ash Lee Jefferson Elementary School	Staff WR tap 1	MVG506	0.0000	Passed	0.0920	Passed
Ash Lee Jefferson Elementary School	Staff WR tap 2 room 216	MVG507	0.0023	Passed	0.2300	Passed
Ash Lee Jefferson Elementary School	Fountain by staff room	MVG508	0.0014	Passed	0.8600	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 1	MVG509	0.0012	Passed	1.1000	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 2	MVG510	0.0037	Passed	0.4400	Passed
Ash Lee Jefferson Elementary School	Boys WR tap 3	MVG511	0.0020	Passed	0.6900	Passed
Astral Drive Elementary School	Boys WR tap 1 (upstairs)	MXV292	0.0061	Exceeds Limit	0.1400	Passed
Astral Drive Elementary School	Boys WR tap 2 (upstairs)	MXV293	0.0034	Passed	0.1200	Passed
Astral Drive Elementary School	Boys WR tap 3 (upstairs)	MXV294	0.0027	Passed	0.1400	Passed
Astral Drive Elementary School	Girls WR tap 1 (upstairs)	MXV295	0.0032	Passed	0.1100	Passed
Astral Drive Elementary School	Girls WR tap 2 (upstairs)	MXV296	0.0040	Passed	0.0330	Passed
Astral Drive Elementary School	Girls WR tap 3 (upstairs)	MXV297	0.0000	Passed	0.0100	Passed
Astral Drive Elementary School	JC tap room 217	MXV298	0.0013	Passed	0.0600	Passed
Astral Drive Elementary School	Art room tap room 215	MXV299	0.0052	Exceeds Limit	0.2900	Passed
Astral Drive Elementary School	Staff room tap room 216	MXV300	0.0011	Passed	0.1900	Passed
Astral Drive Elementary School	Staff room WR #1 tap room 216	MXV301	0.0052	Exceeds Limit	0.1500	Passed
Astral Drive Elementary School	Staff room WR #2 tap room 216	MXV302	0.0026	Passed	0.1500	Passed
Astral Drive Elementary School	Fountain by room 216	MXV303	0.0000	Passed	0.2900	Passed
Astral Drive Elementary School	1st floor boys WR tap 1	MXV304	0.0170	Exceeds Limit	0.1400	Passed
Astral Drive Elementary School	1st floor boys WR tap 2	MXV305	0.0035	Passed	0.1600	Passed
Astral Drive Elementary School	1st floor boys WR tap 3	MXV306	0.0005	Passed	0.0170	Passed
Astral Drive Elementary School	1st floor Girls WR tap 1	MXV307	0.0048	Passed	0.0660	Passed
Astral Drive Elementary School	1st floor Girls WR tap 2	MXV308	0.0650	Exceeds Limit	0.1100	Passed
Astral Drive Elementary School	1st floor Girls WR tap 3	MXV309	0.0170	Exceeds Limit	0.2100	Passed
Astral Drive Elementary School	CR tap room 105	MXV310	0.0032	Passed	0.1800	Passed
Astral Drive Elementary School	CR WR tap room 105	MXV311	0.0410	Exceeds Limit	0.3000	Passed
Astral Drive Elementary School	CR tap room 107	NLS543	0.0016	Passed	0.0690	Passed
Astral Drive Elementary School	Main office staff WR tap	MXV313	0.0004	Passed	0.0350	Passed
Astral Drive Elementary School	Fountain by office	MXV314	0.0008	Passed	0.0360	Passed
Astral Drive Elementary School	CR tap room 101	NLS541	0.0007	Passed	0.0430	Passed
Astral Drive Elementary School	CR tap room 102	NLS540	0.0008	Passed	0.0450	Passed
Astral Drive Elementary School	CR WR tap room 102	MXV317	0.0029	Passed	0.1700	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Astral Drive Elementary School	JC tap room 115	MXV318	0.0009	Passed	0.0300	Passed
Astral Drive Elementary School	CR tap room 103	MXV319	0.0320	Exceeds Limit	0.8000	Passed
Astral Drive Elementary School	Boiler room tap	MXV344	0.0190	Exceeds Limit	0.2100	Passed
Astral Drive Elementary School	Fountain by gym	NLS539	0.0004	Passed	0.0390	Passed
Astral Drive Elementary School	CR tap 1 room 104	NLS542	0.0012	Passed	0.0390	Passed
Astral Drive Elementary School	Music room tap room 109	NLS538	0.0005	Passed	0.0170	Passed
Astral Drive Junior High School	Girls WR tap 1 by room 204	MXU330	0.0051	Exceeds Limit	0.1300	Passed
Astral Drive Junior High School	Girls WR tap 2 by room 204	MXU331	0.0009	Passed	0.0500	Passed
Astral Drive Junior High School	Girls WR tap 3 by room 204	MXU332	0.0540	Exceeds Limit	0.0450	Passed
Astral Drive Junior High School	Girls WR tap 4 by room 204	MXU333	0.0023	Passed	0.0480	Passed
Astral Drive Junior High School	Science lab tap 1 room 204	MXU334	0.0280	Exceeds Limit	1.0000	Passed
Astral Drive Junior High School	Science lab tap 2 room 204	MXU335	0.0310	Exceeds Limit	0.1800	Passed
Astral Drive Junior High School	Science lab tap 3 room 204	MXU336	0.0360	Exceeds Limit	0.8300	Passed
Astral Drive Junior High School	Science lab tap 4 room 204	MXU337	0.0022	Passed	0.0570	Passed
Astral Drive Junior High School	Science lab tap 1 room 206	MXU338	0.0110	Exceeds Limit	0.0760	Passed
Astral Drive Junior High School	Science lab tap 2 room 206	MXU339	0.0470	Exceeds Limit	0.4300	Passed
Astral Drive Junior High School	CR lab tap 1 room 211	MXU344	0.0250	Exceeds Limit	1.6000	Passed
Astral Drive Junior High School	CR lab tap 2 room 211	MXU345	0.0420	Exceeds Limit	1.5000	Passed
Astral Drive Junior High School	CR lab tap 3 room 211	MXU346	0.4000	Exceeds Limit	5.6000	Exceeds Limit
Astral Drive Junior High School	CR lab tap 4 room 211	MXU347	0.0280	Exceeds Limit	2.0000	Passed
Astral Drive Junior High School	Boys WR tap 1 by room 232	MXU348	0.0010	Passed	0.0380	Passed
Astral Drive Junior High School	Boys WR tap 2 by room 232	MXU349	0.0005	Passed	0.0310	Passed
Astral Drive Junior High School	Boys WR tap 3 by room 232	MXU350	0.0010	Passed	0.0310	Passed
Astral Drive Junior High School	JC tap room 232	MXU351	0.0000	Passed	0.0320	Passed
Astral Drive Junior High School	Fountain by room 232	NLS557	0.0009	Passed	0.0320	Passed
Astral Drive Junior High School	Office WR tap room 193	MXU353	0.0380	Exceeds Limit	1.2000	Passed
Astral Drive Junior High School	Office tap room 194	NLS556	0.0780	Exceeds Limit	0.0430	Passed
Astral Drive Junior High School	1st floor office kitchen tap	MXU358	0.0006	Passed	0.0370	Passed
Astral Drive Junior High School	Staff room WR tap room 181	MXU359	0.0014	Passed	0.0370	Passed
Astral Drive Junior High School	Staff room WR tap room 182	MXU360	0.0009	Passed	0.0360	Passed
Astral Drive Junior High School	Girls WR tap 1 by room 143	MXU361	0.0022	Passed	0.0410	Passed
Astral Drive Junior High School	Girls WR tap 2 by room 143	MXU362	0.0000	Passed	0.0400	Passed
Astral Drive Junior High School	Fountain by room 143	MXU363	0.0000	Passed	0.1800	Passed
Astral Drive Junior High School	Boys WR tap 1 by room 143	MXU364	0.0009	Passed	0.0740	Passed
Astral Drive Junior High School	Boys WR tap 2 by room 143	MXU365	0.0017	Passed	0.0580	Passed
Astral Drive Junior High School	Home Ec. Tap 1 room R174	MXU366	0.0016	Passed	0.2300	Passed
Astral Drive Junior High School	Home Ec. Tap 2 room R174	MXU367	0.0036	Passed	0.4100	Passed
Astral Drive Junior High School	Wood shop tap room 165	MXU368	0.0150	Exceeds Limit	0.6800	Passed
Astral Drive Junior High School	JC tap room 164	MXU369	0.0031	Passed	0.0430	Passed
Astral Drive Junior High School	1st floor canteen tap 1	MXU370	0.0012	Passed	0.0770	Passed
Astral Drive Junior High School	1st floor canteen tap 2	MXU371	0.0007	Passed	0.0650	Passed
Astral Drive Junior High School	Gym office WR tap room 153	MXU372	0.0024	Passed	0.0510	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Astral Drive Junior High School	Girls gym locker room tap 1	MXU373	0.0014	Passed	0.1000	Passed
Astral Drive Junior High School	Girls gym locker room tap 2	MXU374	0.0017	Passed	0.1000	Passed
Astral Drive Junior High School	Boys gym locker room tap 1	MXU375	0.0037	Passed	0.1100	Passed
Astral Drive Junior High School	Boys gym locker room tap 2	MXU376	0.0012	Passed	0.0440	Passed
Astral Drive Junior High School	Gym office WR tap room 157	MXU377	0.0021	Passed	0.0540	Passed
Astral Drive Junior High School	CR tap room 143	MXU378	0.0021	Passed	0.0540	Passed
Astral Drive Junior High School	Art room tap 1 room 142	MXU379	0.3300	Exceeds Limit	0.1900	Passed
Astral Drive Junior High School	Art room tap 2 room 142	MXU380	0.6000	Exceeds Limit	3.9000	Exceeds Limit
Astral Drive Junior High School	Student services WR tap room 141	MXU381	0.0091	Exceeds Limit	0.1100	Passed
Astral Drive Junior High School	Resource Room 140 tap	NLS555	0.0008	Passed	0.0310	Passed
Astral Drive Junior High School	1st floor boys WR tap 1 by room 132	MXU383	0.3300	Exceeds Limit	0.4600	Passed
Astral Drive Junior High School	1st floor boys WR tap 2 by room 132	MXU384	0.0250	Exceeds Limit	0.0560	Passed
Astral Drive Junior High School	1st floor boys WR tap 3 by room 132	MXU385	0.0250	Exceeds Limit	0.0690	Passed
Astral Drive Junior High School	JC tap room 132	MXU386	0.0017	Passed	0.0540	Passed
Astral Drive Junior High School	Fountain by room 132	MXU389	0.0000	Passed	0.6700	Passed
Astral Drive Junior High School	1st floor Girls WR tap 1 by room 133	MXU390	0.0051	Exceeds Limit	0.3400	Passed
Astral Drive Junior High School	1st floor Girls WR tap 2 by room 133	MXU391	0.0039	Passed	0.0920	Passed
Astral Drive Junior High School	1st floor Girls WR tap 3 by room 133	MXU392	0.0011	Passed	0.0610	Passed
Astral Drive Junior High School	1st floor Girls WR tap 4 by room 133	MXU393	0.0013	Passed	0.0980	Passed
Atl. Mem. Elem- Shad Bay	Fountain by room 107	MUQ842	0.0110	Exceeds Limit	1.1000	Passed
Atl. Mem. Elem- Shad Bay	Pre-Primary WR tap	MUQ843	0.0300	Exceeds Limit	1.9000	Passed
Atl. Mem. Elem- Shad Bay	Pre-Primary sink tap	MUQ845	2.0000	Exceeds Limit	0.5900	Passed
Atl. Mem. Elem- Shad Bay	Gym WR tap	MUQ846	0.0140	Exceeds Limit	5.4000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Boys WR tap	MUQ847	0.0210	Exceeds Limit	1.9000	Passed
Atl. Mem. Elem- Shad Bay	Janitors office tap	MUQ848	0.0970	Exceeds Limit	6.6000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Girls WR tap	MUQ849	0.0280	Exceeds Limit	2.8000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Music room tap room 108	MUQ850	0.9600	Exceeds Limit	1.3000	Passed
Atl. Mem. Elem- Shad Bay	Fountain across from boys WR	MUQ851	0.0160	Exceeds Limit	6.7000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Sink tap in common room	MUQ852	0.0290	Exceeds Limit	1.5000	Passed
Atl. Mem. Elem- Shad Bay	GN WR tap	MUQ853	0.0390	Exceeds Limit	3.2000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Boys WR tap 1	MUQ854	0.0300	Exceeds Limit	0.9700	Passed
Atl. Mem. Elem- Shad Bay	Boys WR tap 2	MUQ855	0.0210	Exceeds Limit	3.1000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Boys WR tap 3	MUQ856	0.0260	Exceeds Limit	2.3000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Boys WR tap 4	MUQ857	0.0270	Exceeds Limit	0.9000	Passed
Atl. Mem. Elem- Shad Bay	JC tap	MUQ858	0.0170	Exceeds Limit	9.9000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Fountain by JC	MUQ859	0.0260	Exceeds Limit	5.4000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Girls WR tap 1	MUQ860	0.0210	Exceeds Limit	2.8000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Girls WR tap 2	MUQ941	0.0051	Exceeds Limit	3.3000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Girls WR tap 3	MUQ910	0.0130	Exceeds Limit	2.2000	Exceeds Limit
Atl. Mem. Elem- Shad Bay	Girls WR tap 4	MUQ911	0.0170	Exceeds Limit	3.1000	Exceeds Limit
Atlantic Memorial-Terence Bay Elementary School	Fountain by Girls WR	MUM349	0.0095	Exceeds Limit	0.6700	Passed
Atlantic Memorial-Terence Bay Elementary School	Girls WR tap 1	MUM350	0.0850	Exceeds Limit	0.0990	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Atlantic Memorial-Terence Bay Elementary School	Girls WR tap 2	MUM351	0.0170	Exceeds Limit	0.3700	Passed
Atlantic Memorial-Terence Bay Elementary School	JC tap by girls WR	MUM352	0.0056	Exceeds Limit	0.2500	Passed
Atlantic Memorial-Terence Bay Elementary School	Boys WR tap 1	MUM353	0.0180	Exceeds Limit	0.0540	Passed
Atlantic Memorial-Terence Bay Elementary School	Boys WR tap 2	MUM354	0.0160	Exceeds Limit	0.0600	Passed
Atlantic Memorial-Terence Bay Elementary School	GN WR tap 1 beside Readmy	MUM355	0.0450	Exceeds Limit	0.1700	Passed
Atlantic Memorial-Terence Bay Elementary School	GN WR tap 2 beside Readmy	MUM356	0.0190	Exceeds Limit	0.2100	Passed
Atlantic Memorial-Terence Bay Elementary School	GN WR tap at the end of the building	MUM357	0.1200	Exceeds Limit	0.1300	Passed
Atlantic Memorial-Terence Bay Elementary School	GN WR tap	MUM358	0.0190	Exceeds Limit	0.2100	Passed
Atlantic Memorial-Terence Bay Elementary School	GN WR tap	MUM368	0.0250	Exceeds Limit	0.1200	Passed
Atlantic Memorial-Terence Bay Elementary School	Teachers lounge tap	MUM369	0.0150	Exceeds Limit	0.1900	Passed
Atlantic View Elementary School	GN WR tap CR 3	MXK161	0.1700	Exceeds Limit	0.1100	Passed
Atlantic View Elementary School	Fountain by girls WR	MXK162	0.0006	Passed	0.1100	Passed
Atlantic View Elementary School	Girls WR tap 1 by fountain	MXK163	0.0160	Exceeds Limit	0.0110	Passed
Atlantic View Elementary School	Girls WR tap 2 by fountain	MXK164	0.0140	Exceeds Limit	0.0290	Passed
Atlantic View Elementary School	Girls WR tap 3 by fountain	MXK165	0.0051	Exceeds Limit	0.0130	Passed
Atlantic View Elementary School	JC tap between WR's	MXK166	0.0000	Passed	0.0130	Passed
Atlantic View Elementary School	Boys WR tap 1 by JC	MXK167	0.0058	Exceeds Limit	0.0340	Passed
Atlantic View Elementary School	Boys WR tap 2 by JC	MXK168	0.0830	Exceeds Limit	0.5800	Passed
Atlantic View Elementary School	Girls locker room tap	MXK187	0.3100	Exceeds Limit	0.1700	Passed
Atlantic View Elementary School	Staff WR tap in gym	MXK188	0.2500	Exceeds Limit	0.0170	Passed
Atlantic View Elementary School	Caretaker room tap in gym	MXK189	0.0067	Exceeds Limit	0.7300	Passed
Atlantic View Elementary School	Kitchen /cafe tap in gym	MXK190	0.3500	Exceeds Limit	0.0130	Passed
Atlantic View Elementary School	Kitchen sink tap in gym kitchen	MXK191	0.1200	Exceeds Limit	0.0750	Passed
Atlantic View Elementary School	Art/Music room tap	MXK192	0.0450	Exceeds Limit	0.0820	Passed
Atlantic View Elementary School	Kitchen sink tap in staff lounge	MXK193	0.0130	Exceeds Limit	0.0180	Passed
Atlantic View Elementary School	Sick room tap in main office	MXK194	0.0670	Exceeds Limit	0.6500	Passed
Atlantic View Elementary School	Staff WR #1 in main office	MXK195	0.0800	Exceeds Limit	0.1600	Passed
Atlantic View Elementary School	Staff WR #2 in main office	MXK196	0.0830	Exceeds Limit	0.1200	Passed
Atlantic View Elementary School	Boys WR tap 3 by JC	MXK202	0.0310	Exceeds Limit	0.1900	Passed
Atlantic View Elementary School	Breakfast club room tap	MXK206	0.0140	Exceeds Limit	0.1300	Passed
Auburn Drive High School	Science Lab tap room 301	MXA146	0.0000	Passed	1.1000	Passed
Auburn Drive High School	Science Lab tap 1 room 302	MXA147	0.0000	Passed	0.7600	Passed
Auburn Drive High School	Science Lab tap 2 room 302	MXA148	0.0007	Passed	0.7600	Passed
Auburn Drive High School	Science Lab tap 3 room 302	MXA149	0.0000	Passed	0.9500	Passed
Auburn Drive High School	Science Lab tap 4 room 302	MXA150	0.0007	Passed	0.9200	Passed
Auburn Drive High School	Science Lab tap 1 room 303	MXA151	0.0000	Passed	1.0000	Passed
Auburn Drive High School	Science Lab tap 2 room 303	MXA152	0.0041	Passed	0.4600	Passed
Auburn Drive High School	Science Lab tap 3 room 303	MXA153	0.0013	Passed	0.4400	Passed
Auburn Drive High School	Science Lab tap 4 room 303	MXA154	0.0008	Passed	0.7600	Passed
Auburn Drive High School	Fountain by room 304	MXA155	0.0000	Passed	1.2000	Passed
Auburn Drive High School	Fountain by room 307	MXA156	0.0072	Exceeds Limit	0.3400	Passed
Auburn Drive High School	CR tap 1 room 313	MXA157	0.0260	Exceeds Limit	0.0620	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Auburn Drive High School	CR tap 2 room 313	MXA158	0.0200	Exceeds Limit	0.1500	Passed
Auburn Drive High School	CR tap 3 room 313	MXA159	0.0098	Exceeds Limit	0.0300	Passed
Auburn Drive High School	CR tap 4 room 313	MXA160	0.0018	Passed	0.5200	Passed
Auburn Drive High School	CR tap 5 room 313	MXA161	0.0000	Passed	0.3500	Passed
Auburn Drive High School	Prep room tap Room 314	MXA162	0.0009	Passed	0.5400	Passed
Auburn Drive High School	Science Lab tap 1 room 314	MXA163	0.0000	Passed	0.9100	Passed
Auburn Drive High School	Science Lab tap 2 room 314	MXA164	0.0009	Passed	0.5900	Passed
Auburn Drive High School	Science Lab tap 3 room 314	MXA165	0.0014	Passed	0.6000	Passed
Auburn Drive High School	Science Lab tap 4 room 314	MXA166	0.0006	Passed	0.7000	Passed
Auburn Drive High School	Science Lab tap 5 room 314	MXA167	0.0000	Passed	1.1000	Passed
Auburn Drive High School	Science Lab tap 6 room 314	MXA168	0.0000	Passed	0.7000	Passed
Auburn Drive High School	Science Lab tap 7 room 314	MXA169	0.0000	Passed	0.7700	Passed
Auburn Drive High School	Science Lab tap 8 room 314	MXA170	0.0000	Passed	0.7400	Passed
Auburn Drive High School	Science Lab tap 9 room 314	MXA171	0.0000	Passed	0.7500	Passed
Auburn Drive High School	Science Lab tap 1 room 315	MXA172	0.1800	Exceeds Limit	0.6400	Passed
Auburn Drive High School	Science Lab tap 2 room 315	MXA173	0.0029	Passed	0.8100	Passed
Auburn Drive High School	Science Lab tap 3 room 315	MXA174	0.0000	Passed	0.6400	Passed
Auburn Drive High School	Science Lab tap 4 room 315	MXA175	0.0020	Passed	0.2100	Passed
Auburn Drive High School	Science Lab tap 5 room 315	MXA176	0.0250	Exceeds Limit	0.5300	Passed
Auburn Drive High School	Science Lab tap 6 room 315	MXA177	0.0099	Exceeds Limit	0.7300	Passed
Auburn Drive High School	Science Lab tap 7 room 315	MXA178	0.0051	Exceeds Limit	0.1600	Passed
Auburn Drive High School	Science Lab tap 8 room 315	MXA179	0.0007	Passed	0.8700	Passed
Auburn Drive High School	Science Lab tap 9 room 315	MXA180	0.0015	Passed	0.4700	Passed
Auburn Drive High School	Boys WR tap 1 by room 301	MXA181	0.0006	Passed	0.5000	Passed
Auburn Drive High School	Boys WR tap 2 by room 301	MXA182	0.0000	Passed	0.1900	Passed
Auburn Drive High School	Boys WR tap 3 by room 301	MXA183	0.0008	Passed	0.0570	Passed
Auburn Drive High School	Boys WR tap 4 by room 301	MXA184	0.0061	Exceeds Limit	0.7700	Passed
Auburn Drive High School	Boys WR tap 5 by room 301	MXA185	0.0009	Passed	0.1600	Passed
Auburn Drive High School	Staff WR #1 tap by room 301	MXA186	0.0071	Exceeds Limit	0.1600	Passed
Auburn Drive High School	Staff WR #2 tap by room 301	MXA187	0.0010	Passed	0.6600	Passed
Auburn Drive High School	Girls WR tap 1 by room 301	MXA188	0.0029	Passed	0.4900	Passed
Auburn Drive High School	Girls WR tap 2 by room 301	MXA189	0.0000	Passed	0.5400	Passed
Auburn Drive High School	Girls WR tap 3 by room 301	MXA190	0.0049	Passed	0.3900	Passed
Auburn Drive High School	Girls WR tap 4 by room 301	MXA191	0.0027	Passed	0.1500	Passed
Auburn Drive High School	Girls WR tap 5 by room 301	MXA192	0.0051	Exceeds Limit	0.3400	Passed
Auburn Drive High School	JC tap by WR's	MXA193	0.0012	Passed	0.3600	Passed
Auburn Drive High School	Fountain by stairs	MXA194	0.0000	Passed	0.1600	Passed
Auburn Drive High School	Music room tap room 201	MXA195	0.0110	Exceeds Limit	0.5400	Passed
Auburn Drive High School	Fountain by room 202	MXA196	0.0011	Passed	0.2300	Passed
Auburn Drive High School	Fine arts room tap 1 room 202	MXA197	0.0000	Passed	0.9500	Passed
Auburn Drive High School	Fine arts room tap 2 room 202	MXA198	0.0000	Passed	0.4300	Passed
Auburn Drive High School	Fine arts room tap 1 room 203	MXA199	0.0058	Exceeds Limit	0.4600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Auburn Drive High School	Fine arts room tap 2 room 203	MXA200	0.0380	Exceeds Limit	0.6700	Passed
Auburn Drive High School	Fine arts room tap room 204	MXA201	0.0000	Passed	0.7300	Passed
Auburn Drive High School	Fountain by room 207	MXA202	0.0010	Passed	0.3500	Passed
Auburn Drive High School	CR tap room 209	MXA203	0.0041	Passed	0.2600	Passed
Auburn Drive High School	GN WR tap 1 room 209	MXA204	0.0055	Exceeds Limit	0.5500	Passed
Auburn Drive High School	GN WR tap 2 room 209	MXA205	0.0000	Passed	0.4800	Passed
Auburn Drive High School	Fountain by room 212	MXA206	0.0000	Passed	0.0890	Passed
Auburn Drive High School	JC tap by student services	MXA207	0.0000	Passed	0.1500	Passed
Auburn Drive High School	Student services tap	MXA208	0.0210	Exceeds Limit	0.1500	Passed
Auburn Drive High School	Mens staff room WR tap	MXA209	0.0006	Passed	0.0580	Passed
Auburn Drive High School	Female staff room WR tap	MXA210	0.0000	Passed	0.2900	Passed
Auburn Drive High School	Staff room kitchen tap	MXA211	0.0008	Passed	0.3100	Passed
Auburn Drive High School	Library WR tap	MXA212	0.0018	Passed	1.0000	Passed
Auburn Drive High School	Library kitchen tap	MXA213	0.0000	Passed	0.0350	Passed
Auburn Drive High School	Cafeteria tap 1	MXA214	0.0014	Passed	0.3000	Passed
Auburn Drive High School	Cafeteria tap 2	MXA215	0.0000	Passed	0.0550	Passed
Auburn Drive High School	Cafeteria tap 3	MXA216	0.0052	Exceeds Limit	0.7500	Passed
Auburn Drive High School	Gym GN WR tap	MXA217	0.0072	Exceeds Limit	0.4100	Passed
Auburn Drive High School	Gym male change room tap 1	MXA218	0.0042	Passed	0.4600	Passed
Auburn Drive High School	Gym male change room tap 2	MXA219	0.0013	Passed	0.3000	Passed
Auburn Drive High School	Female gym change room tap 1	MXA220	0.0059	Exceeds Limit	0.4300	Passed
Auburn Drive High School	Female gym change room tap 2	MXA221	0.0000	Passed	0.4700	Passed
Auburn Drive High School	Fountain in gym	MXA222	0.0054	Exceeds Limit	0.7600	Passed
Auburn Drive High School	Gym office WR tap (Mr. Bush)	MXA223	0.0006	Passed	0.7600	Passed
Auburn Drive High School	Fountain by room 223	MXA224	0.0000	Passed	0.1200	Passed
Auburn Drive High School	JC tap in maintenance room	MXA225	0.0052	Exceeds Limit	0.7300	Passed
Auburn Drive High School	Food Lab CR 213 wash tap	NLS564	0.0017	Passed	0.0470	Passed
Auburn Drive High School	CR tap 1 room 213	MXA227	0.0000	Passed	0.3700	Passed
Auburn Drive High School	CR tap 2 room 213	MXA228	0.0000	Passed	0.4600	Passed
Auburn Drive High School	CR tap 3 room 213	MXA229	0.0014	Passed	0.9500	Passed
Auburn Drive High School	CR tap 1 room 214	MXA230	0.0023	Passed	0.7700	Passed
Auburn Drive High School	CR tap 2 room 214	MXA231	0.0018	Passed	0.2800	Passed
Auburn Drive High School	Main floor girls WR tap 1	MXA232	0.0038	Passed	0.2000	Passed
Auburn Drive High School	Main floor girls WR tap 2	MXA233	0.0014	Passed	0.2600	Passed
Auburn Drive High School	Main floor girls WR tap 3	MXA234	0.0014	Passed	0.1900	Passed
Auburn Drive High School	Main floor girls WR tap 4	MXA235	0.0011	Passed	0.1600	Passed
Auburn Drive High School	Main floor boys WR tap 1	MXA236	0.0011	Passed	0.1500	Passed
Auburn Drive High School	Main floor boys WR tap 2	MXA237	0.0009	Passed	0.1300	Passed
Auburn Drive High School	Main floor boys WR tap 3	MXA238	0.0170	Exceeds Limit	0.4300	Passed
Auburn Drive High School	Main floor boys WR tap 4	MXA239	0.0000	Passed	0.2500	Passed
Auburn Drive High School	JC tap room 110	MXH473	0.0007	Passed	0.3000	Passed
Auburn Drive High School	JC tap room 111	MXH474	0.0022	Passed	0.3600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Auburn Drive High School	JC tap room 112	MXH475	0.0016	Passed	0.1700	Passed
Auburn Drive High School	Basement boys WR tap 1	MXH476	0.0010	Passed	0.1100	Passed
Auburn Drive High School	Basement boys WR tap 2	MXH477	0.0009	Passed	0.1200	Passed
Auburn Drive High School	Basement boys WR tap 3	MXH478	0.0011	Passed	0.0970	Passed
Auburn Drive High School	GN WR tap by boys WR	MXH479	0.0006	Passed	0.1600	Passed
Auburn Drive High School	Fountain between GN WR's	MXH480	0.0051	Exceeds Limit	0.2600	Passed
Auburn Drive High School	GN WR tap by girls WR	MXH481	0.0250	Exceeds Limit	0.5800	Passed
Auburn Drive High School	Basement girls WR tap 1	MXH482	0.0100	Exceeds Limit	0.0450	Passed
Auburn Drive High School	Basement girls WR tap 2	MXH483	0.0015	Passed	0.0260	Passed
Auburn Drive High School	Basement girls WR tap 3	MXH484	0.0008	Passed	0.0290	Passed
Auburn Drive High School	Basement girls WR tap 4	MXH485	0.0058	Exceeds Limit	0.1500	Passed
Auburn Drive High School	Basement girls WR tap 5	MXH486	0.0000	Passed	0.0180	Passed
Auburn Drive High School	JC tap by girls WR	MXH487	0.0006	Passed	1.0000	Passed
Auburn Drive High School	Science Lab tap 3 room 315	NBS263	0.0006	Passed	0.6300	Passed
Auburn Drive High School	Science Lab tap 4 room 315	NBS264	0.0022	Passed	0.1600	Passed
Basinview Drive Community School	Caretaker office tap	MSP510	0.0000	Passed	0.0190	Passed
Basinview Drive Community School	CR tap room 131	MSP511	0.0200	Exceeds Limit	0.4200	Passed
Basinview Drive Community School	CR tap room 132	MSP512	0.0006	Passed	0.1900	Passed
Basinview Drive Community School	CR WR tap room 133	MSP513	0.0010	Passed	0.1200	Passed
Basinview Drive Community School	CR tap room 133	MSP514	0.0067	Exceeds Limit	0.4600	Passed
Basinview Drive Community School	JC tap after room 133	MSP515	0.0011	Passed	0.0900	Passed
Basinview Drive Community School	GN WR tap room 137	MSP516	0.0000	Passed	0.0980	Passed
Basinview Drive Community School	CR tap room 138	MSP517	0.0009	Passed	0.6700	Passed
Basinview Drive Community School	CR WR tap room 139	MSP518	0.0000	Passed	0.0420	Passed
Basinview Drive Community School	CR tap room 139	MSP519	0.0000	Passed	0.0460	Passed
Basinview Drive Community School	Staff WR 1 by room 139	MSP524	0.0000	Passed	0.0590	Passed
Basinview Drive Community School	Staff WR 2 by room 139	MSP525	0.0000	Passed	0.0750	Passed
Basinview Drive Community School	Staff room kitchen sink tap	MSP526	0.0000	Passed	0.0170	Passed
Basinview Drive Community School	1st floor boys WR tap 1	MSP527	0.0000	Passed	0.0280	Passed
Basinview Drive Community School	1st floor boys WR tap 1	MSP528	0.0000	Passed	0.0310	Passed
Basinview Drive Community School	1st floor Girls WR tap 1	MSP529	0.0011	Passed	0.1500	Passed
Basinview Drive Community School	1st floor Girls WR tap 2	MSP530	0.0000	Passed	0.1100	Passed
Basinview Drive Community School	Fountain after girls WR	MSP531	0.0010	Passed	0.2800	Passed
Basinview Drive Community School	CR tap room 106	MSP532	0.0006	Passed	0.1800	Passed
Basinview Drive Community School	CR tap room 107	MSP533	0.0000	Passed	0.0700	Passed
Basinview Drive Community School	Boiler room tap after room 107	MSP534	0.0000	Passed	0.0073	Passed
Basinview Drive Community School	Music room sink tap	MSP535	0.0000	Passed	0.0088	Passed
Basinview Drive Community School	Boys locker room tap 1	MSP536	0.0023	Passed	0.0540	Passed
Basinview Drive Community School	Boys locker room tap 2	MSP537	0.0000	Passed	0.0240	Passed
Basinview Drive Community School	Fountain in boys locker room	MSP538	0.0009	Passed	0.3800	Passed
Basinview Drive Community School	Fountain in girls locker room	NLV833	0.0004	Passed	0.0110	Passed
Basinview Drive Community School	Girls locker room tap 1	MSP540	0.0017	Passed	0.1600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Basinview Drive Community School	Girls locker room tap 2	MSP541	0.0027	Passed	0.0560	Passed
Basinview Drive Community School	WR in girls locker room tap	MSP542	0.0000	Passed	0.0130	Passed
Basinview Drive Community School	Cafeteria large sink tap	MSP543	0.0000	Passed	0.4700	Passed
Basinview Drive Community School	Cafeteria small sink tap	MSP544	0.0032	Passed	0.9300	Passed
Basinview Drive Community School	Mech room tap after 207	MSP545	0.0000	Passed	0.0540	Passed
Basinview Drive Community School	CR sink tap room 212	NLV834	0.0004	Passed	0.0060	Passed
Basinview Drive Community School	CR WR sink tap room 213	MSP547	0.0000	Passed	0.0210	Passed
Basinview Drive Community School	CR tap room 213	MSP548	0.0012	Passed	0.1700	Passed
Basinview Drive Community School	Boys WR tap 1 by room 213	MSP549	0.0000	Passed	0.0170	Passed
Basinview Drive Community School	Boys WR tap 2 by room 213	MSP550	0.0000	Passed	0.0170	Passed
Basinview Drive Community School	Boys WR tap 3 by room 213	MSP551	0.0018	Passed	0.0550	Passed
Basinview Drive Community School	Girls WR tap 1 by room 213	MSP552	0.0006	Passed	0.1000	Passed
Basinview Drive Community School	Girls WR tap 2 by room 213	MSP553	0.0000	Passed	0.0330	Passed
Basinview Drive Community School	Girls WR tap 3 by room 213	MSP554	0.0000	Passed	0.0370	Passed
Basinview Drive Community School	Fountain after Girls WR	MSP555	0.0005	Passed	0.6200	Passed
Basinview Drive Community School	Mech. Room tap	MSP556	0.0000	Passed	0.0061	Passed
Basinview Drive Community School	GN staff WR tap	MSP557	0.0014	Passed	0.0490	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 1 across form rm 203	MUQ659	0.0016	Passed	0.0740	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 2 across form rm 203	MUQ660	0.0180	Exceeds Limit	0.0960	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 3 across form rm 203	MUQ661	0.0098	Exceeds Limit	0.1200	Passed
Beaver Bank-Kinsac Elementary School	JC tap beside boys WR	MUQ662	0.0220	Exceeds Limit	0.1100	Passed
Beaver Bank-Kinsac Elementary School	Fountain beside JC	MUQ663	0.0035	Passed	0.1200	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 1 beside rm 201	MUQ664	0.0027	Passed	0.1800	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 2 beside rm 201	MUQ665	0.0018	Passed	0.1300	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 3 beside rm 201	MUQ666	0.0013	Passed	0.0820	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 1 in basement	MUQ667	0.0019	Passed	0.0840	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 2 in basement	MUQ668	0.0050	Passed	0.1200	Passed
Beaver Bank-Kinsac Elementary School	Fountain in basement between WR's	MUQ669	0.0029	Passed	0.0980	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 1 in basement	MUQ670	0.0110	Exceeds Limit	0.1200	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 2 in basement	MUQ671	0.0036	Passed	0.0860	Passed
Beaver Bank-Kinsac Elementary School	JC tap in basement	MUQ672	0.0007	Passed	0.0820	Passed
Beaver Bank-Kinsac Elementary School	Breakfast club room tap in basement	MUQ673	0.0011	Passed	0.0760	Passed
Beaver Bank-Kinsac Elementary School	CR tap room 202	MUQ674	0.0007	Passed	0.1700	Passed
Beaver Bank-Kinsac Elementary School	CR tap room 203	MUQ675	0.0028	Passed	0.1900	Passed
Beaver Bank-Kinsac Elementary School	Staff WR tap in main office	MUQ676	0.0055	Exceeds Limit	0.1100	Passed
Beaver Bank-Kinsac Elementary School	Staff room tap	MUQ677	0.0013	Passed	0.0620	Passed
Beaver Bank-Kinsac Elementary School	Staff room WR in staff room	MUQ678	0.0180	Exceeds Limit	0.1300	Passed
Beaver Bank-Kinsac Elementary School	Staff female WR in staff room	MUQ679	0.0120	Exceeds Limit	0.8800	Passed
Beaver Bank-Kinsac Elementary School	CR tap room 217	MUQ680	0.0015	Passed	0.0410	Passed
Beaver Bank-Kinsac Elementary School	Staff WR tap by room 217	MUQ681	0.0005	Passed	0.0260	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 1 beside room 204	MUQ682	0.0079	Exceeds Limit	0.1100	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 2 beside room 204	MUQ683	0.0110	Exceeds Limit	0.0960	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Beaver Bank-Kinsac Elementary School	Girls WR tap 3 beside room 204	MUQ684	0.0051	Exceeds Limit	0.0720	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 4 beside room 204	MUQ685	0.0052	Exceeds Limit	0.0690	Passed
Beaver Bank-Kinsac Elementary School	Girls WR tap 5 beside room 204	MUQ686	0.0037	Passed	0.0650	Passed
Beaver Bank-Kinsac Elementary School	JC tap room 204	MUQ687	0.0020	Passed	0.0240	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 1 by room 204	MUQ688	0.0027	Passed	0.0570	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 2 by room 204	MUQ689	0.0012	Passed	0.0520	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 3 by room 204	MUQ690	0.0005	Passed	0.0250	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 4 by room 204	MUQ691	0.0036	Passed	0.0390	Passed
Beaver Bank-Kinsac Elementary School	Boys WR tap 5 by room 204	MUQ692	0.0017	Passed	0.0620	Passed
Beaver Bank-Kinsac Elementary School	Fountain beside boys WR	MUQ693	0.0065	Exceeds Limit	0.2200	Passed
Beaver Bank-Monarch Drive Elementary School	Fountain beside room 224	MUN104	0.0000	Passed	0.0071	Passed
Beaver Bank-Monarch Drive Elementary School	Art room tap room 205B	MUN105	0.0056	Exceeds Limit	0.0150	Passed
Beaver Bank-Monarch Drive Elementary School	Fountain beside girls WR	MUN106	0.0007	Passed	0.0420	Passed
Beaver Bank-Monarch Drive Elementary School	2nd floor Girls WR tap 1	MUN107	0.0027	Passed	0.1900	Passed
Beaver Bank-Monarch Drive Elementary School	2nd floor Girls WR tap 2	MUN108	0.0017	Passed	0.4800	Passed
Beaver Bank-Monarch Drive Elementary School	2nd floor Girls WR tap 3	MUN109	0.0024	Passed	0.2600	Passed
Beaver Bank-Monarch Drive Elementary School	2nd floor Boys WR tap 1	MUN110	0.0200	Exceeds Limit	0.6100	Passed
Beaver Bank-Monarch Drive Elementary School	2nd floor Boys WR tap 2	MUN111	0.1000	Exceeds Limit	2.0000	Passed
Beaver Bank-Monarch Drive Elementary School	2nd floor Boys WR tap 3	MUN112	0.0075	Exceeds Limit	0.6000	Passed
Beaver Bank-Monarch Drive Elementary School	JC tap room 210	MUN113	0.0006	Passed	0.0200	Passed
Beaver Bank-Monarch Drive Elementary School	CR tap room 122	MUN114	0.0020	Passed	0.0130	Passed
Beaver Bank-Monarch Drive Elementary School	GN WR tap room 122	MUN115	0.0094	Exceeds Limit	0.0550	Passed
Beaver Bank-Monarch Drive Elementary School	GN WR tap room 124	MUN116	0.0160	Exceeds Limit	0.0700	Passed
Beaver Bank-Monarch Drive Elementary School	CR tap room 124	MUN117	0.0012	Passed	0.0280	Passed
Beaver Bank-Monarch Drive Elementary School	CR tap room 123	MUN118	0.0035	Passed	0.0039	Passed
Beaver Bank-Monarch Drive Elementary School	Fountain beside room 123	MUN119	0.0000	Passed	0.0033	Passed
Beaver Bank-Monarch Drive Elementary School	CR tap room 121	MUN120	0.0017	Passed	0.0064	Passed
Beaver Bank-Monarch Drive Elementary School	Girls WR tap 1 beside room 121	MUN121	0.0350	Exceeds Limit	1.6000	Passed
Beaver Bank-Monarch Drive Elementary School	Girls WR tap 2 beside room 121	MUN122	0.0270	Exceeds Limit	0.5800	Passed
Beaver Bank-Monarch Drive Elementary School	Girls WR tap 3 beside room 121	MUN123	0.0210	Exceeds Limit	1.3000	Passed
Beaver Bank-Monarch Drive Elementary School	Boys WR tap 1 across from mech. Room	MUN132	0.0061	Exceeds Limit	0.0620	Passed
Beaver Bank-Monarch Drive Elementary School	Boys WR tap 2 across from mech. Room	MUN133	0.0073	Exceeds Limit	0.0430	Passed
Beaver Bank-Monarch Drive Elementary School	Boys WR tap 3 across from mech. Room	MUN134	0.0100	Exceeds Limit	0.4000	Passed
Beaver Bank-Monarch Drive Elementary School	Library room tap room 104	MUN135	0.1400	Exceeds Limit	0.2600	Passed
Beaver Bank-Monarch Drive Elementary School	CR tap room 101	MUN136	0.0006	Passed	0.0120	Passed
Beaver Bank-Monarch Drive Elementary School	CR tap room 104	MUN137	0.0019	Passed	0.0052	Passed
Beaver Bank-Monarch Drive Elementary School	Staff room kitchen tap	MUN138	0.0031	Passed	0.6500	Passed
Beaver Bank-Monarch Drive Elementary School	Staff room WR tap	MUN139	0.0009	Passed	0.4300	Passed
Beaver Bank-Monarch Drive Elementary School	Staff room WR tap	MUN140	0.0032	Passed	0.4100	Passed
Beaver Bank-Monarch Drive Elementary School	Fountain beside machine shop room	MUN141	0.0047	Passed	0.0820	Passed
Beaver Bank-Monarch Drive Elementary School	Sick room tap in main office	MUN188	0.0090	Exceeds Limit	0.0740	Passed
Beaver Bank-Monarch Drive Elementary School	JC tap beside gym	MUN189	0.0010	Passed	0.0082	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Beaver Bank-Monarch Drive Elementary School	Fountain beside gym	MUN190	0.0021	Passed	0.0410	Passed
Beaver Bank-Monarch Drive Elementary School	Girls Change room tap	MUN191	0.0024	Passed	0.0056	Passed
Beaver Bank-Monarch Drive Elementary School	Boys change room tap	MUN192	0.0037	Passed	0.0160	Passed
Beaver Bank-Monarch Drive Elementary School	Music room tap room 108	MUN193	0.0180	Exceeds Limit	0.0180	Passed
Beaver Bank-Monarch Drive Elementary School	Canteen room tap	MUN194	0.0043	Passed	0.0580	Passed
Bedford South School	CR tap room 1014	MYW981	0.0006	Passed	0.1800	Passed
Bedford South School	CR tap room 1013	MYW982	0.0028	Passed	0.2700	Passed
Bedford South School	GN WR tap room 1016	MYW983	0.0039	Passed	0.2600	Passed
Bedford South School	CR tap room 1012	MYW984	0.0000	Passed	0.1600	Passed
Bedford South School	CR tap room 1011	MYW985	0.0009	Passed	0.0970	Passed
Bedford South School	CR tap room 1027	MYW986	0.0000	Passed	0.1600	Passed
Bedford South School	CR tap room 1026	MYW987	0.0000	Passed	0.1900	Passed
Bedford South School	CR tap room 1025	MYW988	0.0000	Passed	0.1800	Passed
Bedford South School	CR WR tap room 1029	MYW989	0.0011	Passed	0.3400	Passed
Bedford South School	CR tap room 1021	MYW990	0.0000	Passed	0.1700	Passed
Bedford South School	CR tap room 1034	MYX068	0.0006	Passed	0.2600	Passed
Bedford South School	CR tap room 1033	MYX069	0.0000	Passed	0.2300	Passed
Bedford South School	GN WR tap room 1036	MYX070	0.0011	Passed	0.1600	Passed
Bedford South School	CR tap room 1032	MYX071	0.0000	Passed	0.1500	Passed
Bedford South School	CR tap room 1031	MYX072	0.0023	Passed	0.3100	Passed
Bedford South School	Fountain by room 1061	MYX073	0.0018	Passed	0.7500	Passed
Bedford South School	Boys locker room tap 1 room 1060	MYX074	0.0019	Passed	0.2000	Passed
Bedford South School	Boys locker room tap 2 room 1060	MYX075	0.0140	Exceeds Limit	0.5600	Passed
Bedford South School	Girls locker room tap 1 room 1057	MYX076	0.0040	Passed	0.2500	Passed
Bedford South School	Girls locker room tap 2 room 1057	MYX077	0.0049	Passed	0.3100	Passed
Bedford South School	Gym office WR tap	MYX141	0.0011	Passed	0.2700	Passed
Bedford South School	Arts room tap 1 room 1069	MYX142	0.0000	Passed	0.0240	Passed
Bedford South School	Arts room tap 2 room 1069	MYX143	0.0006	Passed	0.0500	Passed
Bedford South School	GN WR tap room 1068	MYX144	0.0020	Passed	0.1600	Passed
Bedford South School	GN WR tap room 1067	MYX145	0.0000	Passed	0.1300	Passed
Bedford South School	JC tap room 1066	MYX146	0.0000	Passed	0.0940	Passed
Bedford South School	Storage room tap room 1079	MYX147	0.0044	Passed	0.1500	Passed
Bedford South School	Cafeteria/Kitchen tap 1 room 1080	MYX148	0.0010	Passed	0.2900	Passed
Bedford South School	Cafeteria/Kitchen tap 2 room 1080	MYX149	0.0043	Passed	0.1500	Passed
Bedford South School	Cafeteria/Kitchen tap 3 room 1080	MYX150	0.0000	Passed	0.3000	Passed
Bedford South School	Cafeteria/Kitchen tap 4 room 1080	MYX166	0.0007	Passed	0.0990	Passed
Bedford South School	Health room tap	MYX167	0.0000	Passed	0.1500	Passed
Bedford South School	Main office WR tap room 1081	MYX168	0.0000	Passed	0.1100	Passed
Bedford South School	Library work room tap room 1081	MYX169	0.0009	Passed	0.1700	Passed
Bedford South School	Boys WR tap 1 room 1043	MYX170	0.0000	Passed	0.1100	Passed
Bedford South School	Boys WR tap 2 room 1043	MYX171	0.0008	Passed	0.1100	Passed
Bedford South School	Boys WR tap 3 room 1043	MYX172	0.0011	Passed	0.1300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bedford South School	Boys WR tap 4 room 1043	MYX173	0.0000	Passed	0.1200	Passed
Bedford South School	JC tap room 1046	MYX174	0.0000	Passed	0.0610	Passed
Bedford South School	GN WR tap room 1047	MYX175	0.0010	Passed	0.2200	Passed
Bedford South School	Girls WR tap 1 room 1048	MYX191	0.0009	Passed	0.1400	Passed
Bedford South School	Girls WR tap 2 room 1048	MYX192	0.0032	Passed	0.2900	Passed
Bedford South School	Girls WR tap 3 room 1048	MYX193	0.0020	Passed	0.2000	Passed
Bedford South School	Girls WR tap 4 room 1048	MYX194	0.0008	Passed	0.1400	Passed
Bedford South School	Fountain by room 1048	MYX195	0.0000	Passed	0.2900	Passed
Bedford South School	CR tap 1 room 2039	MYX196	0.0000	Passed	0.1800	Passed
Bedford South School	CR tap 2 room 2039	MYX197	0.0005	Passed	0.1800	Passed
Bedford South School	CR tap room 2038	MYX198	0.0006	Passed	0.6700	Passed
Bedford South School	CR tap room 2037	MYX199	0.0010	Passed	0.2700	Passed
Bedford South School	CR tap 1 room 2036	MYX200	0.0006	Passed	0.1600	Passed
Bedford South School	CR tap 2 room 2036	MYX221	0.0012	Passed	0.1900	Passed
Bedford South School	CR tap 1 room 2029	MYX222	0.0006	Passed	0.1400	Passed
Bedford South School	CR tap 2 room 2029	MYX223	0.0013	Passed	0.2500	Passed
Bedford South School	CR tap 3 room 2029	MYX224	0.0160	Exceeds Limit	0.3400	Passed
Bedford South School	CR tap 4 room 2029	MYX225	0.0010	Passed	0.5300	Passed
Bedford South School	CR tap 1 room 2028	MYX226	0.0014	Passed	0.5300	Passed
Bedford South School	CR tap 2 room 2028	MYX227	0.0027	Passed	0.6000	Passed
Bedford South School	CR tap 3 room 2028	MYX228	0.0014	Passed	0.2000	Passed
Bedford South School	CR tap 4 room 2028	MYX229	0.0011	Passed	0.2200	Passed
Bedford South School	CR tap room 2027	MYX230	0.0006	Passed	0.1800	Passed
Bedford South School	CR tap room 2026	MYX242	0.0009	Passed	0.2600	Passed
Bedford South School	Home Ec. Tap 1 room 2012	MYX243	0.0015	Passed	0.1700	Passed
Bedford South School	Home Ec. Tap 2 room 2012	MYX244	0.0020	Passed	0.3300	Passed
Bedford South School	Home Ec. Tap 3 room 2012	MYX245	0.0006	Passed	0.1300	Passed
Bedford South School	Home Ec. Tap 4 room 2012	MYX246	0.0000	Passed	0.1100	Passed
Bedford South School	Tech ed tap room 2071	MYX247	0.0010	Passed	0.2200	Passed
Bedford South School	Staff room WR tap room 2073	MYX248	0.0000	Passed	0.0370	Passed
Bedford South School	Staff room tap room 2075	MYX249	0.0000	Passed	0.1600	Passed
Bedford South School	Staff room WR tap room 2074	MYX250	0.0000	Passed	0.0290	Passed
Bedford South School	CR tap room 2049	MYX251	0.0006	Passed	0.2200	Passed
Bedford South School	CR tap room 2048	MYX290	0.0022	Passed	2.4000	Exceeds Limit
Bedford South School	CR tap room 2047	MYX291	0.0000	Passed	0.3700	Passed
Bedford South School	CR tap room 2046	MYX292	0.0000	Passed	0.1600	Passed
Bedford South School	JC tap room 2064	MYX294	0.0000	Passed	0.0620	Passed
Bedford South School	GN WR tap room 2065	MYX295	0.0008	Passed	0.1800	Passed
Bedford South School	Fountain by room 2065	MYX296	0.0033	Passed	0.5400	Passed
Bedford South School	Girls WR tap 1 room 2056	MYX297	0.0051	Exceeds Limit	0.3200	Passed
Bedford South School	Girls WR tap 2 room 2056	MYX298	0.0022	Passed	0.2400	Passed
Bedford South School	Girls WR tap 3 room 2056	MYX299	0.0030	Passed	0.3100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bedford South School	Girls WR tap 4 room 2056	MYX300	0.0017	Passed	0.2300	Passed
Bedford South School	Boys WR tap 1 room 2055	MYX301	0.0076	Exceeds Limit	0.4100	Passed
Bedford South School	Boys WR tap 2 room 2055	MYX302	0.0077	Exceeds Limit	0.4700	Passed
Bedford South School	Boys WR tap 3 room 2055	MYX303	0.0790	Exceeds Limit	1.8000	Passed
Bedford South School	Boys WR tap 4 room 2055	MYX307	0.0130	Exceeds Limit	0.3300	Passed
Bedford South School	Fountain by room 2029	MYX308	0.0009	Passed	0.6400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	JC tap room 1	MUK838	0.0046	Passed	0.0400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 1 room 212	MUK839	0.0110	Exceeds Limit	0.0490	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 2 room 212	MUK840	0.1000	Exceeds Limit	0.0470	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 3 room 212	MUK841	0.1500	Exceeds Limit	0.0940	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 4 room 212	MUK842	0.1000	Exceeds Limit	0.1600	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Fountain beside room 212	MUK843	0.0200	Exceeds Limit	0.3600	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Art room tap 1 room 207	MUK844	0.0050	Passed	0.0400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Art room tap 2 room 207	MUK845	0.0730	Exceeds Limit	0.2400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 1 room 216	MUK846	0.0500	Exceeds Limit	0.1900	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 2 room 216	MUK847	0.0220	Exceeds Limit	0.0800	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 3 room 216	MUK850	0.0500	Exceeds Limit	0.1000	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 4 room 216	MUK851	0.1300	Exceeds Limit	0.1900	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Fountain by room 216	MUK852	0.0035	Passed	0.1100	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Fountain by staff room	MUK853	0.0000	Passed	0.3400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR 1 tap in staff room	MUK854	0.0006	Passed	0.0370	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR 2 tap in staff room	MUK855	0.0020	Passed	0.0420	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Staff room kitchen tap	MUK856	0.0160	Exceeds Limit	0.1700	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 104	MUK857	0.0013	Passed	0.2800	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR tap room 100	MUK858	0.0058	Exceeds Limit	0.1100	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 102	MUK859	0.0025	Passed	0.2100	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 101	MUK860	0.0014	Passed	0.4400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Kitchen sink tap room 105	MUK861	0.0700	Exceeds Limit	0.3500	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Cafeteria/kitchen double compartment sink tap	MUK862	0.0029	Passed	0.2500	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Cafeteria/kitchen hand washing sink tap	MUK863	0.0025	Passed	0.5000	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 1 room 107	MUK864	0.0140	Exceeds Limit	0.1000	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 2 room 107	MUK865	0.0098	Exceeds Limit	0.1000	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 3 room 107	MUK866	0.0440	Exceeds Limit	0.0970	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Girls WR tap 4 room 107	MUK867	0.0100	Exceeds Limit	0.0800	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 1 room 109	MUK868	0.0059	Exceeds Limit	0.0930	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 2 room 109	MUK869	0.0066	Exceeds Limit	0.0780	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 3 room 109	MUK870	0.0071	Exceeds Limit	0.0930	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Boys WR tap 4 room 109	MUK871	0.0061	Exceeds Limit	0.1100	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 111	MUK872	0.0260	Exceeds Limit	0.3200	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR tap room 132	MUK873	0.0130	Exceeds Limit	0.1300	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR tap room 133	MUK874	0.0140	Exceeds Limit	0.1300	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 113	MUK875	0.0030	Passed	0.1500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 116	MUK876	0.0110	Exceeds Limit	0.5500	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 114	MUK877	0.0058	Exceeds Limit	0.6200	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 112	MUK878	0.0084	Exceeds Limit	0.8600	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	CR tap room 110	MUK879	0.0023	Passed	0.2300	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR tap room 131	MUK880	0.0210	Exceeds Limit	0.1200	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	JC tap by room 131	MUK881	0.0006	Passed	0.0260	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Fountain by JC	MUK882	0.0007	Passed	0.4500	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Music room tap room 108	MUK883	0.0520	Exceeds Limit	0.1900	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR tap in gym	MUK884	0.0099	Exceeds Limit	0.1400	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	Gym office WR tap	MUK885	0.0110	Exceeds Limit	0.7200	Passed
Beechville-Lakeside-Timberlea Junior Elementary School	GN WR tap in gym	MUK886	0.5500	Exceeds Limit	0.4800	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Staff room kitchen tap	MUJ397	0.0014	Passed	0.0760	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Staff room female WR tap 1	MUJ398	0.0037	Passed	0.1200	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Staff room female WR tap 2	MUJ399	0.0270	Exceeds Limit	0.1300	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Staff room male WR tap	MUJ400	0.0110	Exceeds Limit	0.0800	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Boys WR tap 1 beside Library	MUJ401	0.0037	Passed	0.1600	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Boys WR tap 2 beside Library	MUJ402	0.0098	Exceeds Limit	0.1900	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Boys WR tap 3 beside Library	MUJ403	0.0160	Exceeds Limit	0.2100	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	JC tap near library	MUJ404	0.0006	Passed	0.0270	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Fountain beside JC	MUJ405	0.0220	Exceeds Limit	0.5600	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Girls WR tap 1 across from room 203	MUJ406	0.0068	Exceeds Limit	0.2500	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Girls WR tap 2 across from room 203	MUJ407	0.0095	Exceeds Limit	0.3000	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Girls WR tap 3 across from room 203	MUJ408	0.0027	Passed	0.2600	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Girls WR tap 4 across from room 203	MUJ409	0.0021	Passed	0.1400	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Cooking room tap 1	NNS470	0.0006	Passed	0.0130	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Cooking room tap 2	NNS471	0.0004	Passed	0.0130	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Sewing room tap (kitchen)	MUJ412	0.0140	Exceeds Limit	0.5900	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	French room kitchen tap room 200	MUJ413	0.0130	Exceeds Limit	0.3800	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Cafeteria/kitchen hand washing sink tap	MUJ414	0.0028	Passed	0.1700	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Cafeteria kitchen sink tap	NNS469	0.0004	Passed	0.0100	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Cafeteria/kitchen double compartment sink tap	MUJ416	0.0040	Passed	0.3500	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Boys Change room tap 1	MUJ417	0.0074	Exceeds Limit	0.2200	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Boys Change room tap 2	MUJ418	0.0026	Passed	0.1200	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Fountain across from room 105	MUJ419	0.0052	Exceeds Limit	0.1200	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Staff WR across from room 105	MUJ420	0.0005	Passed	0.0510	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Staff WR across from room 104	MUJ421	0.0007	Passed	0.0340	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Girls Change room tap 1	MUJ422	0.0700	Exceeds Limit	0.3200	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Girls Change room tap 2	MUJ423	0.0130	Exceeds Limit	0.3100	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Metal RM kitchen sink tap	MUJ424	0.0069	Exceeds Limit	0.4800	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Art room multi tap sink tap 1	MUJ425	0.0007	Passed	0.0610	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Art room multi tap sink tap 2	MUJ426	0.0000	Passed	0.0580	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	Art room multi tap sink tap 3	MUJ427	0.0000	Passed	0.0540	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Beechville-Lakeside-Timberlea Senior Elementary School	Art room multi tap sink tap 4	MUJ428	0.0000	Passed	0.0470	Passed
Beechville-Lakeside-Timberlea Senior Elementary School	JC tap beside room 101	MUJ429	0.0070	Exceeds Limit	0.1200	Passed
Bel Ayr Elementary School	Staff room WR #1 tap room 120	MXJ925	0.0072	Exceeds Limit	0.0560	Passed
Bel Ayr Elementary School	Staff room kitchen tap room 120	MXJ926	0.0010	Passed	0.0540	Passed
Bel Ayr Elementary School	Staff room WR #2 tap room 120	MXJ927	0.0011	Passed	0.0590	Passed
Bel Ayr Elementary School	Fountain by room 112	MXJ928	0.0010	Passed	0.6100	Passed
Bel Ayr Elementary School	Boys WR tap 1 by room 124	MXJ929	0.0068	Exceeds Limit	0.1700	Passed
Bel Ayr Elementary School	Boys WR tap 2 by room 124	MXJ930	0.0055	Exceeds Limit	0.1900	Passed
Bel Ayr Elementary School	Boys WR tap 3 by room 124	MXJ931	0.0016	Passed	0.0570	Passed
Bel Ayr Elementary School	JC tap room 124	MXJ932	0.0062	Exceeds Limit	0.0570	Passed
Bel Ayr Elementary School	Girls WR tap 1 by room 124	MXJ933	0.0034	Passed	0.0840	Passed
Bel Ayr Elementary School	Girls WR tap 2 by room 124	MXJ934	0.0067	Exceeds Limit	0.0530	Passed
Bel Ayr Elementary School	Girls WR tap 3 by room 124	MXJ935	0.0028	Passed	0.0410	Passed
Bel Ayr Elementary School	Learning centre WR tap	MXJ936	0.0012	Passed	0.0540	Passed
Bel Ayr Elementary School	Girls WR tap 1 by room 122	MXJ937	0.0008	Passed	0.3200	Passed
Bel Ayr Elementary School	Girls WR tap 2 by room 122	MXJ938	0.0000	Passed	0.0510	Passed
Bel Ayr Elementary School	Boys WR tap 1 by room 122	MXJ939	0.0055	Exceeds Limit	0.1000	Passed
Bel Ayr Elementary School	Boys WR tap 2 by room 122	MXJ940	0.0016	Passed	0.0620	Passed
Bel Ayr Elementary School	Boys WR tap 3 by room 122	MXJ941	0.0011	Passed	0.0510	Passed
Bel Ayr Elementary School	Gym/Cafeteria tap	NLS536	0.0040	Passed	0.0160	Passed
Bel Ayr Elementary School	Fountain by room 123	NLS537	0.0004	Passed	0.0420	Passed
Bel Ayr Elementary School	JC tap room 123	MXJ944	0.0018	Passed	0.1100	Passed
Bel Ayr Elementary School	Main office tap 1 room 118	MXJ945	0.0034	Passed	0.1000	Passed
Bel Ayr Elementary School	Main office tap 2 room 119	MXJ946	0.0017	Passed	0.0920	Passed
Bell Park Academic Centre	Staff room tap room 218	MYA895	0.0015	Passed	0.2600	Passed
Bell Park Academic Centre	Male staff room WR tap room 218	MYA896	0.0039	Passed	0.3200	Passed
Bell Park Academic Centre	Female staff room WR tap room 218	MYA897	0.0024	Passed	0.2300	Passed
Bell Park Academic Centre	Fountain by room 218	MYA898	0.0028	Passed	0.3400	Passed
Bell Park Academic Centre	Girls WR tap 1 by room 206	MYA899	0.0022	Passed	0.0650	Passed
Bell Park Academic Centre	Girls WR tap 2 by room 206	MYA900	0.0034	Passed	0.1400	Passed
Bell Park Academic Centre	Girls WR tap 3 by room 206	MYA901	0.0058	Exceeds Limit	0.1400	Passed
Bell Park Academic Centre	Fountain by room 206	MYA902	0.0042	Passed	0.2200	Passed
Bell Park Academic Centre	Boys WR tap 1 by room 205	MYA903	0.0098	Exceeds Limit	0.3700	Passed
Bell Park Academic Centre	Boys WR tap 2 by room 205	MYA904	0.0130	Exceeds Limit	0.4500	Passed
Bell Park Academic Centre	Boys WR tap 3 by room 205	MYA910	0.0100	Exceeds Limit	0.4200	Passed
Bell Park Academic Centre	CR tap room 216	MYA911	0.0074	Exceeds Limit	0.1800	Passed
Bell Park Academic Centre	JC tap by room 203	MYA912	0.0007	Passed	0.1300	Passed
Bell Park Academic Centre	CR tap room 101	MYA913	0.0025	Passed	0.1800	Passed
Bell Park Academic Centre	Fountain by room 101	MYA914	0.0010	Passed	0.2900	Passed
Bell Park Academic Centre	CR tap room 102	MYA915	0.0008	Passed	0.4500	Passed
Bell Park Academic Centre	CR WR tap room 102	MYA916	0.0011	Passed	0.1700	Passed
Bell Park Academic Centre	CR WR tap room 101	MYA917	0.0059	Exceeds Limit	0.1400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bell Park Academic Centre	CR WR tap room 103	MYA918	0.0015	Passed	0.3000	Passed
Bell Park Academic Centre	Staff WR tap by office	MYH195	0.0010	Passed	0.1000	Passed
Bell Park Academic Centre	Girls WR tap 1 near office	MYH196	0.0170	Exceeds Limit	0.4000	Passed
Bell Park Academic Centre	Girls WR tap 2 near office	MYH197	0.0170	Exceeds Limit	0.3800	Passed
Bell Park Academic Centre	Girls WR tap 3 near office	MYH198	0.0270	Exceeds Limit	0.3800	Passed
Bell Park Academic Centre	Fountain between WR's	NLW022	0.0040	Passed	0.1400	Passed
Bell Park Academic Centre	Boys WR tap 1 near office	MYH200	0.0130	Exceeds Limit	0.3000	Passed
Bell Park Academic Centre	Boys WR tap 2 near office	MYH201	0.0057	Exceeds Limit	0.1600	Passed
Bell Park Academic Centre	JC tap by boys WR	MYH202	0.0014	Passed	0.0450	Passed
Bell Park Academic Centre	Kitchen/Cafeteria hand washing tap	MYH203	0.0017	Passed	0.5700	Passed
Bell Park Academic Centre	Kitchen/Cafeteria Triple compartment tap 1	MYH204	0.0017	Passed	0.5200	Passed
Bell Park Academic Centre	Kitchen/Cafeteria Triple compartment tap 2	MYH205	0.0009	Passed	0.1900	Passed
Bell Park Academic Centre	Main office tap	MYH206	0.0011	Passed	0.6600	Passed
BFEC (Dartmouth)	Staff WR tap by youth centre	MYA741	0.0210	Exceeds Limit	0.1700	Passed
BFEC (Dartmouth)	Youth centre tap 1	MYA742	0.0250	Exceeds Limit	1.3000	Passed
BFEC (Dartmouth)	Youth centre tap 2	MYA743	0.0190	Exceeds Limit	1.4000	Passed
BFEC (Dartmouth)	Youth centre tap 3	MYA744	0.5100	Exceeds Limit	1.9000	Passed
BFEC (Dartmouth)	Staff room male WR tap	MYA745	0.0260	Exceeds Limit	0.2600	Passed
BFEC (Dartmouth)	Staff room female WR tap	MYA746	0.0430	Exceeds Limit	0.3800	Passed
BFEC (Dartmouth)	Upstairs boys WR tap 1	MYA747	0.1900	Exceeds Limit	1.7000	Passed
BFEC (Dartmouth)	Upstairs boys WR tap 2	MYA748	0.4000	Exceeds Limit	4.1000	Exceeds Limit
BFEC (Dartmouth)	Upstairs boys WR tap 3	MYA749	0.3700	Exceeds Limit	2.2000	Exceeds Limit
BFEC (Dartmouth)	Upstairs boys WR tap 4	MYA750	0.2000	Exceeds Limit	1.1000	Passed
BFEC (Dartmouth)	JC tap between WR's	MYA751	0.0500	Exceeds Limit	0.5100	Passed
BFEC (Dartmouth)	Fountain Between WR's	MYA752	0.0230	Exceeds Limit	0.9100	Passed
BFEC (Dartmouth)	Upstairs Girls WR tap 1	MYA753	0.1100	Exceeds Limit	1.2000	Passed
BFEC (Dartmouth)	Upstairs Girls WR tap 2	MYA754	0.5000	Exceeds Limit	2.9000	Exceeds Limit
BFEC (Dartmouth)	Upstairs Girls WR tap 3	MYA755	0.5600	Exceeds Limit	3.0000	Exceeds Limit
BFEC (Dartmouth)	Upstairs Girls WR tap 4	MYA756	0.2000	Exceeds Limit	1.0000	Passed
BFEC (Dartmouth)	JC tap room 12	MYA757	0.0550	Exceeds Limit	1.2000	Passed
BFEC (Dartmouth)	Downstairs boys WR tap 1	MYA758	0.0630	Exceeds Limit	0.6500	Passed
BFEC (Dartmouth)	Downstairs boys WR tap 2	MYA759	0.3200	Exceeds Limit	1.8000	Passed
BFEC (Dartmouth)	Downstairs boys WR tap 3	MYA760	0.1500	Exceeds Limit	1.1000	Passed
BFEC (Dartmouth)	Downstairs boys WR tap 4	MYA762	1.8000	Exceeds Limit	3.5000	Exceeds Limit
BFEC (Dartmouth)	Fountain beside Janitors room	MYA763	0.0006	Passed	0.3700	Passed
BFEC (Dartmouth)	JC tap in Janitors room	MYA764	0.0033	Passed	0.0590	Passed
BFEC (Dartmouth)	Downstairs Girls WR tap 1	MYA765	0.2200	Exceeds Limit	4.4000	Exceeds Limit
BFEC (Dartmouth)	Downstairs Girls WR tap 2	MYA766	0.3700	Exceeds Limit	4.7000	Exceeds Limit
BFEC (Dartmouth)	Downstairs Girls WR tap 3	MYA767	0.0480	Exceeds Limit	1.1000	Passed
BFEC (Dartmouth)	Downstairs Girls WR tap 4	MYA768	0.0390	Exceeds Limit	0.8900	Passed
BFEC (Dartmouth)	CR tap room 17	MYA769	0.0078	Exceeds Limit	1.8000	Passed
Bicentennial School	Principle office WR tap	MYR712	0.0035	Passed	0.2300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bicentennial School	Office WR tap room 04	MYR713	0.0059	Exceeds Limit	0.0520	Passed
Bicentennial School	JC tap by room 18	MYR714	0.0008	Passed	0.0330	Passed
Bicentennial School	Boys WR tap 1 by Library	MYR715	0.0046	Passed	0.1800	Passed
Bicentennial School	Boys WR tap 2 by Library	MYR716	0.0008	Passed	0.0300	Passed
Bicentennial School	Boys WR tap 3 by Library	MYR717	0.0012	Passed	0.0330	Passed
Bicentennial School	Boys WR tap 4 by Library	MYR718	0.0000	Passed	0.0310	Passed
Bicentennial School	Boys WR tap 5 by Library	MYR719	0.0000	Passed	0.0320	Passed
Bicentennial School	Boys WR tap 6 by Library	MYR720	0.0006	Passed	0.0360	Passed
Bicentennial School	Boys WR tap 7 by Library	MYR721	0.0006	Passed	0.0310	Passed
Bicentennial School	Boys WR tap 8 by Library	MYR722	0.0011	Passed	0.0350	Passed
Bicentennial School	Staff GN WR tap by library	MYR723	0.0020	Passed	0.0610	Passed
Bicentennial School	Fountain by library	MYR724	0.0020	Passed	0.4700	Passed
Bicentennial School	Staff GN WR tap by library	MYR725	0.0013	Passed	0.0500	Passed
Bicentennial School	Girls WR tap 1 by library	MYR726	0.0120	Exceeds Limit	0.3000	Passed
Bicentennial School	Girls WR tap 2 by library	MYR727	0.0019	Passed	0.0580	Passed
Bicentennial School	Girls WR tap 3 by library	MYR728	0.0011	Passed	0.0310	Passed
Bicentennial School	Girls WR tap 4 by library	MYR729	0.0000	Passed	0.0240	Passed
Bicentennial School	Girls WR tap 5 by library	MYR730	0.0000	Passed	0.0220	Passed
Bicentennial School	Girls WR tap 6 by library	MYR731	0.0000	Passed	0.0190	Passed
Bicentennial School	Girls WR tap 7 by library	MYR732	0.0000	Passed	0.0160	Passed
Bicentennial School	Girls WR tap 8 by library	MYR733	0.0000	Passed	0.0200	Passed
Bicentennial School	Art CR tap room 19	MYR734	0.0016	Passed	0.1000	Passed
Bicentennial School	Learning centre WR #1 tap	MYR735	0.0015	Passed	0.3700	Passed
Bicentennial School	Learning centre WR #2 tap	MYR736	0.0016	Passed	0.3200	Passed
Bicentennial School	JC tap by CR #2	MYR737	0.0000	Passed	0.0170	Passed
Bicentennial School	Boys WR tap 1 by CR #1	MYR738	0.0010	Passed	0.0190	Passed
Bicentennial School	Boys WR tap 2 by CR #1	MYR739	0.0750	Exceeds Limit	0.3300	Passed
Bicentennial School	Gym office WR tap	MYR740	0.0420	Exceeds Limit	0.5800	Passed
Bicentennial School	Fountain by gym office	MYR741	0.0000	Passed	0.4000	Passed
Bicentennial School	Fountain by gym door	MYR742	0.0043	Passed	0.5600	Passed
Bicentennial School	Pre-primary WR tap 1 by Teachers room	MYR743	0.0012	Passed	0.0220	Passed
Bicentennial School	Pre-primary WR tap 2 by Teachers room	MYR744	0.0130	Exceeds Limit	0.4500	Passed
Bicentennial School	Pre-primary WR tap 3 by Teachers room	MYR745	0.0071	Exceeds Limit	0.5600	Passed
Bicentennial School	Fountain by TR	NMK042	0.0015	Passed	0.0960	Passed
Bicentennial School	JC tap by room 9	MYR747	0.0005	Passed	0.0610	Passed
Bicentennial School	Staff room kitchen tap	MYR748	0.0000	Passed	0.2200	Passed
Bicentennial School	Mimeograph room tap	MYR749	0.0000	Passed	0.0700	Passed
Bicentennial School	GN WR tap near staff room	MYR750	0.0008	Passed	0.0500	Passed
Bicentennial School	Admin assistant room tap	MYR751	0.0026	Passed	0.2000	Passed
Bicentennial School	Science lab tap 1 room 27	MYR752	0.1800	Exceeds Limit	0.7400	Passed
Bicentennial School	Science lab tap 2 room 27	MYR753	0.0740	Exceeds Limit	1.0000	Passed
Bicentennial School	Science lab tap 3 room 27	MYR754	0.1200	Exceeds Limit	1.1000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Bicentennial School	Science lab tap 4 room 27	MYR755	0.0520	Exceeds Limit	1.0000	Passed
Bicentennial School	Science lab tap 5 room 27	MYR756	0.0230	Exceeds Limit	0.8500	Passed
Bicentennial School	Science lab tap 6 room 27	MYR757	0.0350	Exceeds Limit	0.9800	Passed
Bicentennial School	Science lab tap 7 room 27	MYR758	0.0790	Exceeds Limit	1.3000	Passed
Bicentennial School	Science lab tap 8 room 27	MYR759	0.0730	Exceeds Limit	0.7100	Passed
Bicentennial School	Science lab tap 9 room 27	MYR760	0.0076	Exceeds Limit	0.2400	Passed
Bicentennial School	Science lab tap 10 room 27	MYR761	0.0086	Exceeds Limit	0.2600	Passed
Bicentennial School	Science lab tap 11 room 27	MYR762	0.0140	Exceeds Limit	0.3100	Passed
Bicentennial School	Science lab tap 12 room 27	MYR763	0.0068	Exceeds Limit	0.1900	Passed
Bicentennial School	Science lab tap 13 room 27	MYR764	0.0039	Passed	0.1300	Passed
Bicentennial School	Science lab tap 14 room 27	MYR765	0.0036	Passed	0.1200	Passed
Bicentennial School	Science lab tap 15 room 27	MYR766	0.0071	Exceeds Limit	0.2400	Passed
Bicentennial School	Science lab tap 16 room 27	MYR767	0.0130	Exceeds Limit	0.2700	Passed
Bicentennial School	Science lab tap 17 room 27	MYR768	0.0046	Passed	0.1400	Passed
Bicentennial School	Science lab tap 18 room 27	MYR769	0.0023	Passed	0.1000	Passed
Bicentennial School	Science lab tap 19 room 27	MYR770	0.0084	Exceeds Limit	0.2100	Passed
Bicentennial School	JC tap by room 29	MYR771	0.0009	Passed	0.0370	Passed
Bicentennial School	CR tap room 29	MYR772	0.0021	Passed	0.1700	Passed
Bicentennial School	Fountain by room 31	MYR773	0.0010	Passed	0.0380	Passed
Bicentennial School	Tech ed sink tap	MYR774	0.0022	Passed	0.0670	Passed
Bicentennial School	Tech ed room fountain	MYR775	0.0120	Exceeds Limit	0.0980	Passed
Bicentennial School	CR tap room 30	MYR776	0.0084	Exceeds Limit	0.3000	Passed
Bicentennial School	Boys WR tap 1 by room 30	MYR777	0.0240	Exceeds Limit	0.9700	Passed
Bicentennial School	Boys WR tap 2 by room 30	MYR778	0.0220	Exceeds Limit	1.5000	Passed
Bicentennial School	Boys WR tap 3 by room 30	MYR779	0.0120	Exceeds Limit	0.1700	Passed
Bicentennial School	Boys WR tap 4 by room 30	MYR780	0.0013	Passed	0.0800	Passed
Bicentennial School	GN WR tap by room 29	MYR781	0.0006	Passed	0.0280	Passed
Bicentennial School	GN WR tap by boys WR	MYR782	0.0013	Passed	0.1300	Passed
Bicentennial School	Boys WR tap 1 by room 29	MYR783	0.0380	Exceeds Limit	1.4000	Passed
Bicentennial School	Boys WR tap 2 by room 29	MYR784	0.0130	Exceeds Limit	2.0000	Passed
Bicentennial School	Boys WR tap 3 by room 29	MYR785	0.0022	Passed	0.2100	Passed
Bicentennial School	Boys WR tap 4 by room 29	MYR786	0.0250	Exceeds Limit	4.2000	Exceeds Limit
Bicentennial School	Fountain by room 29	MYR787	0.0000	Passed	0.5300	Passed
Brookhouse Elementary School	Staff WR tap room 111	MWI326	0.0160	Exceeds Limit	0.1300	Passed
Brookhouse Elementary School	Staff room kitchen tap room 111	MWI327	0.0007	Passed	0.0290	Passed
Brookhouse Elementary School	Staff WR tap room 111	MWI328	0.0000	Passed	0.0210	Passed
Brookhouse Elementary School	Fountain by room 205	MWI329	0.0007	Passed	0.7400	Passed
Brookhouse Elementary School	Fountain across from room 205	NLJ906	0.0022	Passed	0.0690	Passed
Brookhouse Elementary School	JC tap across from room 205	MWI331	0.0008	Passed	0.0330	Passed
Brookhouse Elementary School	Girls WR tap 1 room 206	MWI332	0.0560	Exceeds Limit	0.3800	Passed
Brookhouse Elementary School	Girls WR tap 2 room 206	MWI333	0.2300	Exceeds Limit	2.2000	Exceeds Limit
Brookhouse Elementary School	Girls WR tap 3 room 206	MWI334	0.1200	Exceeds Limit	1.2000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Brookhouse Elementary School	Girls WR tap 4 room 206	MWI335	0.2700	Exceeds Limit	1.3000	Passed
Brookhouse Elementary School	Staff WR tap room 204	MWI336	0.0015	Passed	0.4700	Passed
Brookhouse Elementary School	fountain by room 136	NLJ907	0.0180	Exceeds Limit	0.1000	Passed
Brookhouse Elementary School	JC tap by room 136	MWI338	0.0006	Passed	0.0400	Passed
Brookhouse Elementary School	Boys WR tap 1 room 136	MWI339	0.0220	Exceeds Limit	0.3500	Passed
Brookhouse Elementary School	Boys WR tap 2 room 136	MWI340	0.0046	Passed	0.1800	Passed
Brookhouse Elementary School	Boys WR tap 3 room 136	MWI341	0.0019	Passed	0.0590	Passed
Brookhouse Elementary School	Learning centre WR tap	MWI342	0.0090	Exceeds Limit	0.5700	Passed
Brookhouse Elementary School	Gym office WR tap (gym)	MWI343	0.0079	Exceeds Limit	0.2600	Passed
Brookhouse Elementary School	Boys WR tap 1 by room 127	MWI344	0.0030	Passed	0.0500	Passed
Brookhouse Elementary School	Boys WR tap 2 by room 127	MWI345	0.0026	Passed	0.0420	Passed
Brookhouse Elementary School	Boys WR tap 3 by room 127	MWI348	0.0017	Passed	0.0280	Passed
Brookhouse Elementary School	JC tap by room 127	MWI349	0.0035	Passed	0.0370	Passed
Brookhouse Elementary School	Girls WR tap 1 by room 104	MWI350	0.0000	Passed	0.0100	Passed
Brookhouse Elementary School	Girls WR tap 2 by room 104	MWI351	0.0055	Exceeds Limit	0.0840	Passed
Brookhouse Elementary School	Girls WR tap 3 by room 104	MWI352	0.0000	Passed	0.0120	Passed
Brookhouse Elementary School	Girls WR tap 1 room 112	MWI353	0.0016	Passed	0.0300	Passed
Brookhouse Elementary School	Girls WR tap 2 room 112	MWI354	0.0010	Passed	0.0180	Passed
Brookhouse Elementary School	Girls WR tap 3 room 112	MWI355	0.0009	Passed	0.0130	Passed
Brookhouse Elementary School	Girls WR tap 4 room 112	MWI356	0.0009	Passed	0.0130	Passed
Brookhouse Elementary School	Fountain by room 112	MWI357	0.0045	Passed	1.1000	Passed
Brookhouse Elementary School	Boys WR tap 1 room 125	MWI390	0.0140	Exceeds Limit	0.1300	Passed
Brookhouse Elementary School	Boys WR tap 2 room 125	MWI391	0.0120	Exceeds Limit	0.1100	Passed
Brookhouse Elementary School	Boys WR tap 3 room 125	MWI392	0.0140	Exceeds Limit	0.2700	Passed
Brookhouse Elementary School	Fountain by room 125	MWI393	0.0010	Passed	0.6400	Passed
Brookhouse Elementary School	Office tap room 115	NLJ908	0.0004	Passed	0.0170	Passed
Brookhouse Elementary School	Principals office WR tap room 116	MWI395	0.0031	Passed	0.0830	Passed
Brookside Junior High School	Girls WR tap 1	MUQ912	0.0120	Exceeds Limit	0.4300	Passed
Brookside Junior High School	Girls WR tap 2	MUQ913	0.0260	Exceeds Limit	0.4200	Passed
Brookside Junior High School	Girls WR tap 3	MUQ914	0.0110	Exceeds Limit	0.5300	Passed
Brookside Junior High School	Girls WR tap 4	MUQ915	0.0300	Exceeds Limit	0.5600	Passed
Brookside Junior High School	GN WR tap	MUQ916	0.0370	Exceeds Limit	0.6700	Passed
Brookside Junior High School	GN WR tap	MUQ917	0.0045	Passed	0.3100	Passed
Brookside Junior High School	Boys WR tap 1	MUQ918	0.0190	Exceeds Limit	0.5300	Passed
Brookside Junior High School	Boys WR tap 2	MUQ919	0.0330	Exceeds Limit	0.4700	Passed
Brookside Junior High School	Boys WR tap 3	MUQ920	0.0830	Exceeds Limit	0.6300	Passed
Brookside Junior High School	Unnamed storage room tap	MUQ921	0.0130	Exceeds Limit	0.1200	Passed
Brookside Junior High School	Kitchen/Cafe. Tap 1	MUQ922	0.0032	Passed	0.2200	Passed
Brookside Junior High School	Kitchen/Cafe. Tap 2	MUQ923	0.0130	Exceeds Limit	0.4600	Passed
Brookside Junior High School	Kitchen/Cafe. Tap 3	MUQ924	0.0610	Exceeds Limit	0.8300	Passed
Brookside Junior High School	Boiler room tap	MUQ925	0.0037	Passed	0.3000	Passed
Brookside Junior High School	JC tap	MUQ926	0.2400	Exceeds Limit	2.7000	Exceeds Limit

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Brookside Junior High School	Principles office WR tap	MUQ927	0.0071	Exceeds Limit	0.6600	Passed
Brookside Junior High School	2nd floor staff room tap 1	MUQ928	0.0120	Exceeds Limit	0.6800	Passed
Brookside Junior High School	2nd floor staff room tap 2	MUQ929	0.0130	Exceeds Limit	0.4900	Passed
Brookside Junior High School	2nd floor Girls WR tap 1	MUQ931	0.0150	Exceeds Limit	0.6500	Passed
Brookside Junior High School	2nd floor Girls WR tap 2	MUQ932	0.0330	Exceeds Limit	0.8900	Passed
Brookside Junior High School	2nd floor Girls WR tap 3	MUQ933	0.2200	Exceeds Limit	0.3100	Passed
Brookside Junior High School	2nd floor JC tap	MUQ934	0.0260	Exceeds Limit	0.5400	Passed
Brookside Junior High School	2nd floor Boys WR tap 1	MUQ935	0.0160	Exceeds Limit	0.6900	Passed
Brookside Junior High School	2nd floor Boys WR tap 2	MUQ936	0.0120	Exceeds Limit	0.4500	Passed
Brookside Junior High School	Staff room tap 2 (kitchen)	NAK447	0.0029	Passed	0.3100	Passed
Brookside Junior High School	Boys WR tap 3	NAK453	0.0190	Exceeds Limit	0.2600	Passed
Brookside Junior High School	Fountain by room 208	NAK454	0.0063	Exceeds Limit	0.2800	Passed
Brookside Junior High School	Fountain by room 106	NAK455	0.0047	Passed	0.2100	Passed
Burton Ettinger Elementary School	CR tap room 218	MRX345	0.0032	Passed	0.0540	Passed
Burton Ettinger Elementary School	CR tap room 220	MRX346	0.0064	Exceeds Limit	0.1900	Passed
Burton Ettinger Elementary School	CR tap room 221	MRX347	0.0029	Passed	0.1600	Passed
Burton Ettinger Elementary School	CR tap room 222	MRX348	0.0210	Exceeds Limit	0.2200	Passed
Burton Ettinger Elementary School	CR tap room 223	MRX349	0.0042	Passed	0.2000	Passed
Burton Ettinger Elementary School	Fountain by room 224	MRX350	0.0000	Passed	0.1800	Passed
Burton Ettinger Elementary School	JC tap room 224	MRX351	0.0063	Exceeds Limit	0.1300	Passed
Burton Ettinger Elementary School	Staff room tap room 227	NIU634	0.0004	Passed	0.0140	Passed
Burton Ettinger Elementary School	JC tap room 238	MRX353	0.0006	Passed	0.0160	Passed
Burton Ettinger Elementary School	GN WR tap room 231	MRX354	0.0018	Passed	0.1600	Passed
Burton Ettinger Elementary School	Girls WR tap 1 room 236	MRX355	0.0000	Passed	0.1700	Passed
Burton Ettinger Elementary School	Girls WR tap 2 room 236	MRX356	0.0000	Passed	0.0600	Passed
Burton Ettinger Elementary School	Girls WR (staff WR) tap room 236	MRX357	0.0000	Passed	0.0076	Passed
Burton Ettinger Elementary School	Fountain by room 236	MRX358	0.0000	Passed	0.5000	Passed
Burton Ettinger Elementary School	Boys WR tap 1 room 237	MRX359	0.0130	Exceeds Limit	0.1200	Passed
Burton Ettinger Elementary School	Boys WR tap 2 room 237	MRX360	0.0008	Passed	0.0120	Passed
Burton Ettinger Elementary School	Boys WR (staff WR) tap room 237	MRX361	0.0000	Passed	0.0630	Passed
Burton Ettinger Elementary School	Fountain close to office room 101	NIU633	0.0045	Passed	0.0440	Passed
Burton Ettinger Elementary School	Staff room WR tap 1 room 104	MRX363	0.0048	Passed	0.0550	Passed
Burton Ettinger Elementary School	Staff room WR tap 2 room 104	MRX364	0.0140	Exceeds Limit	0.0690	Passed
Burton Ettinger Elementary School	Staff room kitchen tap room 104	MRX365	0.0077	Exceeds Limit	0.1600	Passed
Burton Ettinger Elementary School	Girls WR tap 1 by room 108	MRX366	0.0058	Exceeds Limit	0.1500	Passed
Burton Ettinger Elementary School	Girls WR tap 2 by room 108	MRX367	0.0024	Passed	0.0920	Passed
Burton Ettinger Elementary School	Girls WR tap 3 by room 108	MRX368	0.0100	Exceeds Limit	0.1100	Passed
Burton Ettinger Elementary School	Staff WR tap by room 108	MRX369	0.0020	Passed	0.0840	Passed
Burton Ettinger Elementary School	Boys WR tap 1 by room 108	MRX370	0.0019	Passed	0.0800	Passed
Burton Ettinger Elementary School	Boys WR tap 2 by room 108	MRX371	0.0200	Exceeds Limit	0.4600	Passed
Burton Ettinger Elementary School	Boys WR tap 3 by room 108	MRX372	0.0022	Passed	0.1200	Passed
Burton Ettinger Elementary School	JC tap across from room 102	MRX373	0.0330	Exceeds Limit	0.3800	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Burton Ettinger Elementary School	Girls locker room tap in gym	MRX374	0.0048	Passed	0.1100	Passed
Burton Ettinger Elementary School	GN locker room in gym	MRX375	0.0028	Passed	0.0850	Passed
Burton Ettinger Elementary School	Kitchen tap room 111	MRX376	0.0061	Exceeds Limit	0.1200	Passed
Burton Ettinger Elementary School	Kitchen double compartment sink room 111	MRX377	0.0012	Passed	0.1000	Passed
Burton Ettinger Elementary School	Fountain by room 112	MRX378	0.0000	Passed	0.1100	Passed
Burton Ettinger Elementary School	Girls WR tap 1 by room 116	MRX379	0.0013	Passed	0.3300	Passed
Burton Ettinger Elementary School	Girls WR tap 2 by room 116	MRX380	0.0000	Passed	0.0420	Passed
Burton Ettinger Elementary School	Girls WR tap 3 by room 116	MRX381	0.0000	Passed	0.2700	Passed
Burton Ettinger Elementary School	Boys WR tap 1 room 116	MRX382	0.0083	Exceeds Limit	0.1100	Passed
Burton Ettinger Elementary School	Boys WR tap 2 room 116	MRX383	0.0017	Passed	0.0140	Passed
Caldwell Road Elementary School	CR WR tap room 1A	MQE455	0.0029	Passed	0.1900	Passed
Caldwell Road Elementary School	Boys WR tap 1 by room 6	MQE456	0.0010	Passed	0.3200	Passed
Caldwell Road Elementary School	Boys WR tap 2 by room 6	MQE457	0.0020	Passed	0.1700	Passed
Caldwell Road Elementary School	Boys WR tap 3 by room 6	MQE458	0.0012	Passed	0.1000	Passed
Caldwell Road Elementary School	JC tap 1 by room 6	MQE459	0.0009	Passed	0.0760	Passed
Caldwell Road Elementary School	Fountain by room 6	NLS565	0.0007	Passed	0.0190	Passed
Caldwell Road Elementary School	Girls WR tap 1 by room 6	MQE461	0.0030	Passed	0.1300	Passed
Caldwell Road Elementary School	Girls WR tap 2 by room 6	MQE462	0.0017	Passed	0.0760	Passed
Caldwell Road Elementary School	Girls WR tap 3 by room 6	MQE463	0.0008	Passed	0.0520	Passed
Caldwell Road Elementary School	Learning centre WR tap by room 7	MQE464	0.0017	Passed	0.1400	Passed
Caldwell Road Elementary School	1st floor boys WR tap 1	MQE465	0.0026	Passed	0.1900	Passed
Caldwell Road Elementary School	1st floor boys WR tap 2	MQE466	0.0008	Passed	0.0390	Passed
Caldwell Road Elementary School	1st floor Girls WR tap 1	MQE467	0.0021	Passed	0.1500	Passed
Caldwell Road Elementary School	1st floor Girls WR tap 2	MQE468	0.0490	Exceeds Limit	0.5000	Passed
Caldwell Road Elementary School	Fountain by main entrance	MQE469	0.0020	Passed	0.4800	Passed
Caldwell Road Elementary School	2nd floor girls WR tap	MQE470	0.0069	Exceeds Limit	0.1100	Passed
Caldwell Road Elementary School	2nd floor boys WR tap	MQE471	0.0044	Passed	0.0960	Passed
Caldwell Road Elementary School	Fountain by room 208	MQE472	0.0023	Passed	0.2100	Passed
Caldwell Road Elementary School	2nd floor JC tap by room 208	MQE473	0.0022	Passed	0.0950	Passed
Caldwell Road Elementary School	Music room tap room 122	NLS566	0.0041	Passed	0.0170	Passed
Caldwell Road Elementary School	1st floor staff kitchen tap	MQE475	0.0000	Passed	0.0270	Passed
Caldwell Road Elementary School	1st floor staff WR 1 tap	MQE476	0.0000	Passed	0.0200	Passed
Caldwell Road Elementary School	1st floor staff WR 2 tap	MQE477	0.0000	Passed	0.0130	Passed
Caledonia Junior High School	CR tap room 108	MXU489	0.0260	Exceeds Limit	1.5000	Passed
Caledonia Junior High School	Boys WR tap 1 by room 108	MXU490	0.0023	Passed	0.2200	Passed
Caledonia Junior High School	Boys WR tap 2 by room 108	MXU491	0.0120	Exceeds Limit	0.2200	Passed
Caledonia Junior High School	Boys WR tap 3 by room 108	MXU492	0.0068	Exceeds Limit	0.1600	Passed
Caledonia Junior High School	JC tap between WR's	MXU493	0.0011	Passed	0.0320	Passed
Caledonia Junior High School	Girls WR tap 1 by room 108	MXU494	0.0920	Exceeds Limit	0.6600	Passed
Caledonia Junior High School	Girls WR tap 2 by room 108	MXU495	0.0051	Exceeds Limit	0.4100	Passed
Caledonia Junior High School	Girls WR tap 3 by room 108	MXU496	0.0035	Passed	0.4200	Passed
Caledonia Junior High School	Girls WR tap 4 by room 108	MXU497	0.0025	Passed	0.3700	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Caledonia Junior High School	Girls WR tap 5 by room 108	MXU498	0.0190	Exceeds Limit	0.6400	Passed
Caledonia Junior High School	CR tap 1 room 109	MXU506	0.0025	Passed	0.2100	Passed
Caledonia Junior High School	CR tap 2 room 109	MXU507	0.1300	Exceeds Limit	0.2900	Passed
Caledonia Junior High School	Staff Kitchen tap room 110	NLJ938	0.0004	Passed	0.0520	Passed
Caledonia Junior High School	Staff WR1 tap room 110	MXU509	0.0073	Exceeds Limit	0.2000	Passed
Caledonia Junior High School	Staff WR2 tap room 110	MXU510	0.0076	Exceeds Limit	0.3100	Passed
Caledonia Junior High School	JC tap room 112	MXU511	0.0005	Passed	0.0230	Passed
Caledonia Junior High School	CR tap room 104	MXU512	0.0630	Exceeds Limit	0.6800	Passed
Caledonia Junior High School	GN WR tap room 115	MXU513	0.0130	Exceeds Limit	0.2900	Passed
Caledonia Junior High School	Fountain by room 115	MXU514	0.0023	Passed	0.4900	Passed
Caledonia Junior High School	Science lab tap 1 room 217	MXU515	0.0530	Exceeds Limit	0.4300	Passed
Caledonia Junior High School	Science lab tap 2 room 217	MXU516	0.0680	Exceeds Limit	0.6700	Passed
Caledonia Junior High School	Science lab tap 3 room 217	MXU517	0.4100	Exceeds Limit	3.0000	Exceeds Limit
Caledonia Junior High School	Science lab tap 4 room 217	MXU518	0.2700	Exceeds Limit	1.8000	Passed
Caledonia Junior High School	Science lab tap 5 room 217	MXU519	0.1700	Exceeds Limit	0.9900	Passed
Caledonia Junior High School	Science lab tap 6 room 217	MXU520	0.0037	Passed	0.0710	Passed
Caledonia Junior High School	Science lab tap 7 room 217	MXU521	1.2000	Exceeds Limit	8.2000	Exceeds Limit
Caledonia Junior High School	Science lab tap 8 room 217	MXU522	0.1000	Exceeds Limit	0.3700	Passed
Caledonia Junior High School	Science lab tap 9 room 217	MXU523	0.0740	Exceeds Limit	0.8700	Passed
Caledonia Junior High School	Science lab tap 10 room 217	MXU524	0.4100	Exceeds Limit	3.5000	Exceeds Limit
Caledonia Junior High School	Science lab tap 11 room 217	MXU525	0.2700	Exceeds Limit	0.9600	Passed
Caledonia Junior High School	Science lab tap 12 room 217	MXU526	0.0600	Exceeds Limit	0.5700	Passed
Caledonia Junior High School	Science lab tap 13 room 217	MXU527	0.2300	Exceeds Limit	0.9500	Passed
Caledonia Junior High School	Science lab tap 14 room 217	MXU528	0.0470	Exceeds Limit	1.2000	Passed
Caledonia Junior High School	Science lab tap 15 room 217	MXU529	0.0210	Exceeds Limit	1.1000	Passed
Caledonia Junior High School	Fountain after sci lab	MXU530	0.0070	Exceeds Limit	0.3200	Passed
Caledonia Junior High School	Family studies tap 1 room 215	MXU531	0.0010	Passed	0.1700	Passed
Caledonia Junior High School	Family studies tap 2 room 215	NMK130	0.0012	Passed	0.0550	Passed
Caledonia Junior High School	Family studies tap 3 room 215	NMK131	0.0019	Passed	0.0440	Passed
Caledonia Junior High School	Family studies tap 4 room 215	MXU534	0.0042	Passed	0.7900	Passed
Caledonia Junior High School	Family studies tap 5 room 215	MXU535	0.0009	Passed	0.9300	Passed
Caledonia Junior High School	CR tap 1 room 207	MXU536	0.0069	Exceeds Limit	0.2400	Passed
Caledonia Junior High School	CR tap 2 room 207	MXU537	0.1000	Exceeds Limit	0.8200	Passed
Caledonia Junior High School	CR tap 3 room 207	MXU538	0.0053	Exceeds Limit	1.4000	Passed
Caledonia Junior High School	Girls WR tap 1 by room 207	MXU539	0.0120	Exceeds Limit	0.5700	Passed
Caledonia Junior High School	Girls WR tap 2 by room 207	MXU540	0.0085	Exceeds Limit	0.1800	Passed
Caledonia Junior High School	Girls WR tap 3 by room 207	MXU541	0.0046	Passed	0.1300	Passed
Caledonia Junior High School	JC tap between WR's	MXU542	0.0230	Exceeds Limit	0.4800	Passed
Caledonia Junior High School	Boys WR tap 1 by room 207	MXU583	0.0420	Exceeds Limit	0.3200	Passed
Caledonia Junior High School	Boys WR tap 2 by room 207	MXU589	0.0140	Exceeds Limit	0.1500	Passed
Caledonia Junior High School	Boys WR tap 3 by room 207	MXU590	0.0360	Exceeds Limit	0.2400	Passed
Caledonia Junior High School	Girls WR tap 3 by room 108	MYH020	0.0061	Exceeds Limit	0.4000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Caudle Park Elementary School	Fountain by room 101	MPX379	0.0000	Passed	0.0870	Passed
Caudle Park Elementary School	1st floor boys WR tap 1	MPX380	0.0016	Passed	0.1100	Passed
Caudle Park Elementary School	1st floor boys WR tap 2	MPX381	0.0006	Passed	0.0920	Passed
Caudle Park Elementary School	1st floor JC tap	MPX382	0.0000	Passed	0.0440	Passed
Caudle Park Elementary School	1st floor staff WR tap	MPX383	0.0020	Passed	0.0300	Passed
Caudle Park Elementary School	1st floor staff WR tap	MPX384	0.0019	Passed	0.0420	Passed
Caudle Park Elementary School	1st floor Girls WR tap 1	MPX385	0.0020	Passed	0.1500	Passed
Caudle Park Elementary School	1st floor Girls WR tap 2	MPX386	0.0007	Passed	0.1000	Passed
Caudle Park Elementary School	1st floor Girls WR tap 3	MPX387	0.0023	Passed	0.0990	Passed
Caudle Park Elementary School	Main office WR tap	MPX388	0.0000	Passed	0.1100	Passed
Caudle Park Elementary School	2nd floor staff room kitchen tap	MPX389	0.0007	Passed	0.1700	Passed
Caudle Park Elementary School	Fountain by room 202	MPX390	0.0026	Passed	0.1800	Passed
Caudle Park Elementary School	2nd floor boys WR tap 2	MPX392	0.0008	Passed	0.0730	Passed
Caudle Park Elementary School	2nd floor boys WR tap 3	MPX393	0.0009	Passed	0.0840	Passed
Caudle Park Elementary School	2nd floor boys WR tap 4	MPX394	0.0006	Passed	0.1500	Passed
Caudle Park Elementary School	2nd floor JC tap	MPX395	0.0000	Passed	0.0320	Passed
Caudle Park Elementary School	2nd floor staff room WR tap	MPX396	0.0011	Passed	0.2000	Passed
Caudle Park Elementary School	2nd floor girls WR tap 1	MPX397	0.0031	Passed	0.1800	Passed
Caudle Park Elementary School	2nd floor girls WR tap 2	MPX398	0.0008	Passed	0.0850	Passed
Caudle Park Elementary School	2nd floor girls WR tap 3	MPX399	0.0007	Passed	0.0590	Passed
Caudle Park Elementary School	2nd floor girls WR tap 4	MPX400	0.0013	Passed	0.0720	Passed
Caudle Park Elementary School	Fountain by room 303	MPX401	0.0018	Passed	0.2300	Passed
Caudle Park Elementary School	3rd floor boys WR tap	MPX402	0.0010	Passed	0.0950	Passed
Caudle Park Elementary School	3rd floor Girls WR tap	MPX403	0.0007	Passed	0.1800	Passed
Caudle Park Elementary School	3rd floor JC tap	MPX404	0.0000	Passed	0.0230	Passed
Caudle Park Elementary School	CR tap room 101	NFZ878	0.0006	Passed	0.0800	Passed
Caudle Park Elementary School	2nd floor boys WR tap 1	NFZ879	0.0000	Passed	0.0580	Passed
Cavalier Drive School	Main office WR tap	MPQ776	0.0027	Passed	0.0310	Passed
Cavalier Drive School	Fountain by room 102	MPQ777	0.0110	Exceeds Limit	0.0660	Passed
Cavalier Drive School	WR by room 102 tap 1	MPQ778	0.0180	Exceeds Limit	0.2700	Passed
Cavalier Drive School	WR by room 102 tap 2	MPQ779	0.0160	Exceeds Limit	0.2400	Passed
Cavalier Drive School	Learning centre tap	MPQ780	0.0038	Passed	0.0470	Passed
Cavalier Drive School	WR by room 104 tap 1	MPQ781	0.0100	Exceeds Limit	0.1700	Passed
Cavalier Drive School	WR by room 104 tap 2	MPQ782	0.0007	Passed	0.0340	Passed
Cavalier Drive School	CR tap room 108	MPQ783	0.0037	Passed	0.0200	Passed
Cavalier Drive School	CR tap room 110	MPQ784	0.0036	Passed	0.4400	Passed
Cavalier Drive School	CR tap room 111	MPQ785	0.0320	Exceeds Limit	0.5500	Passed
Cavalier Drive School	Fountain by room 107	MPQ788	0.0200	Exceeds Limit	0.1400	Passed
Cavalier Drive School	1st floor boys WR tap 1	MPQ789	0.0110	Exceeds Limit	0.0980	Passed
Cavalier Drive School	1st floor boys WR tap 2	MPQ790	0.0057	Exceeds Limit	0.0450	Passed
Cavalier Drive School	1st floor JC tap	MPQ791	0.0006	Passed	0.0230	Passed
Cavalier Drive School	1st floor Girls WR tap 1	MPQ792	0.0180	Exceeds Limit	0.3500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cavalier Drive School	1st floor Girls WR tap 2	MPQ793	0.0900	Exceeds Limit	0.2100	Passed
Cavalier Drive School	1st floor Girls WR tap 3	MPQ794	0.0890	Exceeds Limit	0.1700	Passed
Cavalier Drive School	Staff room WR tap 1	MPQ795	0.0140	Exceeds Limit	0.1300	Passed
Cavalier Drive School	Staff room WR tap 2	MPQ796	0.0018	Passed	0.0190	Passed
Cavalier Drive School	Staff room kitchen tap	MPQ797	0.0011	Passed	0.0410	Passed
Cavalier Drive School	Gym boys WR tap	MPQ798	0.0055	Exceeds Limit	0.1400	Passed
Cavalier Drive School	Gym Girls WR tap	MPQ799	0.0091	Exceeds Limit	0.1400	Passed
Cavalier Drive School	Fountain by room 165	MPQ800	0.0049	Passed	0.2300	Passed
Cavalier Drive School	Kitchen tap by room 167	MPQ801	0.0070	Exceeds Limit	0.4300	Passed
Cavalier Drive School	CR tap room 156	MPQ802	0.1800	Exceeds Limit	0.3300	Passed
Cavalier Drive School	CR tap 1 room 152	MPQ803	0.0011	Passed	0.0170	Passed
Cavalier Drive School	CR tap 2 room 152	MPQ804	0.0450	Exceeds Limit	0.2200	Passed
Cavalier Drive School	2nd floor fountain by room	MPQ805	0.0026	Passed	0.1800	Passed
Cavalier Drive School	2nd floor girls WR tap 1	MPQ806	0.1700	Exceeds Limit	0.2400	Passed
Cavalier Drive School	2nd floor girls WR tap 2	MPQ807	0.0550	Exceeds Limit	0.0830	Passed
Cavalier Drive School	2nd floor girls WR tap 3	MPQ810	0.1100	Exceeds Limit	0.1500	Passed
Cavalier Drive School	2nd floor boys WR tap 1	MPQ811	0.0230	Exceeds Limit	0.2200	Passed
Cavalier Drive School	2nd floor boys WR tap 2	MPQ812	0.0110	Exceeds Limit	0.1100	Passed
Cavalier Drive School	2nd floor boys WR tap 3	MPQ813	0.0270	Exceeds Limit	0.2200	Passed
Cavalier Drive School	2nd floor JC tap	MPQ814	0.0000	Passed	0.0058	Passed
Cavalier Drive School	CR tap room 205	MPQ815	0.0034	Passed	0.0210	Passed
Cavalier Drive School	CR tap room 203	MPQ816	0.3000	Exceeds Limit	0.0340	Passed
Cavalier Drive School	CR tap room 201	MPQ817	0.0033	Passed	0.2300	Passed
Cavalier Drive School	CR tap room 202	MPQ818	0.0100	Exceeds Limit	0.2100	Passed
Cavalier Drive School	CR tap room 204	MPQ819	0.0012	Passed	0.0210	Passed
Cavalier Drive School	CR WR tap room 204	MPQ822	0.0096	Exceeds Limit	0.0760	Passed
Cavalier Drive School	Fountain by room 204	MPQ823	0.0260	Exceeds Limit	0.1700	Passed
Cavalier Drive School	CR tap room 206	MPQ824	0.0026	Passed	0.0150	Passed
Cavalier Drive School	CR WR tap room 206	MPQ825	0.0030	Passed	0.0680	Passed
Central Spryfield Elementary School	Kitchen tap room 104	NKX271	0.0004	Passed	0.0060	Passed
Central Spryfield Elementary School	Fountain by room 104	MRC993	0.0013	Passed	0.1300	Passed
Central Spryfield Elementary School	Boys WR tap 1 by room 104	MRC994	0.0210	Exceeds Limit	0.1600	Passed
Central Spryfield Elementary School	Boys WR tap 2 by room 104	MRC995	0.0260	Exceeds Limit	0.0470	Passed
Central Spryfield Elementary School	Boys WR tap 3 by room 104	MRC996	0.0083	Exceeds Limit	0.0480	Passed
Central Spryfield Elementary School	Girls WR tap 1 by room 104	MRC997	0.1800	Exceeds Limit	0.1400	Passed
Central Spryfield Elementary School	Girls WR tap 2 by room 104	MRC998	0.0160	Exceeds Limit	0.1000	Passed
Central Spryfield Elementary School	Girls WR tap 3 by room 104	MRC999	0.0067	Exceeds Limit	0.0650	Passed
Central Spryfield Elementary School	JC tap room 113	NKV272	0.0004	Passed	0.0080	Passed
Central Spryfield Elementary School	Kitchen tap 1 room 116	NKX275	0.0004	Passed	0.0100	Passed
Central Spryfield Elementary School	Kitchen tap 2 room 116	MRD002	0.0031	Passed	0.3700	Passed
Central Spryfield Elementary School	Staff room kitchen tap room 112	NKX273	0.0004	Passed	0.0060	Passed
Central Spryfield Elementary School	Staff WR tap 1 room 112	MRD004	0.0066	Exceeds Limit	0.0430	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Central Spryfield Elementary School	Staff WR tap 2 room 112	MRD005	0.0083	Exceeds Limit	0.0440	Passed
Central Spryfield Elementary School	Learning centre tap room 103	MRD006	0.0012	Passed	0.0440	Passed
Central Spryfield Elementary School	Learning centre WR tap room 103	MRD007	0.0100	Exceeds Limit	0.0360	Passed
Central Spryfield Elementary School	CR tap room 100C	MRD008	0.0000	Passed	0.0600	Passed
Central Spryfield Elementary School	Girls WR tap 1 by room 100C	MRD009	0.0000	Passed	0.1000	Passed
Central Spryfield Elementary School	Girls WR tap 2 by room 100C	MRD010	0.0012	Passed	0.0990	Passed
Central Spryfield Elementary School	Girls WR tap 3 by room 100C	MRD011	0.0011	Passed	0.0600	Passed
Central Spryfield Elementary School	Boys WR tap 1 by caretaker office	MRD012	0.0023	Passed	0.0960	Passed
Central Spryfield Elementary School	Boys WR tap 2 by caretaker office	MRD013	0.0058	Exceeds Limit	0.2900	Passed
Central Spryfield Elementary School	JC tap by caretaker room	MRD014	0.0011	Passed	0.0670	Passed
Central Spryfield Elementary School	Fountain by room 100B	MRD015	0.0016	Passed	0.1300	Passed
Central Spryfield Elementary School	CR tap room 100B	MRD016	0.0015	Passed	0.1700	Passed
Central Spryfield Elementary School	Boys WR tap 1 room 214	MRD017	0.0018	Passed	0.0440	Passed
Central Spryfield Elementary School	Boys WR tap 2 room 214	MRD018	0.0093	Exceeds Limit	0.0430	Passed
Central Spryfield Elementary School	Boys WR tap 3 room 214	MRD019	0.0080	Exceeds Limit	0.0570	Passed
Central Spryfield Elementary School	JC tap room 212	MRD020	0.0016	Passed	0.0520	Passed
Central Spryfield Elementary School	Fountain by room 212	MRD021	0.0005	Passed	0.3600	Passed
Central Spryfield Elementary School	Girls WR tap 1 room 215	MRD022	0.0010	Passed	0.0410	Passed
Central Spryfield Elementary School	Girls WR tap 2 room 215	MRD023	0.0052	Exceeds Limit	0.0380	Passed
Central Spryfield Elementary School	Girls WR tap 3 room 215	MRD024	0.0010	Passed	0.0370	Passed
Central Spryfield Elementary School	Guidance kitchen tap room 217	NKX274	0.0006	Passed	0.0110	Passed
Central Spryfield Elementary School	Guidance WR tap room 217	MRD026	0.0065	Exceeds Limit	0.1700	Passed
Central Spryfield Elementary School	Fountain by room 200B	MRD027	0.0037	Passed	0.1300	Passed
Central Spryfield Elementary School	CR tap room 200B	MRD028	0.0034	Passed	0.0610	Passed
Charles P. Allen High School	2008A-T1	MNX510	0.0000	Passed	0.2800	Passed
Charles P. Allen High School	FOUNTAIN BY 2008A	MNX511	0.0000	Passed	0.5100	Passed
Charles P. Allen High School	2029-T1	MNX512	0.0000	Passed	0.5600	Passed
Charles P. Allen High School	2029-T2	MNX513	0.0000	Passed	0.4700	Passed
Charles P. Allen High School	2029-T3	MNX514	0.0000	Passed	0.6500	Passed
Charles P. Allen High School	2030-T1	MNX515	0.0000	Passed	0.7500	Passed
Charles P. Allen High School	2030-T2	MNX516	0.0000	Passed	0.7000	Passed
Charles P. Allen High School	2030-T3	MNX517	0.0000	Passed	0.6800	Passed
Charles P. Allen High School	FOUNTAIN BY 2028	MNX518	0.0000	Passed	0.4800	Passed
Charles P. Allen High School	2032	MNX519	0.0000	Passed	0.3800	Passed
Charles P. Allen High School	2031	MNX524	0.0000	Passed	0.0790	Passed
Charles P. Allen High School	2028	MNX525	0.0000	Passed	0.6600	Passed
Charles P. Allen High School	2044	MNX526	0.0000	Passed	0.3600	Passed
Charles P. Allen High School	2044B-T1	MNX527	0.0000	Passed	0.2700	Passed
Charles P. Allen High School	2044B-T2	MNX528	0.0000	Passed	0.3100	Passed
Charles P. Allen High School	2045-T1	MNX529	0.0000	Passed	0.7400	Passed
Charles P. Allen High School	2045-T2	MNX530	0.0000	Passed	0.6500	Passed
Charles P. Allen High School	2045-T3	MNX531	0.0000	Passed	0.7900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Charles P. Allen High School	2046-T1	MNX532	0.0000	Passed	0.9900	Passed
Charles P. Allen High School	2046-T2	MNX533	0.0000	Passed	0.6900	Passed
Charles P. Allen High School	2046-T3	MNX541	0.0000	Passed	0.7200	Passed
Charles P. Allen High School	2047	MNX542	0.0000	Passed	0.3700	Passed
Charles P. Allen High School	2048	MNX543	0.0044	Passed	0.4400	Passed
Charles P. Allen High School	FOUNTAIN BY 2049	MNX544	0.0000	Passed	0.3000	Passed
Charles P. Allen High School	Locker room tap 1 room 2068	MOE400	0.0000	Passed	1.0000	Passed
Charles P. Allen High School	Locker room tap 2 room 2068	MOE401	0.0000	Passed	1.2000	Passed
Charles P. Allen High School	Locker room tap 1 room 2067	MOE402	0.0006	Passed	0.8400	Passed
Charles P. Allen High School	Locker room tap 2 room 2067	MOE403	0.0000	Passed	0.8200	Passed
Charles P. Allen High School	Locker room tap 1 room 2066	MOE404	0.0025	Passed	0.8200	Passed
Charles P. Allen High School	Locker room tap 2 room 2066	MOE405	0.0011	Passed	0.4900	Passed
Charles P. Allen High School	Locker room tap 1 room 2065	MOE406	0.0000	Passed	0.5900	Passed
Charles P. Allen High School	Locker room tap 2 room 2065	MOE407	0.0000	Passed	0.5400	Passed
Charles P. Allen High School	Fountain by locker room 2067	MPC109	0.0000	Passed	0.3800	Passed
Charles P. Allen High School	Fountain by locker room 2065	MPC110	0.0000	Passed	0.4700	Passed
Charles P. Allen High School	Learning studio tap room 1002	MPM943	0.0000	Passed	0.9300	Passed
Charles P. Allen High School	Fountain by room 1003	MPM944	0.0000	Passed	0.5000	Passed
Charles P. Allen High School	WR tap room 1005	MPM945	0.0000	Passed	0.4600	Passed
Charles P. Allen High School	CR tap room 1004	MPM946	0.0000	Passed	0.7200	Passed
Charles P. Allen High School	Fountain by room 1015	MPM947	0.0000	Passed	0.4300	Passed
Charles P. Allen High School	CR tap room 1015 (tech ed)	MPM948	0.0000	Passed	0.7200	Passed
Charles P. Allen High School	CR tap room 1016 (tech ed)	MPM949	0.0000	Passed	0.8100	Passed
Charles P. Allen High School	CR tap 1 room 1024 (art room)	MPM950	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	CR tap 2 room 1024 (art room)	MPM951	0.0000	Passed	0.9400	Passed
Charles P. Allen High School	CR tap 1 room 1027 (art room)	MPM952	0.0000	Passed	0.0720	Passed
Charles P. Allen High School	CR tap 2 room 1027 (art room)	MPM953	0.0000	Passed	0.7400	Passed
Charles P. Allen High School	CR tap room 1026	MPM954	0.0000	Passed	0.8300	Passed
Charles P. Allen High School	Boys WR tap 1 room 1028	MPM955	0.0000	Passed	0.8500	Passed
Charles P. Allen High School	Boys WR tap 2 room 1028	MPM956	0.0000	Passed	0.8400	Passed
Charles P. Allen High School	Boys WR tap 3 room 1028	MPM957	0.0000	Passed	0.8000	Passed
Charles P. Allen High School	JC tap room 1031	MPM958	0.0000	Passed	0.5400	Passed
Charles P. Allen High School	Staff WR tap room 1030	MPM959	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	Girls WR tap 1 room 1029	MPM960	0.0000	Passed	0.5400	Passed
Charles P. Allen High School	Girls WR tap 2 room 1029	MPM961	0.0000	Passed	0.6500	Passed
Charles P. Allen High School	Girls WR tap 3 room 1029	MPM962	0.0000	Passed	0.6000	Passed
Charles P. Allen High School	Caretaker room tap room 1066	MPM964	0.0000	Passed	0.4100	Passed
Charles P. Allen High School	JC tap room 1065	MPM965	0.0007	Passed	0.1300	Passed
Charles P. Allen High School	Girls WR tap 1 room 1055	MPM966	0.0018	Passed	0.4400	Passed
Charles P. Allen High School	Girls WR tap 2 room 1055	MPM967	0.0015	Passed	0.5500	Passed
Charles P. Allen High School	Girls WR tap 3 room 1055	MPM968	0.0000	Passed	0.7200	Passed
Charles P. Allen High School	Staff WR tap room 1056	MPM969	0.0000	Passed	1.0000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Charles P. Allen High School	JC tap room 1057	MPM970	0.0011	Passed	0.3200	Passed
Charles P. Allen High School	Boys WR tap 1 room 1054	MPM971	0.0000	Passed	0.7200	Passed
Charles P. Allen High School	Boys WR tap 2 room 1054	MPM972	0.0000	Passed	0.6900	Passed
Charles P. Allen High School	Boys WR tap 3 room 1054	MPM973	0.0000	Passed	0.7700	Passed
Charles P. Allen High School	Fountain by room 1054	MPM974	0.0000	Passed	0.4700	Passed
Charles P. Allen High School	Staff WR room 1048	MPM975	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	CR tap room 3004	MSA126	0.0000	Passed	0.2100	Passed
Charles P. Allen High School	Fountain by room 3006	MSA127	0.0000	Passed	0.6100	Passed
Charles P. Allen High School	CR tap room 3028	MSA128	0.0000	Passed	0.8100	Passed
Charles P. Allen High School	Fountain by room 3028	MSA129	0.0000	Passed	0.6300	Passed
Charles P. Allen High School	Boys WR tap 1 room 3029	MSA130	0.0000	Passed	0.4900	Passed
Charles P. Allen High School	Boys WR tap 2 room 3029	MSA131	0.0000	Passed	0.5200	Passed
Charles P. Allen High School	Boys WR tap 3 room 3029	MSA132	0.0000	Passed	0.5500	Passed
Charles P. Allen High School	JC tap room 3032	MSA133	0.0007	Passed	0.3800	Passed
Charles P. Allen High School	Staff WR tap room 3031	MSA134	0.0000	Passed	0.2600	Passed
Charles P. Allen High School	Girls WR tap 1 room 3030	MSA135	0.0000	Passed	0.6500	Passed
Charles P. Allen High School	Girls WR tap 2 room 3030	MSA136	0.0000	Passed	0.5600	Passed
Charles P. Allen High School	Girls WR tap 3 room 3030	MSA137	0.0000	Passed	0.6500	Passed
Charles P. Allen High School	GN WR tap room 3059	MSA138	0.0000	Passed	0.3800	Passed
Charles P. Allen High School	CR tap 1 room 3060	MSA139	0.0000	Passed	0.8900	Passed
Charles P. Allen High School	CR tap 2 room 3060	MSA140	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	CR tap 3 room 3060	MSA141	0.0000	Passed	0.5900	Passed
Charles P. Allen High School	Mech. Room tap room ST.9.1	MSA142	0.0000	Passed	0.1100	Passed
Charles P. Allen High School	CR tap room 3061	MSA143	0.0000	Passed	0.1500	Passed
Charles P. Allen High School	Science lab tap 1 room 3062	MSA144	0.0000	Passed	0.1700	Passed
Charles P. Allen High School	Science lab tap 2 room 3062	MSA145	0.0000	Passed	0.0970	Passed
Charles P. Allen High School	Science lab tap 3 room 3062	MSA146	0.0000	Passed	1.2000	Passed
Charles P. Allen High School	Change room tap room 3052A	MSA147	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	CR tap 1 room 3051	MSA148	0.0000	Passed	0.2200	Passed
Charles P. Allen High School	CR tap 2 room 3051	MSA149	0.0000	Passed	0.9300	Passed
Charles P. Allen High School	CR tap 3 room 3051	MSA150	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	CR tap 4 room 3051	MSA151	0.0000	Passed	0.1100	Passed
Charles P. Allen High School	CR tap 5 room 3051	MSA152	0.0000	Passed	1.2000	Passed
Charles P. Allen High School	CR tap room 3050	MSA153	0.0000	Passed	0.1100	Passed
Charles P. Allen High School	CR tap 1 room 3049	MSA154	0.0000	Passed	0.3600	Passed
Charles P. Allen High School	CR tap 2 room 3049	MSA155	0.0000	Passed	0.1600	Passed
Charles P. Allen High School	Fountain before room 3046	MSA156	0.0000	Passed	0.5000	Passed
Charles P. Allen High School	Girls WR tap 1 room 3046	MSA157	0.0000	Passed	0.7100	Passed
Charles P. Allen High School	Girls WR tap 2 room 3046	MSA158	0.0000	Passed	0.6200	Passed
Charles P. Allen High School	Girls WR tap 3 room 3046	MSA159	0.0000	Passed	0.6200	Passed
Charles P. Allen High School	Staff WR tap room 3047	MSA160	0.0000	Passed	0.6800	Passed
Charles P. Allen High School	Chem lab tap 1 room 3044	MSA161	0.0029	Passed	0.7500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Charles P. Allen High School	Chem lab tap 2 room 3044	MSA162	0.0000	Passed	0.5000	Passed
Charles P. Allen High School	Chem lab tap 3 room 3044	MSA163	0.0000	Passed	0.6400	Passed
Charles P. Allen High School	Chem lab tap 4 room 3044	MSA164	0.0000	Passed	0.6100	Passed
Charles P. Allen High School	Multipurpose lab tap 1 room 3041	MSA165	0.0000	Passed	0.8300	Passed
Charles P. Allen High School	Multipurpose lab tap 2 room 3041	MSA166	0.0000	Passed	0.8100	Passed
Charles P. Allen High School	Multipurpose lab tap 3 room 3041	MSA167	0.0000	Passed	1.0000	Passed
Charles P. Allen High School	Multipurpose lab tap 4 room 3041	MSA168	0.0000	Passed	0.3700	Passed
Charles P. Allen High School	Multipurpose lab tap 5 room 3041	MSA169	0.0000	Passed	1.2000	Passed
Charles P. Allen High School	Multipurpose lab tap 6 room 3041	MSA170	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	Boys WR tap 1 room 3045	MSA171	0.0000	Passed	0.9300	Passed
Charles P. Allen High School	Boys WR tap 2 room 3045	MSA172	0.0000	Passed	0.8300	Passed
Charles P. Allen High School	Boys WR tap 3 room 3045	MSA173	0.0000	Passed	1.0000	Passed
Charles P. Allen High School	Chem lab tap 1 room 3044	MSA174	0.0000	Passed	1.1000	Passed
Charles P. Allen High School	Chem lab tap 2 room 3044	MSA175	0.0000	Passed	0.7400	Passed
Charles P. Allen High School	Chem lab tap 3 room 3044	MSA176	0.0000	Passed	0.6100	Passed
Charles P. Allen High School	Chem lab tap 4 room 3044	MSA177	0.0000	Passed	0.8000	Passed
Charles P. Allen High School	Chem lab tap 5 room 3044	MSA178	0.0000	Passed	0.7900	Passed
Charles P. Allen High School	Chem lab tap 6 room 3044	MSA179	0.0000	Passed	0.6800	Passed
Charles P. Allen High School	Chem lab tap 7 room 3044	MSA180	0.0000	Passed	0.9900	Passed
Charles P. Allen High School	JC tap room 3048	MSA181	0.0000	Passed	0.2600	Passed
Charles P. Allen High School	Multipurpose lab tap 7 room 3041	MSA182	0.0000	Passed	0.1600	Passed
Charles P. Allen High School	Multipurpose lab tap 8 room 3041	MSA183	0.0000	Passed	0.2800	Passed
Charles P. Allen High School	Music room 1069 tap	NES631	0.0000	Passed	0.0620	Passed
Chebucto Heights Elementary School	CR tap 1 room 212	NKX388	0.0004	Passed	0.0100	Passed
Chebucto Heights Elementary School	CR tap (math resource) room 212A	MQS752	0.0580	Exceeds Limit	1.9000	Passed
Chebucto Heights Elementary School	2nd floor girls WR tap 1	MQS753	0.0016	Passed	0.0910	Passed
Chebucto Heights Elementary School	2nd floor girls WR tap 2	MQS754	0.0044	Passed	0.0700	Passed
Chebucto Heights Elementary School	2nd floor girls WR tap 3	MQS755	0.0016	Passed	0.1500	Passed
Chebucto Heights Elementary School	2nd floor girls WR tap 4	MQS756	0.0077	Exceeds Limit	0.1500	Passed
Chebucto Heights Elementary School	2nd floor boys WR tap 1	MQS757	0.0025	Passed	0.0670	Passed
Chebucto Heights Elementary School	2nd floor boys WR tap 2	MQS758	0.0028	Passed	0.0620	Passed
Chebucto Heights Elementary School	2nd floor boys WR tap 3	MQS759	0.0014	Passed	0.0720	Passed
Chebucto Heights Elementary School	2nd floor boys WR tap 4	MQS760	0.0021	Passed	0.0730	Passed
Chebucto Heights Elementary School	CR tap room 203	MQS761	0.0032	Passed	0.0220	Passed
Chebucto Heights Elementary School	JC tap by room 202	MQS762	0.0005	Passed	0.0069	Passed
Chebucto Heights Elementary School	CR tap room 202	MQS763	0.0018	Passed	0.0150	Passed
Chebucto Heights Elementary School	Fountain between room 220 and 217	MQS764	0.0027	Passed	0.1300	Passed
Chebucto Heights Elementary School	CR tap 1 room 216	NKX389	0.0040	Passed	0.0100	Passed
Chebucto Heights Elementary School	CR tap 2 room 216	MQS766	0.0018	Passed	0.0900	Passed
Chebucto Heights Elementary School	CR tap room 213	MQS767	0.0031	Passed	0.0780	Passed
Chebucto Heights Elementary School	Boys locker room tap room 152	MQS768	0.0015	Passed	0.1200	Passed
Chebucto Heights Elementary School	JC tap room 157	MQS769	0.0015	Passed	0.1800	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Chebucto Heights Elementary School	Gym office WR tap	MQS770	0.0490	Exceeds Limit	0.1800	Passed
Chebucto Heights Elementary School	Girls locker room tap room 147	MQS771	0.0015	Passed	0.0960	Passed
Chebucto Heights Elementary School	Fountain by gym	MQS772	0.0000	Passed	0.1500	Passed
Chebucto Heights Elementary School	JC tap by gym	MQS773	0.0011	Passed	0.1600	Passed
Chebucto Heights Elementary School	Gym kitchen tap	MQS774	0.0160	Exceeds Limit	0.7900	Passed
Chebucto Heights Elementary School	Girls WR tap 1 room 114	MQS775	0.0000	Passed	0.0130	Passed
Chebucto Heights Elementary School	Girls WR tap 2 room 114	MQS776	0.0009	Passed	0.0180	Passed
Chebucto Heights Elementary School	Girls WR tap 3 room 114	MQS777	0.0019	Passed	0.0430	Passed
Chebucto Heights Elementary School	Boys WR tap 1 room 115	MQS778	0.0006	Passed	0.0028	Passed
Chebucto Heights Elementary School	Boys WR tap 2 room 115	MQS779	0.0000	Passed	0.0018	Passed
Chebucto Heights Elementary School	Boys WR tap 3 room 115	MQS780	0.0000	Passed	0.0025	Passed
Chebucto Heights Elementary School	Boys WR tap 4 room 115	MQS781	0.0009	Passed	0.0078	Passed
Chebucto Heights Elementary School	CR tap room 120	MQS782	0.0017	Passed	0.0330	Passed
Chebucto Heights Elementary School	GN WR tap room 120	MQS783	0.0056	Exceeds Limit	0.0110	Passed
Chebucto Heights Elementary School	JC tap room 121	MQS784	0.0000	Passed	0.0057	Passed
Chebucto Heights Elementary School	CR tap room 124	NKX390	0.0012	Passed	0.0040	Passed
Chebucto Heights Elementary School	CR WR tap room 124	MQS786	0.0007	Passed	0.0220	Passed
Chebucto Heights Elementary School	Fountain by room 132	MQS787	0.0012	Passed	0.0340	Passed
Chebucto Heights Elementary School	Staff WR tap 1 room 112	MQS788	0.0007	Passed	0.0260	Passed
Chebucto Heights Elementary School	Staff WR tap 2 room 112	MQS789	0.0005	Passed	0.0240	Passed
Chebucto Heights Elementary School	Staff room kitchen tap	MQS790	0.0008	Passed	0.0240	Passed
Chebucto Heights Elementary School	Break room tap	MQS791	0.0017	Passed	0.2700	Passed
Chebucto Heights Elementary School	Health room WR tap room 109	MQS792	0.0016	Passed	0.1400	Passed
Citadel High School	Bio Lab tap 1 room 209	MTU825	0.0000	Passed	0.0400	Passed
Citadel High School	Bio Lab tap 2 room 209	MTU826	0.0000	Passed	0.0600	Passed
Citadel High School	Bio Lab tap 3 room 209	MTU827	0.0000	Passed	0.0480	Passed
Citadel High School	Bio Lab tap 4 room 209	MTU828	0.0000	Passed	0.0330	Passed
Citadel High School	Bio Lab tap 5 room 209	MTU829	0.0000	Passed	0.0300	Passed
Citadel High School	Science Lab tap 1 room 210	MTU830	0.0055	Exceeds Limit	0.4300	Passed
Citadel High School	Science Lab tap 2 room 210	MTU831	0.0030	Passed	0.2400	Passed
Citadel High School	Science Lab tap 3 room 210	MTU832	0.0021	Passed	0.1500	Passed
Citadel High School	Science Lab tap 4 room 210	MTU833	0.0000	Passed	0.0320	Passed
Citadel High School	Science Lab tap 5 room 210	MTU834	0.0000	Passed	0.0170	Passed
Citadel High School	Physics lab tap 1 room 212	MTU839	0.0020	Passed	0.2300	Passed
Citadel High School	Physics lab tap 2 room 212	MTU840	0.0016	Passed	0.1800	Passed
Citadel High School	Physics lab tap 3 room 212	MTU841	0.0015	Passed	0.1500	Passed
Citadel High School	Physics lab tap 4 room 212	MTU842	0.0000	Passed	0.0220	Passed
Citadel High School	Physics lab tap 5 room 212	MTU843	0.0000	Passed	0.0170	Passed
Citadel High School	Physics lab tap 1 room 213	MTU844	0.0005	Passed	0.0620	Passed
Citadel High School	Physics lab tap 2 room 213	MTU845	0.0000	Passed	0.0270	Passed
Citadel High School	Physics lab tap 3 room 213	MTU846	0.0000	Passed	0.0350	Passed
Citadel High School	Physics lab tap 4 room 213	MTU847	0.0007	Passed	0.0840	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Citadel High School	Physics lab tap 5 room 213	MTU848	0.0000	Passed	0.0310	Passed
Citadel High School	Men's room tap 1	MTU855	0.0011	Passed	0.0980	Passed
Citadel High School	Men's room tap 2	MTU856	0.0009	Passed	0.0550	Passed
Citadel High School	Men's room tap 3	MTU857	0.0007	Passed	0.0700	Passed
Citadel High School	Men's room tap 4	MTU858	0.0000	Passed	0.0490	Passed
Citadel High School	Men's room tap 5	MTU859	0.0008	Passed	0.0400	Passed
Citadel High School	Staff room tap 1	MTU860	0.0007	Passed	0.0790	Passed
Citadel High School	Staff room tap 2	MTU861	0.0000	Passed	0.0460	Passed
Citadel High School	Women's room tap 1	MTU862	0.0000	Passed	0.0440	Passed
Citadel High School	Women's room tap 2	MTU863	0.0007	Passed	0.0710	Passed
Citadel High School	Women's room tap 3	MTU864	0.0014	Passed	0.1100	Passed
Citadel High School	Women's room tap 4	MTU868	0.0014	Passed	0.0940	Passed
Citadel High School	Women's room tap 5	MTU869	0.0005	Passed	0.0590	Passed
Citadel High School	CR WR tap room 220	MTU870	0.0000	Passed	0.0180	Passed
Citadel High School	Library sink tap	MTU872	0.0000	Passed	0.0930	Passed
Citadel High School	CR tap by room 221	MTU873	0.0000	Passed	0.0910	Passed
Citadel High School	JC tap by room 221	MTU874	0.0000	Passed	0.0200	Passed
Citadel High School	2nd floor fountain by elevator	MTU875	0.0000	Passed	0.1400	Passed
Citadel High School	1st floor fountain by elevator	MTU876	0.0000	Passed	0.1600	Passed
Citadel High School	Cafeteria/kitchen tap 1	MTU877	0.0013	Passed	0.1200	Passed
Citadel High School	Cafeteria/kitchen tap 2	MTU881	0.0000	Passed	0.2000	Passed
Citadel High School	Cafeteria/kitchen tap 3	MTU882	0.0000	Passed	0.0700	Passed
Citadel High School	Cafeteria/kitchen tap 4	MTU883	0.0000	Passed	0.0530	Passed
Citadel High School	Cafeteria/kitchen tap 5	MTU884	0.0000	Passed	0.0490	Passed
Citadel High School	Fountain by room 103	MTU885	0.0000	Passed	0.1400	Passed
Citadel High School	Fountain by room 106	MTU886	0.0000	Passed	0.2000	Passed
Citadel High School	Boiler room tap	MTU887	0.0000	Passed	0.2400	Passed
Citadel High School	1st floor mens WR tap 1	MTU888	0.0007	Passed	0.0930	Passed
Citadel High School	1st floor mens WR tap 2	MTU889	0.0000	Passed	0.0470	Passed
Citadel High School	1st floor mens WR tap 3	MTU890	0.0028	Passed	0.0760	Passed
Citadel High School	1st floor mens WR tap 4	MTU894	0.0085	Exceeds Limit	0.7900	Passed
Citadel High School	1st floor mens WR tap 5	MTU895	0.0000	Passed	0.0440	Passed
Citadel High School	1st floor staff room tap 1	MTU896	0.0000	Passed	0.0720	Passed
Citadel High School	1st floor staff room tap 2	MTU897	0.0000	Passed	0.0460	Passed
Citadel High School	JC tap by staff room	MTU898	0.0000	Passed	0.1300	Passed
Citadel High School	1st floor womens WR tap 1 (by JC)	MTU899	0.0016	Passed	0.1000	Passed
Citadel High School	1st floor womens WR tap 2 (by JC)	MTU900	0.0031	Passed	0.3700	Passed
Citadel High School	1st floor womens WR tap 3 (by JC)	MTU901	0.0013	Passed	0.1400	Passed
Citadel High School	1st floor womens WR tap 4 (by JC)	MTU902	0.0008	Passed	0.0870	Passed
Citadel High School	Tech ed tap room 115	MTU906	0.0000	Passed	0.0170	Passed
Citadel High School	GN WR tap room 120	MTU907	0.0000	Passed	0.0540	Passed
Citadel High School	CR tap room 120	MTU908	0.0000	Passed	0.0660	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Citadel High School	Main office tap 1	MTU909	0.0000	Passed	0.0230	Passed
Citadel High School	Main office tap 2	MTU910	0.0000	Passed	0.0190	Passed
Citadel High School	Fountain in girls locker room	MTU911	0.0000	Passed	0.1200	Passed
Citadel High School	Girls locker room tap 1	MTU913	0.0000	Passed	0.0510	Passed
Citadel High School	Girls locker room tap 2	MTU914	0.0067	Exceeds Limit	0.2500	Passed
Citadel High School	JC tap near gym	MTU915	0.0019	Passed	0.1700	Passed
Citadel High School	Boys locker room tap 1	MTU917	0.0010	Passed	0.2600	Passed
Citadel High School	Boys locker room tap 2 room 153	MTU918	0.0025	Passed	0.1200	Passed
Citadel High School	1st floor staff WR	MTU919	0.0073	Exceeds Limit	0.1300	Passed
Citadel High School	Recycling room tap	MTU920	0.0000	Passed	0.0590	Passed
Citadel High School	Drama room tap room 122	MTU921	0.0000	Passed	0.0230	Passed
Citadel High School	Men's WR tap 1 by room 122	MTU922	0.0010	Passed	0.0400	Passed
Citadel High School	Men's WR tap 2 by room 122	MTU923	0.0000	Passed	0.0310	Passed
Citadel High School	Men's WR tap 3 by room 122	MTU924	0.0000	Passed	0.0640	Passed
Citadel High School	Men's WR tap 4 by room 122	MTU925	0.0000	Passed	0.0380	Passed
Citadel High School	JC tap by men's WR	MTU926	0.0000	Passed	0.0320	Passed
Citadel High School	1st floor Girls WR tap 1	MTU927	0.0000	Passed	0.0520	Passed
Citadel High School	1st floor Girls WR tap 2	MTU928	0.0000	Passed	0.0470	Passed
Citadel High School	1st floor Girls WR tap 4	MTU930	0.0016	Passed	0.0360	Passed
Citadel High School	1st floor Girls WR tap 5	MTU931	0.0021	Passed	0.0990	Passed
Citadel High School	1st floor Girls WR tap 6	MTU932	0.0006	Passed	0.0410	Passed
Citadel High School	1st floor Girls WR tap 7	MTU933	0.0010	Passed	0.0570	Passed
Citadel High School	CR tap 1 room 301	MTV128	0.0000	Passed	0.0360	Passed
Citadel High School	CR tap 2 room 301	MTV129	0.0000	Passed	0.0250	Passed
Citadel High School	CR tap 1 room 302	MTV130	0.0000	Passed	0.1400	Passed
Citadel High School	CR tap 2 room 302	MTV131	0.0000	Passed	0.1300	Passed
Citadel High School	Fountain by room 305	MTV132	0.0000	Passed	0.1500	Passed
Citadel High School	Fountain by room 308	MTV133	0.0000	Passed	0.2400	Passed
Citadel High School	CR tap 2 room 311	MTV135	0.0013	Passed	0.1600	Passed
Citadel High School	CR tap 3 room 311	MTV136	0.0007	Passed	0.0920	Passed
Citadel High School	CR tap 4 room 311	MTV137	0.0000	Passed	0.0580	Passed
Citadel High School	CR tap 5 room 311	MTV155	0.0007	Passed	0.0880	Passed
Citadel High School	CR tap 1 room 312	MTV156	0.0005	Passed	0.1100	Passed
Citadel High School	CR tap 2 room 312	MTV157	0.0006	Passed	0.0690	Passed
Citadel High School	CR tap 3 room 312	MTV158	0.0000	Passed	0.0610	Passed
Citadel High School	CR tap 4 room 312	MTV159	0.0000	Passed	0.0560	Passed
Citadel High School	CR tap 1 room 314	MTV160	0.0007	Passed	0.0560	Passed
Citadel High School	CR tap 2 room 314	MTV161	0.0000	Passed	0.0400	Passed
Citadel High School	CR tap 3 room 314	MTV162	0.0006	Passed	0.0530	Passed
Citadel High School	CR tap 4 room 314	MTV163	0.0008	Passed	0.0710	Passed
Citadel High School	CR tap 5 room 314	MTV164	0.0000	Passed	0.0420	Passed
Citadel High School	CR tap 6 room 314	MTV165	0.0000	Passed	0.0490	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Citadel High School	CR tap 7 room 314	MTV166	0.0000	Passed	0.0510	Passed
Citadel High School	CR tap 8 room 314	MTV167	0.0000	Passed	0.0480	Passed
Citadel High School	CR tap 9 room 314	MTV168	0.0000	Passed	0.0160	Passed
Citadel High School	CR tap 10 room 314	MTV169	0.0000	Passed	0.0300	Passed
Citadel High School	CR tap 1 room 315	MTV170	0.0010	Passed	0.1000	Passed
Citadel High School	CR tap 2 room 315	MTV171	0.0000	Passed	0.0430	Passed
Citadel High School	CR tap 3 room 315	MTV172	0.0006	Passed	0.0520	Passed
Citadel High School	CR tap 4 room 315	MTV173	0.0000	Passed	0.0510	Passed
Citadel High School	CR tap 5 room 315	MTV174	0.0000	Passed	0.0430	Passed
Citadel High School	CR tap 6 room 315	MTV188	0.0000	Passed	0.0380	Passed
Citadel High School	CR tap 7 room 315	MTV189	0.0000	Passed	0.0220	Passed
Citadel High School	CR tap 8 room 315	MTV190	0.0000	Passed	0.0140	Passed
Citadel High School	CR tap 9 room 315	MTV191	0.0000	Passed	0.0140	Passed
Citadel High School	Mens WR tap 1 room 316	MTV192	0.0000	Passed	0.0550	Passed
Citadel High School	Mens WR tap 2 room 316	MTV193	0.0000	Passed	0.0410	Passed
Citadel High School	Mens WR tap 3 room 316	MTV194	0.0005	Passed	0.0590	Passed
Citadel High School	Mens WR tap 4 room 316	MTV195	0.0015	Passed	0.3300	Passed
Citadel High School	Mens WR tap 5 room 316	MTV196	0.0006	Passed	0.1200	Passed
Citadel High School	Women's WR tap 1 by room 316	MTV197	0.0014	Passed	0.2400	Passed
Citadel High School	Women's WR tap 2 by room 316	MTV198	0.0007	Passed	0.1400	Passed
Citadel High School	Women's WR tap 3 by room 316	MTV199	0.0017	Passed	0.4400	Passed
Citadel High School	Women's WR tap 4 by room 316	MTV200	0.0011	Passed	0.3000	Passed
Citadel High School	Women's WR tap 5 by room 316	MTV201	0.0011	Passed	0.3000	Passed
Citadel High School	3rd floor staff room tap 1	MTV202	0.0000	Passed	0.0410	Passed
Citadel High School	3rd floor staff room tap 2	MTV203	0.0000	Passed	0.0770	Passed
Citadel High School	3rd floor staff room tap 3	MTV204	0.0014	Passed	0.0700	Passed
Citadel High School	CR tap 1 room 321	MTV205	0.0000	Passed	0.1100	Passed
Citadel High School	CR tap 2 room 321	MTV206	0.0000	Passed	0.0410	Passed
Citadel High School	CR tap 3 room 321	MTV207	0.0000	Passed	0.0380	Passed
Citadel High School	CR tap 4 room 321	MTV208	0.0000	Passed	0.0310	Passed
Citadel High School	GN WR tap by room 321	MTV209	0.0000	Passed	0.0410	Passed
Citadel High School	Storage room tap by JC	MTV210	0.0000	Passed	0.1800	Passed
Citadel High School	3rd floor JC tap	MTV211	0.0000	Passed	0.0330	Passed
Citadel High School	2nd floor teen health room tap	MTV212	0.0010	Passed	0.2100	Passed
Citadel High School	Fountain by room 203	MTV213	0.0000	Passed	0.1300	Passed
Citadel High School	Fountain by room 206	MTV214	0.0000	Passed	0.1100	Passed
Citadel High School	CR tap 5 room 312	MTV215	0.0010	Passed	0.1300	Passed
Citadel High School	1st floor Girls WR tap 3	NDO548	0.0000	Passed	0.0360	Passed
Citadel High School	1st floor womens WR tap 5 (by JC)	NDO549	0.0011	Passed	0.0480	Passed
Clayton Park Junior High School	Cr tap room 214	MRM447	0.0061	Exceeds Limit	0.3500	Passed
Clayton Park Junior High School	JC tap by room 214	MRM448	0.0000	Passed	0.0580	Passed
Clayton Park Junior High School	Boys WR tap 1 by room 200	MRM449	0.0000	Passed	0.0200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Clayton Park Junior High School	Boys WR tap 2 by room 200	MRM450	0.0014	Passed	0.0390	Passed
Clayton Park Junior High School	Boys WR tap 3 by room 200	MRM451	0.0056	Exceeds Limit	0.0540	Passed
Clayton Park Junior High School	Fountain by room 200	MRM452	0.0013	Passed	0.3700	Passed
Clayton Park Junior High School	Staff WR tap by room 200	MRM453	0.0000	Passed	0.0160	Passed
Clayton Park Junior High School	Girls WR tap 1 by room 200	MRM454	0.0018	Passed	0.4200	Passed
Clayton Park Junior High School	Girls WR tap 2 by room 200	MRM455	0.0009	Passed	0.3500	Passed
Clayton Park Junior High School	Girls WR tap 3 by room 200	MRM456	0.0010	Passed	0.2400	Passed
Clayton Park Junior High School	Family studies tap 1 by room 106	MRM464	0.0007	Passed	0.2900	Passed
Clayton Park Junior High School	Family studies tap 2 by room 106	MRM465	0.0000	Passed	0.1800	Passed
Clayton Park Junior High School	Family studies tap 3 by room 106	MRM466	0.0033	Passed	0.1300	Passed
Clayton Park Junior High School	Family studies tap 4 by room 106	MRM467	0.0000	Passed	0.0410	Passed
Clayton Park Junior High School	Family studies tap 45by room 106	MRM468	0.0000	Passed	0.0430	Passed
Clayton Park Junior High School	CR tap room 145	MRM469	0.0047	Passed	0.2200	Passed
Clayton Park Junior High School	Conference room WR tap by room 134	MRM470	0.0038	Passed	0.0950	Passed
Clayton Park Junior High School	Conference room kitchen tap room 134	NIU530	0.0004	Passed	0.0160	Passed
Clayton Park Junior High School	Conference room WR tap by room 134	MRM472	0.0000	Passed	0.1100	Passed
Clayton Park Junior High School	Boys locker room tap by room 121	MRM473	0.0005	Passed	0.0370	Passed
Clayton Park Junior High School	Fountain by room 118	MRM474	0.0000	Passed	0.3000	Passed
Clayton Park Junior High School	Girls locker room tap by room 114	MRM475	0.0110	Exceeds Limit	0.8500	Passed
Clayton Park Junior High School	Boys WR tap 1 by room 100	MRM476	0.0000	Passed	0.0084	Passed
Clayton Park Junior High School	Boys WR tap 2 by room 100	MRM477	0.0000	Passed	0.0140	Passed
Clayton Park Junior High School	Boys WR tap 3 by room 100	MRM478	0.0024	Passed	0.0530	Passed
Clayton Park Junior High School	Fountain by room 100B	MRM479	0.0000	Passed	0.4000	Passed
Clayton Park Junior High School	JC tap by room 100	MRM480	0.0000	Passed	0.0099	Passed
Clayton Park Junior High School	Girls WR tap 1 by room 104	MRM481	0.0000	Passed	0.0600	Passed
Clayton Park Junior High School	Girls WR tap 2 by room 104	MRM482	0.0000	Passed	0.0840	Passed
Clayton Park Junior High School	Girls WR tap 3 by room 104	MRM483	0.0065	Exceeds Limit	0.0680	Passed
Clayton Park Junior High School	Staff room tap room 104	NIU531	0.0019	Passed	0.0016	Passed
Clayton Park Junior High School	JC tap by room 003	MRM485	0.0014	Passed	0.0650	Passed
Clayton Park Junior High School	Band room closet kitchen tap by room 144	MRM486	0.0057	Exceeds Limit	0.0720	Passed
Clayton Park Junior High School	Band room kitchen tap by room 144	MRM487	0.0064	Exceeds Limit	0.2000	Passed
Clayton Park Junior High School	CR tap room 023	MRM488	0.0000	Passed	0.0830	Passed
Clayton Park Junior High School	CR tap room 025	MRM489	0.0000	Passed	0.0470	Passed
Clayton Park Junior High School	Principals office WR tap room 117	MRM490	0.0012	Passed	0.0280	Passed
Clayton Park Junior High School	Art room tap by gym	MRM491	0.0009	Passed	0.0730	Passed
Colby Village Elementary School	CR tap room 203	MWG569	0.0075	Exceeds Limit	0.1500	Passed
Colby Village Elementary School	Boys WR tap 1 by room 203	MWG570	0.0055	Exceeds Limit	0.2000	Passed
Colby Village Elementary School	Boys WR tap 2 by room 203	MWG571	0.0037	Passed	0.1300	Passed
Colby Village Elementary School	Boys WR tap 3 by room 203	MWG572	0.0032	Passed	0.0270	Passed
Colby Village Elementary School	Boys WR tap 4 by room 203	MWG573	0.0029	Passed	0.0250	Passed
Colby Village Elementary School	JC tap by gym	MWG574	0.0009	Passed	0.0520	Passed
Colby Village Elementary School	Fountain by gym	NLV943	0.0004	Passed	0.0250	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Colby Village Elementary School	Girls WR tap 1 by gym	MWG576	0.0041	Passed	0.0660	Passed
Colby Village Elementary School	Girls WR tap 2 by gym	MWG577	0.0040	Passed	0.0640	Passed
Colby Village Elementary School	Girls WR tap 3 by gym	MWG578	0.0063	Exceeds Limit	0.1600	Passed
Colby Village Elementary School	Girls WR tap 4 by gym	MWG579	0.0047	Passed	0.0670	Passed
Colby Village Elementary School	GN WR tap room 212	MWG580	0.0043	Passed	0.0700	Passed
Colby Village Elementary School	GN WR tap room 211	MWG581	0.0120	Exceeds Limit	0.3100	Passed
Colby Village Elementary School	Boys WR tap 1 by room 211	MWG582	0.0066	Exceeds Limit	0.2100	Passed
Colby Village Elementary School	Boys WR tap 2 by room 211	MWG583	0.0025	Passed	0.2600	Passed
Colby Village Elementary School	Boys WR tap 3 by room 211	MWG584	0.0084	Exceeds Limit	0.1200	Passed
Colby Village Elementary School	Boys WR tap 4 by room 211	MWG585	0.0300	Exceeds Limit	0.3300	Passed
Colby Village Elementary School	JC tap by staff room	MWG586	0.0009	Passed	0.0470	Passed
Colby Village Elementary School	Fountain by staff room	NLV942	0.0004	Passed	0.0250	Passed
Colby Village Elementary School	Girls WR tap 1 by staff room	MWG588	0.3300	Exceeds Limit	1.5000	Passed
Colby Village Elementary School	Girls WR tap 2 by staff room	MWG589	0.2900	Exceeds Limit	0.3300	Passed
Colby Village Elementary School	Girls WR tap 3 by staff room	MWG590	0.1600	Exceeds Limit	0.3900	Passed
Colby Village Elementary School	Girls WR tap 4 by staff room	MWG591	0.4500	Exceeds Limit	0.2100	Passed
Colby Village Elementary School	Staff room WR 1 tap	MWG592	0.0072	Exceeds Limit	0.1000	Passed
Colby Village Elementary School	Staff room kitchen tap	NLV941	0.0032	Passed	0.0230	Passed
Colby Village Elementary School	Staff room WR 2 tap	MWG594	0.0250	Exceeds Limit	0.0690	Passed
Cole Harbour District High School	Breakfast room tap 1	NMD819	0.0004	Passed	0.0170	Passed
Cole Harbour District High School	Breakfast room tap 2	NMD822	0.0004	Passed	0.0120	Passed
Cole Harbour District High School	Breakfast room tap 3	MXH625	0.0022	Passed	1.9000	Passed
Cole Harbour District High School	Breakfast room tap 4	NMD823	0.0004	Passed	0.0100	Passed
Cole Harbour District High School	Breakfast room handwashing tap	MXH627	0.0000	Passed	1.6000	Passed
Cole Harbour District High School	Fountain by room 308	NMD818	0.0009	Passed	0.0580	Passed
Cole Harbour District High School	Staff WR tap by room 308	MXH629	0.0009	Passed	0.0660	Passed
Cole Harbour District High School	Boys WR tap 1 by room 309	MXH630	0.0039	Passed	0.2500	Passed
Cole Harbour District High School	Boys WR tap 2 by room 309	MXH631	0.0024	Passed	0.3400	Passed
Cole Harbour District High School	JC tap by room 309	MXH632	0.0010	Passed	0.1600	Passed
Cole Harbour District High School	Fountain across from room 309	MXH633	0.0008	Passed	0.0870	Passed
Cole Harbour District High School	Girls WR tap 1 by room 309	MXH634	0.0076	Exceeds Limit	0.3400	Passed
Cole Harbour District High School	Girls WR tap 2 by room 309	MXH635	0.0025	Passed	0.2300	Passed
Cole Harbour District High School	Server room tap in library	MXH636	0.5700	Exceeds Limit	0.5900	Passed
Cole Harbour District High School	CR tap room 208	MXH637	0.0009	Passed	0.5400	Passed
Cole Harbour District High School	Learning centre WR tap	MXH638	0.0008	Passed	1.2000	Passed
Cole Harbour District High School	Learning centre kitchen tap	MXH639	0.0008	Passed	0.5500	Passed
Cole Harbour District High School	GN WR tap across from learning centre	MXH640	0.0000	Passed	0.7000	Passed
Cole Harbour District High School	Fountain by room 208	MXH641	0.0000	Passed	0.3200	Passed
Cole Harbour District High School	Staff WR tap by room 208	MXH642	0.0035	Passed	0.0710	Passed
Cole Harbour District High School	Staff Room 208 tap	NMD824	0.0004	Passed	0.0150	Passed
Cole Harbour District High School	Boys WR tap 1 by cafeteria	MXH644	0.0079	Exceeds Limit	0.1900	Passed
Cole Harbour District High School	Boys WR tap 2 by cafeteria	MXH645	0.0010	Passed	0.1100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cole Harbour District High School	Boys WR tap 3 by cafeteria	MXH646	0.0022	Passed	0.0950	Passed
Cole Harbour District High School	JC tap by WR's	MXH647	0.0008	Passed	0.0450	Passed
Cole Harbour District High School	Girls WR tap 1 by JC	MXH648	0.0045	Passed	0.1900	Passed
Cole Harbour District High School	Girls WR tap 2 by JC	MXH649	0.0024	Passed	0.1200	Passed
Cole Harbour District High School	Girls WR tap 3 by JC	MXH650	0.0095	Exceeds Limit	0.2100	Passed
Cole Harbour District High School	Student Services GN WR tap	MXH651	0.0000	Passed	0.5600	Passed
Cole Harbour District High School	Cafeteria/Kitchen handwashing tap	MXH652	0.0000	Passed	0.4200	Passed
Cole Harbour District High School	Cafeteria/kitchen triple compartment sink tap	NMD825	0.0004	Passed	0.0150	Passed
Cole Harbour District High School	Cafeteria/kitchen single compartment sink tap	MXH654	0.0008	Passed	0.3900	Passed
Cole Harbour District High School	Male locker room tap 1	MXH655	0.0110	Exceeds Limit	0.2200	Passed
Cole Harbour District High School	Male locker room tap 2	MXH656	0.0000	Passed	0.7900	Passed
Cole Harbour District High School	Male locker room tap 3	MXH657	0.0008	Passed	0.7800	Passed
Cole Harbour District High School	Male locker room tap 4	MXH658	0.0000	Passed	0.8200	Passed
Cole Harbour District High School	Student Services GN WR tap	MXH659	0.0017	Passed	0.8000	Passed
Cole Harbour District High School	Female locker room tap 1	MXH660	0.0000	Passed	0.6200	Passed
Cole Harbour District High School	Female locker room tap 2	MXH661	0.0006	Passed	0.6200	Passed
Cole Harbour District High School	Female locker room tap 3	MXH662	0.0000	Passed	0.4900	Passed
Cole Harbour District High School	Female locker room tap 4	MXH663	0.0000	Passed	0.4100	Passed
Cole Harbour District High School	Air handler room tap	MXH664	0.0000	Passed	0.3300	Passed
Cole Harbour District High School	Fountain by gym door	MXH665	0.0000	Passed	0.7600	Passed
Cole Harbour District High School	Fountain in skilled trades room	MXH666	0.0000	Passed	1.6000	Passed
Cole Harbour District High School	Staff WR tap in main office	MXH667	0.0006	Passed	0.3700	Passed
Cole Harbour District High School	JC tap in Mech. Room	MXH668	0.0052	Exceeds Limit	0.3500	Passed
Cole Harbour District High School	Science lab tap 1 room 120	MXH669	0.0056	Exceeds Limit	0.1100	Passed
Cole Harbour District High School	Science lab tap 2 room 120	MXH670	0.3700	Exceeds Limit	1.7000	Passed
Cole Harbour District High School	Science lab tap 3 room 120	MXH671	0.0130	Exceeds Limit	0.8500	Passed
Cole Harbour District High School	Science lab tap 4 room 120	MXH672	0.0800	Exceeds Limit	0.6500	Passed
Cole Harbour District High School	Science lab tap 5 room 120	MXH673	0.0360	Exceeds Limit	1.1000	Passed
Cole Harbour District High School	Science lab tap 6 room 120	MXH674	0.1000	Exceeds Limit	0.9400	Passed
Cole Harbour District High School	Science lab tap 7 room 120	MXH675	0.0160	Exceeds Limit	0.7400	Passed
Cole Harbour District High School	Science lab tap 8 room 120	MXH676	0.0260	Exceeds Limit	0.9200	Passed
Cole Harbour District High School	Lab sink between room 120 and 119	MXH677	0.0140	Exceeds Limit	1.1000	Passed
Cole Harbour District High School	Science lab tap 1 room 119	MXH678	0.0071	Exceeds Limit	0.5600	Passed
Cole Harbour District High School	Science lab tap 2 room 119	MXH679	0.0660	Exceeds Limit	0.7400	Passed
Cole Harbour District High School	Science lab tap 3 room 119	MXH680	0.2200	Exceeds Limit	0.4700	Passed
Cole Harbour District High School	Science lab tap 4 room 119	MXH681	0.1200	Exceeds Limit	0.5000	Passed
Cole Harbour District High School	Science lab tap 5 room 119	MXH682	0.0670	Exceeds Limit	0.7200	Passed
Cole Harbour District High School	Science lab tap 6 room 119	MXH683	0.0066	Exceeds Limit	0.3900	Passed
Cole Harbour District High School	Science lab tap 7 room 119	MXH684	0.0300	Exceeds Limit	0.8500	Passed
Cole Harbour District High School	CR tap room 118	NMD841	0.0004	Passed	0.0040	Passed
Cole Harbour District High School	Girls WR tap 1 by room 108	MXH686	0.0200	Exceeds Limit	0.2000	Passed
Cole Harbour District High School	Girls WR tap 2 by room 108	MXH687	0.0036	Passed	0.1600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cole Harbour District High School	Staff WR tap between WR's	MXH688	0.0052	Exceeds Limit	0.2500	Passed
Cole Harbour District High School	Boys WR tap 1 by room 108	MXH689	0.0022	Passed	0.0950	Passed
Cole Harbour District High School	Boys WR tap 2 by room 108	MXH690	0.0120	Exceeds Limit	0.1800	Passed
Cole Harbour District High School	CR tap room 117	NMD829	0.0004	Passed	0.0260	Passed
Cole Harbour District High School	JC tap by room 117	MXH692	0.0280	Exceeds Limit	0.2200	Passed
Cole Harbour District High School	Fountain by JC	MXH693	0.0000	Passed	0.6600	Passed
Cole Harbour District High School	GN WR tap room 116	MXH694	0.0030	Passed	0.3600	Passed
Cole Harbour District High School	CR tap room 116	NMD828	0.0060	Exceeds Limit	0.0560	Passed
Cole Harbour District High School	Science lab tap 1 room 115	MXH696	0.0940	Exceeds Limit	0.8200	Passed
Cole Harbour District High School	Science lab tap 2 room 115	MXH697	0.0610	Exceeds Limit	0.3200	Passed
Cole Harbour District High School	Science lab tap 3 room 115	MXH698	0.0300	Exceeds Limit	0.7900	Passed
Cole Harbour District High School	Science lab tap 4 room 115	MXH699	0.0930	Exceeds Limit	0.5600	Passed
Cole Harbour District High School	Science lab tap 1 room 114	MXH700	0.0520	Exceeds Limit	2.4000	Exceeds Limit
Cole Harbour District High School	Science lab tap 2 room 114	MXH701	0.0170	Exceeds Limit	1.5000	Passed
Cole Harbour District High School	Science lab tap 3 room 114	MXH702	0.0074	Exceeds Limit	1.3000	Passed
Cole Harbour District High School	Science lab tap 4 room 114	MXH703	0.0097	Exceeds Limit	0.1600	Passed
Cole Harbour District High School	Science lab tap 1 room 113	MXH704	0.0830	Exceeds Limit	0.7500	Passed
Cole Harbour District High School	Science lab tap 2 room 113	MXH705	0.0110	Exceeds Limit	1.1000	Passed
Cole Harbour District High School	Science lab tap 3 room 113	MXH706	1.1000	Exceeds Limit	0.5200	Passed
Cole Harbour District High School	JC tap room 112	MXH707	0.0150	Exceeds Limit	1.0000	Passed
Cole Harbour District High School	CR tap 1 room 109	NMD826	0.0073	Exceeds Limit	0.0460	Passed
Cole Harbour District High School	CR tap 2 room 109	NMD827	0.0065	Exceeds Limit	0.0210	Passed
Colonel John Stuart Elementary School	Fountain by fire panel	MWG652	0.0027	Passed	0.5200	Passed
Colonel John Stuart Elementary School	WR by gym	MWG653	0.0009	Passed	0.1700	Passed
Colonel John Stuart Elementary School	Bar sink tap room 102	NMD726	0.0011	Passed	0.1700	Passed
Colonel John Stuart Elementary School	Kitchen sink tap room 102	MWG655	0.0012	Passed	0.2900	Passed
Colonel John Stuart Elementary School	Staff room WR 1 tap	MWG656	0.0014	Passed	0.0510	Passed
Colonel John Stuart Elementary School	Staff room WR 2 tap	MWG657	0.0016	Passed	0.0840	Passed
Colonel John Stuart Elementary School	Staff room kitchen sink	MWG658	0.0046	Passed	0.1300	Passed
Colonel John Stuart Elementary School	Laundry tub tap across from room 113	MWG659	0.0010	Passed	0.1000	Passed
Colonel John Stuart Elementary School	Girls WR tap 1 by fountain	MWG660	0.0042	Passed	0.0990	Passed
Colonel John Stuart Elementary School	Girls WR tap 2 by fountain	MWG661	0.0038	Passed	0.0670	Passed
Colonel John Stuart Elementary School	Girls WR tap 3 by fountain	MWG662	0.0028	Passed	0.0540	Passed
Colonel John Stuart Elementary School	Girls WR tap 4 by fountain	MWG663	0.0044	Passed	0.0880	Passed
Colonel John Stuart Elementary School	Fountain in between WR's	MWG664	0.0035	Passed	0.7300	Passed
Colonel John Stuart Elementary School	Boys WR tap 1 beside fountain	MWG665	0.0032	Passed	0.1700	Passed
Colonel John Stuart Elementary School	Boys WR tap 2 beside fountain	MWG666	0.0031	Passed	0.1100	Passed
Colonel John Stuart Elementary School	Boys WR tap 3 beside fountain	MWG667	0.0042	Passed	0.0930	Passed
Colonel John Stuart Elementary School	CR tap room 101	NMD725	0.0013	Passed	0.1600	Passed
Crichton Park Elementary School	CR tap room 107	MYR663	0.0007	Passed	0.2800	Passed
Crichton Park Elementary School	Girls WR tap 1 room 109	MYR664	0.0051	Exceeds Limit	0.1900	Passed
Crichton Park Elementary School	Girls WR tap 2 room 109	MYR665	0.0013	Passed	0.0790	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Crichton Park Elementary School	Girls WR tap 3 room 109	MYR666	0.0032	Passed	0.1800	Passed
Crichton Park Elementary School	Girls WR tap 4 room 109	MYR667	0.0020	Passed	0.1100	Passed
Crichton Park Elementary School	Fountain by room 110	MYR668	0.0000	Passed	0.3300	Passed
Crichton Park Elementary School	Boys WR tap 1 room 111	MYR669	0.0150	Exceeds Limit	0.2400	Passed
Crichton Park Elementary School	JC tap in boys WR (111)	MYR670	0.0290	Exceeds Limit	0.3900	Passed
Crichton Park Elementary School	Boys WR tap 2 room 111	MYR671	0.0093	Exceeds Limit	0.0930	Passed
Crichton Park Elementary School	Boys WR tap 3 room 111	MYR672	0.0000	Passed	0.0080	Passed
Crichton Park Elementary School	JC tap in boiler room	MYR673	0.0005	Passed	0.0170	Passed
Crichton Park Elementary School	CR tap room 125	MYR674	0.0170	Exceeds Limit	0.3400	Passed
Crichton Park Elementary School	CR tap room 126	MYR675	0.0120	Exceeds Limit	0.2500	Passed
Crichton Park Elementary School	Boys WR tap 1 room 204	MYR676	0.0064	Exceeds Limit	0.1200	Passed
Crichton Park Elementary School	Boys WR tap 2 room 204	MYR677	0.0011	Passed	0.0150	Passed
Crichton Park Elementary School	JC tap room 205	MYR678	0.0160	Exceeds Limit	0.1500	Passed
Crichton Park Elementary School	Girls WR tap 1 room 206	MYR679	0.0063	Exceeds Limit	0.0430	Passed
Crichton Park Elementary School	Girls WR tap 2 room 206	MYR680	0.0059	Exceeds Limit	0.0750	Passed
Crichton Park Elementary School	CR tap room 208	MYR681	0.0800	Exceeds Limit	0.8800	Passed
Crichton Park Elementary School	Staff WR tap room 203	MYR682	0.0089	Exceeds Limit	0.2300	Passed
Crichton Park Elementary School	Fountain by room 201	NMK054	0.0026	Passed	0.0440	Passed
Crichton Park Elementary School	CR tap room 203	MYR684	0.0160	Exceeds Limit	0.1900	Passed
Crichton Park Elementary School	Boys WR tap room 122	MYR685	0.0310	Exceeds Limit	0.1300	Passed
Crichton Park Elementary School	Fountain by room 121	MYR686	0.0000	Passed	0.2400	Passed
Crichton Park Elementary School	JC tap room 121	MYR687	0.0047	Passed	0.0640	Passed
Crichton Park Elementary School	Girls WR tap room 120	MYR705	0.0000	Passed	0.0082	Passed
Crichton Park Elementary School	CR WR tap room 101	MYR706	0.0830	Exceeds Limit	0.3800	Passed
Crichton Park Elementary School	CR WR tap room 102	MYR707	0.0320	Exceeds Limit	0.2800	Passed
Crichton Park Elementary School	CR WR tap room 103	MYR708	0.0120	Exceeds Limit	0.2300	Passed
Cunard Junior High School	Boys WR tap 1 room 209	MRE108	0.0016	Passed	0.1700	Passed
Cunard Junior High School	Boys WR tap 2 room 209	MRE109	0.0008	Passed	0.0900	Passed
Cunard Junior High School	Boys WR tap 3 room 209	MRE110	0.0007	Passed	0.0680	Passed
Cunard Junior High School	Boys WR tap 4 room 209	MRE111	0.0006	Passed	0.0630	Passed
Cunard Junior High School	JC tap room 209	MRE112	0.0000	Passed	0.0190	Passed
Cunard Junior High School	Fountain by room 211	MRE113	0.0029	Passed	0.2600	Passed
Cunard Junior High School	Girls WR tap 1 room 211	MRE114	0.0000	Passed	0.0760	Passed
Cunard Junior High School	Girls WR tap 2 room 211	MRE115	0.0008	Passed	0.0470	Passed
Cunard Junior High School	Girls WR tap 3 room 211	MRE116	0.0000	Passed	0.0550	Passed
Cunard Junior High School	Girls WR tap 4 room 211	MRE117	0.0000	Passed	0.0390	Passed
Cunard Junior High School	Family studies tap 1 room 212	MRE118	0.0023	Passed	0.0450	Passed
Cunard Junior High School	Family studies tap 2 room 212	MRE119	0.0014	Passed	0.0530	Passed
Cunard Junior High School	Family studies tap 3 room 212	MRE120	0.0000	Passed	0.0140	Passed
Cunard Junior High School	Guidance room tap room 215	MRE121	0.0028	Passed	0.0520	Passed
Cunard Junior High School	GN WR tap room 216	MRE122	0.0000	Passed	0.0300	Passed
Cunard Junior High School	Staff room tap room 200	NKX299	0.0004	Passed	0.0040	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Cunard Junior High School	CR tap room 106	NKX298	0.0004	Passed	0.0041	Passed
Cunard Junior High School	Boys WR tap 1 room 107	MRE125	0.0093	Exceeds Limit	0.1600	Passed
Cunard Junior High School	Boys WR tap 2 room 107	MRE126	0.0012	Passed	0.0560	Passed
Cunard Junior High School	Boys WR tap 3 room 107	MRE127	0.0000	Passed	0.0220	Passed
Cunard Junior High School	Boys WR tap 4 room 107	MRE136	0.0009	Passed	0.0300	Passed
Cunard Junior High School	JC tap room 108	MRE137	0.0033	Passed	0.0810	Passed
Cunard Junior High School	Fountain by room 108	MRE138	0.0000	Passed	0.0960	Passed
Cunard Junior High School	Girls WR tap 1 room 109	MRE139	0.0240	Exceeds Limit	0.1800	Passed
Cunard Junior High School	Girls WR tap 2 room 109	MRE140	0.0028	Passed	0.0390	Passed
Cunard Junior High School	Girls WR tap 3 room 109	MRE141	0.0039	Passed	0.0350	Passed
Cunard Junior High School	Girls WR tap 4 room 109	MRE142	0.0055	Exceeds Limit	0.1300	Passed
Cunard Junior High School	CR tap room 112	MRE143	0.0180	Exceeds Limit	0.9400	Passed
Cunard Junior High School	CR tap room 113	MRE144	0.0025	Passed	0.3200	Passed
Cunard Junior High School	Main office WR tap	MRE145	0.0000	Passed	0.0190	Passed
Dartmouth High School	Main office WR tap	MYV801	0.0000	Passed	0.1300	Passed
Dartmouth High School	Fountain by office	MYV802	0.0000	Passed	0.3900	Passed
Dartmouth High School	GN WR tap in health centre	MYV803	0.0005	Passed	0.9100	Passed
Dartmouth High School	Fountain by health centre	MYV804	0.0000	Passed	0.0400	Passed
Dartmouth High School	Boys WR tap 1 before gym	MYV805	0.0010	Passed	0.0260	Passed
Dartmouth High School	Boys WR tap 2 before gym	MYV806	0.0009	Passed	0.0320	Passed
Dartmouth High School	Girls WR tap 1 before gym	MYV807	0.0015	Passed	0.0390	Passed
Dartmouth High School	Girls WR tap 1 before gym	MYV808	0.0014	Passed	0.0470	Passed
Dartmouth High School	Girls locker room tap 1 room 164	MYV809	0.0010	Passed	0.0310	Passed
Dartmouth High School	Girls locker room tap 2 room 164	MYV810	0.0006	Passed	0.0980	Passed
Dartmouth High School	Gym office WR tap room 162	MYV811	0.0000	Passed	0.6300	Passed
Dartmouth High School	Boys locker room tap 1 room 166	MYV812	0.0008	Passed	0.0160	Passed
Dartmouth High School	Female Change room tap 1 room 165	MYV815	0.0000	Passed	0.2900	Passed
Dartmouth High School	Female Change room tap 1 room 165	MYV816	0.0000	Passed	0.3600	Passed
Dartmouth High School	WR tap in water room 170	MYV817	0.0120	Exceeds Limit	0.6000	Passed
Dartmouth High School	Chem lab tap 1 room 106	MYV818	0.0500	Exceeds Limit	0.4200	Passed
Dartmouth High School	Chem lab tap 2 room 106	MYV819	0.0008	Passed	0.0280	Passed
Dartmouth High School	Chem lab tap 3 room 106	MYV820	0.0024	Passed	0.2800	Passed
Dartmouth High School	Chem lab tap 4 room 106	MYV821	0.0006	Passed	0.3800	Passed
Dartmouth High School	Chem lab tap 5 room 106	MYV822	0.0006	Passed	0.3900	Passed
Dartmouth High School	Chem lab tap 6 room 106	MYV823	0.0012	Passed	0.0890	Passed
Dartmouth High School	Chem lab tap 7 room 106	MYV824	0.0009	Passed	0.1700	Passed
Dartmouth High School	Chem lab tap 8 room 106	MYV825	0.0009	Passed	0.2500	Passed
Dartmouth High School	Chem lab tap 9 room 106	MYV826	0.0008	Passed	0.1700	Passed
Dartmouth High School	Physics lab tap 1 by room 106	MYV827	0.0072	Exceeds Limit	0.2800	Passed
Dartmouth High School	Physics lab tap 2 by room 106	MYV828	0.3800	Exceeds Limit	0.9700	Passed
Dartmouth High School	WR tap in physics lab	MYV829	0.0940	Exceeds Limit	0.9700	Passed
Dartmouth High School	Fountain near physics lab	NMV158	0.0004	Passed	0.0290	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dartmouth High School	Boys WR tap 1 near room 106	MYV831	0.0380	Exceeds Limit	1.3000	Passed
Dartmouth High School	Boys WR tap 2 near room 106	MYV832	0.5500	Exceeds Limit	3.1000	Exceeds Limit
Dartmouth High School	Boys WR tap 3 near room 106	MYV833	2.2000	Exceeds Limit	1.1000	Passed
Dartmouth High School	JC tap near room 106	MYV834	0.0013	Passed	0.0880	Passed
Dartmouth High School	Girls WR tap 1 near room 106	MYV835	0.0690	Exceeds Limit	0.4300	Passed
Dartmouth High School	Girls WR tap 2 near room 106	MYV836	0.0730	Exceeds Limit	0.4200	Passed
Dartmouth High School	Girls WR tap 3 near room 106	MYV837	0.1300	Exceeds Limit	0.7200	Passed
Dartmouth High School	CR tap room 112	MYV838	1.7000	Exceeds Limit	18.0000	Exceeds Limit
Dartmouth High School	CR tap 1 room 116	MYV839	0.2800	Exceeds Limit	0.6100	Passed
Dartmouth High School	CR tap 2 room 116	MYV840	0.0049	Passed	0.1500	Passed
Dartmouth High School	CR tap 3 room 116	MYV841	0.1400	Exceeds Limit	0.2000	Passed
Dartmouth High School	CR tap 4 room 116	MYV842	0.0430	Exceeds Limit	0.2000	Passed
Dartmouth High School	Fountain by room 116	MYV843	0.0000	Passed	0.5900	Passed
Dartmouth High School	Girls WR tap 1 by room 116	MYV844	0.0015	Passed	1.6000	Passed
Dartmouth High School	Girls WR tap 2 by room 116	MYV845	0.0007	Passed	0.3100	Passed
Dartmouth High School	Girls WR tap 3 by room 116	MYV846	0.0006	Passed	0.1800	Passed
Dartmouth High School	Girls WR tap 4 by room 116	MYV847	0.0005	Passed	0.2100	Passed
Dartmouth High School	JC tap by room 116	MYV848	0.0000	Passed	1.1000	Passed
Dartmouth High School	Boys WR tap 1 by room 116	MYV849	0.0000	Passed	0.1900	Passed
Dartmouth High School	Boys WR tap 2 by room 116	MYV850	0.0130	Exceeds Limit	0.7100	Passed
Dartmouth High School	Boys WR tap 3 by room 116	MYV851	0.0017	Passed	0.5300	Passed
Dartmouth High School	Boys WR tap 4 by room 116	MYV852	0.0025	Passed	0.1300	Passed
Dartmouth High School	Learning centre tap 1	MYV853	0.0000	Passed	0.5600	Passed
Dartmouth High School	Learning centre tap 2	MYV854	0.0000	Passed	0.4000	Passed
Dartmouth High School	Boys WR tap 1 after library	MYV855	0.0010	Passed	0.0750	Passed
Dartmouth High School	Boys WR tap 2 after library	MYV856	0.0000	Passed	0.1100	Passed
Dartmouth High School	Fountain between WR's	MYV857	0.0000	Passed	0.9900	Passed
Dartmouth High School	Girls WR tap 1 after library	MYV858	0.0009	Passed	0.0940	Passed
Dartmouth High School	Girls WR tap 2 after library	MYV859	0.0006	Passed	0.2700	Passed
Dartmouth High School	Music room tap room 125	MYV860	0.0000	Passed	0.0620	Passed
Dartmouth High School	Staff room WR #1 tap	MYV861	0.0220	Exceeds Limit	0.2800	Passed
Dartmouth High School	Staff room WR #2 tap	MYV862	0.3300	Exceeds Limit	1.5000	Passed
Dartmouth High School	JC tap by staff room	MYV863	0.0026	Passed	0.0820	Passed
Dartmouth High School	Family studies tap 2	MYV864	0.0076	Exceeds Limit	0.3800	Passed
Dartmouth High School	Family studies tap 3	MYV865	0.0130	Exceeds Limit	0.4300	Passed
Dartmouth High School	Family studies tap 4	MYV866	0.0140	Exceeds Limit	5.3000	Exceeds Limit
Dartmouth High School	Family studies tap 5	MYV867	0.0550	Exceeds Limit	0.6500	Passed
Dartmouth High School	CR tap 2 room 120	MYV870	0.0010	Passed	0.1300	Passed
Dartmouth High School	CR tap 2 room 120	MYV871	0.0008	Passed	0.1300	Passed
Dartmouth High School	Tech ed room tap	MYV872	0.0005	Passed	1.7000	Passed
Dartmouth High School	Cafeteria/Kitchen tap 1	NMV159	0.0004	Passed	0.0200	Passed
Dartmouth High School	Cafeteria/Kitchen tap 2	NMV160	0.0004	Passed	0.0220	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dartmouth High School	Cafeteria/Kitchen tap 3	NMV161	0.0004	Passed	0.0340	Passed
Dartmouth High School	2nd floor fountain before room 251	MYV876	0.0052	Exceeds Limit	0.3500	Passed
Dartmouth High School	Tap in air handling room 251	MYV877	0.0340	Exceeds Limit	0.0310	Passed
Dartmouth High School	Staff WR sink tap before room 213	MYV878	0.0062	Exceeds Limit	0.1500	Passed
Dartmouth High School	Biology lab tap 1 room 213	MYV879	0.0120	Exceeds Limit	0.5100	Passed
Dartmouth High School	Biology lab tap 2 room 213	MYV880	0.0072	Exceeds Limit	0.1900	Passed
Dartmouth High School	Biology lab tap 3 room 213	MYV881	0.0076	Exceeds Limit	0.1500	Passed
Dartmouth High School	Biology lab tap 4 room 213	MYV882	0.6500	Exceeds Limit	0.2300	Passed
Dartmouth High School	Biology lab tap 5 room 213	MYV883	0.0420	Exceeds Limit	0.3300	Passed
Dartmouth High School	CR tap room 213A	MYV884	0.1700	Exceeds Limit	0.5400	Passed
Dartmouth High School	Boys WR tap 1 by room 213	MYV885	0.0120	Exceeds Limit	0.1300	Passed
Dartmouth High School	Boys WR tap 2 by room 213	MYV886	0.0027	Passed	0.1100	Passed
Dartmouth High School	Boys WR tap 3 by room 213	MYV887	0.0023	Passed	0.1100	Passed
Dartmouth High School	JC tap by room 213	MYV888	0.0170	Exceeds Limit	0.4700	Passed
Dartmouth High School	Girls WR tap 1 by room 213	MYV889	0.0093	Exceeds Limit	0.2000	Passed
Dartmouth High School	Girls WR tap 2 by room 213	MYV890	0.0045	Passed	0.1200	Passed
Dartmouth High School	Girls WR tap 3 by room 213	MYV891	0.0043	Passed	0.1100	Passed
Dartmouth High School	Girls WR tap 4 by room 213	MYV892	0.0040	Passed	0.1100	Passed
Dartmouth High School	Art room tap room 222	MYV893	0.0130	Exceeds Limit	0.2900	Passed
Dartmouth High School	CR tap 1 room 223	MYV894	0.0017	Passed	0.2000	Passed
Dartmouth High School	CR tap 2 room 223	MYV895	0.0011	Passed	0.4600	Passed
Dartmouth High School	Music storage tap room 201	MYV896	0.4600	Exceeds Limit	3.4000	Exceeds Limit
Dartmouth High School	Fountain by room 2017	MYV897	0.0000	Passed	0.5800	Passed
Dartmouth High School	Girls WR tap 1 by room 201	MYV898	0.0005	Passed	0.3200	Passed
Dartmouth High School	Girls WR tap 2 by room 201	MYV899	0.0150	Exceeds Limit	1.4000	Passed
Dartmouth High School	Fountain by room 201	MYV900	0.0000	Passed	0.3400	Passed
Dartmouth High School	Girls WR tap 1 Near room 201	MYV901	0.0038	Passed	1.2000	Passed
Dartmouth High School	Girls WR tap 2 Near room 201	MYV902	0.0052	Exceeds Limit	1.5000	Passed
Dartmouth High School	Girls WR tap 3 Near room 201	MYV903	0.0022	Passed	0.3300	Passed
Dartmouth High School	Girls WR tap 4 Near room 201	MYV904	0.0008	Passed	0.1500	Passed
Dartmouth High School	JC tap by girls WR	MYV905	0.0058	Exceeds Limit	0.2600	Passed
Dartmouth High School	Boys WR tap 1 before 2nd floor staff room	MYV906	0.0022	Passed	1.6000	Passed
Dartmouth High School	Boys WR tap 2 before 2nd floor staff room	MYV907	0.0009	Passed	0.6400	Passed
Dartmouth High School	Boys WR tap 3 before 2nd floor staff room	MYV908	0.0012	Passed	0.5100	Passed
Dartmouth High School	Boys WR tap 4 before 2nd floor staff room	MYV909	0.0007	Passed	0.5600	Passed
Dartmouth High School	2nd floor staff room tap 1	MYV910	0.0000	Passed	0.1700	Passed
Dartmouth High School	2nd floor staff room tap 2	MYV911	0.0023	Passed	0.1900	Passed
Dartmouth High School	2nd floor staff room tap 3	MYV912	0.0011	Passed	0.1200	Passed
Dartmouth High School	Boys locker room tap 2 room 166	NAI301	0.0000	Passed	0.2000	Passed
Dartmouth High School	Gym office WR tap room 161	NAI329	0.0032	Passed	0.6500	Passed
Dartmouth High School	Family studies tap 1	NAI330	0.0061	Exceeds Limit	0.2800	Passed
Dartmouth High School	CR tap 2 room 120	NAI331	0.0054	Exceeds Limit	0.2400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dartmouth South Academy	Main office WR tap	MYV778	0.0000	Passed	0.5100	Passed
Dartmouth South Academy	GN WR tap room 140	MYV779	0.0000	Passed	0.0850	Passed
Dartmouth South Academy	GN WR tap 1 room 142	MYV780	0.0006	Passed	0.1100	Passed
Dartmouth South Academy	GN WR tap 2 room 142	MYV781	0.0008	Passed	0.0940	Passed
Dartmouth South Academy	CR WR tap 1 room 148	MYV782	0.0000	Passed	0.0880	Passed
Dartmouth South Academy	CR WR tap 2 room 148	MYV783	0.0006	Passed	0.1200	Passed
Dartmouth South Academy	CR tap room 148	MYV784	0.0000	Passed	0.1600	Passed
Dartmouth South Academy	CR tap room 150	MYV785	0.0000	Passed	0.0480	Passed
Dartmouth South Academy	CR tap room 152	MYV786	0.0000	Passed	0.1200	Passed
Dartmouth South Academy	CR tap room 155	MYV787	0.0000	Passed	0.2400	Passed
Dartmouth South Academy	CR tap room 153	MYV788	0.0006	Passed	0.2400	Passed
Dartmouth South Academy	CR tap room 151	MYV789	0.0000	Passed	0.3400	Passed
Dartmouth South Academy	Learning centre tap 1 room 145	MYV791	0.0000	Passed	0.1200	Passed
Dartmouth South Academy	Learning centre tap 2 room 145	MYV792	0.0000	Passed	0.2000	Passed
Dartmouth South Academy	Learning centre WR tap room 145	MYV793	0.0000	Passed	0.0790	Passed
Dartmouth South Academy	JC tap room 141	MYV794	0.0016	Passed	0.0890	Passed
Dartmouth South Academy	Fountain left of room 135	MYV795	0.0000	Passed	1.1000	Passed
Dartmouth South Academy	Gym change room WR tap room 133DB	MYV797	0.0014	Passed	0.2900	Passed
Dartmouth South Academy	Gym change room tap room 133DN	MYV798	0.0010	Passed	0.1400	Passed
Dartmouth South Academy	Gym change room tap room 133DA	MYV799	0.0010	Passed	0.1800	Passed
Dartmouth South Academy	Music room tap 1 room 131	MYV800	0.0000	Passed	0.2000	Passed
Dartmouth South Academy	Music room tap 2 room 131	NAI150	0.0000	Passed	0.0830	Passed
Dartmouth South Academy	Library tap room 102	NAI151	0.0000	Passed	0.0840	Passed
Dartmouth South Academy	GN WR tap room 106E	NAI152	0.0018	Passed	0.1100	Passed
Dartmouth South Academy	GN WR tap room 106D	NAI153	0.0000	Passed	0.0600	Passed
Dartmouth South Academy	GN WR tap room 106C	NAI154	0.0005	Passed	0.0770	Passed
Dartmouth South Academy	GN WR tap room 106B	NAI155	0.0000	Passed	0.0690	Passed
Dartmouth South Academy	GN WR tap room 106A	NAI156	0.0000	Passed	0.0520	Passed
Dartmouth South Academy	Fountain left of room 110A	NAI157	0.0000	Passed	1.8000	Passed
Dartmouth South Academy	Tech ed room tap room 108	NAI158	0.0000	Passed	0.1600	Passed
Dartmouth South Academy	JC tap room 112	NAI159	0.0000	Passed	0.1400	Passed
Dartmouth South Academy	Innovation lab tap room 114	NAI163	0.0000	Passed	1.6000	Passed
Dartmouth South Academy	Youth health room tap room 107	NAI164	0.0007	Passed	0.5200	Passed
Dartmouth South Academy	Recycle room tap room 101A	NAI165	0.0000	Passed	0.7400	Passed
Dartmouth South Academy	Kitchen tap 1 room 103A	NAI166	0.0000	Passed	0.6400	Passed
Dartmouth South Academy	Kitchen tap 2 room 103A	NAI167	0.0011	Passed	0.1800	Passed
Dartmouth South Academy	JC tap room 103B (off kitchen)	NAI168	0.0000	Passed	0.3800	Passed
Dartmouth South Academy	Staff room kitchen tap room 204	NAI169	0.0000	Passed	0.0750	Passed
Dartmouth South Academy	Staff room WR tap room 204A	NAI170	0.0017	Passed	0.1400	Passed
Dartmouth South Academy	Staff room WR tap room 204B	NAI171	0.0008	Passed	0.0720	Passed
Dartmouth South Academy	Fountain right of room 204	NAI172	0.0000	Passed	1.3000	Passed
Dartmouth South Academy	GN WR tap room 206E	NAI174	0.0009	Passed	0.0500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dartmouth South Academy	GN WR tap room 206D	NAI175	0.0024	Passed	0.0710	Passed
Dartmouth South Academy	GN WR tap room 206C	NAI176	0.0012	Passed	0.1000	Passed
Dartmouth South Academy	GN WR tap room 206B	NAI177	0.0010	Passed	0.0700	Passed
Dartmouth South Academy	GN WR tap room 206A	NAI178	0.0000	Passed	0.0800	Passed
Dartmouth South Academy	Family Studies tap 1 room 208	NAI179	0.0000	Passed	0.0900	Passed
Dartmouth South Academy	Family Studies tap 2 room 208	NAI180	0.0000	Passed	0.0870	Passed
Dartmouth South Academy	Family Studies tap 3 room 208	NAI181	0.0016	Passed	0.3900	Passed
Dartmouth South Academy	Family Studies tap 4 room 208	NAI182	0.0000	Passed	0.7200	Passed
Dartmouth South Academy	Family Studies tap 5 room 208	NAI183	0.0000	Passed	0.7700	Passed
Dartmouth South Academy	JC tap room 214	NAI190	0.0000	Passed	0.2100	Passed
Dartmouth South Academy	Art room tap 1 room 230	NAI191	0.0016	Passed	0.1600	Passed
Dartmouth South Academy	Art room tap 2 room 230	NAI192	0.0010	Passed	0.1100	Passed
Dartmouth South Academy	Art room tap 3 room 230	NAI193	0.0000	Passed	0.8400	Passed
Dartmouth South Academy	GN WR tap room 236	NAI194	0.0005	Passed	0.0700	Passed
Dartmouth South Academy	GN WR tap 1 room 238	NAI195	0.0014	Passed	0.1100	Passed
Dartmouth South Academy	GN WR tap 2 room 238	NAI196	0.0006	Passed	0.2100	Passed
Dartmouth South Academy	CR tap room 244	NAI197	0.0000	Passed	0.3900	Passed
Dartmouth South Academy	CR tap room 251	NAI199	0.0000	Passed	0.4800	Passed
Dartmouth South Academy	CR tap room 247	NAI200	0.0023	Passed	1.2000	Passed
Dartmouth South Academy	CR tap room 245	NAI206	0.0000	Passed	0.4500	Passed
Dartmouth South Academy	CR tap room 241	NAI207	0.0000	Passed	0.0700	Passed
Dartmouth South Academy	Learning centre WR tap room 239	NAI208	0.0020	Passed	0.0530	Passed
Dartmouth South Academy	JC tap room 231	NAI209	0.0000	Passed	0.0370	Passed
Dartmouth South Academy	Fountain right of room 231	NAI210	0.0000	Passed	1.5000	Passed
Dartmouth South Academy	CR tap room 149	NAI211	0.0000	Passed	0.2600	Passed
Dartmouth South Academy	Gym change room tap room 133DN	NAI212	0.0000	Passed	1.2000	Passed
Duc d'Anville Elementary School	CR tap room 230	MRM311	0.0018	Passed	0.0670	Passed
Duc d'Anville Elementary School	Boys WR tap 1 by room 230	MRM312	0.0000	Passed	0.0140	Passed
Duc d'Anville Elementary School	Boys WR tap 2 by room 230	MRM313	0.0012	Passed	0.0170	Passed
Duc d'Anville Elementary School	Boys WR tap 3 by room 230	MRM314	0.0007	Passed	0.0220	Passed
Duc d'Anville Elementary School	Boys WR tap 4 by room 230	MRM315	0.0005	Passed	0.0250	Passed
Duc d'Anville Elementary School	Caretaker room tap in boys WR	MRM316	0.0670	Exceeds Limit	0.0740	Passed
Duc d'Anville Elementary School	Fountain between boys and girls WR	NJI652	0.0120	Exceeds Limit	0.0470	Passed
Duc d'Anville Elementary School	Girls WR tap 1 room 250	MRM318	0.0011	Passed	0.0690	Passed
Duc d'Anville Elementary School	Girls WR tap 2 room 250	MRM319	0.0000	Passed	0.0150	Passed
Duc d'Anville Elementary School	Girls WR tap 3 room 250	MRM320	0.0000	Passed	0.0095	Passed
Duc d'Anville Elementary School	Girls WR tap 4 room 250	MRM328	0.0000	Passed	0.0120	Passed
Duc d'Anville Elementary School	Staff room WR tap room 260	MRM329	0.0011	Passed	0.0480	Passed
Duc d'Anville Elementary School	Staff room Kitchen tap room 260	MRM330	0.0000	Passed	0.0150	Passed
Duc d'Anville Elementary School	Boys WR tap 1 by room 134	MRM331	0.0008	Passed	0.0780	Passed
Duc d'Anville Elementary School	Boys WR tap 2 by room 134	MRM332	0.0000	Passed	0.0200	Passed
Duc d'Anville Elementary School	Boys WR tap 3 by room 134	MRM333	0.0008	Passed	0.0140	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Duc d'Anville Elementary School	GN WR tap room 146	MRM334	0.0083	Exceeds Limit	0.0370	Passed
Duc d'Anville Elementary School	Fountain by room 146	MRM335	0.0011	Passed	0.0150	Passed
Duc d'Anville Elementary School	Girls WR tap 1 room 150	MRM336	0.0026	Passed	0.1200	Passed
Duc d'Anville Elementary School	Girls WR tap 2 room 150	MRM337	0.0006	Passed	0.0096	Passed
Duc d'Anville Elementary School	Girls WR tap 3 room 150	MRM339	0.0000	Passed	0.0150	Passed
Duc d'Anville Elementary School	Resources Rm WR tap room 326	MRM340	0.0007	Passed	0.0200	Passed
Duc d'Anville Elementary School	JC tap by room 326	MRM341	0.0005	Passed	0.0180	Passed
Duc d'Anville Elementary School	CR tap room 405	MRM342	0.0011	Passed	0.6000	Passed
Duc d'Anville Elementary School	Gym teacher WR tap room 415	MRM343	0.0013	Passed	0.0400	Passed
Duc d'Anville Elementary School	JC tap by room 415	MRM344	0.0010	Passed	0.0230	Passed
Duc d'Anville Elementary School	Boys WR tap 1 room 421	MRM345	0.0006	Passed	0.0390	Passed
Duc d'Anville Elementary School	Boys WR tap 2 room 421	MRM346	0.0014	Passed	0.0650	Passed
Duc d'Anville Elementary School	Girls WR tap 1 room 425	MRM347	0.0000	Passed	0.0180	Passed
Duc d'Anville Elementary School	Girls WR tap 2 room 425	MRM348	0.0006	Passed	0.0180	Passed
Duc d'Anville Elementary School	Fountain by room 320	NJI651	0.0035	Passed	0.0470	Passed
Duc d'Anville Elementary School	CR WR tap room 312	MRM350	0.0038	Passed	0.0700	Passed
Duc d'Anville Elementary School	CR WR tap room 311	MRM351	0.0008	Passed	0.0440	Passed
Duc d'Anville Elementary School	CR WR tap room 306	MRM352	0.0026	Passed	0.0760	Passed
Duc d'Anville Elementary School	CR WR tap room 307	MRM353	0.0007	Passed	0.0510	Passed
Dutch Settlement Elementary School	BOYS W/R 121 TAP	MYZ477	0.0011	Passed	0.3800	Passed
Dutch Settlement Elementary School	JANITORS CLOSET 120 TAP	MYZ478	0.0006	Passed	0.2300	Passed
Dutch Settlement Elementary School	GIRLS W/R 119 TAP 1	MYZ479	0.0021	Passed	0.5000	Passed
Dutch Settlement Elementary School	GIRLS W/R 119 TAP 2	MYZ480	0.0015	Passed	0.2600	Passed
Dutch Settlement Elementary School	STAFF W/R 112A TAP	MYZ481	0.0027	Passed	0.2800	Passed
Dutch Settlement Elementary School	STAFF KITCHEN 112 TAP	MYZ482	0.0005	Passed	0.0990	Passed
Dutch Settlement Elementary School	C/R W/R 109 B TAP	MYZ483	0.0008	Passed	0.2500	Passed
Dutch Settlement Elementary School	JANITORS CLOSET 104 TAP	MYZ484	0.0005	Passed	0.0980	Passed
Dutch Settlement Elementary School	GIRLS W/R 107 TAP 1	MYZ509	0.0051	Exceeds Limit	0.2200	Passed
Dutch Settlement Elementary School	GIRLS W/R 107 TAP 2	MYZ510	0.0000	Passed	0.0570	Passed
Dutch Settlement Elementary School	BOYS W/R 105 TAP #1	MYZ511	0.0006	Passed	0.0680	Passed
Dutch Settlement Elementary School	BOYS W/R 105 TAP #2	MYZ512	0.0019	Passed	0.0540	Passed
Dutch Settlement Elementary School	KITCHEN 103 TAP	MYZ513	0.0020	Passed	0.5800	Passed
Dutch Settlement Elementary School	C/R 102 W/R TAP	MYZ514	0.0018	Passed	0.7000	Passed
Dutch Settlement Elementary School	Gym storage room tap	NCL147	0.0150	Exceeds Limit	0.5800	Passed
Dutch Settlement Elementary School	Gym office WR tap	NCL148	0.0130	Exceeds Limit	1.4000	Passed
East St. Margaret's Elementary School	2nd floor boys WR tap 1	MWH004	0.0210	Exceeds Limit	0.5500	Passed
East St. Margaret's Elementary School	2nd floor boys WR tap 2	MWH005	0.0320	Exceeds Limit	0.8400	Passed
East St. Margaret's Elementary School	2nd floor girls WR tap 1	MWH006	0.0150	Exceeds Limit	0.7400	Passed
East St. Margaret's Elementary School	2nd floor girls WR tap 2	MWH007	0.0320	Exceeds Limit	2.4000	Exceeds Limit
East St. Margaret's Elementary School	2nd floor girls WR tap 3	MWH008	0.0250	Exceeds Limit	1.8000	Passed
East St. Margaret's Elementary School	2nd floor GN WR #1 tap	MWH010	0.1700	Exceeds Limit	0.9000	Passed
East St. Margaret's Elementary School	2nd floor GN WR #2 tap	MWH011	0.0120	Exceeds Limit	0.5700	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
East St. Margaret's Elementary School	1st floor Girls WR tap 1	MWH012	0.0065	Exceeds Limit	0.1800	Passed
East St. Margaret's Elementary School	1st floor Girls WR tap 2	MWH013	0.0040	Passed	0.3600	Passed
East St. Margaret's Elementary School	CR tap room 11	MWH016	0.0250	Exceeds Limit	0.6600	Passed
East St. Margaret's Elementary School	JC tap room 5	MWH017	0.0490	Exceeds Limit	2.7000	Exceeds Limit
Eastern Passage Education Centre	CR tap room 1095	NCE082	0.0000	Passed	0.0790	Passed
Eastern Passage Education Centre	CR tap 1 room 1091	NCE083	0.0005	Passed	0.0710	Passed
Eastern Passage Education Centre	CR tap 2 room 1091	NCE084	0.0006	Passed	0.0730	Passed
Eastern Passage Education Centre	Science Lab room 1086 tap 1	NCE085	0.0014	Passed	28.0000	Exceeds Limit
Eastern Passage Education Centre	Science Lab room 1086 tap 2	NCE086	0.0000	Passed	0.6400	Passed
Eastern Passage Education Centre	Science Lab room 1086 tap 3	NCE087	0.0000	Passed	0.2400	Passed
Eastern Passage Education Centre	Science Lab room 1086 tap 4	NCE088	0.0000	Passed	0.5200	Passed
Eastern Passage Education Centre	Science Lab room 1086 tap 5	NCE089	0.0000	Passed	0.1900	Passed
Eastern Passage Education Centre	Science Lab room 1086 tap 6	NCE090	0.0010	Passed	8.7000	Exceeds Limit
Eastern Passage Education Centre	Science Lab room 1085 tap 1	NCE091	0.0150	Exceeds Limit	6.3000	Exceeds Limit
Eastern Passage Education Centre	Science Lab room 1085 tap 2	NCE092	0.0011	Passed	1.0000	Passed
Eastern Passage Education Centre	Science Lab room 1085 tap 3	NCE093	0.0015	Passed	0.5200	Passed
Eastern Passage Education Centre	Science Lab room 1085 tap 4	NCE094	0.0014	Passed	0.5300	Passed
Eastern Passage Education Centre	Science Lab room 1085 tap 5	NCE095	0.0015	Passed	3.0000	Exceeds Limit
Eastern Passage Education Centre	Science Lab room 1085 tap 6	NCE096	0.0010	Passed	1.9000	Passed
Eastern Passage Education Centre	Learning centre WR tap room 1081	NCE097	0.0020	Passed	0.2100	Passed
Eastern Passage Education Centre	Learning centre tap room 1079	NCE098	0.0000	Passed	0.3300	Passed
Eastern Passage Education Centre	CR tap room 1076	NCE099	0.0000	Passed	2.3000	Exceeds Limit
Eastern Passage Education Centre	CR tap 1 room 1072	NCE100	0.0011	Passed	1.7000	Passed
Eastern Passage Education Centre	CR tap 2 room 1072	NCE101	0.0012	Passed	3.9000	Exceeds Limit
Eastern Passage Education Centre	JC tap room 1100	NCE102	0.0000	Passed	0.1900	Passed
Eastern Passage Education Centre	Fountain by room 1100	NCE103	0.0000	Passed	0.8200	Passed
Eastern Passage Education Centre	GN WR tap room 1101	NCE104	0.0011	Passed	2.7000	Exceeds Limit
Eastern Passage Education Centre	Music room tap room 1064	NMV188	0.0011	Passed	0.0950	Passed
Eastern Passage Education Centre	Art room tap room 1061	NCE106	0.0005	Passed	0.5500	Passed
Eastern Passage Education Centre	Girls WR room 1102 tap 1	NCE107	0.0008	Passed	0.3500	Passed
Eastern Passage Education Centre	Girls WR room 1102 tap 2	NCE108	0.0018	Passed	0.3500	Passed
Eastern Passage Education Centre	Girls WR room 1102 tap 3	NCE109	0.0006	Passed	0.2600	Passed
Eastern Passage Education Centre	Girls WR room 1102 tap 4	NCE110	0.0000	Passed	0.2300	Passed
Eastern Passage Education Centre	Fountain by room 1104	NCE111	0.0006	Passed	1.6000	Passed
Eastern Passage Education Centre	Male WR room 1103 tap 1	NCE112	0.0021	Passed	0.1800	Passed
Eastern Passage Education Centre	Male WR room 1103 tap 2	NCE113	0.0007	Passed	0.1500	Passed
Eastern Passage Education Centre	Male WR room 1103 tap 3	NCE114	0.0018	Passed	0.3600	Passed
Eastern Passage Education Centre	Male WR room 1103 tap 4	NCE115	0.0013	Passed	0.2200	Passed
Eastern Passage Education Centre	Fountain by room 1056	NCE116	0.0000	Passed	0.8600	Passed
Eastern Passage Education Centre	Female locker room tap 1 room 1043	NCE117	0.0038	Passed	0.3400	Passed
Eastern Passage Education Centre	Female locker room tap 2 room 1043	NCE118	0.0013	Passed	0.4800	Passed
Eastern Passage Education Centre	Gym office WR tap room 1046	NCE119	0.0006	Passed	1.2000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Eastern Passage Education Centre	Gym office WR tap room 1048	NCE120	0.0017	Passed	2.9000	Exceeds Limit
Eastern Passage Education Centre	Male locker room tap 1 room 1050	NCE121	0.0360	Exceeds Limit	4.4000	Exceeds Limit
Eastern Passage Education Centre	Male locker room tap 2 room 1050	NCE122	0.0290	Exceeds Limit	3.3000	Exceeds Limit
Eastern Passage Education Centre	Recycle room tap room 1038	NCE123	0.0340	Exceeds Limit	13.0000	Exceeds Limit
Eastern Passage Education Centre	GN WR tap room 1037	NCE124	0.0008	Passed	0.6600	Passed
Eastern Passage Education Centre	JC tap room 1035	NCE125	0.0017	Passed	0.5500	Passed
Eastern Passage Education Centre	GN WR tap by room 1029	NCE126	0.0017	Passed	0.2300	Passed
Eastern Passage Education Centre	Family studies room 1029 tap 1	NCE127	0.0012	Passed	1.5000	Passed
Eastern Passage Education Centre	Family studies room 1029 tap 2	NCE128	0.0000	Passed	0.3400	Passed
Eastern Passage Education Centre	Family studies room 1029 tap 3	NCE129	0.0005	Passed	0.4400	Passed
Eastern Passage Education Centre	Family studies room 1029 tap 4	NCE130	0.0000	Passed	0.3200	Passed
Eastern Passage Education Centre	Office WR tap room 1025	NCE131	0.0000	Passed	0.1900	Passed
Eastern Passage Education Centre	Fountain by room 2036	NMV187	0.0004	Passed	0.4200	Passed
Eastern Passage Education Centre	JC tap room 2036	NCE133	0.0000	Passed	0.1100	Passed
Eastern Passage Education Centre	Tech ed room 2029 tap	NCE134	0.0000	Passed	3.9000	Exceeds Limit
Eastern Passage Education Centre	Staff room WR tap room 2026	NCE135	0.0005	Passed	0.4400	Passed
Eastern Passage Education Centre	Staff room WR tap room 2027	NCE136	0.0016	Passed	0.5500	Passed
Eastern Passage Education Centre	Staff room kitchen tap room 2025	NCE137	0.0000	Passed	0.4600	Passed
Eastern Passage Education Centre	CR tap room 2065	NCE138	0.0000	Passed	1.1000	Passed
Eastern Passage Education Centre	CR tap 1 room 2061	NCE139	0.0054	Exceeds Limit	11.0000	Exceeds Limit
Eastern Passage Education Centre	CR tap 2 room 2061	NCE140	0.0028	Passed	2.0000	Passed
Eastern Passage Education Centre	CR tap room 2058	NCE141	0.0011	Passed	0.8500	Passed
Eastern Passage Education Centre	CR tap 1 room 2053	NCE142	0.0000	Passed	5.5000	Exceeds Limit
Eastern Passage Education Centre	CR tap 2 room 2053	NCE143	0.0000	Passed	0.6900	Passed
Eastern Passage Education Centre	CR tap room 2050	NCE144	0.0000	Passed	0.5300	Passed
Eastern Passage Education Centre	CR tap 1 room 2046	NCE145	0.0006	Passed	4.9000	Exceeds Limit
Eastern Passage Education Centre	CR tap 2 room 2046	NCE146	0.0000	Passed	0.8700	Passed
Eastern Passage Education Centre	JC tap room 2071	NCE147	0.0007	Passed	0.1600	Passed
Eastern Passage Education Centre	Fountain by room 2072	NCE148	0.0008	Passed	0.3800	Passed
Eastern Passage Education Centre	GN WR tap room 2072	NCE149	0.0028	Passed	0.5100	Passed
Eastern Passage Education Centre	Boys WR tap 1 by room 2072	NCE150	0.0009	Passed	0.3800	Passed
Eastern Passage Education Centre	Boys WR tap 2 by room 2072	NCE151	0.0011	Passed	0.3600	Passed
Eastern Passage Education Centre	Boys WR tap 2 by room 2072	NCE152	0.0011	Passed	0.4400	Passed
Eastern Passage Education Centre	Boys WR tap 3 by room 2072	NCE153	0.0017	Passed	0.3000	Passed
Eastern Passage Education Centre	Girls WR tap 1 by room 2074	NCE154	0.0030	Passed	0.5600	Passed
Eastern Passage Education Centre	Girls WR tap 2 by room 2074	NCE155	0.0041	Passed	0.6200	Passed
Eastern Passage Education Centre	Girls WR tap 3 by room 2074	NCE156	0.0016	Passed	0.5100	Passed
Eastern Passage Education Centre	Girls WR tap 4 by room 2074	NCE157	0.0049	Passed	0.2000	Passed
Eastern Shore District High School	Girls WR tap 1 by room 225	NAI278	0.0048	Passed	0.1300	Passed
Eastern Shore District High School	Girls WR tap 2 by room 225	NAI279	0.1800	Exceeds Limit	0.1900	Passed
Eastern Shore District High School	JC tap by room 225	NAI280	0.0250	Exceeds Limit	0.1500	Passed
Eastern Shore District High School	Fountain by room 225	NAI281	0.0310	Exceeds Limit	0.1100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Eastern Shore District High School	Boys WR tap 1 by room 224	NAI282	0.0052	Exceeds Limit	0.0600	Passed
Eastern Shore District High School	Boys WR tap 2 by room 224	NAI283	0.2300	Exceeds Limit	0.2400	Passed
Eastern Shore District High School	CR tap room 220	NAI284	0.0018	Passed	0.2400	Passed
Eastern Shore District High School	Sci. Lab tap 1 room 217	NAI285	0.0250	Exceeds Limit	0.1100	Passed
Eastern Shore District High School	Sci. Lab tap 2 room 217	NAI286	0.0024	Passed	0.2600	Passed
Eastern Shore District High School	Sci. Lab tap 3 room 217	NAI287	0.0190	Exceeds Limit	0.5700	Passed
Eastern Shore District High School	Sci. Lab tap 4 room 217	NAI291	0.0024	Passed	0.2600	Passed
Eastern Shore District High School	Sci. Lab tap 5 room 217	NAI292	0.0036	Passed	0.3700	Passed
Eastern Shore District High School	Sci. Lab tap 6 room 217	NAI293	0.0026	Passed	0.4000	Passed
Eastern Shore District High School	Sci. Lab tap 1a room 217	NAI294	0.0230	Exceeds Limit	0.3000	Passed
Eastern Shore District High School	Sci. Lab tap 2a room 217	NAI295	0.0053	Exceeds Limit	0.2600	Passed
Eastern Shore District High School	Sci. Lab tap 3a room 217	NAI296	0.0150	Exceeds Limit	0.3200	Passed
Eastern Shore District High School	Sci. Lab tap 4a room 217	NAI297	0.0050	Passed	0.3000	Passed
Eastern Shore District High School	Sci. Lab tap 5a room 217	NAI298	0.0120	Exceeds Limit	0.4800	Passed
Eastern Shore District High School	Sci. Lab tap 6a room 217	NAI299	0.0032	Passed	0.1100	Passed
Eastern Shore District High School	Sci. Lab tap 1b room 217	NAI300	0.0060	Exceeds Limit	0.4000	Passed
Eastern Shore District High School	Sci. Lab tap 2b room 217	NAI303	0.0170	Exceeds Limit	0.5100	Passed
Eastern Shore District High School	Sci. Lab tap 3b room 217	NAI304	0.1200	Exceeds Limit	0.3700	Passed
Eastern Shore District High School	Sci. Lab tap 4b room 217	NAI305	0.0024	Passed	0.2800	Passed
Eastern Shore District High School	Sci. Lab tap 5b room 217	NAI306	0.0140	Exceeds Limit	0.4100	Passed
Eastern Shore District High School	Sci. Lab tap 6b room 217	NAI307	0.0017	Passed	0.2300	Passed
Eastern Shore District High School	Sci. Lab tap 1c room 217	NAI308	0.0099	Exceeds Limit	0.5900	Passed
Eastern Shore District High School	Sci. Lab tap 2c room 217	NAI309	0.0550	Exceeds Limit	0.2000	Passed
Eastern Shore District High School	Sci. Lab tap 3c room 217	NAI310	0.0040	Passed	0.4300	Passed
Eastern Shore District High School	Sci. Lab tap 1 room 219	NAI311	0.0120	Exceeds Limit	0.3500	Passed
Eastern Shore District High School	Sci. Lab tap 2 room 219	NAI312	0.0410	Exceeds Limit	4.6000	Exceeds Limit
Eastern Shore District High School	Sci. Lab tap 3 room 219	NAI332	0.0078	Exceeds Limit	0.2400	Passed
Eastern Shore District High School	Sci. Lab tap 4 room 219	NAI333	0.0230	Exceeds Limit	2.0000	Passed
Eastern Shore District High School	Sci. Lab tap 5 room 219	NAI334	0.0170	Exceeds Limit	0.5800	Passed
Eastern Shore District High School	Sci. Lab tap 6 room 219	NAI335	0.0056	Exceeds Limit	0.0930	Passed
Eastern Shore District High School	Sci. Lab tap 1a room 219	NAI336	0.0110	Exceeds Limit	0.2700	Passed
Eastern Shore District High School	Staff WR tap 1 room 201a	NAI337	0.0086	Exceeds Limit	0.0450	Passed
Eastern Shore District High School	Staff WR tap 2 room 201a	NAI338	0.0049	Passed	0.0300	Passed
Eastern Shore District High School	CR tap room 201A	NAI339	0.0064	Exceeds Limit	0.3900	Passed
Eastern Shore District High School	Boys WR tap 1 by room 202	NAI340	0.0088	Exceeds Limit	0.1400	Passed
Eastern Shore District High School	Boys WR tap 2 by room 202	NAI341	0.0110	Exceeds Limit	0.1100	Passed
Eastern Shore District High School	Boys WR tap 3 by room 202	NAI347	0.0590	Exceeds Limit	0.1800	Passed
Eastern Shore District High School	Fountain by boys WR	NAI348	0.0110	Exceeds Limit	0.0550	Passed
Eastern Shore District High School	Staff WR tap by JC	NAI349	0.0110	Exceeds Limit	0.0530	Passed
Eastern Shore District High School	JC in janitors sink room	NAI350	0.0011	Passed	0.0740	Passed
Eastern Shore District High School	Girls WR tap 1 by room 201c	NAI351	0.2100	Exceeds Limit	0.1700	Passed
Eastern Shore District High School	Girls WR tap 2 by room 201c	NAI352	0.3800	Exceeds Limit	0.4600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Eastern Shore District High School	Girls WR tap 3 by room 201c	NAI353	0.6700	Exceeds Limit	0.4700	Passed
Eastern Shore District High School	Double compartment sink tap room 212	NAI354	0.0014	Passed	0.0910	Passed
Eastern Shore District High School	Single compartment sink tap room 212	NAI355	0.0039	Passed	0.1700	Passed
Eastern Shore District High School	GN WR tap room 212	NAI356	0.0190	Exceeds Limit	0.1500	Passed
Eastern Shore District High School	CR tap room 213	NAI360	0.0600	Exceeds Limit	0.6400	Passed
Eastern Shore District High School	CR tap room 123b	NAI361	0.0031	Passed	0.6200	Passed
Eastern Shore District High School	CR tap room 122	NAI362	0.0047	Passed	0.1900	Passed
Eastern Shore District High School	Girls WR tap 1 by JC room C	NAI363	0.3500	Exceeds Limit	0.1100	Passed
Eastern Shore District High School	Girls WR tap 2 by JC room C	NAI364	0.0023	Passed	0.0890	Passed
Eastern Shore District High School	JC tap in JC room c	NAI365	0.0570	Exceeds Limit	0.1800	Passed
Eastern Shore District High School	Fountain by janitors room C	NAI366	0.0430	Exceeds Limit	0.7800	Passed
Eastern Shore District High School	Boys WR tap by room 119a	NAI367	0.0017	Passed	0.0490	Passed
Eastern Shore District High School	CR tap room 116	NAI368	0.0034	Passed	0.1400	Passed
Eastern Shore District High School	Gym office WR tap	NAI369	0.0035	Passed	0.6700	Passed
Eastern Shore District High School	Main office WR tap room 1081	NAI372	0.0210	Exceeds Limit	0.4600	Passed
Eastern Shore District High School	GN WR 1 tap in youth centre room	NAI373	0.0007	Passed	0.5100	Passed
Eastern Shore District High School	GN WR 2 tap in youth centre room	NAI374	0.0000	Passed	0.2900	Passed
Eastern Shore District High School	Boys WR tap 1 by fountain	NAI375	0.0049	Passed	0.2600	Passed
Eastern Shore District High School	Boys WR tap 2 by fountain	NAI376	0.0081	Exceeds Limit	0.4100	Passed
Eastern Shore District High School	Boys WR tap 3 by fountain	NAI377	0.0056	Exceeds Limit	0.2800	Passed
Eastern Shore District High School	Staff WR tap by caretakers office	NAI378	0.0025	Passed	0.1500	Passed
Eastern Shore District High School	JC tap in caretakers office	NAI379	0.0000	Passed	0.0410	Passed
Eastern Shore District High School	Fountain by boys WR	NAI380	0.0021	Passed	0.1200	Passed
Eastern Shore District High School	Girls WR tap 1 by main office	NAI381	0.0081	Exceeds Limit	0.6800	Passed
Eastern Shore District High School	Girls WR tap 2 by main office	NAI388	0.0390	Exceeds Limit	0.4300	Passed
Eastern Shore District High School	Girls WR tap 3 by main office	NAI389	0.0069	Exceeds Limit	0.4100	Passed
Eastern Shore District High School	Fountain by girls WR	NAI390	0.0085	Exceeds Limit	0.3100	Passed
Eastern Shore District High School	Single compartment sink 1 tap room 113	NAI391	0.0005	Passed	0.0710	Passed
Eastern Shore District High School	Single compartment sink 2 tap room 113	NKI511	0.0004	Passed	0.0360	Passed
Eastern Shore District High School	Double compartment sink tap room 113	NAI393	0.0020	Passed	0.1900	Passed
Elizabeth Sutherland School	Girls WR tap 1 by fan room	MQZ703	0.0013	Passed	0.1100	Passed
Elizabeth Sutherland School	Girls WR tap 2 by fan room	MQZ704	0.0008	Passed	0.0660	Passed
Elizabeth Sutherland School	Girls WR tap 3 by fan room	MQZ705	0.0011	Passed	0.0670	Passed
Elizabeth Sutherland School	Girls WR tap 4 by fan room	MQZ706	0.0007	Passed	0.0620	Passed
Elizabeth Sutherland School	JC tap by room 7	MQZ707	0.0019	Passed	0.0810	Passed
Elizabeth Sutherland School	Fountain by JC	MQZ708	0.0013	Passed	0.4700	Passed
Elizabeth Sutherland School	Boys WR tap 1 by JC	MQZ709	0.0021	Passed	0.0740	Passed
Elizabeth Sutherland School	Boys WR tap 2 by JC	MQZ710	0.0087	Exceeds Limit	0.0900	Passed
Elizabeth Sutherland School	Boys WR tap 3 by JC	MQZ711	0.0090	Exceeds Limit	0.0630	Passed
Elizabeth Sutherland School	Boys WR tap 4 by JC	MQZ712	0.0027	Passed	0.0590	Passed
Elizabeth Sutherland School	Girls WR tap 1 by canteen	MQZ713	0.0084	Exceeds Limit	0.1600	Passed
Elizabeth Sutherland School	Girls WR tap 2 by canteen	MQZ714	0.0058	Exceeds Limit	0.0860	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Elizabeth Sutherland School	Girls WR tap 3 by canteen	MQZ715	0.0012	Passed	0.0360	Passed
Elizabeth Sutherland School	Girls WR tap 4 by canteen	MQZ716	0.0069	Exceeds Limit	0.2000	Passed
Elizabeth Sutherland School	JC tap by canteen	MQZ717	0.0000	Passed	0.0140	Passed
Elizabeth Sutherland School	Fountain by canteen	MQZ718	0.0034	Passed	0.6100	Passed
Elizabeth Sutherland School	Boys WR tap 1 next to canteen	MQZ719	0.0110	Exceeds Limit	0.2700	Passed
Elizabeth Sutherland School	Boys WR tap 2 next to canteen	MQZ720	0.0520	Exceeds Limit	0.3400	Passed
Elizabeth Sutherland School	Boys WR tap 3 next to canteen	MQZ721	0.0120	Exceeds Limit	0.2200	Passed
Elizabeth Sutherland School	Boys WR tap 4 next to canteen	MQZ722	0.0051	Exceeds Limit	0.1300	Passed
Elizabeth Sutherland School	Caretaker room tap	MQZ723	0.0010	Passed	0.0690	Passed
Elizabeth Sutherland School	Art room kitchen tap 1	MQZ724	0.0200	Exceeds Limit	0.2800	Passed
Elizabeth Sutherland School	Art room kitchen tap 2	MQZ725	0.0010	Passed	0.0330	Passed
Elizabeth Sutherland School	Music room kitchen tap	NKX243	0.0004	Passed	0.0190	Passed
Elizabeth Sutherland School	Staff room WR tap 1	MQZ727	0.0000	Passed	0.0170	Passed
Elizabeth Sutherland School	Staff room WR tap 2	MQZ728	0.0000	Passed	0.0170	Passed
Elizabeth Sutherland School	Staff room WR tap 3	MQZ729	0.0120	Exceeds Limit	0.5900	Passed
Elizabeth Sutherland School	Resource centre kitchen tap	NKX244	0.0004	Passed	0.0170	Passed
Elizabeth Sutherland School	Science room island sink tap	MQZ733	0.0140	Exceeds Limit	0.3500	Passed
Elizabeth Sutherland School	Girls WR tap 1 by gym	MQZ734	0.0010	Passed	0.0820	Passed
Elizabeth Sutherland School	Girls WR tap 2 by gym	MQZ735	0.0005	Passed	0.0860	Passed
Elizabeth Sutherland School	Girls WR tap 3 by gym	MQZ736	0.0012	Passed	0.0890	Passed
Elizabeth Sutherland School	Girls WR tap 4 by gym	MQZ737	0.0000	Passed	0.0790	Passed
Elizabeth Sutherland School	Girls WR tap 6 by gym	MQZ738	0.0022	Passed	0.0840	Passed
Elizabeth Sutherland School	Fountain by gym	MQZ739	0.0010	Passed	0.1900	Passed
Elizabeth Sutherland School	JC tap by gym	MQZ740	0.0022	Passed	0.0770	Passed
Elizabeth Sutherland School	Boys WR tap 1 by gym	MQZ741	0.0052	Exceeds Limit	0.0560	Passed
Elizabeth Sutherland School	Boys WR tap 2 by gym	MQZ742	0.0025	Passed	0.0350	Passed
Elizabeth Sutherland School	Boys WR tap 3 by gym	MQZ743	0.0014	Passed	0.0230	Passed
Elizabeth Sutherland School	Boys WR tap 4 by gym	MQZ744	0.0038	Passed	0.0360	Passed
Elizabeth Sutherland School	Boys WR tap 5 by gym	MQZ745	0.0013	Passed	0.0920	Passed
Elizabeth Sutherland School	Boys WR tap 6 by gym	MQZ746	0.0020	Passed	0.0240	Passed
Elizabeth Sutherland School	Boys Locker room tap 1	MQZ747	0.0014	Passed	0.0970	Passed
Elizabeth Sutherland School	Boys Locker room tap 2	MQZ748	0.0006	Passed	0.0560	Passed
Elizabeth Sutherland School	Girls locker room tap 1	NKX242	0.0004	Passed	0.0130	Passed
Elizabeth Sutherland School	Girls locker room tap 2	MQZ750	0.0008	Passed	0.0150	Passed
Elizabeth Sutherland School	Girls locker room tap 3	MQZ751	0.0037	Passed	0.0900	Passed
Elizabeth Sutherland School	Fountain by main office	MQZ758	0.0000	Passed	0.2800	Passed
Elizabeth Sutherland School	Food lab tap 1	MQZ759	0.0000	Passed	0.0980	Passed
Elizabeth Sutherland School	Food lab tap 2	MQZ760	0.0000	Passed	0.0230	Passed
Elizabeth Sutherland School	Food lab tap 3	MQZ761	0.0011	Passed	0.0940	Passed
Elizabeth Sutherland School	Food lab tap 4	MQZ762	0.0024	Passed	0.0420	Passed
Elizabeth Sutherland School	Health room WR tap	MQZ763	0.0007	Passed	0.0300	Passed
Elizabeth Sutherland School	Health room kitchen tap	MQZ764	0.0000	Passed	0.0180	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Elizabeth Sutherland School	Science room bath sink tap	MRV247	0.0180	Exceeds Limit	0.2500	Passed
Elizabeth Sutherland School	Science room closet sink tap	MRV248	0.0021	Passed	0.0650	Passed
Elizabeth Sutherland School	Girls WR tap 5 by gym	MRV249	0.0000	Passed	0.0660	Passed
Ellenvale Junior High School	Chem lab tap 1 room 208	MVH128	0.0009	Passed	0.0400	Passed
Ellenvale Junior High School	Chem lab tap 2 room 208	MVH129	0.0000	Passed	0.0069	Passed
Ellenvale Junior High School	Chem lab tap 3 room 208	MVH130	0.0000	Passed	0.0140	Passed
Ellenvale Junior High School	Chem lab tap 4 room 208	MVH131	0.0023	Passed	0.1200	Passed
Ellenvale Junior High School	Chem lab tap 5 room 208	MVH132	0.0014	Passed	0.0280	Passed
Ellenvale Junior High School	Fountain across from back staircase	MVH133	0.0000	Passed	0.3900	Passed
Ellenvale Junior High School	Kitchen sink tap 1 room 211	NLK026	0.0017	Passed	0.0050	Passed
Ellenvale Junior High School	Kitchen sink tap 2 room 211	MVH135	0.0047	Passed	0.2100	Passed
Ellenvale Junior High School	Kitchen sink tap 3 room 211	MVH136	0.0028	Passed	0.2400	Passed
Ellenvale Junior High School	Kitchen sink tap 4 room 211	NLK027	0.0004	Passed	0.0090	Passed
Ellenvale Junior High School	Kitchen sink tap 5 room 211	MVH138	0.0017	Passed	0.4400	Passed
Ellenvale Junior High School	Kitchen sink tap 6 room 211	MVH139	0.0032	Passed	0.4000	Passed
Ellenvale Junior High School	Staff WR beside room 212	MVH140	0.0007	Passed	0.0890	Passed
Ellenvale Junior High School	CR tap room 219	NLK028	0.0004	Passed	0.0160	Passed
Ellenvale Junior High School	Fountain across from 201	MVH142	0.0022	Passed	0.0690	Passed
Ellenvale Junior High School	Fountain across from 219	MVH143	0.0019	Passed	0.1500	Passed
Ellenvale Junior High School	2nd floor Girls WR tap 1 by front staircase	MVH144	0.0019	Passed	0.2800	Passed
Ellenvale Junior High School	2nd floor Girls WR tap 2 by front staircase	MVH145	0.0150	Exceeds Limit	0.5300	Passed
Ellenvale Junior High School	2nd floor Girls WR tap 3 by front staircase	MVH146	0.0120	Exceeds Limit	0.2100	Passed
Ellenvale Junior High School	JC tap beside girls WR	MVH147	0.0008	Passed	0.0910	Passed
Ellenvale Junior High School	2nd floor boys WR tap 1 by room 220	MVH148	0.0048	Passed	0.2600	Passed
Ellenvale Junior High School	2nd floor boys WR tap 2 by room 220	MVH149	0.0074	Exceeds Limit	0.2700	Passed
Ellenvale Junior High School	2nd floor boys WR tap 3 by room 220	MVH150	0.0034	Passed	0.3900	Passed
Ellenvale Junior High School	2nd floor boys WR tap 4 by room 220	MVH151	0.0110	Exceeds Limit	0.3600	Passed
Ellenvale Junior High School	Staff WR inside room 101	MVH152	0.0160	Exceeds Limit	1.1000	Passed
Ellenvale Junior High School	Staff kitchen sink tap room 103	MVH153	0.0023	Passed	0.2400	Passed
Ellenvale Junior High School	Male staff WR tap room 103	MVH154	0.0080	Exceeds Limit	0.7900	Passed
Ellenvale Junior High School	female staff WR tap room 103	MVH155	0.0039	Passed	0.0950	Passed
Ellenvale Junior High School	Fountain beside room 103	MVH156	0.0000	Passed	0.2700	Passed
Ellenvale Junior High School	JC tap beside room 105	MVH157	0.0000	Passed	0.0270	Passed
Ellenvale Junior High School	CR tap room 105	NLK024	0.0070	Exceeds Limit	0.0520	Passed
Ellenvale Junior High School	GN WR tap room 105	MVH159	0.0034	Passed	0.0420	Passed
Ellenvale Junior High School	Laundry tub tap room 109	MVH160	0.0000	Passed	0.0200	Passed
Ellenvale Junior High School	Laundry tub tap room 111	NLK023	0.0008	Passed	0.0150	Passed
Ellenvale Junior High School	CR tap room 110	NLK025	0.0008	Passed	0.0150	Passed
Ellenvale Junior High School	Fountain beside room 110	MVH163	0.0043	Passed	0.7000	Passed
Ellenvale Junior High School	CR tap room 112	MVH164	0.0000	Passed	0.0500	Passed
Ellenvale Junior High School	GN WR tap room 118	MVH165	0.0100	Exceeds Limit	0.7200	Passed
Ellenvale Junior High School	GN WR tap room 119	MVH166	0.0054	Exceeds Limit	0.5000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Ellenvale Junior High School	Fountain across from room 116	MVH167	0.0008	Passed	0.1300	Passed
Ellenvale Junior High School	1st floor girls WR tap 1 by front staircase	MVH168	0.0180	Exceeds Limit	0.3700	Passed
Ellenvale Junior High School	1st floor girls WR tap 2 by front staircase	MVH169	0.0077	Exceeds Limit	0.3600	Passed
Ellenvale Junior High School	1st floor girls WR tap 3 by front staircase	MVH170	0.0049	Passed	0.2300	Passed
Ellenvale Junior High School	1st floor girls WR tap 4 by front staircase	MVH171	0.0054	Exceeds Limit	0.1900	Passed
Ellenvale Junior High School	1st floor boys WR tap 1 by room 101	MVH172	0.0100	Exceeds Limit	0.2600	Passed
Ellenvale Junior High School	1st floor boys WR tap 2 by room 101	MVH173	0.0100	Exceeds Limit	0.4500	Passed
Ellenvale Junior High School	1st floor boys WR tap 3 by room 101	MVH174	0.0120	Exceeds Limit	0.3800	Passed
Ellenvale Junior High School	1st floor boys WR tap 4 by room 101	MVH175	0.0140	Exceeds Limit	0.4300	Passed
Eric Graves Memorial Junior High School	Family studies tap 1 room 201	NLS532	0.0006	Passed	0.0100	Passed
Eric Graves Memorial Junior High School	Family studies tap 2 room 201	MVH191	0.0047	Passed	0.2500	Passed
Eric Graves Memorial Junior High School	Family studies tap 3 room 201	NLS533	0.0009	Passed	0.0200	Passed
Eric Graves Memorial Junior High School	Family studies tap 4 room 201	NLS534	0.0017	Passed	0.0190	Passed
Eric Graves Memorial Junior High School	Family studies tap 5 room 201	NLS535	0.0015	Passed	0.0210	Passed
Eric Graves Memorial Junior High School	Fountain by room 201	MVH196	0.0007	Passed	0.4700	Passed
Eric Graves Memorial Junior High School	JC tap by room 202	MVH197	0.0076	Exceeds Limit	0.3700	Passed
Eric Graves Memorial Junior High School	Boys WR tap 1 by room 204	MVH198	0.0440	Exceeds Limit	0.2900	Passed
Eric Graves Memorial Junior High School	Boys WR tap 2 by room 204	MVH199	0.0890	Exceeds Limit	0.8600	Passed
Eric Graves Memorial Junior High School	Boys WR tap 3 by room 204	MVH200	0.0180	Exceeds Limit	0.5400	Passed
Eric Graves Memorial Junior High School	Boys WR tap 4 by room 204	MVH201	0.1100	Exceeds Limit	1.5000	Passed
Eric Graves Memorial Junior High School	Staff WR by room 208	MVH202	0.0043	Passed	0.1300	Passed
Eric Graves Memorial Junior High School	Fountain by room 208	NLS531	0.0004	Passed	0.0100	Passed
Eric Graves Memorial Junior High School	Girls WR tap 1 by room 208	MVH204	0.3300	Exceeds Limit	1.5000	Passed
Eric Graves Memorial Junior High School	Girls WR tap 2 by room 208	MVH205	0.0840	Exceeds Limit	0.7200	Passed
Eric Graves Memorial Junior High School	Girls WR tap 3 by room 208	MVH206	0.1100	Exceeds Limit	0.5200	Passed
Eric Graves Memorial Junior High School	Girls WR tap 4 by room 208	MVH207	0.1100	Exceeds Limit	0.4400	Passed
Eric Graves Memorial Junior High School	CR tap room 210	MVH208	0.0028	Passed	0.0550	Passed
Eric Graves Memorial Junior High School	Chem lab tap 1 room 210	MVH209	0.0620	Exceeds Limit	1.2000	Passed
Eric Graves Memorial Junior High School	Chem lab tap 2 room 210	MVH210	0.3200	Exceeds Limit	1.3000	Passed
Eric Graves Memorial Junior High School	Chem lab tap 3 room 210	MVH211	0.1600	Exceeds Limit	1.1000	Passed
Eric Graves Memorial Junior High School	Chem lab tap 4 room 210	MVH212	0.2200	Exceeds Limit	1.0000	Passed
Eric Graves Memorial Junior High School	Chem lab tap 5 room 210	MVH213	0.1300	Exceeds Limit	1.2000	Passed
Eric Graves Memorial Junior High School	JC tap by room 215	MVH214	0.0019	Passed	0.0810	Passed
Eric Graves Memorial Junior High School	Principal WR tap room 108	MVH215	0.0056	Exceeds Limit	0.1900	Passed
Eric Graves Memorial Junior High School	Staff room kitchen tap room 109	MVH216	0.0052	Exceeds Limit	0.3600	Passed
Eric Graves Memorial Junior High School	Staff mens WR tap 1 room 109	MVH217	0.0940	Exceeds Limit	0.1000	Passed
Eric Graves Memorial Junior High School	Staff mens WR tap 2 room 109	MVH218	0.0036	Passed	0.0420	Passed
Eric Graves Memorial Junior High School	Staff womens WR tap 1 room 109	MVH219	0.0140	Exceeds Limit	0.3500	Passed
Eric Graves Memorial Junior High School	Staff womens WR tap 2 room 109	NLS528	0.0004	Passed	0.0080	Passed
Eric Graves Memorial Junior High School	CR tap room 110	NLS529	0.0004	Passed	0.0050	Passed
Eric Graves Memorial Junior High School	WR tap room 110	MVH222	0.0038	Passed	0.4400	Passed
Eric Graves Memorial Junior High School	JC tap by room 111	MVH223	0.0025	Passed	0.1900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Eric Graves Memorial Junior High School	GN WR tap room 112	MVH224	0.0350	Exceeds Limit	0.3600	Passed
Eric Graves Memorial Junior High School	CR tap room 112	NLS527	0.0005	Passed	0.0070	Passed
Eric Graves Memorial Junior High School	Gym storage room tap	MVH226	0.0820	Exceeds Limit	2.6000	Exceeds Limit
Eric Graves Memorial Junior High School	Fountain by gym	MVH227	0.0006	Passed	0.5400	Passed
Eric Graves Memorial Junior High School	1st floor Girls WR tap 1	MVH228	0.0180	Exceeds Limit	0.4400	Passed
Eric Graves Memorial Junior High School	1st floor Girls WR tap 2	MVH229	0.0160	Exceeds Limit	0.2400	Passed
Eric Graves Memorial Junior High School	1st floor Girls WR tap 3	MVH230	0.0180	Exceeds Limit	0.2000	Passed
Eric Graves Memorial Junior High School	1st floor Girls WR tap 4	MVH231	0.0097	Exceeds Limit	0.2500	Passed
Eric Graves Memorial Junior High School	1st floor boys WR tap 1	MVH232	0.0200	Exceeds Limit	0.3800	Passed
Eric Graves Memorial Junior High School	1st floor boys WR tap 2	MVH233	0.0140	Exceeds Limit	0.3100	Passed
Eric Graves Memorial Junior High School	1st floor boys WR tap 3	MVH234	0.0240	Exceeds Limit	0.3900	Passed
Eric Graves Memorial Junior High School	1st floor boys WR tap 4	MVH235	0.0140	Exceeds Limit	0.3800	Passed
Eric Graves Memorial Junior High School	Fountain by room 202	MVH236	0.0021	Passed	0.4700	Passed
Eric Graves Memorial Junior High School	Tech Ed. Tap	MVH237	0.0310	Exceeds Limit	0.2900	Passed
Eric Graves Memorial Junior High School	Resource room tap room 107	MVH238	0.2400	Exceeds Limit	1.1000	Passed
Eric Graves Memorial Junior High School	CR tap room 105	NLS531	0.0004	Passed	0.0090	Passed
Eric Graves Memorial Junior High School	CR WR tap room 105	MVH240	0.0079	Exceeds Limit	0.4300	Passed
Fairview Heights Elementary School	VP office WR tap	MSG780	0.0027	Passed	0.1200	Passed
Fairview Heights Elementary School	VP office kitchen tap	MSG781	0.0022	Passed	0.4400	Passed
Fairview Heights Elementary School	GN WR tap room P2	MSG782	0.0014	Passed	0.1600	Passed
Fairview Heights Elementary School	kitchen tap room P2	MSG783	0.0018	Passed	0.0900	Passed
Fairview Heights Elementary School	Boys WR tap 1 by gym	MSG784	0.0006	Passed	0.0470	Passed
Fairview Heights Elementary School	Boys WR tap 2 by gym	MSG785	0.0009	Passed	0.0350	Passed
Fairview Heights Elementary School	Boys WR tap 3 by gym	MSG786	0.0000	Passed	0.0120	Passed
Fairview Heights Elementary School	JC tap by gym	MSG787	0.0005	Passed	0.0120	Passed
Fairview Heights Elementary School	Girls WR tap 1 by gym	MSG788	0.0000	Passed	0.0120	Passed
Fairview Heights Elementary School	Girls WR tap 2 by gym	MSG789	0.0006	Passed	0.0092	Passed
Fairview Heights Elementary School	Girls WR tap 3 by gym	MSG790	0.0000	Passed	0.0079	Passed
Fairview Heights Elementary School	Fountain by room 12	MSG791	0.0000	Passed	0.2700	Passed
Fairview Heights Elementary School	Boys WR tap 1 at bottom of stairs	MSG792	0.0013	Passed	0.0700	Passed
Fairview Heights Elementary School	Boys WR tap 2 at bottom of stairs	MSG793	0.0005	Passed	0.0150	Passed
Fairview Heights Elementary School	Boys WR tap 3 at bottom of stairs	MSG794	0.0017	Passed	0.1800	Passed
Fairview Heights Elementary School	Staff WR tap	MSG795	0.0006	Passed	0.0081	Passed
Fairview Heights Elementary School	Girls WR tap 1 by caretaker room	MSG796	0.0009	Passed	0.0240	Passed
Fairview Heights Elementary School	Girls WR tap 2 by caretaker room	MSG797	0.0000	Passed	0.0100	Passed
Fairview Heights Elementary School	Girls WR tap 3 by caretaker room	MSG798	0.0000	Passed	0.0077	Passed
Fairview Heights Elementary School	Caretaker room tap	MSG799	0.0000	Passed	0.0120	Passed
Fairview Heights Elementary School	Fountain by room 6	MSG800	0.0013	Passed	0.2400	Passed
Fairview Heights Elementary School - Annex	JC tap/boiler room tap	MRM940	0.0000	Passed	0.0140	Passed
Fairview Heights Elementary School - Annex	Workroom tap	MRM941	0.0000	Passed	0.0390	Passed
Fairview Heights Elementary School - Annex	Staff kitchen tap off gym	MRM943	0.0000	Passed	0.1100	Passed
Fairview Heights Elementary School - Annex	Boys WR tap 1 by gym	MRM944	0.0011	Passed	0.0840	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Fairview Heights Elementary School - Annex	Boys WR tap 2 by gym	MRM945	0.0008	Passed	0.1400	Passed
Fairview Heights Elementary School - Annex	Boys WR tap 3 by gym	MRM946	0.0000	Passed	0.0490	Passed
Fairview Heights Elementary School - Annex	Girls WR tap 1 by gym	MRM947	0.0009	Passed	0.0470	Passed
Fairview Heights Elementary School - Annex	Girls WR tap 2 by gym	MRM948	0.0006	Passed	0.2800	Passed
Fairview Heights Elementary School - Annex	Girls WR tap 3 by gym	MRM949	0.0038	Passed	0.2200	Passed
Fairview Heights Elementary School - Annex	Girls WR tap 4 by gym	MRM978	0.0008	Passed	0.1200	Passed
Fairview Heights Elementary School - Annex	Fountain by room 3	MRM981	0.0007	Passed	0.0910	Passed
Fairview Heights Elementary School - Annex	Main office WR tap by room 5	MRM982	0.0000	Passed	0.2900	Passed
Fairview Heights Elementary School - Annex	Fountain by gym	MRN019	0.0000	Passed	0.0200	Passed
Fairview Heights Elementary School - Annex	Admin room tap off the gym	NFE692	0.0037	Passed	0.1100	Passed
Fairview Junior High School	Kitchen tap 1 room 236	MRO180	0.0006	Passed	0.0760	Passed
Fairview Junior High School	Kitchen tap 2 room 236	MRO181	0.0019	Passed	0.2700	Passed
Fairview Junior High School	Kitchen tap 3 room 236	MRO182	0.0000	Passed	0.1800	Passed
Fairview Junior High School	Kitchen tap 4 room 236	MRO183	0.0017	Passed	0.1100	Passed
Fairview Junior High School	Kitchen tap 5 room 236	MRO184	0.0009	Passed	0.0610	Passed
Fairview Junior High School	Kitchen tap 1 room 230	MRO185	0.0035	Passed	0.0670	Passed
Fairview Junior High School	fountain beside electrical room	MRO186	0.0014	Passed	0.3300	Passed
Fairview Junior High School	CR tap room 205	MRO187	0.0015	Passed	0.6400	Passed
Fairview Junior High School	male staff WR tap across room 208	MRO188	0.0019	Passed	0.0510	Passed
Fairview Junior High School	female staff WR tap across room 208	MRO189	0.0018	Passed	0.0470	Passed
Fairview Junior High School	JC tap by staff WR's	MRO190	0.0026	Passed	0.0630	Passed
Fairview Junior High School	Boys WR tap 1 by room 205	MRO191	0.0009	Passed	0.0260	Passed
Fairview Junior High School	Boys WR tap 2 by room 205	MRO192	0.0005	Passed	0.0210	Passed
Fairview Junior High School	Boys WR tap 3 by room 205	MRO193	0.0009	Passed	0.0240	Passed
Fairview Junior High School	Boys WR tap 4 by room 205	MRO194	0.0021	Passed	0.0200	Passed
Fairview Junior High School	Fountain by electrical room	MRO195	0.0038	Passed	0.2800	Passed
Fairview Junior High School	Girls WR tap 1 across room 205	MRO196	0.0044	Passed	0.1300	Passed
Fairview Junior High School	Girls WR tap 2 across room 205	MRO197	0.0019	Passed	0.1500	Passed
Fairview Junior High School	Girls WR tap 3 across room 205	MRO198	0.0009	Passed	0.0990	Passed
Fairview Junior High School	Girls WR tap 4 across room 205	MRO199	0.0027	Passed	0.0540	Passed
Fairview Junior High School	Art room tap 1 room 239	MRO200	0.0025	Passed	0.1900	Passed
Fairview Junior High School	Art room tap 2 room 239	MRO201	0.0010	Passed	0.0180	Passed
Fairview Junior High School	JC tap by room 239	MRO202	0.0015	Passed	0.0270	Passed
Fairview Junior High School	Girls WR tap 1 across from room 228	MRO203	0.0017	Passed	0.0140	Passed
Fairview Junior High School	Girls WR tap 2 across from room 228	MRO204	0.0021	Passed	0.0210	Passed
Fairview Junior High School	Girls WR tap 3 across from room 228	MRO205	0.0090	Exceeds Limit	0.0280	Passed
Fairview Junior High School	GN staff WR tap across 228	MRO206	0.0043	Passed	0.0720	Passed
Fairview Junior High School	GN staff WR tap across 230	MRO207	0.0025	Passed	0.0370	Passed
Fairview Junior High School	Boys WR tap 1 across from room 230	MRO208	0.0010	Passed	0.0140	Passed
Fairview Junior High School	Boys WR tap 2 across from room 230	MRO209	0.0022	Passed	0.0380	Passed
Fairview Junior High School	Boys WR tap 3 across from room 230	MRO215	0.0015	Passed	0.0150	Passed
Fairview Junior High School	Kitchen tap 1 room 246	MRO216	0.0048	Passed	0.1500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Fairview Junior High School	Kitchen tap 1 room 247	MRO217	0.0068	Exceeds Limit	0.5000	Passed
Fairview Junior High School	Kitchen tap 1 room 248	MRO218	0.5500	Exceeds Limit	6.6000	Exceeds Limit
Fairview Junior High School	Kitchen tap 2 room 248	MRO219	0.0860	Exceeds Limit	2.2000	Exceeds Limit
Fairview Junior High School	Kitchen tap 3 room 248	MRO220	0.0091	Exceeds Limit	1.4000	Passed
Fairview Junior High School	JC tap room 131	MRO221	0.0022	Passed	0.1300	Passed
Fairview Junior High School	Staff WR tap in office room 137	MRO222	0.0014	Passed	0.0820	Passed
Fairview Junior High School	Staff kitchen tap room 144	MRO223	0.0011	Passed	0.0210	Passed
Fairview Junior High School	Staff WR tap room 144	MRO224	0.0009	Passed	0.0150	Passed
Fairview Junior High School	Staff WR tap room 144	MRO443	0.0013	Passed	0.0200	Passed
Fairview Junior High School	GN WR tap room 140	MRO444	0.0018	Passed	0.0150	Passed
Fairview Junior High School	learning centre WR tap	MRO445	0.0009	Passed	0.0120	Passed
Fairview Junior High School	Fountain across from learning centre	MRO446	0.0000	Passed	0.3400	Passed
Fairview Junior High School	GN WR tap across from room 110	MRO447	0.0100	Exceeds Limit	0.0540	Passed
Fairview Junior High School	staff WR by GN WR	MRO448	0.0009	Passed	0.0310	Passed
Fairview Junior High School	JC tap by staff WR's	MRO449	0.0021	Passed	0.0270	Passed
Fairview Junior High School	Boys WR tap 1 by room 108	MRO450	0.0013	Passed	0.0250	Passed
Fairview Junior High School	Boys WR tap 2 by room 108	MRO451	0.0009	Passed	0.0190	Passed
Fairview Junior High School	Fountain beside electrical room	NNS553	0.0018	Passed	0.0630	Passed
Fairview Junior High School	Girls WR tap 1 across from room 107	MRO460	0.0016	Passed	0.0360	Passed
Fairview Junior High School	Girls WR tap 2 across from room 107	MRO461	0.0011	Passed	0.0200	Passed
Fairview Junior High School	Girls WR tap 3 across from room 107	MRO462	0.0012	Passed	0.0190	Passed
Fairview Junior High School	Girls WR tap 4 across from room 107	MRO463	0.0012	Passed	0.0200	Passed
Fairview Junior High School	CR tap 1 room 160	MRO464	0.0015	Passed	0.2300	Passed
Fairview Junior High School	CR tap 2 room 160	MRO465	0.0000	Passed	0.5400	Passed
Fairview Junior High School	Boiler room tap room 014	MRO466	0.0640	Exceeds Limit	0.2300	Passed
Fairview Junior High School	Wood shop room tap	MRO467	0.0022	Passed	0.1800	Passed
Fairview Junior High School	Computer lab tap room 012	MRO468	0.0170	Exceeds Limit	0.8700	Passed
Fairview Junior High School	JC tap room 009	MRO469	0.0370	Exceeds Limit	0.6300	Passed
Fairview Junior High School	Caretaker room WR tap room 007	MRO471	0.0000	Passed	0.0068	Passed
Fairview Junior High School	Boys locker room tap 1 room 006	MRO472	0.0027	Passed	0.0720	Passed
Fairview Junior High School	Boys locker room tap 2 room 006	MRO473	0.0014	Passed	0.0130	Passed
Fairview Junior High School	Fountain by boys locker room	MRO474	0.0012	Passed	0.1800	Passed
Fairview Junior High School	Girls locker room tap 1 room 005	MRO475	0.0025	Passed	0.0076	Passed
Fairview Junior High School	Girls locker room tap 2 room 005	MRO476	0.0005	Passed	0.0047	Passed
Fairview Junior High School	Phys Ed WR room 013	MRO477	0.0073	Exceeds Limit	0.1500	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 1	MUT708	0.0016	Passed	0.0820	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 2	MUT709	0.0680	Exceeds Limit	0.0960	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 3	MUT710	0.0038	Passed	0.1300	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 4	MUT711	0.0031	Passed	0.1300	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 5	MUT712	0.0220	Exceeds Limit	0.2500	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 6	MUT713	0.0220	Exceeds Limit	0.2500	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 7	MUT714	0.0110	Exceeds Limit	0.2100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 8	MUT715	0.0029	Passed	0.1900	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 9	MUT716	0.0022	Passed	0.1500	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 10	MUT717	0.0017	Passed	0.1200	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 11	MUT718	0.0019	Passed	0.1200	Passed
Five Bridges Junior High School	3rd floor Chem lab room 300 tap 12	MUT719	0.0150	Exceeds Limit	0.3700	Passed
Five Bridges Junior High School	3rd floor Chem lab storage room 300A tap	MUT720	0.4000	Exceeds Limit	0.3200	Passed
Five Bridges Junior High School	Physics lab storage room 303A tap	MUT721	0.0260	Exceeds Limit	0.1300	Passed
Five Bridges Junior High School	Physics lab tap room 303	MUT722	0.0066	Exceeds Limit	0.1200	Passed
Five Bridges Junior High School	CR tap room 307	MUT723	0.0047	Passed	0.0560	Passed
Five Bridges Junior High School	3rd floor staff WR 1 tap	MUT724	0.0017	Passed	0.0770	Passed
Five Bridges Junior High School	3rd floor staff WR 2 tap	MUT725	0.0018	Passed	0.1000	Passed
Five Bridges Junior High School	3rd floor boys WR tap 1	MUT726	0.0022	Passed	0.1000	Passed
Five Bridges Junior High School	3rd floor boys WR tap 2	MUT727	0.0035	Passed	0.0910	Passed
Five Bridges Junior High School	3rd floor boys WR tap 3	MUT728	0.0032	Passed	0.0490	Passed
Five Bridges Junior High School	3rd floor boys WR tap 4	MUT729	0.0018	Passed	0.1000	Passed
Five Bridges Junior High School	Fountain by WR's	MUT730	0.0013	Passed	0.2600	Passed
Five Bridges Junior High School	3rd floor JC tap	MUT731	0.0011	Passed	0.1100	Passed
Five Bridges Junior High School	3rd floor Girls WR tap 1	MUT732	0.0022	Passed	0.0770	Passed
Five Bridges Junior High School	3rd floor Girls WR tap 2	MUT733	0.0011	Passed	0.0600	Passed
Five Bridges Junior High School	3rd floor Girls WR tap 3	MUT734	0.0160	Exceeds Limit	0.1300	Passed
Five Bridges Junior High School	3rd floor Girls WR tap 4	MUT735	0.0120	Exceeds Limit	0.1100	Passed
Five Bridges Junior High School	3rd floor Girls WR tap 5	MUT736	0.0031	Passed	0.0700	Passed
Five Bridges Junior High School	Bio lab room 325 tap 1	MUT737	0.0160	Exceeds Limit	0.1300	Passed
Five Bridges Junior High School	Bio lab room 325 tap 2	MUT738	0.0071	Exceeds Limit	0.1300	Passed
Five Bridges Junior High School	Bio lab room 325 tap 3	MUT739	0.0130	Exceeds Limit	0.2000	Passed
Five Bridges Junior High School	2nd floor girls LR tap 1	MUT740	0.0015	Passed	0.0820	Passed
Five Bridges Junior High School	2nd floor girls LR tap 2	MUT741	0.0009	Passed	0.0760	Passed
Five Bridges Junior High School	Gym office WR tap room 209A	MUT742	0.0330	Exceeds Limit	0.2600	Passed
Five Bridges Junior High School	Gym office WR tap room 211A	MUT743	2.4000	Exceeds Limit	0.4300	Passed
Five Bridges Junior High School	Boys LR tap room 215	MUT744	0.0000	Passed	0.0670	Passed
Five Bridges Junior High School	Learning centre tap room 223	MUT745	0.0010	Passed	0.0720	Passed
Five Bridges Junior High School	Learning centre WR tap room 227	MUT746	0.0072	Exceeds Limit	0.2500	Passed
Five Bridges Junior High School	Learning centre WR tap room 225	MUT747	0.0049	Passed	0.0470	Passed
Five Bridges Junior High School	2nd floor boys WR tap 1	MUT748	0.0012	Passed	0.0530	Passed
Five Bridges Junior High School	2nd floor boys WR tap 2	MUT749	0.0010	Passed	0.0670	Passed
Five Bridges Junior High School	2nd floor boys WR tap 3	MUT750	0.0010	Passed	0.0420	Passed
Five Bridges Junior High School	2nd floor boys WR tap 4	MUT751	0.0013	Passed	0.0370	Passed
Five Bridges Junior High School	Fountain by WR's	MUT752	0.0007	Passed	0.2700	Passed
Five Bridges Junior High School	JC tap by WR's	MUT753	0.0009	Passed	0.1100	Passed
Five Bridges Junior High School	2nd floor Girls WR tap 1	MUT754	0.0026	Passed	0.0720	Passed
Five Bridges Junior High School	2nd floor Girls WR tap 2	MUT755	0.0012	Passed	0.0610	Passed
Five Bridges Junior High School	2nd floor Girls WR tap 3	MUT756	0.0039	Passed	0.0920	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Five Bridges Junior High School	2nd floor Girls WR tap 4	MUT757	0.0066	Exceeds Limit	0.1300	Passed
Five Bridges Junior High School	2nd floor Girls WR tap 5	MUT758	0.0017	Passed	0.0610	Passed
Five Bridges Junior High School	Main office WR tap	MUT759	0.0024	Passed	0.1300	Passed
Five Bridges Junior High School	1st floor boys WR tap 1	MUT760	0.0015	Passed	0.0720	Passed
Five Bridges Junior High School	1st floor boys WR tap 2	MUT761	0.0012	Passed	0.0580	Passed
Five Bridges Junior High School	1st floor boys WR tap 3	MUT762	0.0160	Exceeds Limit	0.0580	Passed
Five Bridges Junior High School	Fountain by 1st floor WR's	NMV996	0.0018	Passed	0.0770	Passed
Five Bridges Junior High School	JC tap by 1st floor WR's	MUT764	0.0007	Passed	0.0290	Passed
Five Bridges Junior High School	1st floor Girls WR tap 1	MUT765	0.0016	Passed	0.0540	Passed
Five Bridges Junior High School	1st floor Girls WR tap 2	MUT766	0.0140	Exceeds Limit	0.0600	Passed
Five Bridges Junior High School	1st floor Girls WR tap 3	MUT767	0.0013	Passed	0.0480	Passed
Five Bridges Junior High School	1st floor Girls WR tap 4	MUT788	0.0012	Passed	0.0430	Passed
Five Bridges Junior High School	Staff male WR tap room 157	MUT789	0.0006	Passed	0.0430	Passed
Five Bridges Junior High School	Staff female WR tap room 158	MUT790	0.0007	Passed	0.0520	Passed
Fleming Tower School	Fountain	MNX823	0.0029	Passed	0.1500	Passed
Fleming Tower School	Teachers room tap	MNX824	0.0029	Passed	0.1400	Passed
Fleming Tower School	Girls WR Tap 1	MNX825	0.0260	Exceeds Limit	0.1900	Passed
Fleming Tower School	Girls WR Tap 2	MNX826	0.0039	Passed	0.1700	Passed
Fleming Tower School	Girls WR Tap 3	MNX827	0.0200	Exceeds Limit	0.2400	Passed
Fleming Tower School	Boys WR Tap 1	MNX828	0.0030	Passed	0.1600	Passed
Fleming Tower School	Boys WR Tap 2	MNX829	0.0008	Passed	0.0250	Passed
Fleming Tower School	Boys WR Tap 3	MNX830	0.0071	Exceeds Limit	0.1400	Passed
Fleming Tower School	CR tap room 2	MOE426	0.0017	Passed	0.1200	Passed
Fleming Tower School	Teachers WR tap	MOE427	0.0023	Passed	0.1100	Passed
Gaetz Brook Junior High School	GN WR tap room 306	NAN920	0.0019	Passed	0.1400	Passed
Gaetz Brook Junior High School	Staff room kitchen tap	NAN921	0.0020	Passed	0.1500	Passed
Gaetz Brook Junior High School	Staff room WR #1 tap	NAN922	0.0077	Exceeds Limit	0.3600	Passed
Gaetz Brook Junior High School	Staff room WR #2 tap	NAN923	0.0048	Passed	0.5900	Passed
Gaetz Brook Junior High School	Girls WR tap 1 by room 305	NAN924	0.0088	Exceeds Limit	0.4400	Passed
Gaetz Brook Junior High School	Girls WR tap 2 by room 305	NAN925	0.0076	Exceeds Limit	0.4600	Passed
Gaetz Brook Junior High School	Fountain by girls WR	NAN926	4.6000	Exceeds Limit	0.2800	Passed
Gaetz Brook Junior High School	JC tap by fountain	NAN927	0.0041	Passed	0.1500	Passed
Gaetz Brook Junior High School	Boys WR tap 1 by JC	NAN928	0.0740	Exceeds Limit	3.2000	Exceeds Limit
Gaetz Brook Junior High School	Boys WR tap 2 by JC	NAN929	0.0010	Passed	0.1400	Passed
Gaetz Brook Junior High School	Ms. O'Connell room tap	NAN930	0.1100	Exceeds Limit	2.5000	Exceeds Limit
Gaetz Brook Junior High School	Sci lab tap before room 300	NAN931	0.0540	Exceeds Limit	0.1800	Passed
Gaetz Brook Junior High School	CR tap 1 room 300	NAN932	1.4000	Exceeds Limit	1.9000	Passed
Gaetz Brook Junior High School	CR tap 2 room 300	NAN933	0.0240	Exceeds Limit	0.2600	Passed
Gaetz Brook Junior High School	CR tap 3 room 300	NAN934	0.0130	Exceeds Limit	0.4100	Passed
Gaetz Brook Junior High School	CR tap 4 room 300	NAN935	0.0390	Exceeds Limit	0.5500	Passed
Gaetz Brook Junior High School	CR tap 5 room 300	NAN936	0.1100	Exceeds Limit	1.3000	Passed
Gaetz Brook Junior High School	Laundry tub tap room 203	NAN937	0.0450	Exceeds Limit	0.4000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Gaetz Brook Junior High School	Girls WR tap 1 by room 204	NAN938	0.0008	Passed	0.1200	Passed
Gaetz Brook Junior High School	Girls WR tap 2 by room 204	NAN939	0.0008	Passed	0.1200	Passed
Gaetz Brook Junior High School	Fountain by girls WR	NAN940	0.0008	Passed	0.1300	Passed
Gaetz Brook Junior High School	JC by fountain	NAN941	0.0007	Passed	0.1300	Passed
Gaetz Brook Junior High School	Boys WR tap 1 by JC	NAN942	0.0007	Passed	0.1200	Passed
Gaetz Brook Junior High School	Boys WR tap 2 by JC	NAN943	0.0860	Exceeds Limit	0.5800	Passed
Gaetz Brook Junior High School	Guidance room rap	NAN944	0.0410	Exceeds Limit	0.1900	Passed
Gaetz Brook Junior High School	Fountain in boys locker room	NAN945	0.0010	Passed	0.0990	Passed
Gaetz Brook Junior High School	Boys locker room tap	NAN946	0.0010	Passed	0.0900	Passed
Gaetz Brook Junior High School	Girls locker room tap	NAN947	0.0067	Exceeds Limit	0.3200	Passed
Gaetz Brook Junior High School	Staff WR in main office	NAN948	0.0056	Exceeds Limit	1.1000	Passed
Gaetz Brook Junior High School	Girls WR tap 1 by room 105	NAN949	0.0110	Exceeds Limit	0.3600	Passed
Gaetz Brook Junior High School	Girls WR tap 2 by room 105	NAN950	0.0017	Passed	0.1400	Passed
Gaetz Brook Junior High School	Fountain by Girls WR	NAN951	0.0190	Exceeds Limit	0.7300	Passed
Gaetz Brook Junior High School	JC by fountain	NAN952	0.0006	Passed	0.1200	Passed
Gaetz Brook Junior High School	Boys WR tap 1 by JC	NAN953	0.0150	Exceeds Limit	0.2800	Passed
Gaetz Brook Junior High School	Boys WR tap 2 by JC	NAN954	0.0092	Exceeds Limit	0.2200	Passed
Gaetz Brook Junior High School	Kitchen/Cafeteria tap 1	NAN955	0.0110	Exceeds Limit	0.7700	Passed
Gaetz Brook Junior High School	Kitchen/Cafeteria handwashing tap	NAN956	0.0210	Exceeds Limit	0.8200	Passed
Gaetz Brook Junior High School	Kitchen/Cafeteria WR tap	NAN957	0.0160	Exceeds Limit	0.2600	Passed
Gaetz Brook Junior High School	Triple compartment sink tap 1 in kitchen	NAN958	0.0340	Exceeds Limit	0.2700	Passed
Gaetz Brook Junior High School	Triple compartment sink tap 2 in kitchen	NAN959	0.0270	Exceeds Limit	0.4600	Passed
Gaetz Brook Junior High School	Photo room tap	NAN960	3.3000	Exceeds Limit	4.9000	Exceeds Limit
Gaetz Brook Junior High School	JC tap in art room	NAN961	0.0940	Exceeds Limit	2.8000	Exceeds Limit
Gaetz Brook Junior High School	Art room tap	NAN962	0.1500	Exceeds Limit	6.1000	Exceeds Limit
George Bissett Elementary School	Girls WR tap 1 by room 207	MXK042	0.0000	Passed	0.3000	Passed
George Bissett Elementary School	Girls WR tap 2 by room 207	MXK043	0.0010	Passed	0.1200	Passed
George Bissett Elementary School	JC by girls WR	MXK044	0.0000	Passed	0.0550	Passed
George Bissett Elementary School	Boys WR tap 1 room 215	MXK045	0.0011	Passed	0.4800	Passed
George Bissett Elementary School	Boys WR tap 2 room 215	MXK046	0.0007	Passed	0.2000	Passed
George Bissett Elementary School	Staff kitchen sink tap room 221	MXK047	0.0016	Passed	0.2000	Passed
George Bissett Elementary School	Staff room WR tap room 221	MXK048	0.0000	Passed	0.0150	Passed
George Bissett Elementary School	Kitchen sink tap across from secretary room	MXK049	0.0070	Exceeds Limit	0.0770	Passed
George Bissett Elementary School	Girls WR tap 1 room 224	MXK050	0.0000	Passed	0.2500	Passed
George Bissett Elementary School	Girls WR tap 2 room 224	MXK051	0.0028	Passed	0.1900	Passed
George Bissett Elementary School	Girls WR tap 3 room 224	MXK052	0.0007	Passed	0.0460	Passed
George Bissett Elementary School	Girls WR tap 4 room 224	MXK053	0.0000	Passed	0.0150	Passed
George Bissett Elementary School	Fountain by girls WR (room 224)	MXK054	0.0015	Passed	0.2200	Passed
George Bissett Elementary School	JC tap room 226	MXK055	0.0023	Passed	0.1100	Passed
George Bissett Elementary School	Boys WR tap 1 room 228	MXK056	0.0140	Exceeds Limit	0.3600	Passed
George Bissett Elementary School	Boys WR tap 2 room 228	MXK057	0.0000	Passed	0.3900	Passed
George Bissett Elementary School	Boys WR tap 3 room 228	MXK058	0.0007	Passed	0.3600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
George Bissett Elementary School	Boys WR tap 4 room 228	MXK059	0.0000	Passed	0.2100	Passed
George Bissett Elementary School	Girls WR tap 1 room 110	MXK060	0.0011	Passed	0.3700	Passed
George Bissett Elementary School	Girls WR tap 2 room 110	MXK061	0.0000	Passed	0.3600	Passed
George Bissett Elementary School	Girls WR tap 3 room 110	MXK062	0.0007	Passed	0.2100	Passed
George Bissett Elementary School	Boys WR tap 1 room 114	MXK063	0.0014	Passed	0.3800	Passed
George Bissett Elementary School	Boys WR tap 2 room 114	MXK064	0.0000	Passed	0.5100	Passed
George Bissett Elementary School	Boys WR tap 3 room 114	MXK065	0.0000	Passed	0.4100	Passed
George Bissett Elementary School	Boys WR tap 4 room 114	MXK066	0.0029	Passed	0.4500	Passed
George Bissett Elementary School	Fountain by room 109	MDD689	0.0004	Passed	0.0350	Passed
Georges P. Vanier Junior High School	Principals office WR tap	MVG411	0.0007	Passed	0.1800	Passed
Georges P. Vanier Junior High School	Fountain by main office	MVG412	0.0006	Passed	0.6700	Passed
Georges P. Vanier Junior High School	Learning centre tap room 158	MVG413	0.0021	Passed	1.0000	Passed
Georges P. Vanier Junior High School	Science lab tap 1 room 161	MVG414	0.0060	Exceeds Limit	0.5800	Passed
Georges P. Vanier Junior High School	Science lab tap 2 room 161	MVG415	0.0390	Exceeds Limit	1.5000	Passed
Georges P. Vanier Junior High School	Science lab tap 3 room 161	MVG416	0.0670	Exceeds Limit	0.8400	Passed
Georges P. Vanier Junior High School	Science lab tap 4 room 161	MVG417	0.3400	Exceeds Limit	1.5000	Passed
Georges P. Vanier Junior High School	CR tap room 164	MVG418	0.0038	Passed	0.8700	Passed
Georges P. Vanier Junior High School	CR tap 1 room 146	MVG419	0.0041	Passed	0.6500	Passed
Georges P. Vanier Junior High School	CR tap 2 room 146	MVG420	0.0010	Passed	0.3500	Passed
Georges P. Vanier Junior High School	CR tap 3 room 146	MVG421	0.0000	Passed	0.0760	Passed
Georges P. Vanier Junior High School	Cafeteria tap 1	MVG422	0.0010	Passed	0.0790	Passed
Georges P. Vanier Junior High School	Cafeteria tap 2	MVG423	0.0040	Passed	0.1700	Passed
Georges P. Vanier Junior High School	fountain by cafeteria	MVG424	0.0019	Passed	0.0760	Passed
Georges P. Vanier Junior High School	Girls WR tap 1 room 120	MVG425	0.0110	Exceeds Limit	0.2400	Passed
Georges P. Vanier Junior High School	Girls WR tap 2 room 120	MVG426	0.0073	Exceeds Limit	0.3300	Passed
Georges P. Vanier Junior High School	Girls WR tap 3 room 120	MVG427	0.0170	Exceeds Limit	0.2600	Passed
Georges P. Vanier Junior High School	Fountain by girls WR	MVG428	0.0016	Passed	1.2000	Passed
Georges P. Vanier Junior High School	JC tap room 124	MVG429	0.0000	Passed	0.0500	Passed
Georges P. Vanier Junior High School	Boys WR tap 1 room 116	MVG430	0.0300	Exceeds Limit	0.3400	Passed
Georges P. Vanier Junior High School	Boys WR tap 2 room 116	MVG431	0.0007	Passed	0.1600	Passed
Georges P. Vanier Junior High School	Boys WR tap 3 room 116	MVG432	0.0007	Passed	0.0570	Passed
Georges P. Vanier Junior High School	Gym office WR tap room 105	MVG433	0.0061	Exceeds Limit	0.1900	Passed
Georges P. Vanier Junior High School	Gym office WR tap room 106	MVG434	0.0036	Passed	0.1700	Passed
Georges P. Vanier Junior High School	2nd floor fountain by elevator	MVG435	0.0033	Passed	0.6500	Passed
Georges P. Vanier Junior High School	Science lab tap 1 room 241	MVG436	0.2000	Exceeds Limit	0.8900	Passed
Georges P. Vanier Junior High School	Science lab tap 2 room 241	MVG437	0.1300	Exceeds Limit	0.6200	Passed
Georges P. Vanier Junior High School	Science lab tap 3 room 241	MVG438	0.1500	Exceeds Limit	1.3000	Passed
Georges P. Vanier Junior High School	Science lab tap 4 room 241	MVG439	0.0370	Exceeds Limit	0.4500	Passed
Georges P. Vanier Junior High School	Science lab tap 5 room 241	MVG440	0.1100	Exceeds Limit	0.4600	Passed
Georges P. Vanier Junior High School	Food lab tap 1 room 231	NND063	0.0004	Passed	0.0200	Passed
Georges P. Vanier Junior High School	Food lab tap 2 room 231	NND075	0.0007	Passed	0.0300	Passed
Georges P. Vanier Junior High School	Food lab tap 3 room 231	NND076	0.0010	Passed	0.0310	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Georges P. Vanier Junior High School	Food lab tap 4 room 231	NND077	0.0009	Passed	0.0350	Passed
Georges P. Vanier Junior High School	Clothes lab tap room 224	MVG445	1.5000	Exceeds Limit	2.4000	Exceeds Limit
Georges P. Vanier Junior High School	Science lab tap 1 room 220	MVG446	0.0280	Exceeds Limit	0.6400	Passed
Georges P. Vanier Junior High School	Science lab tap 2 room 220	MVG447	0.0510	Exceeds Limit	0.4100	Passed
Georges P. Vanier Junior High School	Science lab tap 3 room 220	MVG448	0.0570	Exceeds Limit	0.2300	Passed
Georges P. Vanier Junior High School	Science lab tap 4 room 220	MVG449	0.0075	Exceeds Limit	1.1000	Passed
Georges P. Vanier Junior High School	Girls WR tap 1 room 210	MVG450	0.1600	Exceeds Limit	0.3100	Passed
Georges P. Vanier Junior High School	Girls WR tap 2 room 210	MVG451	0.0420	Exceeds Limit	0.5200	Passed
Georges P. Vanier Junior High School	Girls WR tap 3 room 210	MVG452	0.0110	Exceeds Limit	0.2100	Passed
Georges P. Vanier Junior High School	Girls WR tap 4 room 210	MVG453	0.0092	Exceeds Limit	0.1800	Passed
Georges P. Vanier Junior High School	JC tap room 212	MVG454	0.0053	Exceeds Limit	0.1600	Passed
Georges P. Vanier Junior High School	2nd floor Boys WR tap 1	MVG455	0.0190	Exceeds Limit	0.3900	Passed
Georges P. Vanier Junior High School	2nd floor Boys WR tap 2	MVG456	0.0016	Passed	0.0930	Passed
Georges P. Vanier Junior High School	2nd floor Boys WR tap 3	MVG457	0.0015	Passed	0.0680	Passed
Georges P. Vanier Junior High School	Staff WR tap 1 room 216	MVG458	0.0390	Exceeds Limit	0.3100	Passed
Georges P. Vanier Junior High School	Staff WR tap 2 room 216	MVG459	0.0075	Exceeds Limit	0.3200	Passed
Georges P. Vanier Junior High School	Fountain by staff room	NND078	0.0004	Passed	0.0410	Passed
Gorsebrook Junior High School	Boys locker room tap (1st floor)	MSZ161	0.0060	Exceeds Limit	0.2800	Passed
Gorsebrook Junior High School	Gym GN WR tap	MSZ162	0.0021	Passed	0.1500	Passed
Gorsebrook Junior High School	Gym office tap	MSZ163	0.0018	Passed	0.1400	Passed
Gorsebrook Junior High School	Girls locker room tap	MSZ164	0.0030	Passed	1.9000	Passed
Gorsebrook Junior High School	Fountain by gym	MSZ165	0.0038	Passed	0.2500	Passed
Gorsebrook Junior High School	GN WR 1 tap by room 3	MSZ166	0.0014	Passed	0.2500	Passed
Gorsebrook Junior High School	GN WR 2 tap by room 3	MSZ167	0.0037	Passed	0.2700	Passed
Gorsebrook Junior High School	Art room tap room 3	MSZ168	0.0130	Exceeds Limit	0.8700	Passed
Gorsebrook Junior High School	1st floor staff WR tap	MSZ169	0.0000	Passed	0.0230	Passed
Gorsebrook Junior High School	1st floor staff room kitchen tap	MSZ170	0.0000	Passed	0.0270	Passed
Gorsebrook Junior High School	CR tap room 12	MSZ171	0.0020	Passed	0.2100	Passed
Gorsebrook Junior High School	JC tap by room 18	MSZ172	0.0005	Passed	0.0530	Passed
Gorsebrook Junior High School	Male staff WR tap by room 18	MSZ173	0.0023	Passed	0.0620	Passed
Gorsebrook Junior High School	Boys WR tap 1 by room 18	MSZ174	0.0010	Passed	0.2500	Passed
Gorsebrook Junior High School	Boys WR tap 2 by room 18	MSZ175	0.0038	Passed	0.1100	Passed
Gorsebrook Junior High School	Boys WR tap 3 by room 18	MSZ176	0.0044	Passed	0.2200	Passed
Gorsebrook Junior High School	Boys WR tap 4 by room 18	MSZ177	0.0014	Passed	0.2500	Passed
Gorsebrook Junior High School	Fountain across from room 16	NLJ875	0.0004	Passed	0.0200	Passed
Gorsebrook Junior High School	Female staff WR tap by room 16	MSZ179	0.0026	Passed	0.2300	Passed
Gorsebrook Junior High School	Girls WR tap 1 by room 16	MSZ180	0.0016	Passed	0.1900	Passed
Gorsebrook Junior High School	Girls WR tap 2 by room 16	MSZ181	0.0041	Passed	0.0530	Passed
Gorsebrook Junior High School	Girls WR tap 3 by room 16	MSZ182	0.0024	Passed	0.3000	Passed
Gorsebrook Junior High School	Girls WR tap 4 by room 16	MSZ183	0.0007	Passed	0.0780	Passed
Gorsebrook Junior High School	Girls WR tap 5 by room 16	MSZ184	0.0083	Exceeds Limit	0.3800	Passed
Gorsebrook Junior High School	Resource room tap room 11	MSZ185	0.0009	Passed	0.1000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Gorsebrook Junior High School	Resource room WR tap 1 room 11	MSZ186	0.0020	Passed	0.0490	Passed
Gorsebrook Junior High School	Resource room WR tap 2 room 11	MSZ187	0.0012	Passed	0.0530	Passed
Gorsebrook Junior High School	Fountain by main office	MSZ188	0.0000	Passed	0.3500	Passed
Gorsebrook Junior High School	Basement CR tap room 29	MSZ189	0.0056	Exceeds Limit	0.2100	Passed
Gorsebrook Junior High School	Basement boys WR tap 1	MSZ190	0.0083	Exceeds Limit	0.3100	Passed
Gorsebrook Junior High School	Basement boys WR tap 2	MSZ191	0.0110	Exceeds Limit	0.4600	Passed
Gorsebrook Junior High School	Basement boys WR tap 3	MSZ192	0.0690	Exceeds Limit	4.7000	Exceeds Limit
Gorsebrook Junior High School	Basement Girls WR tap 1	MSZ193	0.0027	Passed	0.2000	Passed
Gorsebrook Junior High School	Basement Girls WR tap 2	MSZ194	0.0051	Exceeds Limit	0.7500	Passed
Gorsebrook Junior High School	Basement Girls WR tap 3	MSZ195	0.0050	Passed	0.1500	Passed
Gorsebrook Junior High School	Basement food lab tap 1	MSZ196	0.0007	Passed	0.0330	Passed
Gorsebrook Junior High School	Basement food lab tap 2	MSZ197	0.0017	Passed	0.0640	Passed
Gorsebrook Junior High School	Basement food lab tap 3	MSZ198	0.0005	Passed	0.0500	Passed
Gorsebrook Junior High School	Basement food lab tap 4	MSZ199	0.0000	Passed	0.0550	Passed
Gorsebrook Junior High School	Storage room tap room 32	MUV531	0.0180	Exceeds Limit	0.1800	Passed
Gorsebrook Junior High School	JC Tap Room 30	MUV532	0.0011	Passed	0.1300	Passed
Gorsebrook Junior High School	Wood Work Rm Tap Room 28 #28	MUV533	0.0000	Passed	0.2500	Passed
Graham Creighton Junior High School	Admin WR tap	MYA071	0.0016	Passed	0.2800	Passed
Graham Creighton Junior High School	Science room tap room 184	MYA072	0.0000	Passed	1.3000	Passed
Graham Creighton Junior High School	Girls WR tap 1 by room 184	MYA073	0.0000	Passed	0.1400	Passed
Graham Creighton Junior High School	Girls WR tap 2 by room 184	MYA074	0.0000	Passed	0.1300	Passed
Graham Creighton Junior High School	JC tap	MYA075	0.0036	Passed	1.2000	Passed
Graham Creighton Junior High School	Fountain between WR's	MYA076	0.0044	Passed	1.5000	Passed
Graham Creighton Junior High School	Boys WR tap 1 before room 162	MYA077	0.0005	Passed	0.1400	Passed
Graham Creighton Junior High School	Boys WR tap 2 before room 162	MYA078	0.0005	Passed	0.1300	Passed
Graham Creighton Junior High School	Learning centre tap room 162	MYA079	0.0006	Passed	0.6000	Passed
Graham Creighton Junior High School	CR tap room 165	MYA080	0.0000	Passed	0.2700	Passed
Graham Creighton Junior High School	Girls WR tap 1 room 112	MYA081	0.0041	Passed	0.3100	Passed
Graham Creighton Junior High School	Girls WR tap 2 room 112	MYA082	0.0010	Passed	0.2400	Passed
Graham Creighton Junior High School	Girls WR tap 3 room 112	MYA083	0.0036	Passed	0.2200	Passed
Graham Creighton Junior High School	GN WR tap room 113	MYA084	0.0018	Passed	0.1000	Passed
Graham Creighton Junior High School	Fountain by room 113	MYA085	0.0000	Passed	0.1700	Passed
Graham Creighton Junior High School	JC tap between WR's	MYA086	0.0044	Passed	0.3100	Passed
Graham Creighton Junior High School	Boys WR tap 1 by room 113	MYA087	0.0031	Passed	0.2400	Passed
Graham Creighton Junior High School	Boys WR tap 2 by room 113	MYA088	0.0010	Passed	0.2200	Passed
Graham Creighton Junior High School	Boys WR tap 3 by room 113	MYA089	0.0012	Passed	0.3600	Passed
Graham Creighton Junior High School	Fountain by boys WR	MYA090	0.0000	Passed	0.7800	Passed
Graham Creighton Junior High School	Girls locker room tap 1	MYA091	0.0000	Passed	0.3900	Passed
Graham Creighton Junior High School	Girls locker room tap 2	MYA092	0.0000	Passed	0.3300	Passed
Graham Creighton Junior High School	Gym office WR tap	MYA093	0.0000	Passed	0.1300	Passed
Graham Creighton Junior High School	Boys locker room tap 1	MYA094	0.0000	Passed	0.7100	Passed
Graham Creighton Junior High School	Boys locker room tap 2	MYA095	0.0007	Passed	0.3200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Graham Creighton Junior High School	Community Area tap room 134	MYA096	0.0006	Passed	0.1600	Passed
Graham Creighton Junior High School	Meeting room tap by room 134	MYA097	0.0006	Passed	1.1000	Passed
Graham Creighton Junior High School	Cafeteria tap 1 room 121	MYA099	0.0000	Passed	0.6700	Passed
Graham Creighton Junior High School	Cafeteria tap 2 room 121	MYA100	0.0000	Passed	0.8000	Passed
Graham Creighton Junior High School	Cafeteria tap 3 room 121	MYA101	0.0007	Passed	0.1500	Passed
Graham Creighton Junior High School	Cafeteria tap 4 room 121	MYA102	0.0000	Passed	0.0350	Passed
Graham Creighton Junior High School	2nd floor fountain by room 121	MYA103	0.0006	Passed	1.4000	Passed
Graham Creighton Junior High School	Art room tap 1	MYA104	0.0000	Passed	0.2800	Passed
Graham Creighton Junior High School	Art room tap 2	MYA105	0.0007	Passed	0.1200	Passed
Graham Creighton Junior High School	Tech Ed. Room tap	MYA106	0.0030	Passed	0.2600	Passed
Graham Creighton Junior High School	Staff room kitchen tap	MYA107	0.0007	Passed	0.1800	Passed
Graham Creighton Junior High School	Staff room WR tap	MYA108	0.0000	Passed	0.2300	Passed
Graham Creighton Junior High School	Library tap	MYA109	0.0000	Passed	0.1700	Passed
Graham Creighton Junior High School	Staff WR tap in gym	MYA110	0.0006	Passed	0.1700	Passed
Graham Creighton Junior High School	Fountain by room 230	MYA111	0.0000	Passed	0.2000	Passed
Graham Creighton Junior High School	Staff WR tap room 230	MYA112	0.0000	Passed	0.1900	Passed
Graham Creighton Junior High School	2nd floor girls WR tap 1	MYA113	0.0000	Passed	0.1500	Passed
Graham Creighton Junior High School	2nd floor girls WR tap 2	MYA114	0.0000	Passed	0.1600	Passed
Graham Creighton Junior High School	JC tap by girls WR	MYA115	0.0000	Passed	0.3700	Passed
Graham Creighton Junior High School	Fountain between WR's	MYA116	0.0000	Passed	0.7700	Passed
Graham Creighton Junior High School	2nd floor boys WR tap 1	MYA117	0.0020	Passed	0.3300	Passed
Graham Creighton Junior High School	2nd floor boys WR tap 2	MYA118	0.0000	Passed	0.1800	Passed
Graham Creighton Junior High School	Girls WR tap 1 by room 205	MYA119	0.0000	Passed	0.1700	Passed
Graham Creighton Junior High School	Girls WR tap 2 by room 205	MYA120	0.0007	Passed	0.1100	Passed
Graham Creighton Junior High School	Girls WR tap 3 by room 205	MYA126	0.0007	Passed	0.4300	Passed
Graham Creighton Junior High School	Staff WR tap room 205	MYA127	0.0011	Passed	0.0930	Passed
Graham Creighton Junior High School	Fountain by room 208	MYA128	0.0000	Passed	1.0000	Passed
Graham Creighton Junior High School	Boys WR tap 1 room 208	MYA129	0.0009	Passed	0.5200	Passed
Graham Creighton Junior High School	Boys WR tap 2 room 208	MYA130	0.0006	Passed	0.1300	Passed
Graham Creighton Junior High School	Boys WR tap 3 room 208	MYA131	0.0008	Passed	0.2000	Passed
Graham Creighton Junior High School	JC tap by room 208	MYA132	0.0005	Passed	0.1100	Passed
Graham Creighton Junior High School	Family studies tap 1 room 209	MYA133	0.0007	Passed	0.2400	Passed
Graham Creighton Junior High School	Family studies tap 2 room 209	NKI307	0.0004	Passed	1.1000	Passed
Graham Creighton Junior High School	Family studies tap 3 room 209	MYA135	0.0000	Passed	0.6700	Passed
Graham Creighton Junior High School	Family studies tap 4 room 209	MYA136	0.0036	Passed	1.2000	Passed
Graham Creighton Junior High School	JC tap before room 121	NAM737	0.0010	Passed	0.1100	Passed
Grosvenor-Wentworth Park Elementary School	Staff room tap	MUL565	0.0015	Passed	0.0300	Passed
Grosvenor-Wentworth Park Elementary School	JC tap near room 113	MUL566	0.0008	Passed	0.0490	Passed
Grosvenor-Wentworth Park Elementary School	CR tap by room 113	MUL567	0.0076	Exceeds Limit	0.2800	Passed
Grosvenor-Wentworth Park Elementary School	CR tap room 113	MUL568	0.0009	Passed	0.0860	Passed
Grosvenor-Wentworth Park Elementary School	CR tap before room 122	MUL569	0.0140	Exceeds Limit	0.1000	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 1 by room 122	MUL570	0.0000	Passed	0.0600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Grosvenor-Wentworth Park Elementary School	Girls WR tap 2 by room 122	MUL571	0.0015	Passed	0.0860	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 1 by room 122	MUL573	0.0009	Passed	0.0740	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 2 by room 122	MUL574	0.0012	Passed	0.0890	Passed
Grosvenor-Wentworth Park Elementary School	Fountain by girls WR	MUL575	0.0000	Passed	0.7000	Passed
Grosvenor-Wentworth Park Elementary School	Gym office WR tap	MUL576	0.0040	Passed	0.0580	Passed
Grosvenor-Wentworth Park Elementary School	CR tap room 145	MUL577	0.0006	Passed	0.1000	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 1 by room 145	MUL578	0.0000	Passed	0.0420	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 2 by room 145	MUL579	0.0009	Passed	0.0640	Passed
Grosvenor-Wentworth Park Elementary School	JC tap between WR's	MUL580	0.0019	Passed	0.0290	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 1 after room 145	MUL581	0.0006	Passed	0.0450	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 2 after room 145	MUL582	0.0012	Passed	0.0300	Passed
Grosvenor-Wentworth Park Elementary School	CR tap room 7	MUL583	0.0019	Passed	0.1200	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 1 by room 7	MUL584	0.0083	Exceeds Limit	0.0590	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 2 by room 7	MUL585	0.0000	Passed	0.0210	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 3 by room 7	MUL586	0.0000	Passed	0.0200	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 4 by room 7	MUL587	0.0013	Passed	0.0560	Passed
Grosvenor-Wentworth Park Elementary School	Girls WR tap 5 by room 7	MUL588	0.0020	Passed	0.0300	Passed
Grosvenor-Wentworth Park Elementary School	Fountain by WR's	MUL589	0.0000	Passed	0.2200	Passed
Grosvenor-Wentworth Park Elementary School	Staff WR tap	MUL590	0.0054	Exceeds Limit	0.0750	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 1 after room 7	MUL591	0.0000	Passed	0.0120	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 2 after room 7	MUL592	0.0000	Passed	0.0060	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 3 after room 7	MUL593	0.0000	Passed	0.0073	Passed
Grosvenor-Wentworth Park Elementary School	Boys WR tap 4 after room 7	MUL594	0.0000	Passed	0.0049	Passed
Grosvenor-Wentworth Park Elementary School	JC tap after boys WR	MUL595	0.0010	Passed	0.0200	Passed
Grosvenor-Wentworth Park Elementary School	Fountain by JC	MUL596	0.0000	Passed	0.1100	Passed
Halifax Central Junior High School	1st floor first aid room tap	MTN563	0.0000	Passed	0.0300	Passed
Halifax Central Junior High School	fountain before boys WR	MTN564	0.0000	Passed	0.2100	Passed
Halifax Central Junior High School	1st floor boys WR tap 1	MTN565	0.0000	Passed	0.0220	Passed
Halifax Central Junior High School	1st floor boys WR tap 2	MTN566	0.0000	Passed	0.0210	Passed
Halifax Central Junior High School	1st floor boys WR tap 3	MTN567	0.0000	Passed	0.0210	Passed
Halifax Central Junior High School	1st floor boys WR tap 4	MTN568	0.0000	Passed	0.0200	Passed
Halifax Central Junior High School	Art room tap room 7	MTN569	0.0036	Passed	0.7800	Passed
Halifax Central Junior High School	Woodshop sink tap	MTN570	0.0006	Passed	0.5000	Passed
Halifax Central Junior High School	Girls locker room tap 1	MTN572	0.0000	Passed	0.0390	Passed
Halifax Central Junior High School	Girls locker room tap 2	MTN587	0.0000	Passed	0.0390	Passed
Halifax Central Junior High School	Boys locker room tap 1	MTN588	0.0000	Passed	0.0082	Passed
Halifax Central Junior High School	Boys locker room tap 2	MTN589	0.0000	Passed	0.0078	Passed
Halifax Central Junior High School	GN WR tap	MTN590	0.0000	Passed	0.0065	Passed
Halifax Central Junior High School	Fountain by room 4	MTN591	0.0031	Passed	0.1300	Passed
Halifax Central Junior High School	Girls WR tap 1 by room 4	MTN592	0.0012	Passed	0.1600	Passed
Halifax Central Junior High School	Girls WR tap 2 by room 4	MTN593	0.0007	Passed	0.0780	Passed
Halifax Central Junior High School	Girls WR tap 3 by room 4	MTN594	0.0006	Passed	0.0450	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Halifax Central Junior High School	Girls WR tap 4 by room 4	MTN595	0.0000	Passed	0.0370	Passed
Halifax Central Junior High School	Girls WR tap 5 by room 4	MTN596	0.0000	Passed	0.0320	Passed
Halifax Central Junior High School	Staff room tap	MTN601	0.0016	Passed	0.0480	Passed
Halifax Central Junior High School	CR tap room 17	MTN602	0.0000	Passed	0.0250	Passed
Halifax Central Junior High School	Family studies tap 1 room 9	MTN603	0.0034	Passed	0.2900	Passed
Halifax Central Junior High School	Family studies tap 2 room 9	MTN604	0.0010	Passed	0.1300	Passed
Halifax Central Junior High School	Family studies tap 3 room 9	MTN605	0.0005	Passed	0.0640	Passed
Halifax Central Junior High School	Girls WR tap 1 by room 9	MTN606	0.0007	Passed	0.1200	Passed
Halifax Central Junior High School	Girls WR tap 2 by room 9	MTN607	0.0006	Passed	0.1200	Passed
Halifax Central Junior High School	Girls WR tap 3 by room 9	MTN608	0.0005	Passed	0.0730	Passed
Halifax Central Junior High School	Girls WR tap 4 by room 9	MTN609	0.0000	Passed	0.0200	Passed
Halifax Central Junior High School	Girls WR tap 5 by room 9	MTN610	0.0000	Passed	0.0190	Passed
Halifax Central Junior High School	Fountain by room 9	MTN612	0.0000	Passed	0.0760	Passed
Halifax Central Junior High School	GN WR tap room 22	MTN613	0.0000	Passed	0.0130	Passed
Halifax Central Junior High School	VP office WR tap	MTN614	0.0021	Passed	0.0800	Passed
Halifax Central Junior High School	Boys WR tap 1 by office	MTN615	0.0000	Passed	0.0150	Passed
Halifax Central Junior High School	Boys WR tap 2 by office	MTN616	0.0000	Passed	0.0140	Passed
Halifax Central Junior High School	Boys WR tap 3 by office	MTN617	0.0000	Passed	0.0140	Passed
Halifax Central Junior High School	Boys WR tap 4 by office	MTN618	0.0000	Passed	0.0140	Passed
Halifax Central Junior High School	Chem lab tap 1	MTN619	0.0011	Passed	0.0170	Passed
Halifax Central Junior High School	Chem lab tap 2	MTN620	0.0006	Passed	0.0120	Passed
Halifax Central Junior High School	Upstairs fountain	MYZ617	0.0011	Passed	0.1800	Passed
Halifax Central Junior High School	Storage room in gym tap (right back corner)	NFZ852	0.0031	Passed	0.0810	Passed
Halifax West High School	CR tap 1 room B329	MUJ165	0.0069	Exceeds Limit	0.3700	Passed
Halifax West High School	CR tap 2 room B329	MUJ166	0.0000	Passed	0.0770	Passed
Halifax West High School	CR tap room B327	MUJ167	0.0000	Passed	0.2000	Passed
Halifax West High School	CR tap room B322	MUJ168	0.0000	Passed	0.8300	Passed
Halifax West High School	CR tap room B315	MUJ169	0.0000	Passed	0.4200	Passed
Halifax West High School	CR tap room B317	MUJ170	0.0000	Passed	0.1400	Passed
Halifax West High School	CR tap room B316	MUJ171	0.0000	Passed	0.0310	Passed
Halifax West High School	Fountain after room B315	MUJ172	0.0000	Passed	0.4600	Passed
Halifax West High School	CR tap room A354	MUJ173	0.0010	Passed	0.7100	Passed
Halifax West High School	CR tap 1 room A353	MUJ174	0.0000	Passed	0.3400	Passed
Halifax West High School	CR tap 2 room A353	MUJ175	0.0000	Passed	0.1100	Passed
Halifax West High School	CR tap 3 room A353	MUJ176	0.0000	Passed	0.3600	Passed
Halifax West High School	CR tap 4 room A353	MUJ177	0.0000	Passed	0.6400	Passed
Halifax West High School	Room A352 tap 1	MUJ178	0.0044	Passed	0.3100	Passed
Halifax West High School	Room A352 tap 2	MUJ179	0.0340	Exceeds Limit	0.2600	Passed
Halifax West High School	Room A352 tap 3	MUJ180	0.0020	Passed	0.9800	Passed
Halifax West High School	Room A352 tap 4	MUJ181	0.0990	Exceeds Limit	0.2300	Passed
Halifax West High School	Room A352 tap 5	MUJ182	0.0009	Passed	0.8500	Passed
Halifax West High School	Room A351 tap 1	MUJ183	0.0000	Passed	0.9100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Halifax West High School	Room A351 tap 2	MUJ184	0.0160	Exceeds Limit	0.1500	Passed
Halifax West High School	Room A351 tap 3	MUJ185	0.0130	Exceeds Limit	0.1100	Passed
Halifax West High School	Room A351 tap 4	MUJ186	0.0000	Passed	0.7400	Passed
Halifax West High School	Room A351 tap 5	MUJ187	0.0019	Passed	0.1800	Passed
Halifax West High School	Room A350 tap 3	MUJ190	0.0024	Passed	0.1100	Passed
Halifax West High School	Room A350 tap 4	MUJ191	0.0063	Exceeds Limit	0.1200	Passed
Halifax West High School	Room A350 tap 5	MUJ192	0.0017	Passed	0.4200	Passed
Halifax West High School	GN WR tap room A332	MUJ193	0.0000	Passed	0.0370	Passed
Halifax West High School	Room A343 tap	MUJ194	0.0081	Exceeds Limit	0.4900	Passed
Halifax West High School	Room A340 tap 1	MUJ195	0.0011	Passed	0.6000	Passed
Halifax West High School	Room A340 tap 2	MUJ196	0.0009	Passed	0.4300	Passed
Halifax West High School	Room A340 tap 3	MUJ197	0.0075	Exceeds Limit	0.0200	Passed
Halifax West High School	Room A340 tap 4	MUJ198	0.0016	Passed	0.5400	Passed
Halifax West High School	Room A340 tap 5	MUJ199	0.0058	Exceeds Limit	0.0180	Passed
Halifax West High School	Room C352 tap	MUJ200	0.0260	Exceeds Limit	0.0960	Passed
Halifax West High School	Mech room tap after room C322H	MUJ201	0.0670	Exceeds Limit	0.1400	Passed
Halifax West High School	Fountain after room C226	MUJ202	0.0000	Passed	0.2100	Passed
Halifax West High School	Dressing room tap 1 room B222	MUJ203	0.0000	Passed	0.0720	Passed
Halifax West High School	Dressing room tap 2 room B222	MUJ204	0.0006	Passed	0.1600	Passed
Halifax West High School	Tech ed. Room tap room B214	MUJ205	0.0012	Passed	0.2400	Passed
Halifax West High School	Kitchen/Cafeteria tap 1 room B202	MUJ206	0.0020	Passed	0.3200	Passed
Halifax West High School	Kitchen/Cafeteria tap 2 room B202	MUJ207	0.0005	Passed	0.4400	Passed
Halifax West High School	Kitchen/Cafeteria tap 3 room B202	MUJ208	0.0006	Passed	0.1400	Passed
Halifax West High School	Main office WR tap	MUJ209	0.0000	Passed	0.1400	Passed
Halifax West High School	Student Services tap	MUJ210	0.0000	Passed	0.1500	Passed
Halifax West High School	Fountain outside gym	MUJ211	0.0000	Passed	0.2400	Passed
Halifax West High School	Gym GN WR tap	MUJ212	0.0000	Passed	0.0350	Passed
Halifax West High School	Fountain in gym	MUJ213	0.0000	Passed	0.0790	Passed
Halifax West High School	Gym office tap room A267	MUJ214	0.0007	Passed	0.2700	Passed
Halifax West High School	Girls locker room 1 tap	MUJ215	0.0007	Passed	0.4500	Passed
Halifax West High School	Boys locker room 1 tap	MUJ216	0.0000	Passed	0.1800	Passed
Halifax West High School	Boys locker room 2 tap	MUJ217	0.0000	Passed	0.3400	Passed
Halifax West High School	Girls locker room 2 tap	MUJ218	0.0015	Passed	0.2000	Passed
Halifax West High School	Gym office tap room A264	MUJ219	0.0000	Passed	0.4500	Passed
Halifax West High School	Fountain by room A264	MUJ220	0.0000	Passed	0.3100	Passed
Halifax West High School	Boys WR tap 1 room A221	MUJ221	0.0000	Passed	0.0740	Passed
Halifax West High School	Boys WR tap 2 room A221	MUJ222	0.0000	Passed	0.1100	Passed
Halifax West High School	Boys WR tap 3 room A221	MUJ223	0.0000	Passed	0.1500	Passed
Halifax West High School	Boys WR tap 4 room A221	MUJ224	0.0017	Passed	0.0910	Passed
Halifax West High School	JC tap by room A221	MUJ225	0.0000	Passed	0.0320	Passed
Halifax West High School	Girls WR tap 1 room A224	MUJ290	0.0008	Passed	0.1200	Passed
Halifax West High School	Girls WR tap 2 room A224	MUJ291	0.0000	Passed	0.1700	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Halifax West High School	Girls WR tap 3 room A224	MUJ292	0.0000	Passed	0.2100	Passed
Halifax West High School	Girls WR tap 4 room A224	MUJ293	0.0000	Passed	0.1600	Passed
Halifax West High School	CR tap room A225	MUJ294	0.0000	Passed	0.4600	Passed
Halifax West High School	GN WR tap 1 room A226	MUJ295	0.0000	Passed	0.1900	Passed
Halifax West High School	GN WR tap 2 room A226	MUJ296	0.0006	Passed	0.1500	Passed
Halifax West High School	Staff WR tap room A230	MUJ297	0.0023	Passed	0.2300	Passed
Halifax West High School	Girls WR tap 1 room A234	MUJ298	0.0000	Passed	0.1300	Passed
Halifax West High School	Girls WR tap 2 room A234	MUJ299	0.0000	Passed	0.1300	Passed
Halifax West High School	Girls WR tap 3 room A234	MUJ300	0.0010	Passed	0.1300	Passed
Halifax West High School	Girls WR tap 4 room A234	MUJ301	0.0066	Exceeds Limit	0.2500	Passed
Halifax West High School	JC tap by room A234	MUJ302	0.0013	Passed	0.0570	Passed
Halifax West High School	Boys WR tap 1 room A235	MUJ303	0.0013	Passed	0.0720	Passed
Halifax West High School	Boys WR tap 2 room A235	MUJ304	0.0000	Passed	0.2600	Passed
Halifax West High School	Boys WR tap 3 room A235	MUJ305	0.0000	Passed	0.2500	Passed
Halifax West High School	Boys WR tap 4 room A235	MUJ306	0.0000	Passed	0.2600	Passed
Halifax West High School	Fountain before student gov. room	MUJ307	0.0000	Passed	0.3500	Passed
Halifax West High School	Mech. Room tap room C135	MUJ308	0.0007	Passed	0.0710	Passed
Halifax West High School	Fountain by room C133	MUJ309	0.0000	Passed	0.1000	Passed
Halifax West High School	Boys WR tap 1 room C161	MUJ310	0.0006	Passed	0.1800	Passed
Halifax West High School	Boys WR tap 2 room C161	MUJ311	0.0000	Passed	0.2200	Passed
Halifax West High School	Boys WR tap 3 room C161	MUJ312	0.0007	Passed	0.1700	Passed
Halifax West High School	Staff WR tap room C160	MUJ313	0.0042	Passed	0.2200	Passed
Halifax West High School	Girls WR tap 1 room C162	MUJ314	0.0057	Exceeds Limit	0.3300	Passed
Halifax West High School	Girls WR tap 2 room C162	MUJ315	0.0000	Passed	0.2300	Passed
Halifax West High School	Girls WR tap 3 room C162	MUJ316	0.0000	Passed	0.1800	Passed
Halifax West High School	Girls WR tap 1 room C172	MUJ317	0.0000	Passed	0.1700	Passed
Halifax West High School	Girls WR tap 2 room C172	MUJ318	0.0000	Passed	0.2200	Passed
Halifax West High School	Girls WR tap 3 room C172	MUJ319	0.0043	Passed	0.3700	Passed
Halifax West High School	Staff WR tap room C170	MUJ320	0.0000	Passed	0.0470	Passed
Halifax West High School	Boys WR tap 1 room C171	MUJ321	0.0096	Exceeds Limit	0.4700	Passed
Halifax West High School	Boys WR tap 2 room C171	MUJ322	0.0000	Passed	0.5000	Passed
Halifax West High School	Boys WR tap 3 room C171	MUJ323	0.0000	Passed	0.2100	Passed
Halifax West High School	Fountain after room C171	MUJ324	0.0000	Passed	0.5500	Passed
Halifax West High School	GN WR tap room C152	MUJ325	0.0009	Passed	0.1800	Passed
Halifax West High School	JC tap After room C152	MUJ326	0.0000	Passed	0.0370	Passed
Halifax West High School	Girls WR tap 1 room A313	MUJ327	0.0033	Passed	0.2500	Passed
Halifax West High School	Girls WR tap 2 room A313	MUJ328	0.0000	Passed	0.1700	Passed
Halifax West High School	Girls WR tap 3 room A313	MUJ329	0.0000	Passed	0.1400	Passed
Halifax West High School	GN WR tap by room A312	MUJ330	0.0000	Passed	0.1800	Passed
Halifax West High School	Boys WR tap 1 room A312	MUJ331	0.0000	Passed	0.3500	Passed
Halifax West High School	Boys WR tap 2 room A312	MUJ332	0.0000	Passed	0.4200	Passed
Halifax West High School	Boys WR tap 3 room A312	MUJ333	0.0006	Passed	0.1900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Halifax West High School	3rd floor fountain after room A312	MUJ334	0.0000	Passed	0.3500	Passed
Halifax West High School	Chem lab tap 1 room A333	MUJ335	0.0000	Passed	0.4000	Passed
Halifax West High School	Chem lab tap 2 room A333	MUJ336	0.0000	Passed	0.4500	Passed
Halifax West High School	Chem lab tap 3 room A333	MUJ337	0.0005	Passed	0.2500	Passed
Halifax West High School	Chem lab tap 4 room A333	MUJ338	0.0000	Passed	0.9900	Passed
Halifax West High School	Chem lab tap 5 room A333	MUJ339	0.0000	Passed	0.6300	Passed
Halifax West High School	Chem lab tap 6 room A333	MUJ340	0.0010	Passed	0.3800	Passed
Halifax West High School	Chem lab tap 7 room A333	MUJ341	0.0008	Passed	0.3900	Passed
Halifax West High School	Chem lab tap 8 room A333	MUJ342	0.0007	Passed	0.4300	Passed
Halifax West High School	Chem lab tap 10 room A333	MUJ343	0.0005	Passed	0.3800	Passed
Halifax West High School	Chem lab tap 1 room A329	MUJ344	0.0006	Passed	0.3400	Passed
Halifax West High School	Chem lab tap 2 room A329	MUJ345	0.0009	Passed	0.1700	Passed
Halifax West High School	Chem lab tap 3 room A329	MUJ346	0.0000	Passed	0.4300	Passed
Halifax West High School	Chem lab tap 4 room A329	MUJ347	0.0013	Passed	0.3400	Passed
Halifax West High School	Chem lab tap 5 room A329	MUJ348	0.0016	Passed	0.3200	Passed
Halifax West High School	Chem lab tap 6 room A329	MUJ349	0.0000	Passed	0.5600	Passed
Halifax West High School	Chem lab tap 7 room A329	MUJ350	0.0000	Passed	0.4900	Passed
Halifax West High School	Chem lab tap 8 room A329	MUJ351	0.0008	Passed	0.3900	Passed
Halifax West High School	Chem lab tap 9 room A329	MUJ352	0.0000	Passed	0.3000	Passed
Halifax West High School	Boys WR tap 1 room A326	MUJ353	0.0043	Passed	0.1400	Passed
Halifax West High School	Boys WR tap 2 room A326	MUJ354	0.0000	Passed	0.3100	Passed
Halifax West High School	Boys WR tap 3 room A326	MUJ355	0.0000	Passed	0.2000	Passed
Halifax West High School	JC tap room A324	MUJ356	0.0008	Passed	0.0370	Passed
Halifax West High School	Girls WR tap 1 room A325	MUJ357	0.0000	Passed	0.1700	Passed
Halifax West High School	Girls WR tap 2 room A325	MUJ358	0.0000	Passed	0.1100	Passed
Halifax West High School	Girls WR tap 3 room A325	MUJ363	0.0026	Passed	0.1100	Passed
Halifax West High School	Fountain after girls WR	MUJ364	0.0000	Passed	0.4400	Passed
Halifax West High School	Staff WR tap room A321	MUJ365	0.0000	Passed	0.0830	Passed
Halifax West High School	Biology lab tap 1 room A319	MUJ366	0.0009	Passed	0.4500	Passed
Halifax West High School	Biology lab tap 2 room A319	MUJ367	0.0000	Passed	0.9300	Passed
Halifax West High School	Biology lab tap 3 room A319	MUJ368	0.0024	Passed	0.3300	Passed
Halifax West High School	Biology lab tap 4 room A319	MUJ369	0.0005	Passed	0.1000	Passed
Halifax West High School	Biology lab tap 5 room A319	MUJ370	0.0000	Passed	0.8500	Passed
Halifax West High School	Biology lab tap 6 room A319	MUJ371	0.0000	Passed	0.6000	Passed
Halifax West High School	Biology lab tap 7 room A319	MUJ372	0.0000	Passed	0.2000	Passed
Halifax West High School	Biology lab tap 1 room A318	MUJ388	0.0029	Passed	0.4300	Passed
Halifax West High School	Biology lab tap 2 room A318	MUJ389	0.0010	Passed	0.5300	Passed
Halifax West High School	Biology lab tap 3 room A318	MUJ390	0.0005	Passed	0.4300	Passed
Halifax West High School	Biology lab tap 4 room A318	MUJ391	0.0000	Passed	0.8500	Passed
Halifax West High School	Biology lab tap 5 room A318	MUJ392	0.0007	Passed	0.4100	Passed
Halifax West High School	CR tap room A317	MUJ393	0.0000	Passed	0.1000	Passed
Halifax West High School	GN WR tap room A315	MUJ394	0.0000	Passed	0.0660	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Halifax West High School	Fountain before room A311	MUJ395	0.0000	Passed	0.1500	Passed
Halifax West High School	JC tap room A311	MUJ396	0.0015	Passed	0.0800	Passed
Halifax West High School	Fountain by room C246	NAO727	0.0000	Passed	0.4300	Passed
Halifax West High School	Fountain by room C240	NAO727	0.0000	Passed	0.4300	Passed
Halifax West High School	Chem lab tap 9 room A333	NAO728	0.0000	Passed	0.5300	Passed
Hammonds Plains Consolidated School	GN WR tap room 220	MTV690	0.0000	Passed	0.0850	Passed
Hammonds Plains Consolidated School	CR tap room 219	MTV691	0.0000	Passed	0.2700	Passed
Hammonds Plains Consolidated School	Fountain room 219	MTV692	0.0000	Passed	0.1200	Passed
Hammonds Plains Consolidated School	Cafeteria/kitchen single compartment sink tap	MTV693	0.0007	Passed	0.1900	Passed
Hammonds Plains Consolidated School	Cafeteria/kitchen double compartment sink tap	MTV694	0.0000	Passed	0.0680	Passed
Hammonds Plains Consolidated School	Cafeteria/kitchen hand washing sink tap	MTV695	0.0000	Passed	0.0460	Passed
Hammonds Plains Consolidated School	Girls WR tap 1 room 225	MTV696	0.0000	Passed	0.1300	Passed
Hammonds Plains Consolidated School	Girls WR tap 2 room 225	MTV697	0.0000	Passed	0.1500	Passed
Hammonds Plains Consolidated School	Girls WR tap 3 room 225	MTV698	0.0000	Passed	0.1100	Passed
Hammonds Plains Consolidated School	Girls WR tap 4 room 225	MTV699	0.0000	Passed	0.1300	Passed
Hammonds Plains Consolidated School	Girls WR tap 5 room 225	MTV700	0.0000	Passed	0.0850	Passed
Hammonds Plains Consolidated School	JC tap by room 225	MTV701	0.0000	Passed	0.0440	Passed
Hammonds Plains Consolidated School	Fountain by room 225	MTV702	0.0000	Passed	0.0560	Passed
Hammonds Plains Consolidated School	Boys WR tap 1 by room 228	MTV703	0.0031	Passed	0.2800	Passed
Hammonds Plains Consolidated School	Boys WR tap 2 by room 228	MTV704	0.0015	Passed	0.2200	Passed
Hammonds Plains Consolidated School	Boys WR tap 3 by room 228	MTV705	0.0000	Passed	0.2300	Passed
Hammonds Plains Consolidated School	Staff GN WR tap room 203C	MTV706	0.0000	Passed	0.0210	Passed
Hammonds Plains Consolidated School	Staff GN WR tap room 203B	MTV707	0.0000	Passed	0.0220	Passed
Hammonds Plains Consolidated School	Staff room kitchen sink room 203	MTV708	0.0000	Passed	0.0440	Passed
Hammonds Plains Consolidated School	Fountain by room 204	MTV709	0.0036	Passed	0.1300	Passed
Hammonds Plains Consolidated School	CR tap room 209	MTV723	0.0130	Exceeds Limit	0.3300	Passed
Hammonds Plains Consolidated School	CR tap room 210	MTV724	0.0031	Passed	0.1500	Passed
Hammonds Plains Consolidated School	CR tap room 211	NLV788	0.0004	Passed	0.0040	Passed
Hammonds Plains Consolidated School	Staff GN WR tap room 238	MTV726	0.0000	Passed	0.0110	Passed
Hammonds Plains Consolidated School	Staff GN WR tap room 237	MTV727	0.0000	Passed	0.0068	Passed
Hammonds Plains Consolidated School	GN WR tap room 242	MTV728	0.0000	Passed	0.2300	Passed
Hammonds Plains Consolidated School	CR tap room 245	NLV789	0.0004	Passed	0.0070	Passed
Hammonds Plains Consolidated School	GN WR tap room 245A	MTV730	0.0000	Passed	0.0980	Passed
Hammonds Plains Consolidated School	GN WR tap room 246A	MTV731	0.0024	Passed	0.2800	Passed
Hammonds Plains Consolidated School	CR tap room 246	NLV790	0.0004	Passed	0.0080	Passed
Hammonds Plains Consolidated School	CR tap room 247	MTV733	0.0000	Passed	0.3700	Passed
Harbour View Elementary School	Fountain by room 213	MYY066	0.0010	Passed	0.3800	Passed
Harbour View Elementary School	CR tap room 214	MYY067	0.0059	Exceeds Limit	0.8900	Passed
Harbour View Elementary School	JC tap by rom 214	MYY068	0.0130	Exceeds Limit	0.1900	Passed
Harbour View Elementary School	Upstairs boys WR tap 1	MYY069	0.0460	Exceeds Limit	0.1500	Passed
Harbour View Elementary School	Upstairs boys WR tap 2	MYY070	0.0160	Exceeds Limit	0.1400	Passed
Harbour View Elementary School	Upstairs boys WR tap 3	MYY071	0.0120	Exceeds Limit	0.1500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Harbour View Elementary School	Upstairs boys WR tap 4	MY072	0.0130	Exceeds Limit	0.1500	Passed
Harbour View Elementary School	Upstairs Girls WR tap 1	MY073	0.0820	Exceeds Limit	0.3100	Passed
Harbour View Elementary School	Upstairs Girls WR tap 2	MY074	0.1900	Exceeds Limit	0.9800	Passed
Harbour View Elementary School	Upstairs Girls WR tap 3	MY075	0.0220	Exceeds Limit	0.2100	Passed
Harbour View Elementary School	Upstairs Girls WR tap 4	MY076	0.0068	Exceeds Limit	0.1400	Passed
Harbour View Elementary School	Fountain by room 215	MY077	0.0000	Passed	0.2900	Passed
Harbour View Elementary School	Fountain by room 204	MY078	0.0028	Passed	0.1800	Passed
Harbour View Elementary School	JC tap by room 204	MY079	0.0000	Passed	0.0190	Passed
Harbour View Elementary School	Fountain by room 208	MY080	0.0011	Passed	0.5400	Passed
Harbour View Elementary School	Student services WR tap	MY081	0.0055	Exceeds Limit	0.0590	Passed
Harbour View Elementary School	WR tap in caretaker room	MY082	0.0005	Passed	0.0300	Passed
Harbour View Elementary School	Fountain by room 115	NMK142	0.0013	Passed	0.0170	Passed
Harbour View Elementary School	Boys WR tap 1 by room 115	MY084	0.0120	Exceeds Limit	0.2800	Passed
Harbour View Elementary School	Boys WR tap 2 by room 115	MY085	0.0110	Exceeds Limit	0.2500	Passed
Harbour View Elementary School	Boys WR tap 3 by room 115	MY102	0.0800	Exceeds Limit	0.3000	Passed
Harbour View Elementary School	Boys WR tap 4 by room 115	MY103	0.0290	Exceeds Limit	0.3800	Passed
Harbour View Elementary School	Learning centre WR tap	MY104	0.0088	Exceeds Limit	0.3200	Passed
Harbour View Elementary School	Staff WR by learning centre	MY105	0.0000	Passed	0.0510	Passed
Harbour View Elementary School	JC tap by room 114	MY106	0.0006	Passed	0.0370	Passed
Harbour View Elementary School	Library WR tap	MY107	0.0120	Exceeds Limit	0.2900	Passed
Harbour View Elementary School	Staff room female WR tap 1	MY108	0.0610	Exceeds Limit	0.1700	Passed
Harbour View Elementary School	Staff room female WR tap 2	MY109	0.0049	Passed	0.2700	Passed
Harbour View Elementary School	staff room tap 1	MY110	0.0120	Exceeds Limit	0.1500	Passed
Harbour View Elementary School	Staff room tap 2 room 308	MY111	0.2000	Exceeds Limit	0.5900	Passed
Harbour View Elementary School	Staff room male WR tap 1	MY112	0.2000	Exceeds Limit	0.7600	Passed
Harbour View Elementary School	Staff room male WR tap 2	MY113	0.0270	Exceeds Limit	0.1700	Passed
Harbour View Elementary School	Staff WR tap in main office	MY114	0.0029	Passed	0.0970	Passed
Harbour View Elementary School	Main office kitchen tap	MY115	0.0021	Passed	0.1200	Passed
Harbour View Elementary School	Staff WR tap in main office	MY116	0.0650	Exceeds Limit	0.1500	Passed
Harbour View Elementary School	Gym office tap	MY117	0.0088	Exceeds Limit	0.1300	Passed
Harbour View Elementary School	Fountain by gym doors	MY118	0.0008	Passed	0.1800	Passed
Harbour View Elementary School	Boys WR tap 1 by gym doors	MY119	0.0590	Exceeds Limit	0.4000	Passed
Harbour View Elementary School	Boys WR tap 2 by gym doors	MY120	0.0130	Exceeds Limit	0.2400	Passed
Harbour View Elementary School	Boys WR tap 3 by gym doors	MY121	0.0140	Exceeds Limit	0.4900	Passed
Harbour View Elementary School	Girls WR tap 1 by gym doors	MY122	0.0056	Exceeds Limit	0.2500	Passed
Harbour View Elementary School	Girls WR tap 2 by gym doors	MY123	0.0031	Passed	0.1600	Passed
Harbour View Elementary School	Girls WR tap 3 by gym doors	MY124	0.0066	Exceeds Limit	0.1100	Passed
Harbour View Elementary School	JC in supplies room	MY125	0.0036	Passed	0.4000	Passed
Harbour View Elementary School	Breakfast room tap 1	NMK143	0.0004	Passed	0.0170	Passed
Harbour View Elementary School	Breakfast room tap 2	NMK144	0.0004	Passed	0.0150	Passed
Harbour View Elementary School	Fountain by room 111	MY128	0.0010	Passed	0.0550	Passed
Harbour View Elementary School	JC tap in boiler room	MY129	0.0082	Exceeds Limit	0.3000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Harold T. Barrett Junior High School	GN WR tap school counselor room	MTA010	0.0057	Exceeds Limit	0.1000	Passed
Harold T. Barrett Junior High School	Staff room WR 1 tap	MTA011	0.0008	Passed	0.0800	Passed
Harold T. Barrett Junior High School	Staff room WR 2 tap	MTA012	0.0009	Passed	0.0750	Passed
Harold T. Barrett Junior High School	Staff room kitchen tap	MTA013	0.0007	Passed	0.0740	Passed
Harold T. Barrett Junior High School	Boys WR tap 1 by staff room	MTA014	0.0015	Passed	0.4100	Passed
Harold T. Barrett Junior High School	Boys WR tap 2 by staff room	MTA015	0.0009	Passed	0.1100	Passed
Harold T. Barrett Junior High School	Fountain by staff room	MTA016	0.0000	Passed	1.6000	Passed
Harold T. Barrett Junior High School	Girls WR tap 1 by gym	MTA017	0.0020	Passed	1.4000	Passed
Harold T. Barrett Junior High School	Girls WR tap 2 by gym	MTA018	0.0011	Passed	0.3300	Passed
Harold T. Barrett Junior High School	Cafeteria kitchen tap 1	MTA019	0.0017	Passed	0.1200	Passed
Harold T. Barrett Junior High School	Cafeteria kitchen tap 2	MTA020	0.0014	Passed	0.0690	Passed
Harold T. Barrett Junior High School	Cafeteria kitchen tap 3	MTA021	0.0012	Passed	0.0560	Passed
Harold T. Barrett Junior High School	Industrial arts room tap by Elec. Room	MTA022	0.0017	Passed	0.1500	Passed
Harold T. Barrett Junior High School	Family studies tap 1	MTA023	0.0000	Passed	0.1600	Passed
Harold T. Barrett Junior High School	Family studies tap 2	MTA024	0.0013	Passed	0.4600	Passed
Harold T. Barrett Junior High School	JC tap by Mech. Room	MTA025	0.0000	Passed	0.0210	Passed
Harold T. Barrett Junior High School	GN WR tap room 107	MTA026	0.0110	Exceeds Limit	0.8600	Passed
Harold T. Barrett Junior High School	CR tap 1 room 203	MTA027	0.0065	Exceeds Limit	0.9400	Passed
Harold T. Barrett Junior High School	CR tap 2 room 203	MTA028	0.0008	Passed	0.4600	Passed
Harold T. Barrett Junior High School	CR tap 3 room 203	MTA029	0.0031	Passed	0.7200	Passed
Harold T. Barrett Junior High School	CR tap 4 room 203	MTA030	0.0091	Exceeds Limit	1.6000	Passed
Harold T. Barrett Junior High School	Girls WR tap 1 by room 205	MTA031	0.0230	Exceeds Limit	0.3700	Passed
Harold T. Barrett Junior High School	Girls WR tap 2 by room 205	MTA032	0.0120	Exceeds Limit	0.2100	Passed
Harold T. Barrett Junior High School	JC tap by room 205	MTA033	0.0009	Passed	0.2700	Passed
Harold T. Barrett Junior High School	Fountain by room 205	MTA034	0.0078	Exceeds Limit	0.2000	Passed
Harold T. Barrett Junior High School	Boys WR tap 1 by room 205	MTA035	0.0045	Passed	0.2400	Passed
Harold T. Barrett Junior High School	Boys WR tap 2 by room 205	MTA036	0.0016	Passed	0.1900	Passed
Harold T. Barrett Junior High School	Boys WR tap 1 by office	MTA037	0.0009	Passed	0.2800	Passed
Harold T. Barrett Junior High School	Boys WR tap 2 by office	MTA038	0.0009	Passed	0.2300	Passed
Harold T. Barrett Junior High School	Boys WR tap 3 by office	MTA039	0.0009	Passed	0.2000	Passed
Harold T. Barrett Junior High School	Fountain by office	MTA040	0.0021	Passed	0.2800	Passed
Harold T. Barrett Junior High School	Girls WR tap 1 by office	MTA041	0.0280	Exceeds Limit	0.3100	Passed
Harold T. Barrett Junior High School	Girls WR tap 2 by office	MTA042	0.0006	Passed	0.1900	Passed
Harold T. Barrett Junior High School	Girls WR tap 3 by office	MTA043	0.0007	Passed	0.2000	Passed
Harrietsfield Elementary School	Staff WR tap	MOV557	0.0041	Passed	0.1900	Passed
Harrietsfield Elementary School	Staff room tap	MOV558	0.0270	Exceeds Limit	0.2300	Passed
Harrietsfield Elementary School	Girls WR tap 1	MOV559	0.0046	Passed	0.0600	Passed
Harrietsfield Elementary School	Girls WR tap 2	MOV560	0.0036	Passed	0.1100	Passed
Harrietsfield Elementary School	Girls WR Tap 3	MOV561	0.0110	Exceeds Limit	0.1700	Passed
Harrietsfield Elementary School	Girls WR Tap 4	MOV562	0.0100	Exceeds Limit	0.3100	Passed
Harrietsfield Elementary School	Boys WR tap 1	MOV563	0.0022	Passed	0.4200	Passed
Harrietsfield Elementary School	Boys WR tap 2	MOV564	0.0022	Passed	0.3100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Harrietsfield Elementary School	Storage room #4	MOV565	0.7300	Exceeds Limit	0.2300	Passed
Harrietsfield Elementary School	Staff WR tap	MOV649	0.0025	Passed	0.1800	Passed
Harrietsfield Elementary School	Girls WR Tap 1	MOV650	0.0180	Exceeds Limit	0.4200	Passed
Harrietsfield Elementary School	Girls WR Tap 2	MOV651	0.0095	Exceeds Limit	0.2500	Passed
Harrietsfield Elementary School	Girls WR Tap 3	MOV652	0.0120	Exceeds Limit	0.2600	Passed
Harrietsfield Elementary School	Boys WR tap 1	MOV653	0.0029	Passed	0.3500	Passed
Harrietsfield Elementary School	boys WR Tap 2	MOV654	0.0063	Exceeds Limit	0.3100	Passed
Harrietsfield Elementary School	boys WR Tap 3	MOV655	0.0081	Exceeds Limit	0.3000	Passed
Harrietsfield Elementary School	JC tap	MOV656	0.0042	Passed	0.1800	Passed
Harrietsfield Elementary School	Boys WR tap 2	MRV010	0.0035	Passed	0.2600	Passed
Harrietsfield Elementary School	2nd floor fountain	MRV011	0.0008	Passed	0.0520	Passed
Harrietsfield Elementary School	1st floor fountain	MRV012	0.0110	Exceeds Limit	0.0950	Passed
Harry R. Hamilton Elementary School	sink tap room beside room 212	MUU017	0.0000	Passed	0.0210	Passed
Harry R. Hamilton Elementary School	Fountain by room 207	MUU018	0.0016	Passed	0.1000	Passed
Harry R. Hamilton Elementary School	Girls WR tap 1 across from room 211	MUU019	0.0150	Exceeds Limit	0.0500	Passed
Harry R. Hamilton Elementary School	Girls WR tap 2 across from room 211	MUU020	0.0076	Exceeds Limit	0.1200	Passed
Harry R. Hamilton Elementary School	Girls WR tap 3 across from room 211	MUU021	0.0310	Exceeds Limit	0.1600	Passed
Harry R. Hamilton Elementary School	Boys WR tap 1 across from elevator	MUU022	0.0029	Passed	0.0570	Passed
Harry R. Hamilton Elementary School	Boys WR tap 2 across from elevator	MUU023	0.0150	Exceeds Limit	0.0550	Passed
Harry R. Hamilton Elementary School	Boys WR tap 3 across from elevator	MUU024	0.0011	Passed	0.0330	Passed
Harry R. Hamilton Elementary School	Staff room WR tap	MUU025	0.0000	Passed	0.0200	Passed
Harry R. Hamilton Elementary School	Staff room Kitchen sink tap	MUU026	0.0000	Passed	0.0210	Passed
Harry R. Hamilton Elementary School	Staff room WR tap	MUU027	0.0013	Passed	0.0330	Passed
Harry R. Hamilton Elementary School	GN WR tap inside room 103	MUU028	0.0013	Passed	0.0940	Passed
Harry R. Hamilton Elementary School	GN WR tap inside room 104	MUU029	0.0021	Passed	0.0730	Passed
Harry R. Hamilton Elementary School	CR tap room 104	MUU030	0.0017	Passed	0.0970	Passed
Harry R. Hamilton Elementary School	sink tap room beside room 110	MUU031	0.0043	Passed	0.1500	Passed
Harry R. Hamilton Elementary School	Fountain beside boys WR	MUU032	0.0380	Exceeds Limit	0.4200	Passed
Harry R. Hamilton Elementary School	Gym office tap	MUU033	0.1700	Exceeds Limit	0.8900	Passed
Harry R. Hamilton Elementary School	Fountain beside gym doors	MUU034	0.0037	Passed	0.0660	Passed
Harry R. Hamilton Elementary School	Girls WR tap 1 across from room 109	MUU035	0.1000	Exceeds Limit	0.7000	Passed
Harry R. Hamilton Elementary School	Girls WR tap 2 across from room 109	MUU036	0.0140	Exceeds Limit	0.2000	Passed
Harry R. Hamilton Elementary School	Girls WR tap 3 across from room 109	MUU037	0.0220	Exceeds Limit	0.4600	Passed
Harry R. Hamilton Elementary School	Boys WR tap 1 across from elevator	MUU038	0.0730	Exceeds Limit	0.0680	Passed
Harry R. Hamilton Elementary School	Boys WR tap 2 across from elevator	MUU039	0.0250	Exceeds Limit	0.0950	Passed
Harry R. Hamilton Elementary School	Boys WR tap 3 across from elevator	MUU040	0.0310	Exceeds Limit	0.2100	Passed
Hawthorn Elementary School	CR tap room 26	MY206	0.0018	Passed	0.7700	Passed
Hawthorn Elementary School	CR tap room 21	MY207	0.0034	Passed	0.2400	Passed
Hawthorn Elementary School	Fountain by room 19	MY208	0.0009	Passed	0.1700	Passed
Hawthorn Elementary School	Boys WR tap 1 by room 20	MY209	0.0015	Passed	0.1000	Passed
Hawthorn Elementary School	Boys WR tap 2 by room 20	MY210	0.0040	Passed	0.2700	Passed
Hawthorn Elementary School	Boys WR tap 3 by room 20	MY211	0.0120	Exceeds Limit	0.1800	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Hawthorn Elementary School	Boys WR tap 4 by room 20	MY212	0.0170	Exceeds Limit	0.4200	Passed
Hawthorn Elementary School	JC tap by GN WR	MY213	0.0009	Passed	0.0950	Passed
Hawthorn Elementary School	GN WR tap	MY214	0.0013	Passed	0.0720	Passed
Hawthorn Elementary School	Girls WR tap 1 by room 28	MY215	0.0061	Exceeds Limit	0.4500	Passed
Hawthorn Elementary School	Girls WR tap 2 by room 28	MY216	0.0049	Passed	0.2000	Passed
Hawthorn Elementary School	Girls WR tap 3 by room 28	MY217	0.0110	Exceeds Limit	0.5500	Passed
Hawthorn Elementary School	Girls WR tap 4 by room 28	MY218	0.0130	Exceeds Limit	0.1800	Passed
Hawthorn Elementary School	CR tap room 15	MY219	0.0022	Passed	0.1700	Passed
Hawthorn Elementary School	Staff room Female WR tap 1	MY220	0.0042	Passed	0.2600	Passed
Hawthorn Elementary School	Staff room Female WR tap 2	MY221	0.0007	Passed	0.0750	Passed
Hawthorn Elementary School	Staff room male WR tap	MY222	0.0840	Exceeds Limit	0.6200	Passed
Hawthorn Elementary School	Staff room kitchen tap	MY223	0.0037	Passed	0.0790	Passed
Hawthorn Elementary School	CR tap room 13	MY224	0.0063	Exceeds Limit	0.7500	Passed
Hawthorn Elementary School	CR tap room 11	MY225	0.0035	Passed	0.5100	Passed
Hawthorn Elementary School	Fountain by boys WR	NM075	0.0004	Passed	0.0050	Passed
Hawthorn Elementary School	CR tap room 12	MY230	0.0220	Exceeds Limit	0.3400	Passed
Hawthorn Elementary School	Boys WR tap 1 by room 12	MY231	0.0320	Exceeds Limit	0.2400	Passed
Hawthorn Elementary School	Boys WR tap 2 by room 12	MY232	0.0071	Exceeds Limit	0.1700	Passed
Hawthorn Elementary School	Boys WR tap 3 by room 12	MY233	0.0200	Exceeds Limit	0.6300	Passed
Hawthorn Elementary School	JC tap by room 12	MY234	0.0037	Passed	0.1200	Passed
Hawthorn Elementary School	Girls WR tap 1 by room 17	MY235	0.0093	Exceeds Limit	0.5200	Passed
Hawthorn Elementary School	Girls WR tap 2 by room 17	MY236	0.0069	Exceeds Limit	0.2600	Passed
Hawthorn Elementary School	Girls WR tap 3 by room 17	MY237	0.0084	Exceeds Limit	0.6300	Passed
Hawthorn Elementary School	Girls WR tap 4 by room 17	MY238	0.0620	Exceeds Limit	0.9200	Passed
Hawthorn Elementary School	CR tap room 7	MY239	0.0041	Passed	0.4100	Passed
Hawthorn Elementary School	Staff WR tap by room 7	MY240	0.0032	Passed	0.3500	Passed
Hawthorn Elementary School	Girls WR tap 1 by staff WR	MY241	0.0052	Exceeds Limit	0.3000	Passed
Hawthorn Elementary School	Girls WR tap 2 by staff WR	MY242	0.0240	Exceeds Limit	0.2800	Passed
Hawthorn Elementary School	Girls WR tap 3 by staff WR	MY243	0.0038	Passed	0.2400	Passed
Hawthorn Elementary School	CR tap by room 6	MY244	0.0120	Exceeds Limit	0.3900	Passed
Hawthorn Elementary School	Lab sink tap by room 6	MY245	0.0120	Exceeds Limit	0.0360	Passed
Hawthorn Elementary School	Boys WR tap 1 near room 6	MY246	0.0160	Exceeds Limit	0.1900	Passed
Hawthorn Elementary School	Boys WR tap 2 near room 6	MY247	0.0041	Passed	0.1800	Passed
Hawthorn Elementary School	Boys WR tap 3 near room 6	MY248	0.0018	Passed	0.0560	Passed
Hawthorn Elementary School	JC tap in sink room	MY249	0.0007	Passed	0.0550	Passed
Hawthorn Elementary School	Caretaker room tap	MY250	0.0022	Passed	0.3700	Passed
Hawthorn Elementary School	Pre-primary room kitchen tap	NM075	0.0004	Passed	0.0280	Passed
Hawthorn Elementary School	Fountain by music room	NM076	0.0016	Passed	0.0260	Passed
Herring Cove Junior High School	Boys WR tap 1 by room 321	MQ625	0.0027	Passed	0.2900	Passed
Herring Cove Junior High School	Boys WR tap 2 by room 321	MQ626	0.0013	Passed	0.2200	Passed
Herring Cove Junior High School	Fountain between room 324 and Girls WR	MQ627	0.0039	Passed	4.1000	Exceeds Limit
Herring Cove Junior High School	Girls WR tap 1 by room 326	MQ628	0.0034	Passed	0.0430	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Herring Cove Junior High School	Girls WR tap 2 by room 326	MQS629	0.0008	Passed	0.0140	Passed
Herring Cove Junior High School	Girls WR tap 3 by room 326	MQS630	0.0012	Passed	0.0120	Passed
Herring Cove Junior High School	CR tap room 327	MQS631	0.0033	Passed	0.0500	Passed
Herring Cove Junior High School	CR tap room 328	MQS632	0.0000	Passed	0.0110	Passed
Herring Cove Junior High School	CR Kitchen tap room 326	MQS633	0.0230	Exceeds Limit	0.3600	Passed
Herring Cove Junior High School	JC tap room 324	MQS634	0.0190	Exceeds Limit	0.0630	Passed
Herring Cove Junior High School	Fountain by room 224	MQS639	0.0014	Passed	0.0990	Passed
Herring Cove Junior High School	JC tap room 224	MQS640	0.0210	Exceeds Limit	0.1400	Passed
Herring Cove Junior High School	Boys WR tap 1 between rm 224 and 228	MQS641	0.0290	Exceeds Limit	0.1900	Passed
Herring Cove Junior High School	Boys WR tap 2 between rm 224 and 228	MQS642	0.0009	Passed	0.0810	Passed
Herring Cove Junior High School	GN WR tap room 229	MQS643	0.0034	Passed	0.2200	Passed
Herring Cove Junior High School	Girls WR tap 1 by room 232	MQS644	0.0015	Passed	0.3200	Passed
Herring Cove Junior High School	Girls WR tap 2 by room 232	MQS645	0.0022	Passed	0.2300	Passed
Herring Cove Junior High School	SR tap room 210	NNS687	0.0009	Passed	0.0140	Passed
Herring Cove Junior High School	CR basin tap room 214	MQS647	0.0007	Passed	0.1000	Passed
Herring Cove Junior High School	Photocopy room tap	MQS648	0.5900	Exceeds Limit	0.6400	Passed
Herring Cove Junior High School	Kitchen tap 1 room 114	MQS649	0.0006	Passed	0.0700	Passed
Herring Cove Junior High School	Kitchen tap 2 room 114	NNS689	0.0019	Passed	0.0340	Passed
Herring Cove Junior High School	Kitchen tap 3 room 114	MQS651	0.0044	Passed	0.2700	Passed
Herring Cove Junior High School	Kitchen tap 4 room 114	NNS691	0.0008	Passed	0.0260	Passed
Herring Cove Junior High School	Kitchen tap room 115	NNS692	0.0009	Passed	0.0270	Passed
Herring Cove Junior High School	Basement boys WR tap 1	MQS654	0.0150	Exceeds Limit	0.3000	Passed
Herring Cove Junior High School	Basement boys WR tap 2	MQS655	0.0047	Passed	0.2700	Passed
Herring Cove Junior High School	JC tap room 131	MQS656	0.0099	Exceeds Limit	0.2200	Passed
Herring Cove Junior High School	Fountain by room 131	MQS657	0.0007	Passed	0.1200	Passed
Herring Cove Junior High School	Basement girls WR tap 1	MQS658	0.0060	Exceeds Limit	0.3600	Passed
Herring Cove Junior High School	Basement girls WR tap 2	MQS710	0.0012	Passed	0.2400	Passed
Herring Cove Junior High School	Basement girls WR tap 3	MQS711	0.0029	Passed	0.2000	Passed
Herring Cove Junior High School	Kitchen tap room 113	MQS712	0.9000	Exceeds Limit	0.2300	Passed
Herring Cove Junior High School	CR tap room 117	MQS713	0.0380	Exceeds Limit	0.3900	Passed
Herring Cove Junior High School	Gym Kitchen Wash Sink tap	MRV313	0.0004	Passed	0.0220	Passed
Herring Cove Junior High School	Gym Kitchen Sink 1 tap	MRV314	0.0004	Passed	0.0280	Passed
Herring Cove Junior High School	Gym Kitchen Sink 2 tap	MRV315	0.0004	Passed	0.0290	Passed
Highland Park Junior High School	fountain by room 400	MSH470	0.0000	Passed	0.0150	Passed
Highland Park Junior High School	Family studies room tap 1 room 400	MSH471	0.0000	Passed	0.4300	Passed
Highland Park Junior High School	Family studies room tap 2 room 400	MSH472	0.0000	Passed	0.0470	Passed
Highland Park Junior High School	Family studies room tap 3 room 400	MSH473	0.0000	Passed	0.0400	Passed
Highland Park Junior High School	Family studies room tap 4 room 400	MSH474	0.0000	Passed	0.0290	Passed
Highland Park Junior High School	Family studies room tap 5 room 400	MSH475	0.0000	Passed	0.0150	Passed
Highland Park Junior High School	staff room tap room 401	MSH476	0.0000	Passed	0.0160	Passed
Highland Park Junior High School	Boys WR tap 1 by room 401	MSH477	0.0020	Passed	0.0140	Passed
Highland Park Junior High School	Boys WR tap 2 by room 401	MSH478	0.0008	Passed	0.0140	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Highland Park Junior High School	Boys WR tap 3 by room 401	MSH479	0.0012	Passed	0.0150	Passed
Highland Park Junior High School	Boys WR tap 4 by room 401	MSH480	0.0023	Passed	0.0210	Passed
Highland Park Junior High School	4th floor JC tap	MSH481	0.0006	Passed	0.0120	Passed
Highland Park Junior High School	4th floor girls WR tap 2	MSH483	0.0011	Passed	0.0410	Passed
Highland Park Junior High School	4th floor girls WR tap 3	MSH484	0.0000	Passed	0.0280	Passed
Highland Park Junior High School	4th floor girls WR tap 4	MSH485	0.0000	Passed	0.0270	Passed
Highland Park Junior High School	CR tap room 407	MSH486	0.0031	Passed	0.4400	Passed
Highland Park Junior High School	CR tap room 409	MSH487	0.0025	Passed	0.3300	Passed
Highland Park Junior High School	CR tap room 301	MSH488	0.0006	Passed	0.0910	Passed
Highland Park Junior High School	CR tap room 300	MSH489	0.0000	Passed	0.0540	Passed
Highland Park Junior High School	Teachers room tap room 204	MSH490	0.0000	Passed	0.0530	Passed
Highland Park Junior High School	Staff room WR 1 tap room 204	MSH491	0.0000	Passed	0.0170	Passed
Highland Park Junior High School	Fountain beside room 204	MSH493	0.0000	Passed	0.1100	Passed
Highland Park Junior High School	Principals office WR tap room 202	MSH494	0.0000	Passed	0.0130	Passed
Highland Park Junior High School	GN WR tap room 200	MSH495	0.0000	Passed	0.0170	Passed
Highland Park Junior High School	CR tap room 203	MSH496	0.0014	Passed	0.0350	Passed
Highland Park Junior High School	Caretakers office tap room 205	MSH497	0.0023	Passed	0.0089	Passed
Highland Park Junior High School	Fountain by gym	MSH498	0.0006	Passed	0.1300	Passed
Highland Park Junior High School	Phys Ed Office Tap	MSP301	0.0021	Passed	0.0320	Passed
Highland Park Junior High School	Boiler Room Tap	MSP302	0.0000	Passed	0.0190	Passed
Highland Park Junior High School	4th floor girls WR tap 1	NFE702	0.0007	Passed	0.0390	Passed
Highland Park Junior High School	2nd floor staff WR 2 tap room 204	NFE719	0.0000	Passed	0.0048	Passed
Hillside Park Elementary School	1st floor boys WR tap 1	MPX259	0.3300	Exceeds Limit	0.3000	Passed
Hillside Park Elementary School	1st floor boys WR tap 2	MPX260	0.0200	Exceeds Limit	0.1400	Passed
Hillside Park Elementary School	1st floor boys WR tap 3	MPX261	0.0017	Passed	0.0480	Passed
Hillside Park Elementary School	1st floor JC tap	MPX262	0.0027	Passed	0.1100	Passed
Hillside Park Elementary School	1st Floor Girls WR tap 1	MPX263	0.0460	Exceeds Limit	0.1900	Passed
Hillside Park Elementary School	1st floor Girls WR tap 2	MPX264	0.0200	Exceeds Limit	0.1700	Passed
Hillside Park Elementary School	1st floor Girls WR tap 3	MPX265	0.3400	Exceeds Limit	0.6300	Passed
Hillside Park Elementary School	CR tap room 108	MPX266	0.0083	Exceeds Limit	0.2500	Passed
Hillside Park Elementary School	Learning Centre Tap room 109	NJG766	0.0005	Passed	0.0190	Passed
Hillside Park Elementary School	CR tap room 110	MPX268	0.0073	Exceeds Limit	0.1600	Passed
Hillside Park Elementary School	2nd floor fountain by room 204	MPX269	0.0032	Passed	0.4700	Passed
Hillside Park Elementary School	CR tap room 207	MPX270	0.0015	Passed	0.1300	Passed
Hillside Park Elementary School	CR tap room 206	MPX271	0.0056	Exceeds Limit	0.2400	Passed
Hillside Park Elementary School	Staff room kitchen tap room 203	MPX272	0.0000	Passed	0.0360	Passed
Hillside Park Elementary School	Staff room female WR tap room 203	MPX273	0.0240	Exceeds Limit	0.1300	Passed
Hillside Park Elementary School	Staff room male WR tap room 203	MPX274	0.0022	Passed	0.0500	Passed
Hillside Park Elementary School	CR tap room 220	MPX275	0.0050	Passed	0.4500	Passed
Hillside Park Elementary School	2nd Floor music room tap	MPX276	0.0420	Exceeds Limit	0.7200	Passed
Hillside Park Elementary School	Gym office WR tap	MPX277	0.0570	Exceeds Limit	0.2100	Passed
Hillside Park Elementary School	2nd floor kitchen tap	MPX278	0.0200	Exceeds Limit	0.2000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Hillside Park Elementary School	2nd floor boys WR tap	MPX279	0.0030	Passed	0.2100	Passed
Hillside Park Elementary School	Fountain by room 220	NJG767	0.0034	Passed	0.1300	Passed
Hillside Park Elementary School	2nd floor girls WR tap	MPX281	0.0560	Exceeds Limit	0.1700	Passed
Hillside Park Elementary School	2nd floor JC tap	MPX282	0.0070	Exceeds Limit	0.2000	Passed
Hillside Park Elementary School	Library room tap room 218	MPX283	0.2100	Exceeds Limit	0.9300	Passed
Hillside Park Elementary School	3rd floor fountain	NJG768	0.0006	Passed	0.0190	Passed
Hillside Park Elementary School	3rd floor girls WR tap 1	MPX285	0.0072	Exceeds Limit	0.0680	Passed
Hillside Park Elementary School	3rd floor girls WR tap 2	MPX286	0.0120	Exceeds Limit	0.0520	Passed
Hillside Park Elementary School	3rd floor girls WR tap 3	MPX287	0.0260	Exceeds Limit	0.1100	Passed
Hillside Park Elementary School	3rd floor JC tap	MPX288	0.0056	Exceeds Limit	0.1300	Passed
Hillside Park Elementary School	3rd floor boys WR tap 1	MQK117	0.0410	Exceeds Limit	0.1500	Passed
Hillside Park Elementary School	3rd floor boys WR tap 2	MQK118	0.0470	Exceeds Limit	0.0600	Passed
Hillside Park Elementary School	3rd floor boys WR tap 3	MQK119	0.0120	Exceeds Limit	0.0410	Passed
Holland Road Elementary School	CR tap room 172	MWI032	0.0011	Passed	0.2500	Passed
Holland Road Elementary School	CR tap room 171	MWI033	0.0007	Passed	0.0770	Passed
Holland Road Elementary School	CR tap room 170	MWI034	0.0005	Passed	0.0700	Passed
Holland Road Elementary School	Primary WR tap room 169	MWI035	0.0000	Passed	0.0680	Passed
Holland Road Elementary School	Fountain by room 170	MWI036	0.0000	Passed	0.3700	Passed
Holland Road Elementary School	Boys WR tap room 172	MWI037	0.0000	Passed	0.0760	Passed
Holland Road Elementary School	Girls WR tap 1 room 173	MWI038	0.0044	Passed	0.0890	Passed
Holland Road Elementary School	Girls WR tap 2 room 173	MWI039	0.0000	Passed	0.0660	Passed
Holland Road Elementary School	CR tap room 123	MWI040	0.0010	Passed	0.0950	Passed
Holland Road Elementary School	CR WR tap room 123	MWI041	0.0008	Passed	0.1900	Passed
Holland Road Elementary School	JC tap by room 123	MWI042	0.0023	Passed	0.1300	Passed
Holland Road Elementary School	CR WR tap room 126	MWI043	0.0013	Passed	0.1700	Passed
Holland Road Elementary School	CR tap room 126	MWI044	0.0000	Passed	0.0340	Passed
Holland Road Elementary School	CR tap room 122	MWI045	0.0029	Passed	0.2500	Passed
Holland Road Elementary School	CR tap room 128	MWI046	0.0010	Passed	0.1700	Passed
Holland Road Elementary School	Music room tap room 130	MWI047	0.0031	Passed	0.0970	Passed
Holland Road Elementary School	CR WR tap room 136	MWI048	0.0013	Passed	0.1600	Passed
Holland Road Elementary School	Boys WR tap 1 by room 136	MWI049	0.0000	Passed	0.0790	Passed
Holland Road Elementary School	Boys WR tap 2 by room 136	MWI050	0.0006	Passed	0.0990	Passed
Holland Road Elementary School	Mech. Room tap across from library	MWI051	0.0019	Passed	0.1000	Passed
Holland Road Elementary School	Fountain across from library	MWI052	0.0022	Passed	0.1400	Passed
Holland Road Elementary School	Girls WR tap 1 by main office	MWI053	0.0000	Passed	0.0440	Passed
Holland Road Elementary School	Girls WR tap 2 by main office	MWI054	0.0018	Passed	0.0660	Passed
Holland Road Elementary School	Girls WR tap 3 by main office	MWI055	0.0006	Passed	0.0240	Passed
Holland Road Elementary School	Staff room WR #1 tap	MWI056	0.0015	Passed	0.2200	Passed
Holland Road Elementary School	Staff room WR #2 tap	MWI057	0.0000	Passed	0.2400	Passed
Holland Road Elementary School	Staff room kitchen tap	MWI058	0.0015	Passed	0.1800	Passed
Holland Road Elementary School	Kitchen tap 1 room 145	MWI059	0.0048	Passed	0.1200	Passed
Holland Road Elementary School	Kitchen tap 2 room 145	MWI060	0.0010	Passed	0.1000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Holland Road Elementary School	Boys locker room tap room 172	MWI061	0.0064	Exceeds Limit	0.0780	Passed
Holland Road Elementary School	Gym office WR tap room 149	MWI062	0.0067	Exceeds Limit	0.0780	Passed
Holland Road Elementary School	Girls locker room tap by room 149	MWI063	0.0017	Passed	0.0850	Passed
Holland Road Elementary School	Fountain by gym	MWI064	0.0010	Passed	0.2500	Passed
Holland Road Elementary School	CR tap room 131	MYZ639	0.0160	Exceeds Limit	0.4200	Passed
Humber Park Elementary School	JC tap room 33	MXK117	0.0053	Exceeds Limit	0.2700	Passed
Humber Park Elementary School	Girls gym change room tap	MXK118	0.0140	Exceeds Limit	0.4200	Passed
Humber Park Elementary School	Boys gym change room tap	MXK119	0.0065	Exceeds Limit	0.5900	Passed
Humber Park Elementary School	Fountain by gym door	MXK120	0.0024	Passed	0.1500	Passed
Humber Park Elementary School	Boys WR tap 1 room 8	MXK121	0.0150	Exceeds Limit	0.1800	Passed
Humber Park Elementary School	Boys WR tap 2 room 8	MXK122	0.0063	Exceeds Limit	0.0920	Passed
Humber Park Elementary School	Boys WR tap 3 room 8	MXK123	0.0042	Passed	0.0580	Passed
Humber Park Elementary School	Boys WR tap 4 room 8	MXK124	0.0000	Passed	0.0260	Passed
Humber Park Elementary School	JC tap room 9	MXK125	0.0005	Passed	0.0100	Passed
Humber Park Elementary School	Fountain by boys WR (Rm 8)	MXK126	0.0037	Passed	0.0390	Passed
Humber Park Elementary School	Fountain by Girls WR (Rm 7)	MXK129	0.0023	Passed	0.0360	Passed
Humber Park Elementary School	Girls WR tap 1 room 7	MXK130	0.0030	Passed	0.0580	Passed
Humber Park Elementary School	Girls WR tap 2 room 7	MXK131	0.0020	Passed	0.0350	Passed
Humber Park Elementary School	Girls WR tap 3 room 7	MXK132	0.0006	Passed	0.0140	Passed
Humber Park Elementary School	Girls WR tap 4 room 7	MXK133	0.0000	Passed	0.0110	Passed
Humber Park Elementary School	Staff room WR #1 tap room 26	MXK134	0.0006	Passed	0.0140	Passed
Humber Park Elementary School	Staff room kitchen tap	MXK135	0.0000	Passed	0.0071	Passed
Humber Park Elementary School	Staff room WR #2 tap by room 26	MXK136	0.0019	Passed	0.2100	Passed
Ian Forsyth Elementary School	JC tap room 206	MWI424	0.0370	Exceeds Limit	0.2200	Passed
Ian Forsyth Elementary School	Staff room WR tap room 204	MWI425	0.0056	Exceeds Limit	0.3400	Passed
Ian Forsyth Elementary School	VP office tap 2 room 202	MWI427	0.0051	Exceeds Limit	0.1400	Passed
Ian Forsyth Elementary School	Girls WR tap 1 room 142	MWI428	0.0130	Exceeds Limit	0.1900	Passed
Ian Forsyth Elementary School	Girls WR tap 2 room 142	MWI429	0.0053	Exceeds Limit	0.1900	Passed
Ian Forsyth Elementary School	Girls WR tap 3 room 142	MWI430	0.0070	Exceeds Limit	0.1900	Passed
Ian Forsyth Elementary School	Girls WR tap 4 room 142	MWI431	0.0360	Exceeds Limit	0.2300	Passed
Ian Forsyth Elementary School	JC tap room 141	MWI432	0.0022	Passed	0.1800	Passed
Ian Forsyth Elementary School	Boys WR tap 1 room 139	MWI434	0.0059	Exceeds Limit	0.1000	Passed
Ian Forsyth Elementary School	Boys WR tap 2 room 139	MWI435	0.0008	Passed	0.0600	Passed
Ian Forsyth Elementary School	Boys WR tap 3 room 139	MWI436	0.0019	Passed	0.0690	Passed
Ian Forsyth Elementary School	Boys WR tap 4 room 139	MWI437	0.0025	Passed	0.1200	Passed
Ian Forsyth Elementary School	CR tap room 129	MWI438	0.0038	Passed	0.5400	Passed
Ian Forsyth Elementary School	VP office tap room 202	NBS099	0.0820	Exceeds Limit	0.6700	Passed
Ian Forsyth Elementary School	Staff room tap room 103	NDP116	0.0420	Exceeds Limit	0.1900	Passed
Ian Forsyth Elementary School	Staff room WR tap room 103	NDP117	0.0250	Exceeds Limit	0.2100	Passed
Ian Forsyth Elementary School	Sick room tap room 104	NDP118	0.0200	Exceeds Limit	0.2600	Passed
Ian Forsyth Elementary School	Fountain by sick room	NDP119	0.0260	Exceeds Limit	0.4800	Passed
Ian Forsyth Elementary School	Gym kitchen tap	NDP120	0.1100	Exceeds Limit	0.4000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Ian Forsyth Elementary School	Boys WR tap 1 by room 111	NDP121	0.1900	Exceeds Limit	0.5700	Passed
Ian Forsyth Elementary School	Boys WR tap 2 by room 111	NDP122	0.1000	Exceeds Limit	0.3500	Passed
Ian Forsyth Elementary School	Boys WR tap 3 by room 111	NDP123	0.1500	Exceeds Limit	0.7700	Passed
Ian Forsyth Elementary School	JC tap room 108	NDP124	0.0410	Exceeds Limit	0.2800	Passed
Ian Forsyth Elementary School	Girls WR tap 1 by room 106	NDP125	0.0076	Exceeds Limit	0.1200	Passed
Ian Forsyth Elementary School	Girls WR tap 2 by room 106	NDP171	0.0220	Exceeds Limit	0.1900	Passed
Ian Forsyth Elementary School	Girls WR tap 3 by room 106	NDP172	0.1700	Exceeds Limit	0.5700	Passed
Ian Forsyth Elementary School	Girls WR tap 1 by room 123	NDP173	0.0780	Exceeds Limit	0.3200	Passed
Ian Forsyth Elementary School	Girls WR tap 2 by room 123	NDP174	0.0150	Exceeds Limit	0.2300	Passed
Ian Forsyth Elementary School	Girls WR tap 3 by room 123	NDP175	0.0059	Exceeds Limit	0.0660	Passed
Ian Forsyth Elementary School	Boys WR tap 1 by room 125	NDP176	0.0210	Exceeds Limit	0.0810	Passed
Ian Forsyth Elementary School	Boys WR tap 2 by room 125	NDP177	0.0120	Exceeds Limit	0.2100	Passed
Ian Forsyth Elementary School	Boys WR tap 3 by room 125	NDP178	0.1100	Exceeds Limit	1.0000	Passed
Ian Forsyth Elementary School	Girls WR tap 4 by room 123	NDP179	0.0220	Exceeds Limit	0.2100	Passed
Ian Forsyth Elementary School	Main office tap	NDP180	0.2500	Exceeds Limit	0.6000	Passed
Ian Forsyth Elementary School	Main office WR tap	NDP229	0.3400	Exceeds Limit	0.3800	Passed
Ian Forsyth Elementary School	JC tap room 127	NDP230	0.0690	Exceeds Limit	0.4300	Passed
Ian Forsyth Elementary School	Fountain by room 140	NDP231	0.1100	Exceeds Limit	0.6900	Passed
Ian Forsyth Elementary School	Fountain by room 130	NDP232	0.0210	Exceeds Limit	1.5000	Passed
Ian Forsyth Elementary School	Fountain by room 126	NDP233	0.0007	Passed	0.7000	Passed
Ian Forsyth Elementary School	Fountain on 2nd floor	NDP234	0.0006	Passed	0.9200	Passed
Inglis Street Elementary School	Caretaker room WR tap room 312	MTA096	0.0007	Passed	0.0950	Passed
Inglis Street Elementary School	YMCA room WR tap room 311	MTA097	0.0000	Passed	0.0360	Passed
Inglis Street Elementary School	Fountain by room 311	MTA098	0.0013	Passed	0.5800	Passed
Inglis Street Elementary School	JC tap room 307	MTA099	0.0013	Passed	0.0740	Passed
Inglis Street Elementary School	Girls WR tap 1 room 308	MTA100	0.0017	Passed	0.1600	Passed
Inglis Street Elementary School	Girls WR tap 2 room 308	MTA101	0.0009	Passed	0.0730	Passed
Inglis Street Elementary School	Girls WR tap 3 room 308	MTA102	0.0007	Passed	0.0400	Passed
Inglis Street Elementary School	CR tap room 305	NLK012	0.0004	Passed	0.0050	Passed
Inglis Street Elementary School	CR tap room 302	MTA104	0.0024	Passed	0.2000	Passed
Inglis Street Elementary School	Boys WR tap 1 room 301	MTA105	0.0014	Passed	0.0470	Passed
Inglis Street Elementary School	Boys WR tap 2 room 301	MTA106	0.0028	Passed	0.0780	Passed
Inglis Street Elementary School	Boys WR tap 3 room 301	MTA107	0.0052	Exceeds Limit	0.0970	Passed
Inglis Street Elementary School	Principals office WR tap room 209	MTA108	0.0000	Passed	0.0220	Passed
Inglis Street Elementary School	Fountain by room 209	MTA109	0.0026	Passed	1.1000	Passed
Inglis Street Elementary School	Staff room tap room 208	NLK011	0.0005	Passed	0.0050	Passed
Inglis Street Elementary School	CR WR tap room 206	MTA111	0.0000	Passed	0.0061	Passed
Inglis Street Elementary School	Girls WR tap 1 room 205	MTA112	0.0000	Passed	0.0120	Passed
Inglis Street Elementary School	Girls WR tap 2 room 205	MTA113	0.0000	Passed	0.0063	Passed
Inglis Street Elementary School	Girls WR tap 3 room 205	MTA114	0.0000	Passed	0.0054	Passed
Inglis Street Elementary School	JC tap room 204	MTA115	0.0011	Passed	0.1500	Passed
Inglis Street Elementary School	Boys WR tap 1 room 200	MTA116	0.0015	Passed	0.2100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Inglis Street Elementary School	Boys WR tap 2 room 200	MTA117	0.0008	Passed	0.0130	Passed
Inglis Street Elementary School	Boys WR tap 3 room 200	MTA118	0.0021	Passed	0.0410	Passed
Inglis Street Elementary School	Boys WR tap 4 room 200	MTA119	0.0015	Passed	0.1300	Passed
Inglis Street Elementary School	Fountain by gym	NLK013	0.0017	Passed	0.1500	Passed
Inglis Street Elementary School	Gym office WR tap	MTA121	0.0019	Passed	0.1200	Passed
Inglis Street Elementary School	Basement JC tap	MTA122	0.0010	Passed	0.2600	Passed
Inglis Street Elementary School	CR tap room 112	MTA123	0.0000	Passed	0.0210	Passed
Inglis Street Elementary School	GN WR tap 1	MTA124	0.0005	Passed	0.0240	Passed
Inglis Street Elementary School	GN WR tap 2 by room 325	MTA125	0.0000	Passed	0.0200	Passed
Inglis Street Elementary School	Bst Boiler Room tap	MUV553	0.0021	Passed	0.1300	Passed
Inglis Street Elementary School	Bst CR	MUV554	0.0011	Passed	0.0490	Passed
Inglis Street Elementary School	Bst Fountain	MUV555	0.0014	Passed	0.3500	Passed
Island View High School	GN WR tap room 304H.1	MYZ388	0.0006	Passed	0.0700	Passed
Island View High School	GN WR tap room 304G	MZD660	0.0033	Passed	0.6300	Passed
Island View High School	GN WR tap room 304F	MZD661	0.0073	Exceeds Limit	0.5200	Passed
Island View High School	GN WR tap room 304E	MZD662	0.0010	Passed	0.1100	Passed
Island View High School	GN WR tap room 304D	MZD663	0.0055	Exceeds Limit	0.9400	Passed
Island View High School	GN WR tap room 304C	MZD664	0.0050	Passed	0.8500	Passed
Island View High School	GN WR tap room 304B	MZD665	0.0014	Passed	0.1900	Passed
Island View High School	GN WR tap room 304A	MZD666	0.0044	Passed	0.3800	Passed
Island View High School	JC TAP ROOM 208B.1	MZD667	0.0000	Passed	0.3800	Passed
Island View High School	CR TAP 1 ROOM 327.1	MZD668	0.0000	Passed	0.1900	Passed
Island View High School	CR TAP 2 ROOM 327.1	MZD669	0.0012	Passed	2.5000	Exceeds Limit
Island View High School	Fountain by room 327.1	MZD670	0.0000	Passed	0.3000	Passed
Island View High School	Life Sci. lab tap 1 room 315.1	MZD671	0.0066	Exceeds Limit	0.2000	Passed
Island View High School	Life Sci. lab tap 2 room 315.1	MZD672	0.0006	Passed	0.0960	Passed
Island View High School	Life Sci. lab tap 3 room 315.1	MZD673	0.0037	Passed	0.4400	Passed
Island View High School	Life Sci. lab tap 4 room 315.1	MZD674	0.0005	Passed	0.2800	Passed
Island View High School	Life Sci. lab tap 5 room 315.1	MZD675	0.0000	Passed	1.1000	Passed
Island View High School	Life Sci. lab tap 6 room 315.1	MZD676	0.0078	Exceeds Limit	0.1700	Passed
Island View High School	Life Sci. lab tap 7 room 315.1	MZD677	0.0000	Passed	0.1900	Passed
Island View High School	Assistive care WR tap	MZD678	0.0080	Exceeds Limit	0.4200	Passed
Island View High School	CR tap room 311A	MZD679	0.0015	Passed	0.4900	Passed
Island View High School	Chem Lab tap 1 room 309	MZD680	0.0000	Passed	0.0340	Passed
Island View High School	Chem Lab tap 2 room 309	MZD681	0.0007	Passed	0.0730	Passed
Island View High School	Chem Lab tap 3 room 309	MZD682	0.0070	Exceeds Limit	0.4900	Passed
Island View High School	Chem Lab tap 4 room 309	MZD683	0.0000	Passed	0.0660	Passed
Island View High School	Chem Lab tap 5 room 309	MZD684	0.0005	Passed	0.0810	Passed
Island View High School	Chem Lab tap 6 room 309	MZD685	0.0007	Passed	0.0570	Passed
Island View High School	Chem Lab tap 7 room 309	MZD686	0.0000	Passed	0.4900	Passed
Island View High School	Chem Lab tap 8 room 309	MZD687	0.0013	Passed	0.0300	Passed
Island View High School	Chem Lab tap 9 room 309	MZD688	0.0007	Passed	0.4200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Island View High School	Staff room tap 1 room 305	MZD689	0.0000	Passed	0.0310	Passed
Island View High School	Staff room tap 2 room 305	MZD690	0.0014	Passed	0.7000	Passed
Island View High School	GN WR tap room 303	MZD691	0.0000	Passed	0.0720	Passed
Island View High School	GN WR tap 1 room 206H	MZD692	0.0032	Passed	0.6100	Passed
Island View High School	GN WR tap 1 room 206G	MZD693	0.0019	Passed	0.2600	Passed
Island View High School	GN WR tap 1 room 206F	MZD694	0.0190	Exceeds Limit	3.6000	Exceeds Limit
Island View High School	GN WR tap 1 room 206E	MZD695	0.0043	Passed	0.9300	Passed
Island View High School	GN WR tap 1 room 206D	MZD696	0.0036	Passed	0.3000	Passed
Island View High School	GN WR tap 1 room 206C	MZD697	0.0013	Passed	0.1200	Passed
Island View High School	GN WR tap 1 room 206B	MZD698	0.0009	Passed	0.1500	Passed
Island View High School	GN WR tap 1 room 206A	MZD699	0.0010	Passed	0.1400	Passed
Island View High School	JC TAP ROOM 208B.1	MZD700	0.0000	Passed	0.0600	Passed
Island View High School	CR tap 1 room 225	MZD701	0.0000	Passed	0.1100	Passed
Island View High School	CR tap 2 room 225	MZD702	0.0044	Passed	0.8400	Passed
Island View High School	CR tap 1 room 227	MZD703	0.0000	Passed	0.2600	Passed
Island View High School	CR tap 2 room 227	MZD704	0.0022	Passed	0.5700	Passed
Island View High School	CR tap room 213	MZD705	0.0010	Passed	0.2200	Passed
Island View High School	Nutrition Lab tap 1 room 211	NNC994	0.0004	Passed	0.1700	Passed
Island View High School	Nutrition Lab tap 2 room 211	MZD707	0.0000	Passed	0.1800	Passed
Island View High School	Nutrition Lab tap 3 room 211	MZD708	0.0000	Passed	0.1200	Passed
Island View High School	Nutrition Lab tap 4 room 211	MZD709	0.0000	Passed	0.0910	Passed
Island View High School	Nutrition Lab tap 5 room 211	MZD710	0.0021	Passed	0.5000	Passed
Island View High School	Nutrition Lab tap 6 room 211	NNC995	0.0004	Passed	0.0190	Passed
Island View High School	Fountain by room 211	MZD712	0.0000	Passed	0.3700	Passed
Island View High School	Main office WR tap room 1081	MZD713	0.0000	Passed	0.0600	Passed
Island View High School	Gym GN WR 1 tap	MZD714	0.0088	Exceeds Limit	1.7000	Passed
Island View High School	Gym GN WR 2 tap	MZD715	0.0056	Exceeds Limit	0.3200	Passed
Island View High School	GN WR tap room 106J.1	MZD716	0.0000	Passed	0.0520	Passed
Island View High School	GN WR tap 1 by room 106F.1	MZD717	0.0000	Passed	0.1200	Passed
Island View High School	GN WR tap 2 by room 106F.1	MZD718	0.0008	Passed	0.2000	Passed
Island View High School	GN WR tap room 106B.1	MZD719	0.0010	Passed	2.3000	Exceeds Limit
Island View High School	JC tap room 112A.1	MZD720	0.0069	Exceeds Limit	0.0690	Passed
Island View High School	Kitchen tap 1 room 112	MZD721	0.0000	Passed	0.1100	Passed
Island View High School	Kitchen tap 2 room 112	MZD722	0.0000	Passed	0.0900	Passed
Island View High School	Kitchen tap 3 room 112	MZD723	0.0000	Passed	0.1200	Passed
Island View High School	JC tap room 114	MZD724	0.0010	Passed	0.2900	Passed
Island View High School	Music room tap room 118	MZD725	0.0009	Passed	0.7100	Passed
Island View High School	Art room tap 1 room 117	MZD726	0.0000	Passed	0.2500	Passed
Island View High School	Art room tap 2 room 117	MZD727	0.0000	Passed	0.1600	Passed
Island View High School	Media room tap room 111B.1	MZD728	0.0026	Passed	0.1300	Passed
Island View High School	Fountain by room 111	MZD729	0.0000	Passed	0.4100	Passed
Island View High School	Production room tap room 107	MZD730	0.0007	Passed	0.5200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Island View High School	Recycle room tap room 105	MZD731	0.0013	Passed	1.1000	Passed
Island View High School	Science Lab tap 1 room 103	MZD855	0.0000	Passed	1.5000	Passed
Island View High School	Science Lab tap 2 room 103	MZD856	0.0000	Passed	0.4100	Passed
Island View High School	Science Lab tap 3 room 103	MZD857	0.0000	Passed	0.0570	Passed
Island View High School	Science Lab tap 4 room 103	NAM732	0.0020	Passed	0.0240	Passed
Island View High School	Science Lab tap 5 room 103	NAM733	0.0120	Exceeds Limit	0.1100	Passed
Island View High School	Science Lab tap 6 room 103	NAM734	0.0023	Passed	0.0620	Passed
Island View High School	Science Lab tap 7 room 103	NAM735	0.0019	Passed	0.1500	Passed
J. L. Ilesley High School	3rd floor GN WR tap	MVV192	0.0000	Passed	0.2200	Passed
J. L. Ilesley High School	3rd floor teachers room tap 1	MVV193	0.0005	Passed	0.0360	Passed
J. L. Ilesley High School	3rd floor teachers room tap 2	MVV194	0.0000	Passed	0.0180	Passed
J. L. Ilesley High School	3rd floor teachers room tap 3	MVV195	0.0000	Passed	0.0290	Passed
J. L. Ilesley High School	3rd floor teachers room tap 4	MVV196	0.2000	Exceeds Limit	0.1200	Passed
J. L. Ilesley High School	3rd floor Science lab tap 1	MVV197	0.0580	Exceeds Limit	1.3000	Passed
J. L. Ilesley High School	3rd floor Science lab tap 2	MVV198	0.0170	Exceeds Limit	0.3900	Passed
J. L. Ilesley High School	3rd floor Science lab tap 3	MVV199	0.0038	Passed	0.1900	Passed
J. L. Ilesley High School	3rd floor Science lab tap 4	MVV200	0.0400	Exceeds Limit	0.5400	Passed
J. L. Ilesley High School	Science room 316 tap 1	MVV201	0.0370	Exceeds Limit	1.1000	Passed
J. L. Ilesley High School	Science room 316 tap 2	MVV202	0.0360	Exceeds Limit	0.8500	Passed
J. L. Ilesley High School	Science room 316 tap 3	MVV203	0.0350	Exceeds Limit	0.7800	Passed
J. L. Ilesley High School	Science room 316 tap 4	MVV204	0.0580	Exceeds Limit	0.9000	Passed
J. L. Ilesley High School	Science room 316 tap 5	MVV205	0.0350	Exceeds Limit	0.7100	Passed
J. L. Ilesley High School	Science room 316 tap 6	MVV206	0.0290	Exceeds Limit	0.5500	Passed
J. L. Ilesley High School	Science room 316 tap 7	MVV207	0.0064	Exceeds Limit	0.4200	Passed
J. L. Ilesley High School	Science room 316 tap 8	MVV208	0.0049	Passed	0.3600	Passed
J. L. Ilesley High School	Science room 316 tap 9	MVV209	0.0250	Exceeds Limit	0.3700	Passed
J. L. Ilesley High School	Science room 316 tap 10	MVV210	0.0330	Exceeds Limit	0.5100	Passed
J. L. Ilesley High School	Science room 316 tap 11	MVV211	0.0810	Exceeds Limit	0.2500	Passed
J. L. Ilesley High School	Science room 316 tap 12	MVV212	0.0083	Exceeds Limit	0.2400	Passed
J. L. Ilesley High School	Science room 316 tap 13	MVV213	0.0160	Exceeds Limit	0.7300	Passed
J. L. Ilesley High School	Science room 316 tap 14	MVV214	0.0350	Exceeds Limit	0.5800	Passed
J. L. Ilesley High School	Science room 316 tap 15	MVV215	0.0490	Exceeds Limit	0.5100	Passed
J. L. Ilesley High School	Science room 316 tap 16	MVV216	0.0170	Exceeds Limit	0.5600	Passed
J. L. Ilesley High School	Science room 316 tap 17	MVV217	0.0770	Exceeds Limit	0.3100	Passed
J. L. Ilesley High School	Science room 316 tap 18	MVV218	0.0700	Exceeds Limit	0.7300	Passed
J. L. Ilesley High School	Science room 316 tap 19	MVV219	0.0580	Exceeds Limit	0.7800	Passed
J. L. Ilesley High School	Girls WR tap 1 room 314	MVV220	0.0009	Passed	0.1400	Passed
J. L. Ilesley High School	Girls WR tap 2 room 314	MVV221	0.0011	Passed	0.1400	Passed
J. L. Ilesley High School	Girls WR tap 3 room 314	MVV222	0.0009	Passed	0.1400	Passed
J. L. Ilesley High School	Girls WR tap 4 room 314	MVV223	0.0012	Passed	0.1100	Passed
J. L. Ilesley High School	JC tap room 312	MVV224	0.0100	Exceeds Limit	0.1200	Passed
J. L. Ilesley High School	3rd floor boys WR tap 1	MVV225	0.0025	Passed	0.1500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
J. L. Ilesley High School	3rd floor boys WR tap 2	MVV226	0.0029	Passed	0.1000	Passed
J. L. Ilesley High School	3rd floor boys WR tap 3	MVV227	0.0013	Passed	0.1000	Passed
J. L. Ilesley High School	3rd floor boys WR tap 4	MVV228	0.0022	Passed	0.1100	Passed
J. L. Ilesley High School	3rd floor boys WR tap 5	MVV229	0.0019	Passed	0.1100	Passed
J. L. Ilesley High School	3rd floor boys WR tap 6	MVV230	0.0024	Passed	0.1200	Passed
J. L. Ilesley High School	3rd floor fountain by boys WR	MVV231	0.0000	Passed	0.1500	Passed
J. L. Ilesley High School	Teachers room 233 tap 1	MVV232	0.0010	Passed	0.0610	Passed
J. L. Ilesley High School	Teachers room 233 tap 2	MVV233	0.0000	Passed	0.0160	Passed
J. L. Ilesley High School	Teachers room 233 tap 3	MVV234	0.0020	Passed	0.0970	Passed
J. L. Ilesley High School	Teachers room 233 tap 4	MVV235	0.0016	Passed	0.0910	Passed
J. L. Ilesley High School	2nd floor fountain	MVV236	0.0022	Passed	0.2100	Passed
J. L. Ilesley High School	Biology lab tap 1 room 218	MVV237	0.0950	Exceeds Limit	1.3000	Passed
J. L. Ilesley High School	Biology lab tap 2 room 218	MVV238	0.0570	Exceeds Limit	0.6600	Passed
J. L. Ilesley High School	Biology lab tap 3 room 218	MVV239	0.0039	Passed	0.7200	Passed
J. L. Ilesley High School	Physics lab room 216 tap 1	MVV240	0.1700	Exceeds Limit	1.2000	Passed
J. L. Ilesley High School	Physics lab room 216 tap 2	MVV241	9.4000	Exceeds Limit	6.2000	Exceeds Limit
J. L. Ilesley High School	Physics lab room 216 tap 3	MVV242	0.3300	Exceeds Limit	0.2600	Passed
J. L. Ilesley High School	Girls WR tap 1 room 214	MVV243	0.0016	Passed	0.0960	Passed
J. L. Ilesley High School	Girls WR tap 2 room 214	MVV244	0.0011	Passed	0.1100	Passed
J. L. Ilesley High School	Girls WR tap 3 room 214	MVV245	0.0010	Passed	0.1400	Passed
J. L. Ilesley High School	Girls WR tap 4 room 214	MVV246	0.0014	Passed	0.1600	Passed
J. L. Ilesley High School	JC tap between WR's	MVV247	0.0009	Passed	0.0600	Passed
J. L. Ilesley High School	Boys WR tap 1 room 210	MVV248	0.0035	Passed	0.1500	Passed
J. L. Ilesley High School	Boys WR tap 2 room 210	MVV249	0.0012	Passed	0.0970	Passed
J. L. Ilesley High School	Boys WR tap 3 room 210	MVV250	0.0009	Passed	0.0980	Passed
J. L. Ilesley High School	Boys WR tap 4 room 210	MVV251	0.0011	Passed	0.1000	Passed
J. L. Ilesley High School	Fountain by boys WR	MVV252	0.0000	Passed	0.9000	Passed
J. L. Ilesley High School	CR tap 1 room 215	MVV253	0.0130	Exceeds Limit	0.3000	Passed
J. L. Ilesley High School	CR tap 2 room 215	MVV254	0.0036	Passed	0.3800	Passed
J. L. Ilesley High School	CR tap 1 room 217	MVV255	0.0047	Passed	0.3600	Passed
J. L. Ilesley High School	CR tap 2 room 217	MVV256	0.0059	Exceeds Limit	0.2300	Passed
J. L. Ilesley High School	JC WR tap	MVV257	0.0086	Exceeds Limit	0.1100	Passed
J. L. Ilesley High School	Girls Staff WR tap 1	MVV258	0.0007	Passed	0.0150	Passed
J. L. Ilesley High School	Girls Staff WR tap 2	MVV259	0.0310	Exceeds Limit	0.0900	Passed
J. L. Ilesley High School	Boys staff WR tap	MVV260	0.0010	Passed	0.0340	Passed
J. L. Ilesley High School	CR tap	MVV261	0.0084	Exceeds Limit	0.1500	Passed
J. L. Ilesley High School	Skilled trade room tap 1	MVV262	0.0240	Exceeds Limit	1.2000	Passed
J. L. Ilesley High School	Skilled trade room tap 2	MVV263	0.0170	Exceeds Limit	0.9700	Passed
J. L. Ilesley High School	Weight room tap	MVV264	0.0120	Exceeds Limit	0.6300	Passed
J. L. Ilesley High School	Family studies tap 1 room 116	MVV265	0.0170	Exceeds Limit	0.4600	Passed
J. L. Ilesley High School	Family studies tap 2 room 116	MVV266	0.0490	Exceeds Limit	0.1900	Passed
J. L. Ilesley High School	Family studies tap 3 room 116	MVV267	0.0023	Passed	0.3500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
J. L. Ilsley High School	Family studies tap 4 room 116	MVV268	0.0047	Passed	0.3200	Passed
J. L. Ilsley High School	Family studies tap 5 room 116	MVV269	0.0740	Exceeds Limit	0.6300	Passed
J. L. Ilsley High School	Family studies tap 6 room 116	MVV270	0.0090	Exceeds Limit	0.4300	Passed
J. L. Ilsley High School	Girls WR tap 1 room 114	MVV271	0.0008	Passed	0.1100	Passed
J. L. Ilsley High School	Girls WR tap 2 room 114	MVV272	0.0013	Passed	0.1000	Passed
J. L. Ilsley High School	Girls WR tap 3 room 114	MVV273	0.0010	Passed	0.1100	Passed
J. L. Ilsley High School	JC tap room 112	MVV274	0.0025	Passed	0.0690	Passed
J. L. Ilsley High School	Boys WR tap 1 room 110	MVV275	0.0010	Passed	0.1200	Passed
J. L. Ilsley High School	Boys WR tap 2 room 110	MVV276	0.0013	Passed	0.0960	Passed
J. L. Ilsley High School	Boys WR tap 3 room 110	MVV277	0.0008	Passed	0.1100	Passed
J. L. Ilsley High School	Boys WR tap 4 room 110	MVV278	0.0009	Passed	0.1100	Passed
J. L. Ilsley High School	Fountain by boys WR	MVV279	0.0000	Passed	1.4000	Passed
J. L. Ilsley High School	CR tap 1 room 106	MVV280	0.0000	Passed	0.0140	Passed
J. L. Ilsley High School	CR tap 2 room 106	MVV281	0.0000	Passed	0.0073	Passed
J. L. Ilsley High School	Boys Locker room tap	MVV282	0.0130	Exceeds Limit	0.2600	Passed
J. L. Ilsley High School	Fountain by gym	MVV283	0.0017	Passed	0.3400	Passed
J. L. Ilsley High School	Girls locker room tap	MVV284	0.0550	Exceeds Limit	0.2200	Passed
J. L. Ilsley High School	Cafeteria tap 1	MVV285	0.0006	Passed	0.1900	Passed
J. L. Ilsley High School	Cafeteria tap 2	MVV286	0.0034	Passed	0.4400	Passed
John MacNeil Elementary School	Staff room kitchen sink tap	NMK080	0.0004	Passed	0.0020	Passed
John MacNeil Elementary School	Staff room WR #1 tap	MYA977	0.0024	Passed	0.0170	Passed
John MacNeil Elementary School	Staff room WR #2 tap	MYA978	0.0000	Passed	0.0240	Passed
John MacNeil Elementary School	Learning centre tap room 1	MYA979	0.0012	Passed	0.0300	Passed
John MacNeil Elementary School	Fountain by room 1	MYA980	0.0000	Passed	0.3300	Passed
John MacNeil Elementary School	Boys WR tap 1 by resource room	MYA981	0.0720	Exceeds Limit	0.9100	Passed
John MacNeil Elementary School	Boys WR tap 2 by resource room	MYA982	0.0097	Exceeds Limit	0.1200	Passed
John MacNeil Elementary School	JC tap by resource room	MYA983	0.0000	Passed	0.0150	Passed
John MacNeil Elementary School	Girls WR tap 1 by resource room	MYA984	0.0024	Passed	0.1900	Passed
John MacNeil Elementary School	Girls WR tap 2 by resource room	MYA985	0.0000	Passed	0.1100	Passed
John MacNeil Elementary School	Girls WR tap 3 by resource room	MYA986	0.0037	Passed	0.1100	Passed
John MacNeil Elementary School	Girls WR tap 1	MYA987	0.1200	Exceeds Limit	0.6800	Passed
John MacNeil Elementary School	Girls WR tap 2	MYA988	0.0200	Exceeds Limit	0.2200	Passed
John MacNeil Elementary School	Girls WR tap 3	MYA989	0.0015	Passed	0.0290	Passed
John MacNeil Elementary School	Girls WR tap 4	MYA990	0.0014	Passed	0.0230	Passed
John MacNeil Elementary School	Boys WR tap 1	MYA991	0.1100	Exceeds Limit	2.9000	Exceeds Limit
John MacNeil Elementary School	Boys WR tap 2	MYA992	0.0053	Exceeds Limit	0.1000	Passed
John MacNeil Elementary School	Boys WR tap 3	MYA993	0.0018	Passed	0.0330	Passed
John MacNeil Elementary School	Cafeteria/Kitchen tap in gym	MYA994	0.1100	Exceeds Limit	0.7700	Passed
John Martin Junior High School	GN WR tap by upstairs girls WR	MYR793	0.0081	Exceeds Limit	0.2100	Passed
John Martin Junior High School	Girls WR tap 1 by breakfast/lunch room	MYR794	0.0160	Exceeds Limit	0.6600	Passed
John Martin Junior High School	Girls WR tap 2 by breakfast/lunch room	MYR795	0.0770	Exceeds Limit	0.5900	Passed
John Martin Junior High School	Girls WR tap 3 by breakfast/lunch room	MYR796	0.0400	Exceeds Limit	0.2300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
John Martin Junior High School	Girls WR tap 4 by breakfast/lunch room	MYR797	0.1300	Exceeds Limit	1.2000	Passed
John Martin Junior High School	Staff WR by Girls WR	MYR798	0.0400	Exceeds Limit	1.2000	Passed
John Martin Junior High School	JC tap in caretaker supplies room	MYR799	0.0008	Passed	0.0230	Passed
John Martin Junior High School	Learning centre WR tap	MYR800	0.0410	Exceeds Limit	0.4200	Passed
John Martin Junior High School	Boys WR tap 1 by learning centre	MYR801	2.2000	Exceeds Limit	53.0000	Exceeds Limit
John Martin Junior High School	Boys WR tap 2 by learning centre	MYR802	0.0670	Exceeds Limit	4.1000	Exceeds Limit
John Martin Junior High School	Boys WR tap 3 by learning centre	MYR803	0.0600	Exceeds Limit	6.4000	Exceeds Limit
John Martin Junior High School	Fountain by learning centre room	MYR804	0.0028	Passed	0.5400	Passed
John Martin Junior High School	Fountain by room 213	NMV097	0.0013	Passed	0.2100	Passed
John Martin Junior High School	Boys WR tap 1 by staff WR	MYR806	0.1900	Exceeds Limit	2.8000	Exceeds Limit
John Martin Junior High School	Boys WR tap 2 by staff WR	MYR807	0.0620	Exceeds Limit	1.8000	Passed
John Martin Junior High School	Boys WR tap 3 by staff WR	MYR808	0.6900	Exceeds Limit	3.3000	Exceeds Limit
John Martin Junior High School	Staff WR by Caretaker room	MYR809	0.0220	Exceeds Limit	0.2200	Passed
John Martin Junior High School	JC inside caretaker room	MYR810	0.0007	Passed	0.0140	Passed
John Martin Junior High School	GN WR by girls WR	MYR811	0.0230	Exceeds Limit	0.1300	Passed
John Martin Junior High School	Girls WR tap 1 by GN WR	MYR812	0.3400	Exceeds Limit	0.9300	Passed
John Martin Junior High School	Girls WR tap 2 by GN WR	MYR813	0.2900	Exceeds Limit	2.4000	Exceeds Limit
John Martin Junior High School	Girls WR tap 3 by GN WR	MYR814	0.3900	Exceeds Limit	5.6000	Exceeds Limit
John Martin Junior High School	Fountain by caretaker supplies room	NMV097	0.0030	Passed	0.0350	Passed
John Martin Junior High School	Fountain by room 203	NMV100	0.0068	Exceeds Limit	0.1100	Passed
John Martin Junior High School	Kitchen sink in breakfast room	NMV101	0.0004	Passed	0.0030	Passed
John Martin Junior High School	CR tap room 203	MYR818	0.0480	Exceeds Limit	0.5100	Passed
John Martin Junior High School	Kitchen/Cafeteria tap 1 after room 203	MYR819	0.0049	Passed	0.1500	Passed
John Martin Junior High School	Kitchen/Cafeteria tap 2 after room 203	MYR820	0.0017	Passed	0.0130	Passed
John Martin Junior High School	Staff WR tap by caretaker supplies room	MYR821	0.0320	Exceeds Limit	0.2900	Passed
John Martin Junior High School	Fountain by back gym doors	MYR822	0.0029	Passed	1.7000	Passed
John Martin Junior High School	Staff WR tap in teachers WR	MYR823	0.0140	Exceeds Limit	0.1800	Passed
John Martin Junior High School	JC tap in caretaker supplies room	MYR824	0.0014	Passed	0.0230	Passed
John Martin Junior High School	Gym office WR tap	MYR825	0.0470	Exceeds Limit	0.7800	Passed
John Martin Junior High School	Girls WR tap 1 in gym	MYR826	0.0440	Exceeds Limit	0.4700	Passed
John Martin Junior High School	Girls WR tap 2 in gym	MYR827	0.0200	Exceeds Limit	0.3900	Passed
John Martin Junior High School	Girls WR tap 3 in gym	MYR828	0.0200	Exceeds Limit	0.1900	Passed
John Martin Junior High School	Girls WR tap 4 in gym	MYR829	0.0110	Exceeds Limit	0.1800	Passed
John Martin Junior High School	Boys WR tap 1 in gym	MYR830	0.0320	Exceeds Limit	0.0950	Passed
John Martin Junior High School	Boys WR tap 2 in gym	MYR831	0.0000	Passed	0.0058	Passed
John Martin Junior High School	Boys WR tap 3 in gym	MYR832	0.0240	Exceeds Limit	0.0480	Passed
John Martin Junior High School	Boys WR tap 4 in gym	MYR833	0.0098	Exceeds Limit	0.0210	Passed
John Martin Junior High School	Staff shower room tap in gym	MYR834	0.0900	Exceeds Limit	1.6000	Passed
John Martin Junior High School	JC tap by boiler room	MYR835	0.0024	Passed	0.0390	Passed
John Martin Junior High School	JC tap in tech ed. Room	MYR836	0.0078	Exceeds Limit	0.2500	Passed
John Martin Junior High School	GN WR tap in tech ed. Room	MYR837	0.0320	Exceeds Limit	0.2000	Passed
John Martin Junior High School	Kitchen/Cafeteria Double compartment sink tap	NMV102	0.0004	Passed	0.0029	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
John Martin Junior High School	hand washing sink tap in family studies room	NMV103	0.0030	Passed	0.0900	Passed
John Martin Junior High School	Family studies room tap 1	NMV104	0.0004	Passed	0.0220	Passed
John Martin Junior High School	Family studies room tap 2	NMV105	0.0004	Passed	0.0230	Passed
John Martin Junior High School	Family studies room tap 3	NMV106	0.0004	Passed	0.0140	Passed
John Martin Junior High School	Family studies room tap 4	NMV107	0.0004	Passed	0.0280	Passed
John Martin Junior High School	Family studies room tap 5	NMV108	0.0004	Passed	0.0270	Passed
John Martin Junior High School	Games room tap	NMV109	0.0100	Exceeds Limit	0.1400	Passed
John Martin Junior High School	Office staff WR tap	MYR846	0.0540	Exceeds Limit	0.2000	Passed
John Martin Junior High School	Science lab #1 tap 1	MYR847	0.1600	Exceeds Limit	0.1800	Passed
John Martin Junior High School	Science lab #1 tap 3	MYR848	0.2000	Exceeds Limit	2.3000	Exceeds Limit
John Martin Junior High School	Science lab #1 tap 4	MYR849	0.3600	Exceeds Limit	0.8100	Passed
John Martin Junior High School	Science lab #1 tap 5	MYR850	0.1400	Exceeds Limit	2.0000	Passed
John Martin Junior High School	Science lab #1 tap 6	MYR851	1.0000	Exceeds Limit	3.2000	Exceeds Limit
John Martin Junior High School	Science lab #2 tap 1	MYR856	0.3400	Exceeds Limit	2.1000	Exceeds Limit
John Martin Junior High School	Science lab #2 tap 2	MYR857	1.5000	Exceeds Limit	0.5500	Passed
John Martin Junior High School	Science lab #2 tap 3	MYR858	0.4400	Exceeds Limit	0.2800	Passed
John Martin Junior High School	Science lab #2 tap 4	MYR859	0.7500	Exceeds Limit	0.5700	Passed
John Martin Junior High School	Science lab #2 tap 5	MYR860	1.1000	Exceeds Limit	1.8000	Passed
John Martin Junior High School	Science lab #2 tap 6	MYR861	0.1400	Exceeds Limit	1.3000	Passed
John Martin Junior High School	Science lab #3 tap 1	MYR862	0.5800	Exceeds Limit	0.8400	Passed
John Martin Junior High School	Science lab #3 tap 2	MYR863	1.2000	Exceeds Limit	0.4300	Passed
John Martin Junior High School	Science lab #3 tap 3	MYR864	0.6500	Exceeds Limit	0.1800	Passed
John Martin Junior High School	Science lab #3 tap 4	MYR865	3.4000	Exceeds Limit	0.6700	Passed
John Martin Junior High School	Science lab #3 tap 5	MYR866	3.5000	Exceeds Limit	0.4700	Passed
John Martin Junior High School	Science lab #3 tap 6	MYR867	3.9000	Exceeds Limit	1.6000	Passed
John Martin Junior High School	Lab sink in science lab tap 1	MYR868	3.4000	Exceeds Limit	0.9100	Passed
John Martin Junior High School	Handwashing sink in science lab	MYR869	0.0390	Exceeds Limit	0.5800	Passed
John Martin Junior High School	Science lab #1 tap 2	NAI288	0.3800	Exceeds Limit	1.2000	Passed
John W. MacLeod Elementary School	CR tap room 10	MNX927	0.0010	Passed	0.1300	Passed
John W. MacLeod Elementary School	CR tap room 9	MNX928	0.0000	Passed	0.0079	Passed
John W. MacLeod Elementary School	CR tap room 8	MNX929	0.0043	Passed	0.0630	Passed
John W. MacLeod Elementary School	CR tap room 13	MNX930	0.0096	Exceeds Limit	0.0640	Passed
John W. MacLeod Elementary School	Fountain by room 13	MNX931	0.0000	Passed	0.0690	Passed
John W. MacLeod Elementary School	Fountain by room 18	MNX932	0.0000	Passed	0.1700	Passed
John W. MacLeod Elementary School	Fountain by room 3	MNX933	0.0000	Passed	0.2200	Passed
John W. MacLeod Elementary School	Room 22 tap 1	MNY246	0.0022	Passed	0.2200	Passed
John W. MacLeod Elementary School	Room 22 tap 2	MNY247	0.0014	Passed	0.0980	Passed
John W. MacLeod Elementary School	Room 22 tap 3	MNY248	0.0036	Passed	0.2700	Passed
John W. MacLeod Elementary School	Room 22 tap 4	MNY249	0.0054	Exceeds Limit	0.1600	Passed
John W. MacLeod Elementary School	Fountain by room 22	MNY250	0.0035	Passed	0.0430	Passed
John W. MacLeod Elementary School	Room 27 tap 1	MNY251	0.0005	Passed	0.1100	Passed
John W. MacLeod Elementary School	Room 27 tap 2	MNY252	0.0000	Passed	0.0950	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
John W. MacLeod Elementary School	Room 27 tap 3	MNY253	0.0000	Passed	0.0670	Passed
John W. MacLeod Elementary School	Room 27 tap 4	MNY254	0.0000	Passed	0.0680	Passed
John W. MacLeod Elementary School	Room 29 tap 1	MNY255	0.0020	Passed	0.0290	Passed
John W. MacLeod Elementary School	Room 29 tap 2	MNY256	0.0010	Passed	0.0230	Passed
John W. MacLeod Elementary School	Room 29 tap 3	MNY257	0.0000	Passed	0.0150	Passed
John W. MacLeod Elementary School	Room 29 tap 4	MNY258	0.0008	Passed	0.0190	Passed
John W. MacLeod Elementary School	Room 32 tap	MNY259	0.0024	Passed	0.1200	Passed
John W. MacLeod Elementary School	Room 38 tap	MNY260	0.0014	Passed	0.1100	Passed
John W. MacLeod Elementary School	Room 4 tap 1	MNY261	0.0011	Passed	0.1100	Passed
John W. MacLeod Elementary School	Room 4 tap 2	MNY262	0.0013	Passed	0.1200	Passed
John W. MacLeod Elementary School	CR Tap Room 34	MSP473	0.0012	Passed	0.0170	Passed
Joseph Giles Elementary School	Boys WR tap 1 across from room 11	MVV982	0.0040	Passed	0.1400	Passed
Joseph Giles Elementary School	Boys WR tap 2 across from room 11	MVV983	0.0037	Passed	0.1300	Passed
Joseph Giles Elementary School	Boys WR tap 3 across from room 11	MVV984	0.0021	Passed	0.1800	Passed
Joseph Giles Elementary School	CR tap room 3	MVV985	0.0037	Passed	0.1100	Passed
Joseph Giles Elementary School	CR WR tap room 3	MVV986	0.0010	Passed	0.0360	Passed
Joseph Giles Elementary School	Fountain beside teachers room	MVV987	0.0017	Passed	0.2000	Passed
Joseph Giles Elementary School	WR tap in teachers lounge	MVV988	0.0011	Passed	0.0260	Passed
Joseph Giles Elementary School	Kitchen tap in teachers lounge	MVV989	0.0015	Passed	0.0140	Passed
Joseph Giles Elementary School	JC tap beside girls WR	MVV990	0.0000	Passed	0.0380	Passed
Joseph Giles Elementary School	Girls WR tap 1 across from teachers lounge	MVV991	0.0025	Passed	0.1800	Passed
Joseph Giles Elementary School	Girls WR tap 2 across from teachers lounge	MVV992	0.0031	Passed	0.1800	Passed
Joseph Giles Elementary School	Girls WR tap 3 across from teachers lounge	MVV993	0.0025	Passed	0.1500	Passed
Joseph Giles Elementary School	CR tap in room 29	MVV994	0.0290	Exceeds Limit	1.4000	Passed
Joseph Giles Elementary School	WR tap in boys shower room	MVV995	0.0063	Exceeds Limit	0.2500	Passed
Joseph Giles Elementary School	JC tap in boys shower room	MVV996	0.0037	Passed	0.1100	Passed
Joseph Giles Elementary School	Fountain beside boys shower room	MVV997	0.0009	Passed	0.4000	Passed
Joseph Giles Elementary School	WR tap in girls shower room	MVV998	0.0017	Passed	0.2500	Passed
Joseph Giles Elementary School	Fountain beside girls shower room	MVV999	0.0046	Passed	0.2700	Passed
Joseph Howe Elementary School	2nd floor boys WR tap 1	MTP738	0.0007	Passed	0.0640	Passed
Joseph Howe Elementary School	2nd floor boys WR tap 2	MTP739	0.0014	Passed	0.0380	Passed
Joseph Howe Elementary School	2nd floor boys WR tap 3	MTP740	0.0000	Passed	0.0280	Passed
Joseph Howe Elementary School	2nd floor JC tap	MTP741	0.0000	Passed	0.0088	Passed
Joseph Howe Elementary School	2nd floor fountain by girls WR	MTP742	0.0260	Exceeds Limit	1.8000	Passed
Joseph Howe Elementary School	2nd floor Girls WR tap 1	MTP743	0.0000	Passed	0.0100	Passed
Joseph Howe Elementary School	2nd floor Girls WR tap 2	MTP744	0.0000	Passed	0.0140	Passed
Joseph Howe Elementary School	2nd floor Girls WR tap 3	MTP745	0.0000	Passed	0.0130	Passed
Joseph Howe Elementary School	2nd floor Girls WR tap 4	MTP746	0.0000	Passed	0.0190	Passed
Joseph Howe Elementary School	2nd floor Girls WR tap 5	MTP747	0.0000	Passed	0.0210	Passed
Joseph Howe Elementary School	2nd floor staff room WR 1 tap	MTP757	0.0000	Passed	0.0031	Passed
Joseph Howe Elementary School	2nd floor staff room WR 2 tap	MTP758	0.0000	Passed	0.0039	Passed
Joseph Howe Elementary School	staff room kitchen tap	MTP759	0.0000	Passed	0.0036	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Joseph Howe Elementary School	1st floor boys WR tap 1	MTP760	0.0000	Passed	0.0110	Passed
Joseph Howe Elementary School	1st floor boys WR tap 2	MTP761	0.0000	Passed	0.0180	Passed
Joseph Howe Elementary School	1st floor boys WR tap 3	MTP762	0.0010	Passed	0.0430	Passed
Joseph Howe Elementary School	1st floor boys WR tap 4	MTP763	0.0009	Passed	0.0600	Passed
Joseph Howe Elementary School	1st floor JC tap	MTP764	0.0087	Exceeds Limit	0.5600	Passed
Joseph Howe Elementary School	1st floor fountain by JC	MTP765	0.0007	Passed	0.1900	Passed
Joseph Howe Elementary School	1st floor Girls WR tap 1	MTP766	0.0000	Passed	0.0130	Passed
Joseph Howe Elementary School	1st floor Girls WR tap 2	MTP770	0.0044	Passed	0.1800	Passed
Joseph Howe Elementary School	1st floor Girls WR tap 3	MTP771	0.0000	Passed	0.0140	Passed
Joseph Howe Elementary School	1st floor Girls WR tap 4	MTP772	0.0006	Passed	0.0690	Passed
Joseph Howe Elementary School	1st floor CR WR tap	MTP773	0.0097	Exceeds Limit	0.1300	Passed
Joseph Howe Elementary School	GN WR tap (kitchen)	MTP774	0.0000	Passed	0.0480	Passed
Joseph Howe Elementary School	Pre primary 2nd floor fountain	MTP775	0.0034	Passed	0.0620	Passed
Joseph Howe Elementary School	2nd floor Pre primary Laundry/WR tap 1	MTP776	0.0000	Passed	0.0190	Passed
Joseph Howe Elementary School	2nd floor Pre primary Laundry/WR tap 2	MTP777	0.0000	Passed	0.0160	Passed
Joseph Howe Elementary School	2nd floor Pre primary Laundry/WR tap 3	MTP778	0.0000	Passed	0.0140	Passed
Joseph Howe Elementary School	Boys WR tap 1 basement by gym	MTP779	0.2700	Exceeds Limit	1.6000	Passed
Joseph Howe Elementary School	Boys WR tap 1 basement by gym	MTP781	0.0031	Passed	0.0910	Passed
Joseph Howe Elementary School	Basement fountain near caretakers room	NMD863	0.0004	Passed	0.0080	Passed
Joseph Howe Elementary School	Basement JC tap	MTP783	0.0000	Passed	0.0490	Passed
Joseph Howe Elementary School	Caretakers room tap by room 138	MTP784	0.0018	Passed	0.0510	Passed
Joseph Howe Elementary School	Girls WR tap 1 room 138	MTP785	0.0000	Passed	0.0190	Passed
Joseph Howe Elementary School	Girls WR tap 2 room 138	MTP786	0.0013	Passed	0.0260	Passed
Joseph Howe Elementary School	Breakfast club room tap (basement)	MTP787	0.0007	Passed	0.0290	Passed
Joseph Howe Elementary School	GN Gym WR tap 1	MTP788	0.0024	Passed	0.0770	Passed
Joseph Howe Elementary School	GN Gym WR tap 2	MTP789	0.0000	Passed	0.0140	Passed
Joseph Howe Elementary School	GN Gym WR tap 3	MTP790	0.0000	Passed	0.0120	Passed
Joseph Howe Elementary School	GN Gym WR tap 4	MTP793	0.0000	Passed	0.0110	Passed
Kingswood Elementary School	Fountain across from room 242	NLV853	0.0050	Passed	0.0080	Passed
Kingswood Elementary School	JC tap room 233	MUU155	0.0000	Passed	0.0380	Passed
Kingswood Elementary School	Girls WR tap 1 by room 233	MUU156	0.2600	Exceeds Limit	0.3400	Passed
Kingswood Elementary School	Girls WR tap 2 by room 233	MUU157	0.2300	Exceeds Limit	0.8400	Passed
Kingswood Elementary School	Boys WR tap 1 by room 232	MUU158	0.0310	Exceeds Limit	0.1500	Passed
Kingswood Elementary School	Boys WR tap 2 by room 232	MUU159	0.0200	Exceeds Limit	0.0660	Passed
Kingswood Elementary School	GN WR tap room 232	MUU160	0.0005	Passed	0.0600	Passed
Kingswood Elementary School	Boys WR tap 1 by room 225	MUU161	0.0020	Passed	0.0500	Passed
Kingswood Elementary School	Boys WR tap 2 by room 225	MUU162	0.0028	Passed	0.0910	Passed
Kingswood Elementary School	Girls WR tap 1 by room 224	MUU163	0.0007	Passed	0.1900	Passed
Kingswood Elementary School	Girls WR tap 2 by room 224	MUU164	0.0015	Passed	0.1900	Passed
Kingswood Elementary School	GN WR tap room 224	MUU165	0.0000	Passed	0.0077	Passed
Kingswood Elementary School	Fountain by room 204	MUU166	0.0016	Passed	0.2700	Passed
Kingswood Elementary School	Laundry tub tap room 240	MUU167	0.0000	Passed	0.0380	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Kingswood Elementary School	GN WR tap room 20	MUU168	0.0041	Passed	0.1300	Passed
Kingswood Elementary School	CR tap room 210	MUU169	0.0000	Passed	0.0350	Passed
Kingswood Elementary School	CR tap room 112	MUU170	0.0009	Passed	0.5000	Passed
Kingswood Elementary School	CR tap room 113	MUU171	0.0000	Passed	0.3900	Passed
Kingswood Elementary School	fountain across from room 184	MUU172	0.0020	Passed	0.8600	Passed
Kingswood Elementary School	CR tap room 117	MUU173	0.0000	Passed	0.3900	Passed
Kingswood Elementary School	CR tap room 118	MUU174	0.0000	Passed	0.5000	Passed
Kingswood Elementary School	CR tap room 120	MUU175	0.0000	Passed	0.4700	Passed
Kingswood Elementary School	CR tap room 119	MUU176	0.0000	Passed	0.3600	Passed
Kingswood Elementary School	CR tap room 116	MUU177	0.0017	Passed	0.6800	Passed
Kingswood Elementary School	CR tap 1 room 115	MUU178	0.0000	Passed	0.0680	Passed
Kingswood Elementary School	CR tap 2 room 115	MUU179	0.0000	Passed	0.5600	Passed
Kingswood Elementary School	GN WR tap room 114	MUU180	0.0016	Passed	0.0600	Passed
Kingswood Elementary School	Boys WR tap 1 by room 114	MUU181	0.0470	Exceeds Limit	0.1100	Passed
Kingswood Elementary School	Boys WR tap 2 by room 114	MUU182	0.0350	Exceeds Limit	0.1500	Passed
Kingswood Elementary School	Girls WR tap 1 by room 167	MUU183	0.0730	Exceeds Limit	0.1200	Passed
Kingswood Elementary School	Girls WR tap 2 by room 167	MUU184	0.0094	Exceeds Limit	0.0720	Passed
Kingswood Elementary School	GN WR tap room 165	MUU185	0.0006	Passed	0.0660	Passed
Kingswood Elementary School	GN WR tap room 166	MUU186	0.0150	Exceeds Limit	0.0370	Passed
Kingswood Elementary School	CR tap room 167	MUU187	0.0000	Passed	0.0300	Passed
Kingswood Elementary School	CR tap room 110	MUU188	0.0000	Passed	0.0410	Passed
Kingswood Elementary School	Staff WR tap room 180 (main office)	MUU189	0.0000	Passed	0.0380	Passed
Kingswood Elementary School	Library Kitchen tap room 107	MUU190	0.0012	Passed	0.1100	Passed
Kingswood Elementary School	Boys WR tap 1 by room 106	MUU191	0.0031	Passed	0.3100	Passed
Kingswood Elementary School	Boys WR tap 2 by room 106	MUU192	0.0230	Exceeds Limit	0.2000	Passed
Kingswood Elementary School	Girls WR tap 1 by room 183	MUU193	0.0012	Passed	0.0340	Passed
Kingswood Elementary School	Girls WR tap 2 by room 183	MUU194	0.0029	Passed	0.1100	Passed
Kingswood Elementary School	CR tap room 102	MUU195	0.0000	Passed	0.2500	Passed
Kingswood Elementary School	GN WR tap room 187	MUU196	0.0000	Passed	0.0870	Passed
Kingswood Elementary School	GN WR tap room 124	MUU197	0.0005	Passed	0.0360	Passed
Kingswood Elementary School	Cr tap room 101	MUU198	0.0000	Passed	0.0430	Passed
Kingswood Elementary School	Cr tap room 103	MUU199	0.0000	Passed	0.2400	Passed
Kingswood Elementary School	GN WR tap room 121	MUU200	0.0000	Passed	0.0390	Passed
Kingswood Elementary School	GN WR tap room 186	MUU201	0.0200	Exceeds Limit	0.5200	Passed
Kingswood Elementary School	CR tap room 104	MUU202	0.0000	Passed	0.0590	Passed
Kingswood Elementary School	Fountain beside room 104	MUU203	0.0020	Passed	0.6800	Passed
Kingswood Elementary School	Music room tap room 105	MUU204	0.0035	Passed	0.0640	Passed
Kingswood Elementary School	Laundry tub tap room 138	MUU205	0.0005	Passed	0.0980	Passed
Kingswood Elementary School	Cafeteria/kitchen handwashing tap	MUU206	0.0000	Passed	0.5200	Passed
Kingswood Elementary School	Cafeteria/kitchen single compartment sink tap	MUU207	0.0022	Passed	0.4900	Passed
Kingswood Elementary School	Cafeteria/kitchen handwashing tap	MUU208	0.0052	Exceeds Limit	0.7500	Passed
Kingswood Elementary School	Cafeteria/kitchen Triple compartment sink tap 1	MUU209	0.0000	Passed	0.4900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Kingswood Elementary School	Cafeteria/kitchen Triple compartment sink tap 2	MUU210	0.0009	Passed	0.0850	Passed
Kingswood Elementary School	Cafeteria/kitchen single compartment sink tap	NLV864	0.0010	Passed	0.0550	Passed
Kingswood Elementary School	Cafeteria/stage kitchen tap 1	MUU212	0.0000	Passed	0.0440	Passed
Kingswood Elementary School	Cafeteria/stage kitchen tap 2	MUU213	0.0047	Passed	0.5100	Passed
Kingswood Elementary School	JC tap room 142	MUU214	0.0000	Passed	0.0310	Passed
Kingswood Elementary School	Fountain in gym by room 144	MUU215	0.0000	Passed	0.4400	Passed
Kingswood Elementary School	Boys change room tap room 144	MUU216	0.0008	Passed	0.1600	Passed
Kingswood Elementary School	Girls Change room tap room 150	MUU217	0.0015	Passed	0.0740	Passed
Kingswood Elementary School	Gym office WR tap room 146	MUU218	0.0011	Passed	0.0850	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 306	MUW210	0.0000	Passed	0.4600	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 308	MUW211	0.0008	Passed	0.0820	Passed
LeMarchant-St. Thomas Elementary School	Assist care WR tap	MUW212	0.0000	Passed	0.1800	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 314	MUW213	0.0005	Passed	0.1500	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 316	MUW214	0.0009	Passed	0.1600	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 318	MUW215	0.0000	Passed	0.2800	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 322	MUW216	0.0011	Passed	0.0700	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 326	MUW217	0.0020	Passed	0.1800	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 325	MUW218	0.0000	Passed	0.2100	Passed
LeMarchant-St. Thomas Elementary School	CR tap Room 323	MUW219	0.0000	Passed	0.2300	Passed
LeMarchant-St. Thomas Elementary School	3rd floor WR sink tap 1	MUW220	0.0018	Passed	0.6300	Passed
LeMarchant-St. Thomas Elementary School	3rd floor WR sink tap 2	MUW221	0.0045	Passed	0.6000	Passed
LeMarchant-St. Thomas Elementary School	3rd floor WR sink tap 3	MUW222	0.0110	Exceeds Limit	0.5900	Passed
LeMarchant-St. Thomas Elementary School	3rd floor WR sink tap 4	MUW223	0.0020	Passed	0.6200	Passed
LeMarchant-St. Thomas Elementary School	Fountain by WR	MUW224	0.0000	Passed	0.3700	Passed
LeMarchant-St. Thomas Elementary School	Fountain by JC	MUW225	0.0000	Passed	0.3200	Passed
LeMarchant-St. Thomas Elementary School	JC tap by room 301	MUW226	0.0000	Passed	0.4700	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 301	MUW227	0.0000	Passed	0.1000	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 302	MUW228	0.0000	Passed	0.0380	Passed
LeMarchant-St. Thomas Elementary School	CR tap 1 room 206	MUW229	0.0000	Passed	0.2300	Passed
LeMarchant-St. Thomas Elementary School	CR tap 2 room 206	MUW230	0.0008	Passed	0.5600	Passed
LeMarchant-St. Thomas Elementary School	Fountain 1	MUW231	0.0000	Passed	0.7900	Passed
LeMarchant-St. Thomas Elementary School	Fountain 2	MUW232	0.0000	Passed	0.6600	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 216	MUW233	0.0000	Passed	0.3400	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 218	MUW234	0.0093	Exceeds Limit	0.3600	Passed
LeMarchant-St. Thomas Elementary School	Fountain 1	MUW235	0.0000	Passed	0.3100	Passed
LeMarchant-St. Thomas Elementary School	Fountain 2	MUW236	0.0000	Passed	0.3100	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 220	MUW237	0.0000	Passed	0.3900	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 222	MUW238	0.0000	Passed	0.5200	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 226	MUW239	0.0041	Passed	0.2700	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 225	MUW240	0.0000	Passed	0.2700	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 221	MUW241	0.0000	Passed	0.1600	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 213	MUW242	0.0000	Passed	0.3000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
LeMarchant-St. Thomas Elementary School	2nd floor WR sink tap 1	MUW243	0.0052	Exceeds Limit	0.8700	Passed
LeMarchant-St. Thomas Elementary School	2nd floor WR sink tap 2	MUW244	0.0016	Passed	0.7000	Passed
LeMarchant-St. Thomas Elementary School	2nd floor WR sink tap 3	MUW245	0.0017	Passed	0.6600	Passed
LeMarchant-St. Thomas Elementary School	2nd floor WR sink tap 4	MUW246	0.0014	Passed	0.6300	Passed
LeMarchant-St. Thomas Elementary School	JC tap room 209	MUW247	0.0000	Passed	0.3400	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 202	MUW248	0.0000	Passed	0.1900	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 204	MUW249	0.0000	Passed	0.6800	Passed
LeMarchant-St. Thomas Elementary School	WR tap in room 102 (main office)	MUW250	0.0000	Passed	0.4900	Passed
LeMarchant-St. Thomas Elementary School	Fountain 1 by room 110	MUW251	0.0000	Passed	0.0710	Passed
LeMarchant-St. Thomas Elementary School	Fountain 2 by room 114	MUW252	0.0000	Passed	0.1000	Passed
LeMarchant-St. Thomas Elementary School	GN WR in room 114	MUW253	0.0220	Exceeds Limit	0.6300	Passed
LeMarchant-St. Thomas Elementary School	Kitchen sink tap room 114	MUW254	0.0006	Passed	0.9500	Passed
LeMarchant-St. Thomas Elementary School	GN WR in room 116	MUW255	0.0000	Passed	0.2500	Passed
LeMarchant-St. Thomas Elementary School	Kitchen sink tap room 116	MUW256	0.0000	Passed	0.2200	Passed
LeMarchant-St. Thomas Elementary School	GN WR in room 122	MUW257	0.0008	Passed	0.4900	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 122	MUW258	0.0006	Passed	0.3900	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 124	MUW259	0.0000	Passed	0.6500	Passed
LeMarchant-St. Thomas Elementary School	GN WR in room 124	MUW260	0.0000	Passed	0.3500	Passed
LeMarchant-St. Thomas Elementary School	GN WR in room 126	MUW261	0.0000	Passed	0.4800	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 126	MUW262	0.0000	Passed	0.3600	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 125	MUW263	0.0000	Passed	0.2700	Passed
LeMarchant-St. Thomas Elementary School	GN WR in room 125	MUW264	0.0000	Passed	0.4700	Passed
LeMarchant-St. Thomas Elementary School	JC tap room 121	MUW265	0.0000	Passed	0.2000	Passed
LeMarchant-St. Thomas Elementary School	GN WR room 119B (in gym)	MUW266	0.0000	Passed	0.1600	Passed
LeMarchant-St. Thomas Elementary School	Staff WR inside gym	MUW267	0.0000	Passed	1.2000	Passed
LeMarchant-St. Thomas Elementary School	Main floor GN WR tap 1	MUW268	0.0033	Passed	0.6000	Passed
LeMarchant-St. Thomas Elementary School	Main floor GN WR tap 2	MUW269	0.0013	Passed	0.6100	Passed
LeMarchant-St. Thomas Elementary School	Main floor GN WR tap 3	MUW270	0.0052	Exceeds Limit	0.6100	Passed
LeMarchant-St. Thomas Elementary School	Main floor GN WR tap 4	MUW271	0.0010	Passed	0.6700	Passed
LeMarchant-St. Thomas Elementary School	Kitchen tap 1 on stage	MUW272	0.0000	Passed	0.1500	Passed
LeMarchant-St. Thomas Elementary School	Kitchen tap 2 on stage	MUW273	0.0000	Passed	0.0560	Passed
LeMarchant-St. Thomas Elementary School	Music room tap	MUW274	0.0000	Passed	1.1000	Passed
LeMarchant-St. Thomas Elementary School	Laundry tub tap room 109	MUW275	0.0000	Passed	0.4200	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 129	MUW276	0.0000	Passed	0.1200	Passed
LeMarchant-St. Thomas Elementary School	Cafeteria/kitchen double compartment tap	MUW277	0.0000	Passed	0.1600	Passed
LeMarchant-St. Thomas Elementary School	Cafeteria/kitchen hand washing tap	MUW278	0.0010	Passed	0.2700	Passed
LeMarchant-St. Thomas Elementary School	Cafeteria/kitchen JC tap	MUW279	0.0010	Passed	0.6900	Passed
LeMarchant-St. Thomas Elementary School	Cafeteria/kitchen single compartment tap	MUW280	0.0000	Passed	0.3900	Passed
LeMarchant-St. Thomas Elementary School	Laundry tub tap in boiler room (outside)	MUW281	0.0005	Passed	0.6600	Passed
LeMarchant-St. Thomas Elementary School	1st floor GN WR tap 3	NAM727	0.0000	Passed	0.4600	Passed
LeMarchant-St. Thomas Elementary School	CR tap room 114	NAM728	0.0005	Passed	0.0940	Passed
LeMarchant-St. Thomas Elementary School	2nd floor GN WR tap 1	NAM729	0.0000	Passed	0.4200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
LeMarchant-St. Thomas Elementary School	CR tap room 218	NAM730	0.0000	Passed	0.0820	Passed
LeMarchant-St. Thomas Elementary School	3rd floor GN WR tap 3	NAM731	0.0006	Passed	0.5000	Passed
Leslie Thomas Junior High School	3rd floor boys WR tap 1	MOP577	0.0028	Passed	0.1100	Passed
Leslie Thomas Junior High School	3rd floor boys WR tap 2	MOP578	0.0034	Passed	0.0930	Passed
Leslie Thomas Junior High School	3rd floor girls WR tap 1	MOP579	0.0036	Passed	0.0900	Passed
Leslie Thomas Junior High School	3rd floor girls WR tap 2	MOP580	0.0024	Passed	0.0810	Passed
Leslie Thomas Junior High School	3rd floor girls WR tap 3	MOP581	0.0150	Exceeds Limit	0.0800	Passed
Leslie Thomas Junior High School	3rd floor fountain by room 3D	MOP582	0.0011	Passed	0.5900	Passed
Leslie Thomas Junior High School	CR tap room 308	MOP583	0.0062	Exceeds Limit	0.4200	Passed
Leslie Thomas Junior High School	CR WR #1 tap room 308	MOP584	0.0030	Passed	0.0780	Passed
Leslie Thomas Junior High School	CR WR #2 tap room 308	MOP585	0.0019	Passed	0.0700	Passed
Leslie Thomas Junior High School	CR tap room 3D	MOP586	0.0021	Passed	0.0670	Passed
Leslie Thomas Junior High School	2nd floor boys WR tap 1	MOP587	0.0250	Exceeds Limit	0.2400	Passed
Leslie Thomas Junior High School	2nd floor boys WR tap 2	MOP588	0.0062	Exceeds Limit	0.0770	Passed
Leslie Thomas Junior High School	2nd floor girls WR tap 1	MOP589	0.0170	Exceeds Limit	0.1900	Passed
Leslie Thomas Junior High School	2nd floor girls WR tap 2	MOP590	0.0022	Passed	0.0860	Passed
Leslie Thomas Junior High School	Fountain in room 2A	NJH081	0.0055	Exceeds Limit	0.0890	Passed
Leslie Thomas Junior High School	JC tap room 2A	MOP592	0.0010	Passed	0.0500	Passed
Leslie Thomas Junior High School	Main office WR tap	MOP593	0.0086	Exceeds Limit	0.0940	Passed
Leslie Thomas Junior High School	2nd floor café tap	MOP594	0.0028	Passed	0.3900	Passed
Leslie Thomas Junior High School	1st floor CR tap room 113	MOP595	0.0022	Passed	0.2600	Passed
Leslie Thomas Junior High School	1st floor CR tap 1 room 111	MOP596	0.0007	Passed	0.3800	Passed
Leslie Thomas Junior High School	1st floor CR tap 2 room 111	MOP597	0.0069	Exceeds Limit	0.1600	Passed
Leslie Thomas Junior High School	CR tap room 110	MOP598	0.0016	Passed	0.8000	Passed
Leslie Thomas Junior High School	CR tap room 108	MOP599	0.0710	Exceeds Limit	0.8900	Passed
Leslie Thomas Junior High School	CR tap room 109	MOP600	0.0021	Passed	0.0760	Passed
Leslie Thomas Junior High School	CR tap room 107	MOP601	0.0590	Exceeds Limit	0.8200	Passed
Leslie Thomas Junior High School	CR tap room 106	MOP602	0.0380	Exceeds Limit	1.1000	Passed
Leslie Thomas Junior High School	1st floor boys WR tap 1	MOP603	0.0120	Exceeds Limit	0.1600	Passed
Leslie Thomas Junior High School	1st floor boys WR tap 2	MOP604	0.0053	Exceeds Limit	0.1300	Passed
Leslie Thomas Junior High School	JC tap room 1B	MOP605	0.0025	Passed	0.0730	Passed
Leslie Thomas Junior High School	1st floor fountain by room 1B	MOP606	0.0010	Passed	0.7000	Passed
Leslie Thomas Junior High School	1st floor Girls WR tap 1	MOP607	0.0064	Exceeds Limit	0.1900	Passed
Leslie Thomas Junior High School	1st floor Girls WR tap 2	MOP608	0.0013	Passed	0.0760	Passed
Leslie Thomas Junior High School	1st floor Girls WR tap 3	MOP609	0.0023	Passed	0.0820	Passed
Lockview High School	CR tap room A108	NBQ671	0.0066	Exceeds Limit	1.8000	Passed
Lockview High School	CR tap 1 room A112	NBQ672	0.0026	Passed	0.9500	Passed
Lockview High School	CR tap 2 room A112	NBQ673	0.0130	Exceeds Limit	0.0470	Passed
Lockview High School	Staff WR tap room C105	NBQ674	0.0160	Exceeds Limit	0.1000	Passed
Lockview High School	Staff WR tap room C106	NBQ675	0.0049	Passed	0.0720	Passed
Lockview High School	Staff room tap by room C106	NBQ676	0.0018	Passed	0.0940	Passed
Lockview High School	Library support room tap room C117	NBQ677	0.0360	Exceeds Limit	0.2100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Lockview High School	Library support WR tap room C117	NBQ678	0.0120	Exceeds Limit	0.3400	Passed
Lockview High School	Male WR tap 1 by section A	NBQ679	0.0130	Exceeds Limit	0.0700	Passed
Lockview High School	Male WR tap 2 by section A	NBQ680	0.0190	Exceeds Limit	0.0650	Passed
Lockview High School	Male WR tap 3 by section A	NBQ681	0.0280	Exceeds Limit	0.0570	Passed
Lockview High School	Male WR tap 4 by section A	NBQ682	0.0370	Exceeds Limit	0.0650	Passed
Lockview High School	Science lab tap 1 room B101	NBQ683	0.0013	Passed	0.7100	Passed
Lockview High School	Science lab tap 2 room B101	NBQ684	0.0082	Exceeds Limit	0.9200	Passed
Lockview High School	Science lab tap 3 room B101	NBQ685	0.0050	Passed	1.3000	Passed
Lockview High School	Science lab tap 4 room B101	NBQ686	0.0048	Passed	0.7600	Passed
Lockview High School	Science lab tap 5 room B101	NBQ687	0.0011	Passed	1.7000	Passed
Lockview High School	Science lab tap 6 room B101	NBQ688	0.0008	Passed	1.4000	Passed
Lockview High School	Science lab tap 7 room B101	NBQ689	0.0008	Passed	1.1000	Passed
Lockview High School	Science lab tap 8 room B101	NBQ690	0.0005	Passed	1.0000	Passed
Lockview High School	Science lab tap 9 room B101	NBQ691	0.0067	Exceeds Limit	0.7400	Passed
Lockview High School	Science lab tap 10 room B101	NBQ692	0.0180	Exceeds Limit	1.1000	Passed
Lockview High School	Science lab tap 11 room B101	NBQ693	0.0037	Passed	0.8900	Passed
Lockview High School	Science lab tap 12 room B101	NBQ694	0.0009	Passed	2.1000	Exceeds Limit
Lockview High School	Science lab tap 13 room B101	NBQ695	0.0044	Passed	1.2000	Passed
Lockview High School	Science lab tap 14 room B101	NBQ696	0.0024	Passed	1.6000	Passed
Lockview High School	Science lab tap 15 room B101	NBQ697	0.0068	Exceeds Limit	0.4000	Passed
Lockview High School	Science lab tap 16 room B101	NBQ698	0.0039	Passed	0.9600	Passed
Lockview High School	Science lab tap 17 room B101	NBQ699	0.0110	Exceeds Limit	0.8700	Passed
Lockview High School	Science lab tap 18 room B101	NBQ700	0.0810	Exceeds Limit	0.9300	Passed
Lockview High School	Science lab room B102 tap 1	NBQ701	0.0055	Exceeds Limit	1.5000	Passed
Lockview High School	Science lab room B102 tap 2	NBQ702	0.0053	Exceeds Limit	0.7900	Passed
Lockview High School	Science lab room B102 tap 3	NBQ703	0.0090	Exceeds Limit	0.5800	Passed
Lockview High School	Science lab room B102 tap 4	NBQ704	0.0043	Passed	1.6000	Passed
Lockview High School	Science lab room B102 tap 5	NBQ705	0.0059	Exceeds Limit	0.7700	Passed
Lockview High School	Science lab room B102 tap 6	NBQ706	0.0013	Passed	1.7000	Passed
Lockview High School	Science lab room B102 tap 7	NBQ707	0.0084	Exceeds Limit	0.6500	Passed
Lockview High School	Science lab room B102 tap 8	NBQ708	0.0140	Exceeds Limit	0.6800	Passed
Lockview High School	Science lab room B102 tap 9	NBQ709	0.0057	Exceeds Limit	0.2700	Passed
Lockview High School	Science lab room B102 tap 10	NBQ710	0.0088	Exceeds Limit	1.3000	Passed
Lockview High School	Science lab room B102 tap 11	NBQ711	0.0084	Exceeds Limit	0.2000	Passed
Lockview High School	Science lab room B102 tap 12	NBQ712	0.0019	Passed	1.2000	Passed
Lockview High School	Science lab room B102 tap 13	NBQ713	0.0036	Passed	0.8200	Passed
Lockview High School	Science lab room B102 tap 14	NBQ714	0.0031	Passed	1.8000	Passed
Lockview High School	Science lab room B102 tap 15	NBQ715	0.0029	Passed	0.5600	Passed
Lockview High School	Science lab room B102 tap 16	NBQ716	0.0017	Passed	1.6000	Passed
Lockview High School	Science lab room B102 tap 17	NBQ717	0.0013	Passed	0.6400	Passed
Lockview High School	Science lab room B102 tap 18	NBQ718	0.0047	Passed	1.6000	Passed
Lockview High School	Integrated Science lab room B104 tap 1	NBQ719	0.4000	Exceeds Limit	0.4200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Lockview High School	Integrated Science lab room B104 tap 2	NBQ720	0.0120	Exceeds Limit	5.1000	Exceeds Limit
Lockview High School	Integrated Science lab room B104 tap 3	NBQ721	0.0088	Exceeds Limit	0.6000	Passed
Lockview High School	Integrated Science lab room B104 tap 4	NBQ722	0.0170	Exceeds Limit	0.0530	Passed
Lockview High School	Integrated Science lab room B104 tap 5	NBQ723	0.0140	Exceeds Limit	0.0570	Passed
Lockview High School	Bio Lab room B105 tap 1	NBQ724	0.0130	Exceeds Limit	0.1400	Passed
Lockview High School	Bio Lab room B105 tap 2	NBQ725	0.0810	Exceeds Limit	0.2600	Passed
Lockview High School	Bio Lab room B105 tap 3	NBQ726	0.0210	Exceeds Limit	0.0890	Passed
Lockview High School	Bio Lab room B105 tap 4	NBQ727	0.0150	Exceeds Limit	0.2000	Passed
Lockview High School	Bio Lab prep room tap room B107	NBQ728	0.0300	Exceeds Limit	0.1300	Passed
Lockview High School	Bio lab room B106 tap 1	NBQ729	0.0160	Exceeds Limit	0.3600	Passed
Lockview High School	Bio lab room B106 tap 2	NBQ730	0.0170	Exceeds Limit	0.1200	Passed
Lockview High School	Bio lab room B106 tap 3	NBQ731	0.0330	Exceeds Limit	0.3800	Passed
Lockview High School	Bio lab room B106 tap 4	NBQ732	0.0120	Exceeds Limit	0.2200	Passed
Lockview High School	Integrated Science lab room B109 tap 1	NBQ733	0.0100	Exceeds Limit	0.0790	Passed
Lockview High School	Integrated Science lab room B109 tap 2	NBQ734	0.0160	Exceeds Limit	0.1700	Passed
Lockview High School	Integrated Science lab room B109 tap 3	NBQ735	0.0440	Exceeds Limit	0.0570	Passed
Lockview High School	Integrated Science lab room B109 tap 4	NBQ736	0.0170	Exceeds Limit	0.1300	Passed
Lockview High School	Integrated Science lab room B109 tap 5	NBQ737	0.0390	Exceeds Limit	0.4500	Passed
Lockview High School	Physics lab room 110 tap 1	NBQ738	0.0840	Exceeds Limit	4.4000	Exceeds Limit
Lockview High School	Physics lab room 110 tap 2	NBQ739	0.0046	Passed	0.4100	Passed
Lockview High School	Prep room tap room B112	NBQ740	0.0450	Exceeds Limit	0.2300	Passed
Lockview High School	Physics lab room B111 tap 1	NBQ741	0.0490	Exceeds Limit	0.8200	Passed
Lockview High School	Physics lab room B111 tap 2	NBQ742	0.0062	Exceeds Limit	0.0730	Passed
Lockview High School	JC tap room C137	NBQ743	0.0060	Exceeds Limit	0.0970	Passed
Lockview High School	Female WR by room B113 tap 1	NBQ744	0.0038	Passed	0.0950	Passed
Lockview High School	Female WR by room B113 tap 2	NBQ745	0.0021	Passed	0.0830	Passed
Lockview High School	Female WR by room B113 tap 3	NBQ746	0.0010	Passed	0.0670	Passed
Lockview High School	Female WR by room B113 tap 4	NBQ747	0.0082	Exceeds Limit	0.0990	Passed
Lockview High School	CR WR tap room D109	NBQ748	0.0390	Exceeds Limit	0.1700	Passed
Lockview High School	CR tap room D109	NBQ749	0.0017	Passed	0.1600	Passed
Lockview High School	CR tap 1 room D103	NBQ750	0.0037	Passed	2.0000	Passed
Lockview High School	CR tap 2 room D103	NBQ751	0.0098	Exceeds Limit	1.5000	Passed
Lockview High School	CR WR tap room D106B	NBQ752	0.0100	Exceeds Limit	0.2400	Passed
Lockview High School	Fountain by D-pod	NBQ753	0.0000	Passed	1.8000	Passed
Lockview High School	Health room tap room C122	NCK025	0.0059	Exceeds Limit	0.0650	Passed
Lockview High School	Office WR tap room D128	NCK026	0.0000	Passed	0.0760	Passed
Lockview High School	Office Kitchen tap room D125	NCK027	0.0043	Passed	0.4000	Passed
Lockview High School	Office WR tap room D116	NCK028	0.0110	Exceeds Limit	0.0840	Passed
Lockview High School	Office WR tap room D115	NCK029	0.0016	Passed	0.2500	Passed
Lockview High School	Production room F131 tap 1	NCK030	0.0037	Passed	0.6500	Passed
Lockview High School	Production room F131 tap 2	NCK031	0.0130	Exceeds Limit	0.5200	Passed
Lockview High School	Fountain by room F131	NCK032	0.0140	Exceeds Limit	1.1000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Lockview High School	GN WR tap 1 by room F127	NCK033	0.0330	Exceeds Limit	0.0830	Passed
Lockview High School	GN WR tap 2 by room F127	NCK034	0.0150	Exceeds Limit	0.0540	Passed
Lockview High School	GN WR tap 3 by room F128	NCK055	0.0150	Exceeds Limit	0.0560	Passed
Lockview High School	GN WR tap 4 by room F128	NCK056	0.0420	Exceeds Limit	0.0500	Passed
Lockview High School	GN WR tap room F127	NCK057	0.0014	Passed	0.0660	Passed
Lockview High School	Kitchen tap 1 room F102	NCK058	0.0024	Passed	0.2000	Passed
Lockview High School	Kitchen tap 2 room F102	NCK059	0.0088	Exceeds Limit	0.4800	Passed
Lockview High School	Kitchen tap 3 room F102	NCK060	0.0010	Passed	0.3300	Passed
Lockview High School	Kitchen tap 4 room F102	NCK061	0.0000	Passed	0.2800	Passed
Lockview High School	Music room tap room F122	NCK062	0.0018	Passed	0.8100	Passed
Lockview High School	JC tap room F117	NCK063	0.0019	Passed	0.0600	Passed
Lockview High School	JC tap room F121	NCK064	0.0015	Passed	0.0810	Passed
Lockview High School	JC tap room F121	NCK095	0.0980	Exceeds Limit	0.2000	Passed
Lockview High School	Home Ec. Tap 1 room F113	NND091	0.0004	Passed	0.0110	Passed
Lockview High School	Home Ec. Tap 2 room F113	NND092	0.0004	Passed	0.0120	Passed
Lockview High School	Home Ec. Tap 3 room F113	NCK098	0.0027	Passed	0.2200	Passed
Lockview High School	Home Ec. Tap 4 room F113	NND093	0.0004	Passed	0.0086	Passed
Lockview High School	Home Ec. Prep tap room F111	NND094	0.0004	Passed	0.0068	Passed
Lockview High School	Art room tap 1 F110	NCK101	0.0130	Exceeds Limit	0.2400	Passed
Lockview High School	Art room tap 2 F110	NCK102	0.0250	Exceeds Limit	0.2400	Passed
Lockview High School	Art room tap 1 F109	NCK103	0.0100	Exceeds Limit	0.1600	Passed
Lockview High School	Art room tap 2 F109	NCK104	0.0750	Exceeds Limit	0.7600	Passed
Lockview High School	Fountain by room F106	NCK190	0.0000	Passed	0.4700	Passed
Lockview High School	Female WR tap 1 F Pod	NCK191	0.0033	Passed	0.0710	Passed
Lockview High School	Female WR tap 2 F Pod	NCK192	0.0065	Exceeds Limit	0.1100	Passed
Lockview High School	Female WR tap 3 F Pod	NCK193	0.0020	Passed	0.0780	Passed
Lockview High School	Male WR tap 1 F Pod	NCK194	0.0023	Passed	0.0680	Passed
Lockview High School	Male WR tap 2 F Pod	NCK195	0.0067	Exceeds Limit	0.0660	Passed
Lockview High School	Male WR tap 3 F Pod	NCK196	0.0028	Passed	0.0630	Passed
Lockview High School	Fountain by room F106	NCK197	0.0000	Passed	1.3000	Passed
Lockview High School	Student council room tap roomF101	NCK198	0.0073	Exceeds Limit	0.8200	Passed
Lockview High School	Boys locker room tap 1 room E115	NCK199	0.0016	Passed	0.1300	Passed
Lockview High School	Boys locker room tap 2 room E115	NCK246	0.0025	Passed	0.1500	Passed
Lockview High School	Boys locker room tap room E114	NCK247	0.0094	Exceeds Limit	0.4400	Passed
Lockview High School	Girls locker room tap 1 room E110	NCK248	0.0068	Exceeds Limit	0.3600	Passed
Lockview High School	Girls locker room tap 2 room E110	NCK249	0.0058	Exceeds Limit	0.1800	Passed
Lockview High School	Girls locker room tap 1 room E111	NCK250	0.0022	Passed	0.1100	Passed
Lockview High School	Girls locker room tap 2 room E111	NCK251	0.0069	Exceeds Limit	0.1600	Passed
Lockview High School	Multipurpose room WR tap 1 room E109	NCK252	0.0025	Passed	0.3600	Passed
Lockview High School	Multipurpose room WR tap 2 room E109	NCK253	0.0220	Exceeds Limit	0.3700	Passed
Lockview High School	Tech ed room tap 1 room C214	NCK254	0.0070	Exceeds Limit	0.9200	Passed
Lockview High School	Tech ed room tap 2 room C214	NCK255	0.0260	Exceeds Limit	0.2300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Lockview High School	CR TAP ROOM C216	NCK328	0.0013	Passed	2.2000	Exceeds Limit
Lockview High School	CR tap 1 room A209	NCK329	0.0049	Passed	1.2000	Passed
Lockview High School	CR tap 2 room A209	NCK330	0.0390	Exceeds Limit	0.2200	Passed
Lockview High School	CR tap 1 room A205	NCK331	0.0220	Exceeds Limit	0.1100	Passed
Lockview High School	CR tap 2 room A205	NCK332	0.0047	Passed	1.2000	Passed
Lockview High School	CR tap 1 room B202	NCK333	0.0130	Exceeds Limit	0.3100	Passed
Lockview High School	CR tap 2 room B202	NCK334	0.0010	Passed	1.0000	Passed
Lockview High School	CR tap 1 room B207	NCK335	0.0260	Exceeds Limit	0.2800	Passed
Lockview High School	CR tap 2 room B207	NCK336	0.0710	Exceeds Limit	0.0840	Passed
Lockview High School	JC tap room B214	NCK337	0.0016	Passed	0.1900	Passed
Lockview High School	GN WR tap room C219	NCK338	0.1200	Exceeds Limit	0.5900	Passed
Lockview High School	GN WR tap room C202	NCK339	0.0073	Exceeds Limit	0.0720	Passed
Lockview High School	Male WR by room C202 tap 1	NCK340	0.0098	Exceeds Limit	0.3500	Passed
Lockview High School	Male WR by room C202 tap 2	NCK341	0.0064	Exceeds Limit	0.2400	Passed
Lockview High School	Male WR by room C202 tap 3	NCK342	0.0051	Exceeds Limit	0.3100	Passed
Lockview High School	Male WR by room C202 tap 4	NCK343	0.0073	Exceeds Limit	0.1800	Passed
Lockview High School	Male WR by room C202 tap 5	NCK344	0.0250	Exceeds Limit	0.2700	Passed
Lockview High School	Female WR by room C202 tap 1	NCK345	0.0043	Passed	0.1200	Passed
Lockview High School	Female WR by room C202 tap 2	NCK346	0.0034	Passed	0.1000	Passed
Lockview High School	Female WR by room C202 tap 3	NCK347	0.0058	Exceeds Limit	0.2400	Passed
Lockview High School	Female WR by room C202 tap 4	NCK365	0.0055	Exceeds Limit	0.0820	Passed
Lockview High School	Female WR by room C202 tap 5	NCK366	0.0035	Passed	0.0670	Passed
Lockview High School	Female WR by room C202 tap 6	NCK367	0.0034	Passed	0.0810	Passed
Lockview High School	CR tap 1 room D207	NCK368	0.0064	Exceeds Limit	1.3000	Passed
Lockview High School	CR tap 2 room D207	NCK369	0.0230	Exceeds Limit	0.3400	Passed
Lockview High School	CR tap room D203	NCK370	0.0075	Exceeds Limit	1.7000	Passed
Madeline Symonds Middle School	CR tap room 1095	NAO960	0.0000	Passed	0.3300	Passed
Madeline Symonds Middle School	CR tap 1 room 1091	NAO961	0.0000	Passed	0.5000	Passed
Madeline Symonds Middle School	CR tap 2 room 1091	NAO962	0.0006	Passed	0.2000	Passed
Madeline Symonds Middle School	Science Lab tap 1 room 1086	NAO963	0.0016	Passed	0.3000	Passed
Madeline Symonds Middle School	Science Lab tap 2 room 1086	NAO964	0.0000	Passed	0.6000	Passed
Madeline Symonds Middle School	Science Lab tap 3 room 1086	NAO965	0.0000	Passed	0.6600	Passed
Madeline Symonds Middle School	Science Lab tap 4 room 1086	NAO966	0.0000	Passed	0.9600	Passed
Madeline Symonds Middle School	Science Lab tap 5 room 1086	NAO967	0.0000	Passed	0.5200	Passed
Madeline Symonds Middle School	Science Lab tap 6 room 1086	NAO968	0.0017	Passed	0.8000	Passed
Madeline Symonds Middle School	Science Lab tap 1 room 1085	NAO969	0.0000	Passed	0.7700	Passed
Madeline Symonds Middle School	Science Lab tap 2 room 1085	NAO970	0.0007	Passed	0.1900	Passed
Madeline Symonds Middle School	Science Lab tap 3 room 1085	NAO971	0.0014	Passed	0.7400	Passed
Madeline Symonds Middle School	Science Lab tap 4 room 1085	NAO972	0.0011	Passed	0.3500	Passed
Madeline Symonds Middle School	Science Lab tap 5 room 1085	NAO973	0.0000	Passed	0.5700	Passed
Madeline Symonds Middle School	Science Lab tap 6 room 1085	NAO974	0.0016	Passed	0.6300	Passed
Madeline Symonds Middle School	Learning centre WR tap room 1081	NAO975	0.0035	Passed	0.3000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Madeline Symonds Middle School	Learning centre tap room 1079	NAO976	0.0000	Passed	0.3300	Passed
Madeline Symonds Middle School	CR tap room 1076	NAO977	0.0000	Passed	0.4000	Passed
Madeline Symonds Middle School	CR tap 1 room 1072	NAO978	0.0000	Passed	0.8500	Passed
Madeline Symonds Middle School	CR tap 2 room 1072	NAO979	0.0000	Passed	0.2900	Passed
Madeline Symonds Middle School	JC tap room 1100	NAO980	0.0007	Passed	0.0760	Passed
Madeline Symonds Middle School	Fountain by room 1101	NAO981	0.0010	Passed	0.5000	Passed
Madeline Symonds Middle School	GN WR tap room 1101	NAO982	0.0006	Passed	0.1100	Passed
Madeline Symonds Middle School	Boys WR tap 1 by room 1095	NAO983	0.0006	Passed	0.1200	Passed
Madeline Symonds Middle School	Boys WR tap 2 by room 1095	NAO984	0.0010	Passed	0.1500	Passed
Madeline Symonds Middle School	Boys WR tap 3 by room 1095	NAO985	0.0007	Passed	0.1600	Passed
Madeline Symonds Middle School	Boys WR tap 4 by room 1095	NAO986	0.0010	Passed	0.2400	Passed
Madeline Symonds Middle School	Art room tap room 1061	NAO988	0.0016	Passed	0.1000	Passed
Madeline Symonds Middle School	Girls locker room tap 1 room 1043	NAO989	0.0010	Passed	0.2100	Passed
Madeline Symonds Middle School	Girls locker room tap 2 room 1043	NAO990	0.0006	Passed	0.1900	Passed
Madeline Symonds Middle School	Gym office WR tap room 1046	NAO991	0.0000	Passed	0.3200	Passed
Madeline Symonds Middle School	Gym office WR tap room 1048	NAO992	0.0000	Passed	0.3100	Passed
Madeline Symonds Middle School	Male locker room tap 1 room 1050	NAO993	0.0006	Passed	0.4300	Passed
Madeline Symonds Middle School	Male locker room tap 2 room 1050	NAO994	0.0007	Passed	0.4200	Passed
Madeline Symonds Middle School	Female WR tap room 1036	NAO995	0.0019	Passed	0.0850	Passed
Madeline Symonds Middle School	JC tap room 1035	NAO996	0.0008	Passed	0.0370	Passed
Madeline Symonds Middle School	Male WR tap room 1037	NAO997	0.0006	Passed	0.1600	Passed
Madeline Symonds Middle School	Family studies tap 1 room 1029	NAO998	0.0000	Passed	0.2500	Passed
Madeline Symonds Middle School	Family studies tap 2 room 1029	NAO999	0.0007	Passed	0.0910	Passed
Madeline Symonds Middle School	Family studies tap 3 room 1029	NAP000	0.0000	Passed	0.0960	Passed
Madeline Symonds Middle School	Family studies tap 4 room 1029	NAP001	0.0000	Passed	0.0860	Passed
Madeline Symonds Middle School	Office WR tap room 1035	NAP002	0.0000	Passed	0.0690	Passed
Madeline Symonds Middle School	CR tap room 2065	NAP003	0.0000	Passed	0.2500	Passed
Madeline Symonds Middle School	CR tap 1 room 2061	NAP004	0.0067	Exceeds Limit	3.0000	Exceeds Limit
Madeline Symonds Middle School	CR tap 2 room 2061	NAP005	0.0007	Passed	0.8100	Passed
Madeline Symonds Middle School	CR tap room 2058	NAP006	0.0000	Passed	0.6300	Passed
Madeline Symonds Middle School	CR tap 1 room 2053	NAP007	0.0037	Passed	0.6800	Passed
Madeline Symonds Middle School	CR tap 2 room 2053	NAP008	0.0000	Passed	0.1500	Passed
Madeline Symonds Middle School	CR tap room 2050	NAP009	0.0000	Passed	0.2400	Passed
Madeline Symonds Middle School	CR tap 1 room 2046	NAP010	0.0011	Passed	0.5300	Passed
Madeline Symonds Middle School	CR tap 2 room 2046	NAP011	0.0016	Passed	0.2700	Passed
Madeline Symonds Middle School	Female WR tap 1 by room 2046	NAP012	0.0005	Passed	0.4400	Passed
Madeline Symonds Middle School	Female WR tap 2 by room 2046	NAP013	0.0000	Passed	0.1900	Passed
Madeline Symonds Middle School	Female WR tap 3 by room 2046	NAP014	0.0006	Passed	0.2100	Passed
Madeline Symonds Middle School	Female WR tap 4 by room 2046	NAP015	0.0008	Passed	0.2600	Passed
Madeline Symonds Middle School	JC tap room 2071	NAP016	0.0008	Passed	0.0690	Passed
Madeline Symonds Middle School	GN WR tap room 2072	NAP017	0.0007	Passed	0.1000	Passed
Madeline Symonds Middle School	Male WR tap 1 by room 2072	NAP018	0.0011	Passed	0.1900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Madeline Symonds Middle School	Male WR tap 2 by room 2072	NAP019	0.0009	Passed	0.1500	Passed
Madeline Symonds Middle School	Male WR tap 3 by room 2072	NAP020	0.0008	Passed	0.1600	Passed
Madeline Symonds Middle School	Male WR tap 4 by room 2072	NAP021	0.0170	Exceeds Limit	1.0000	Passed
Madeline Symonds Middle School	JC tap room 2036	NAP022	0.0032	Passed	0.1700	Passed
Madeline Symonds Middle School	Tech ed tap room 2039	NAP023	0.0000	Passed	0.3900	Passed
Madeline Symonds Middle School	Staff room WR tap room 2026	NAP024	0.0000	Passed	0.2100	Passed
Madeline Symonds Middle School	Staff room WR tap room 2027	NAP025	0.0008	Passed	0.2200	Passed
Madeline Symonds Middle School	Staff room kitchen tap room 2025	NAP026	0.0008	Passed	0.1200	Passed
Marine Drive Academy	Awaiting results from NSTIR	NEW SCHOOL		Passed		Passed
Michael Wallace Elementary School	GN WR tap room 29B	MXV210	0.0120	Exceeds Limit	0.2600	Passed
Michael Wallace Elementary School	Fountain by room 29B	NLJ974	0.0014	Passed	0.0310	Passed
Michael Wallace Elementary School	Caretakers office tap after room 29B	MXV212	0.0011	Passed	0.0460	Passed
Michael Wallace Elementary School	Girls WR tap 1 near room 29B	MXV213	0.0007	Passed	0.0590	Passed
Michael Wallace Elementary School	Girls WR tap 2 near room 29B	MXV214	0.0013	Passed	0.0320	Passed
Michael Wallace Elementary School	Girls WR tap 3 near room 29B	MXV215	0.0000	Passed	0.0160	Passed
Michael Wallace Elementary School	Boys WR tap 1	MXV216	0.0007	Passed	0.2200	Passed
Michael Wallace Elementary School	Boys WR tap 2	MXV217	0.0012	Passed	0.0380	Passed
Michael Wallace Elementary School	Boys WR tap 3	MXV218	0.0005	Passed	0.0190	Passed
Michael Wallace Elementary School	2nd floor GN WR tap room 2A	MXV219	0.0061	Exceeds Limit	0.1100	Passed
Michael Wallace Elementary School	2nd floor fountain between WR's	NLJ976	0.0008	Passed	0.0170	Passed
Michael Wallace Elementary School	Boys WR tap 1 room 11	MXV221	0.0014	Passed	0.0660	Passed
Michael Wallace Elementary School	Boys WR tap 2 room 11	MXV222	0.0000	Passed	0.0160	Passed
Michael Wallace Elementary School	Boys WR tap 3 room 11	MXV223	0.0000	Passed	0.0100	Passed
Michael Wallace Elementary School	Boys WR tap 4 room 11	MXV224	0.0000	Passed	0.0100	Passed
Michael Wallace Elementary School	Boys WR tap 5 room 11	MXV225	0.0013	Passed	0.0880	Passed
Michael Wallace Elementary School	Girls WR tap 1 room 17	MXV226	0.0110	Exceeds Limit	0.1600	Passed
Michael Wallace Elementary School	Girls WR tap 2 room 17	MXV227	0.0016	Passed	0.0380	Passed
Michael Wallace Elementary School	Girls WR tap 3 room 17	MXV228	0.0008	Passed	0.0130	Passed
Michael Wallace Elementary School	Girls WR tap 4 room 17	MXV229	0.0170	Exceeds Limit	0.2800	Passed
Michael Wallace Elementary School	Girls WR tap 5 room 17	MXV230	0.0019	Passed	0.0300	Passed
Michael Wallace Elementary School	Fountain by room 17	MXV231	0.0280	Exceeds Limit	0.2700	Passed
Michael Wallace Elementary School	Main office GN WR tap	MXV232	0.0120	Exceeds Limit	0.1600	Passed
Millwood Elementary School	Girls WR tap 1 by fan room	MSZ955	0.0000	Passed	0.0440	Passed
Millwood Elementary School	Girls WR tap 2 by fan room	MSZ956	0.0000	Passed	0.0320	Passed
Millwood Elementary School	Girls WR tap 3 by fan room	MSZ957	0.0000	Passed	0.0500	Passed
Millwood Elementary School	Boys WR tap 1 by fan room	MSZ958	0.0000	Passed	0.0071	Passed
Millwood Elementary School	Boys WR tap 2 by fan room	MSZ959	0.0000	Passed	0.0062	Passed
Millwood Elementary School	Boys WR tap 3 by fan room	MSZ960	0.0000	Passed	0.0065	Passed
Millwood Elementary School	JC tap by room 202	MSZ961	0.0000	Passed	0.0056	Passed
Millwood Elementary School	Fountain by room 202	MSZ962	0.0011	Passed	0.0740	Passed
Millwood Elementary School	Girls WR tap 1 by elevator	MSZ963	0.0000	Passed	0.0070	Passed
Millwood Elementary School	Girls WR tap 2 by elevator	MSZ964	0.0000	Passed	0.0091	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Millwood Elementary School	Girls WR tap 3 by elevator	MSZ965	0.0000	Passed	0.0072	Passed
Millwood Elementary School	Boys WR tap 1 by elevator	MSZ966	0.0000	Passed	0.0076	Passed
Millwood Elementary School	Boys WR tap 2 by elevator	MSZ967	0.0000	Passed	0.0064	Passed
Millwood Elementary School	Boys WR tap 3 by elevator	MSZ968	0.0000	Passed	0.0055	Passed
Millwood Elementary School	Caretaker room tap by elec. Rm	MSZ969	0.0000	Passed	0.0032	Passed
Millwood Elementary School	fountain by room 135	MSZ970	0.0036	Passed	0.3100	Passed
Millwood Elementary School	CR tap room 135	MSZ971	0.0000	Passed	0.0071	Passed
Millwood Elementary School	GN WR tap room 135	MSZ972	0.0000	Passed	0.0060	Passed
Millwood Elementary School	GN WR tap room 132	MSZ973	0.0008	Passed	0.0570	Passed
Millwood Elementary School	CR tap room 132	MSZ974	0.0000	Passed	0.0065	Passed
Millwood Elementary School	CR tap room 128	MSZ975	0.0000	Passed	0.0067	Passed
Millwood Elementary School	CR tap room 127	MSZ976	0.0000	Passed	0.0067	Passed
Millwood Elementary School	CR tap room 123	MSZ977	0.0000	Passed	0.0059	Passed
Millwood Elementary School	CR WR tap room 123	MSZ978	0.0008	Passed	0.0940	Passed
Millwood Elementary School	CR tap room 122	MSZ979	0.0000	Passed	0.0098	Passed
Millwood Elementary School	CR tap by room 122	MSZ980	0.0006	Passed	0.0076	Passed
Millwood Elementary School	Staff room kitchen tap	MSZ981	0.0000	Passed	0.0100	Passed
Millwood Elementary School	Staff room WR 1 tap	MSZ982	0.0000	Passed	0.0075	Passed
Millwood Elementary School	Staff room WR 2 tap	MSZ983	0.0000	Passed	0.0064	Passed
Millwood Elementary School	Office hand wash tap	MSZ984	0.0013	Passed	0.0150	Passed
Millwood Elementary School	Girls locker room tap	MSZ985	0.0035	Passed	0.2600	Passed
Millwood Elementary School	Gym office WR tap	MSZ986	0.0006	Passed	0.0220	Passed
Millwood Elementary School	Boys locker room tap	MSZ987	0.0330	Exceeds Limit	0.2600	Passed
Millwood Elementary School	Kitchen - kitchen tap	MSZ988	0.0000	Passed	0.0090	Passed
Millwood High School	JC tap room 241	MTN671	0.0005	Passed	0.0250	Passed
Millwood High School	Boys WR tap 1 room 204	MTN672	0.0006	Passed	0.0200	Passed
Millwood High School	Boys WR tap 2 room 204	MTN673	0.0010	Passed	0.0250	Passed
Millwood High School	Boys WR tap 3 room 204	MTN674	0.0011	Passed	0.0260	Passed
Millwood High School	Boys WR tap 4 room 204	MTN675	0.0043	Passed	0.0330	Passed
Millwood High School	Boys WR tap 5 room 204	MTN676	0.0000	Passed	0.0800	Passed
Millwood High School	Boys WR tap 6 room 204	MTN677	0.0005	Passed	0.0190	Passed
Millwood High School	Girls WR tap 1 room 205	MTN678	0.0350	Exceeds Limit	0.2900	Passed
Millwood High School	Girls WR tap 2 room 205	MTN679	0.0015	Passed	0.1000	Passed
Millwood High School	Girls WR tap 3 room 205	MTN680	0.0005	Passed	0.1100	Passed
Millwood High School	Girls WR tap 4 room 205	MTN681	0.0000	Passed	0.0790	Passed
Millwood High School	Girls WR tap 5 room 205	MTN682	0.0045	Passed	0.2000	Passed
Millwood High School	Girls WR tap 6 room 205	MTN683	0.0026	Passed	0.0400	Passed
Millwood High School	Fountain by room 206	MTN684	0.0007	Passed	0.2400	Passed
Millwood High School	GN WR tap room 202	MTN685	0.0030	Passed	0.5800	Passed
Millwood High School	CR tap room 202	MTN686	0.0016	Passed	0.0520	Passed
Millwood High School	CR tap room 240	MTN687	0.0006	Passed	0.0280	Passed
Millwood High School	CR tap room 229	MTN688	0.0056	Exceeds Limit	0.8600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Millwood High School	Physics lab tap 1 room 226	MTN689	0.0025	Passed	0.1800	Passed
Millwood High School	Physics lab tap 2 room 226	MTN690	0.0200	Exceeds Limit	1.1000	Passed
Millwood High School	Physics lab storage tap room 231	MTN691	0.0041	Passed	0.0570	Passed
Millwood High School	Art room tap 1 room 223	MTN692	0.0000	Passed	0.1200	Passed
Millwood High School	Art room tap 2 room 223	MTN693	0.0007	Passed	0.0500	Passed
Millwood High School	Science room tap 1 room 222	MTN694	0.0120	Exceeds Limit	0.2200	Passed
Millwood High School	Science room tap 2 room 222	MTN695	0.0006	Passed	0.0510	Passed
Millwood High School	Chem lab tap 1 room 220	MTN696	0.0010	Passed	0.0310	Passed
Millwood High School	Chem lab tap 2 room 220	MTN697	0.0019	Passed	0.0630	Passed
Millwood High School	Chem lab tap 3 room 220	MTN698	0.0013	Passed	0.0330	Passed
Millwood High School	Chem lab tap 4 room 220	MTN699	0.0000	Passed	0.0120	Passed
Millwood High School	Chem lab tap 5 room 220	MTN700	0.0006	Passed	0.0490	Passed
Millwood High School	Science room tap 1 room 215	MTN704	0.0098	Exceeds Limit	0.4500	Passed
Millwood High School	Science room tap 2 room 215	MTN705	0.0023	Passed	0.8400	Passed
Millwood High School	Science room tap 3 room 215	MTN706	0.0059	Exceeds Limit	1.0000	Passed
Millwood High School	Science room tap 1 room 216	MTN707	0.0060	Exceeds Limit	0.3100	Passed
Millwood High School	GN WR beside room 202	MTN708	0.0068	Exceeds Limit	0.0530	Passed
Millwood High School	Main office GN WR tap 1	MTN709	0.0070	Exceeds Limit	0.0410	Passed
Millwood High School	Main office GN WR tap 2	MTN710	0.0000	Passed	0.0310	Passed
Millwood High School	Main office GN WR tap 3	MTN711	0.0037	Passed	0.0380	Passed
Millwood High School	CR tap room 109	MTN712	0.0018	Passed	0.0500	Passed
Millwood High School	Kitchen sink tap room 117	MTN713	0.0079	Exceeds Limit	1.0000	Passed
Millwood High School	Cafeteria kitchen triple compartment sink tap	MTN714	0.0007	Passed	0.0440	Passed
Millwood High School	Fountain by girls WR	MTN715	0.0010	Passed	0.1600	Passed
Millwood High School	Girls WR tap 1 room 120	MTN716	0.0210	Exceeds Limit	0.1500	Passed
Millwood High School	Girls WR tap 2 room 120	MTN717	0.0033	Passed	0.0540	Passed
Millwood High School	Girls WR tap 3 room 120	MTN718	0.0012	Passed	0.0570	Passed
Millwood High School	Girls WR tap 4 room 120	MTN719	0.0015	Passed	0.0540	Passed
Millwood High School	Girls WR tap 5 room 120	MTN720	0.0099	Exceeds Limit	0.0840	Passed
Millwood High School	Girls WR tap 6 room 120	MTN721	0.0009	Passed	0.0260	Passed
Millwood High School	Boys WR tap 1 room 119	MTN722	0.0029	Passed	0.0970	Passed
Millwood High School	Boys WR tap 2 room 119	MTN723	0.0000	Passed	0.0240	Passed
Millwood High School	Boys WR tap 3 room 119	MTN728	0.0016	Passed	0.0800	Passed
Millwood High School	JC tap room 123	MTN729	0.0000	Passed	0.0190	Passed
Millwood High School	Laundry tub tap room 129	MTN730	0.0042	Passed	0.0760	Passed
Millwood High School	Girls locker room tap 1 room 150	MTN731	0.0007	Passed	0.0330	Passed
Millwood High School	Girls locker room tap 2 room 150	MTN732	0.0007	Passed	0.0350	Passed
Millwood High School	Girls locker room tap 3 room 150	MTN733	0.0010	Passed	0.0400	Passed
Millwood High School	Fountain in girls locker room 150	MTN734	0.0041	Passed	0.0540	Passed
Millwood High School	Gym office WR tap room 151	MTN735	0.0019	Passed	0.0970	Passed
Millwood High School	GN WR tap room 152	MTN736	0.0018	Passed	0.0360	Passed
Millwood High School	Boys locker room tap 1 room 153	MTN737	0.0000	Passed	0.0390	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Millwood High School	Boys locker room tap 2 room 153	MTN738	0.0000	Passed	0.0410	Passed
Mount Edward Elementary School	Staff room tap	MUW070	0.0006	Passed	0.0640	Passed
Mount Edward Elementary School	Staff room WR tap	MUW071	0.0029	Passed	0.0400	Passed
Mount Edward Elementary School	CR tap room 8	MUW072	0.0029	Passed	0.2300	Passed
Mount Edward Elementary School	Kitchen sink tap in canteen in gym	NLO084	0.0012	Passed	0.0180	Passed
Mount Edward Elementary School	Boys WR tap 1 by gym	MUW074	0.0094	Exceeds Limit	0.2300	Passed
Mount Edward Elementary School	Boys WR tap 2 by gym	MUW075	0.0022	Passed	0.0840	Passed
Mount Edward Elementary School	Boys WR tap 3 by gym	MUW076	0.0029	Passed	0.0570	Passed
Mount Edward Elementary School	GN WR tap by boys WR	MUW077	0.0079	Exceeds Limit	0.2600	Passed
Mount Edward Elementary School	JC tap by girls WR	MUW078	0.0020	Passed	0.5400	Passed
Mount Edward Elementary School	Girls WR tap 1 by JC	MUW079	0.0020	Passed	0.2500	Passed
Mount Edward Elementary School	Girls WR tap 2 by JC	MUW086	0.0051	Exceeds Limit	0.1000	Passed
Mount Edward Elementary School	Girls WR tap 3 by JC	MUW087	0.0012	Passed	0.0840	Passed
Mount Edward Elementary School	Fountain across from staff room	MUW088	0.0013	Passed	0.2200	Passed
Mount Edward Elementary School	Girls WR tap 1 by office	MUW089	0.0055	Exceeds Limit	0.2300	Passed
Mount Edward Elementary School	Girls WR tap 2 by office	MUW090	0.0020	Passed	0.2300	Passed
Mount Edward Elementary School	Boys WR tap 1 by office	MUW091	0.0064	Exceeds Limit	0.3600	Passed
Mount Edward Elementary School	Boys WR tap 2 by office	MUW092	0.0048	Passed	0.3300	Passed
Mount Edward Elementary School	Boys WR tap 3 by office	MUW093	0.0220	Exceeds Limit	0.1900	Passed
Mount Edward Elementary School	Fountain by JC	MUW094	0.0013	Passed	0.2000	Passed
Mount Edward Elementary School	JC tap beside fountain	MUW095	0.0011	Passed	0.0560	Passed
Mount Edward Elementary School	Low sink in main office	MUW126	0.0019	Passed	0.1300	Passed
Mount Edward Elementary School	Staff WR in principals office	MUW127	0.0100	Exceeds Limit	0.1200	Passed
Musquodoboit Rural High School	General science tap 1 room 2205	MVW073	0.0000	Passed	0.0400	Passed
Musquodoboit Rural High School	General science tap 2 room 2205	MVW074	0.0007	Passed	0.1500	Passed
Musquodoboit Rural High School	General science tap 3 room 2205	MVW075	0.0019	Passed	0.0480	Passed
Musquodoboit Rural High School	General science tap 4 room 2205	MVW076	0.0009	Passed	0.0410	Passed
Musquodoboit Rural High School	GN WR TAP ROOM 2701	MVW077	0.0008	Passed	0.1200	Passed
Musquodoboit Rural High School	Fountain by room 2701	MVW078	0.0011	Passed	0.1000	Passed
Musquodoboit Rural High School	GN WR tap 1 by room 2103	MVW079	0.0011	Passed	0.1100	Passed
Musquodoboit Rural High School	GN WR tap 2 by room 2103	MVW080	0.0013	Passed	0.1700	Passed
Musquodoboit Rural High School	GN WR tap 3 by room 2103	MVW081	0.0012	Passed	0.1500	Passed
Musquodoboit Rural High School	JC tap room 2103	MVW082	0.0010	Passed	0.1100	Passed
Musquodoboit Rural High School	GN WR tap 1 by room 2309	MVW085	0.0015	Passed	0.1300	Passed
Musquodoboit Rural High School	GN WR tap 2 by room 2309	MVW086	0.0010	Passed	0.1300	Passed
Musquodoboit Rural High School	GN WR tap 3 by room 2309	MVW087	0.0013	Passed	0.1500	Passed
Musquodoboit Rural High School	Physics lab tap 1 room 2309	MVW088	0.0000	Passed	0.2000	Passed
Musquodoboit Rural High School	Physics lab tap 2 room 2309	MVW089	0.0021	Passed	0.0300	Passed
Musquodoboit Rural High School	Physics lab tap 3 room 2309	MVW090	0.0017	Passed	0.2400	Passed
Musquodoboit Rural High School	Gen Science lab tap 1 room 2303	MVW091	0.0008	Passed	0.1300	Passed
Musquodoboit Rural High School	Gen Science lab tap 2 room 2303	MVW092	0.0000	Passed	0.1500	Passed
Musquodoboit Rural High School	Gen Science lab tap 3 room 2303	MVW093	0.0009	Passed	0.0540	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Musquodoboit Rural High School	Gen Science lab tap 4 room 2303	MVW094	0.0011	Passed	0.0790	Passed
Musquodoboit Rural High School	Gen Science lab tap 5 room 2303	MVW095	0.0000	Passed	0.0980	Passed
Musquodoboit Rural High School	Chem lab tap 1 room 2301	MVW096	0.0051	Exceeds Limit	0.0990	Passed
Musquodoboit Rural High School	Chem lab tap 2 room 2301	MVW097	0.0140	Exceeds Limit	0.1800	Passed
Musquodoboit Rural High School	Chem lab tap 3 room 2301	MVW098	0.0013	Passed	0.2500	Passed
Musquodoboit Rural High School	Chem lab tap 4 room 2301	MVW099	0.0029	Passed	0.0560	Passed
Musquodoboit Rural High School	Chem lab tap 5 room 2301	MVW100	0.0059	Exceeds Limit	0.1300	Passed
Musquodoboit Rural High School	Chem lab tap 6 room 2301	MVW101	0.0000	Passed	0.0320	Passed
Musquodoboit Rural High School	Chem lab tap 7 room 2301	MVW102	0.0000	Passed	0.3500	Passed
Musquodoboit Rural High School	Chem lab tap 8 room 2301	MVW103	0.0000	Passed	0.1800	Passed
Musquodoboit Rural High School	Chem lab tap 9 room 2301	MVW104	0.0006	Passed	0.1500	Passed
Musquodoboit Rural High School	Chem lab tap 10 room 2301	MVW107	0.0010	Passed	0.0960	Passed
Musquodoboit Rural High School	Family studies tap 1 room 2206	MVW108	0.0000	Passed	0.1900	Passed
Musquodoboit Rural High School	Family studies tap 2 room 2206	MVW109	0.0006	Passed	0.1300	Passed
Musquodoboit Rural High School	Family studies tap 3 room 2206	MVW110	0.0012	Passed	0.2100	Passed
Musquodoboit Rural High School	Family studies tap 4 room 2206	MVW111	0.0007	Passed	0.1200	Passed
Musquodoboit Rural High School	GN WR tap 1 room 2110	MVW112	0.0028	Passed	0.1700	Passed
Musquodoboit Rural High School	GN WR tap 2 room 2110	MVW113	0.0035	Passed	0.2000	Passed
Musquodoboit Rural High School	GN WR tap 3 room 2110	MVW114	0.0013	Passed	0.1200	Passed
Musquodoboit Rural High School	JC tap room 2112	MVW115	0.0020	Passed	0.1400	Passed
Musquodoboit Rural High School	GN WR tap 1 room 2111	MVW116	0.0017	Passed	0.1400	Passed
Musquodoboit Rural High School	GN WR tap 2 room 2111	MVW119	0.0022	Passed	0.1400	Passed
Musquodoboit Rural High School	GN WR tap 3 room 2111	MVW120	0.0066	Exceeds Limit	0.4300	Passed
Musquodoboit Rural High School	Learning centre WR tap	MVW121	0.0014	Passed	0.0590	Passed
Musquodoboit Rural High School	Music room tap room 1426	MVW122	0.0032	Passed	0.4800	Passed
Musquodoboit Rural High School	Cafeteria tap 1 room 1422	MVW123	0.0006	Passed	0.1300	Passed
Musquodoboit Rural High School	Cafeteria tap 2 room 1422	MVW124	0.0005	Passed	0.1400	Passed
Musquodoboit Rural High School	Cafeteria tap 3 room 1422	MVW125	0.0012	Passed	0.1700	Passed
Musquodoboit Rural High School	Cafeteria tap 4 room 1422	MVW126	0.0016	Passed	0.2000	Passed
Musquodoboit Rural High School	Cafeteria tap 5 room 1422	MVW127	0.0006	Passed	0.3400	Passed
Musquodoboit Rural High School	Male locker room tap room 1413	MVW128	0.0010	Passed	0.1500	Passed
Musquodoboit Rural High School	Female locker room tap room 1415	MVW129	0.0008	Passed	0.1500	Passed
Musquodoboit Rural High School	Fountain by gym	MVW130	0.0008	Passed	0.1000	Passed
Musquodoboit Rural High School	Fountain by WR's	MVW131	0.0009	Passed	0.0970	Passed
Musquodoboit Rural High School	Male WR tap 1 room 1123	MVW132	0.0029	Passed	0.2200	Passed
Musquodoboit Rural High School	Male WR tap 2 room 1123	MVW133	0.0018	Passed	0.1300	Passed
Musquodoboit Rural High School	Male WR tap 3 room 1123	MVW134	0.0017	Passed	0.1700	Passed
Musquodoboit Rural High School	JC tap room 1125	MVW135	0.0052	Exceeds Limit	0.1400	Passed
Musquodoboit Rural High School	Female WR tap 1 room 1124	MVW136	0.0014	Passed	0.1500	Passed
Musquodoboit Rural High School	Female WR tap 2 room 1124	MVW137	0.0014	Passed	0.1100	Passed
Musquodoboit Rural High School	Female WR tap 3 room 1124	MVW138	0.0017	Passed	0.1600	Passed
Musquodoboit Rural High School	Tech ed tap room 1303	MVW139	0.0007	Passed	0.1400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Musquodoboit Rural High School	Art room tap room 1305	MVW140	0.0014	Passed	0.2100	Passed
Musquodoboit Rural High School	CR tap 1 room 1301	MVW141	0.0000	Passed	0.2100	Passed
Musquodoboit Rural High School	CR tap 2 room 1301	MVW142	0.0010	Passed	0.1600	Passed
Musquodoboit Rural High School	Staff room tap 1 room 1112	MVW143	0.0007	Passed	0.1300	Passed
Musquodoboit Rural High School	Staff room tap 2 room 1112	MVW144	0.0023	Passed	0.3800	Passed
Musquodoboit Rural High School	Staff room tap 3 room 1112	MVW145	0.0008	Passed	0.3200	Passed
Musquodoboit Rural High School	Admin WR tap room 1104	MVW146	0.0007	Passed	0.1400	Passed
Musquodoboit Rural High School	Seminar room tap room 1127	MVW147	0.0070	Exceeds Limit	0.1600	Passed
Musquodoboit Rural High School	Fountain by room 1127	MVW148	0.0000	Passed	0.0980	Passed
Musquodoboit Rural High School	Staff WR tap hall	MVW182	0.0005	Passed	0.1400	Passed
Musquodoboit Rural High School	GN WR tap 1 room 1201	MVW183	0.0012	Passed	0.1300	Passed
Musquodoboit Rural High School	GN WR tap 2 room 1201	MVW184	0.0012	Passed	0.1200	Passed
Musquodoboit Rural High School	GN WR tap 3 room 1201	MVW185	0.0014	Passed	0.1100	Passed
Musquodoboit Rural High School	JC tap room 1203	MVW186	0.0040	Passed	0.5300	Passed
Musquodoboit Rural High School	GN WR tap 1 room 1202	MVW187	0.0035	Passed	0.4200	Passed
Musquodoboit Valley Education Centre	Kitchen tap 1 room 173	MVV862	0.0052	Exceeds Limit	0.9300	Passed
Musquodoboit Valley Education Centre	Kitchen tap 2 room 173	MVV863	0.0065	Exceeds Limit	0.8100	Passed
Musquodoboit Valley Education Centre	Kitchen tap 3 room 173	MVV864	0.0000	Passed	1.1000	Passed
Musquodoboit Valley Education Centre	Fountain by room 173	MVV865	0.0008	Passed	0.9200	Passed
Musquodoboit Valley Education Centre	Girls WR tap 1 room 171	MVV866	0.0000	Passed	0.5300	Passed
Musquodoboit Valley Education Centre	Girls WR tap 2 room 171	MVV867	0.0006	Passed	0.7700	Passed
Musquodoboit Valley Education Centre	Girls WR tap 3 room 171	MVV868	0.0006	Passed	0.6400	Passed
Musquodoboit Valley Education Centre	Girls WR tap 4 room 171	MVV869	0.0058	Exceeds Limit	1.1000	Passed
Musquodoboit Valley Education Centre	Boys WR tap 1 room 170	MVV870	0.0010	Passed	0.6000	Passed
Musquodoboit Valley Education Centre	Boys WR tap 2 room 170	MVV871	0.0005	Passed	0.5100	Passed
Musquodoboit Valley Education Centre	Boys WR tap 3 room 170	MVV873	0.0011	Passed	0.6800	Passed
Musquodoboit Valley Education Centre	Fountain by room 170	MVV874	0.0009	Passed	1.2000	Passed
Musquodoboit Valley Education Centre	Boys change room 185 tap 1	MVV875	0.0017	Passed	0.6900	Passed
Musquodoboit Valley Education Centre	Boys change room 185 tap 2	MVV876	0.0013	Passed	0.7400	Passed
Musquodoboit Valley Education Centre	Gym office WR tap room 187	MVV877	0.0019	Passed	0.6600	Passed
Musquodoboit Valley Education Centre	Girls change room 189 tap 1	MVV878	0.0460	Exceeds Limit	2.3000	Exceeds Limit
Musquodoboit Valley Education Centre	Girls change room 189 tap 2	MVV879	0.0290	Exceeds Limit	1.7000	Passed
Musquodoboit Valley Education Centre	Art/music room tap	MVV880	0.0150	Exceeds Limit	0.8100	Passed
Musquodoboit Valley Education Centre	admin office WR tap	MVV881	0.0020	Passed	2.2000	Exceeds Limit
Musquodoboit Valley Education Centre	GN WR tap by office	MVV882	0.0022	Passed	0.6900	Passed
Musquodoboit Valley Education Centre	GN WR tap 1 room 140	MVV883	0.0009	Passed	0.4100	Passed
Musquodoboit Valley Education Centre	GN WR tap 2 room 140	MVV884	0.0007	Passed	0.4900	Passed
Musquodoboit Valley Education Centre	GN WR tap 3 room 140	MVV885	0.0019	Passed	0.9200	Passed
Musquodoboit Valley Education Centre	Fountain by room 140	MVV886	0.0000	Passed	0.2600	Passed
Musquodoboit Valley Education Centre	CR tap room 142	MVV887	0.0006	Passed	0.3800	Passed
Musquodoboit Valley Education Centre	CR tap room 153	MVV888	0.0016	Passed	0.9700	Passed
Musquodoboit Valley Education Centre	CR tap room 155	MVV889	0.0010	Passed	0.7700	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Musquodoboit Valley Education Centre	CR tap room 156	MVV890	0.0015	Passed	0.8400	Passed
Musquodoboit Valley Education Centre	Fountain by room 156	MVV891	0.0028	Passed	0.7000	Passed
Musquodoboit Valley Education Centre	GN WR tap 1 room 141	MVV892	0.0016	Passed	0.4800	Passed
Musquodoboit Valley Education Centre	GN WR tap 2 room 141	MVV915	0.0013	Passed	0.6500	Passed
Musquodoboit Valley Education Centre	GN WR tap 3 room 141	MVV916	0.0013	Passed	0.7200	Passed
Musquodoboit Valley Education Centre	JC tap by room 141	MVV917	0.0012	Passed	0.2200	Passed
Musquodoboit Valley Education Centre	Staff room WR #1 tap	MVV918	0.0000	Passed	0.1500	Passed
Musquodoboit Valley Education Centre	Staff room WR #2 tap	MVV919	0.0045	Passed	0.4300	Passed
Musquodoboit Valley Education Centre	Staff room kitchen tap	MVV920	0.0010	Passed	0.2700	Passed
Nelson Whynder Elementary School	Mens WR tap room 105	MXU463	0.0057	Exceeds Limit	1.1000	Passed
Nelson Whynder Elementary School	Staff room tap 1 room 110	MXU464	0.0016	Passed	0.4200	Passed
Nelson Whynder Elementary School	Staff room tap 2 room 110	MXU465	0.0027	Passed	0.3000	Passed
Nelson Whynder Elementary School	Staff WR tap room 112	MXU466	0.0012	Passed	0.1700	Passed
Nelson Whynder Elementary School	JC tap room 113	MXU467	0.0011	Passed	0.1600	Passed
Nelson Whynder Elementary School	Dentist room tap 1	MXU468	0.0011	Passed	0.0370	Passed
Nelson Whynder Elementary School	Dentist room tap 2	MXU469	0.0032	Passed	0.2800	Passed
Nelson Whynder Elementary School	Dentist room tap 3	MXU470	0.0000	Passed	0.1300	Passed
Nelson Whynder Elementary School	JC tap near room 113	MXU471	0.0000	Passed	1.0000	Passed
Nelson Whynder Elementary School	CR tap room 132	NAI070	0.0014	Passed	0.5000	Passed
Nelson Whynder Elementary School	CR WR tap room 132	NAI071	0.0008	Passed	0.5500	Passed
Nelson Whynder Elementary School	CR WR tap room 136	NAI072	0.0026	Passed	0.8600	Passed
Nelson Whynder Elementary School	CR tap room 136	NAI073	0.0017	Passed	0.2900	Passed
Nelson Whynder Elementary School	Boys WR tap 1 room 138	NAI074	0.0013	Passed	0.3100	Passed
Nelson Whynder Elementary School	Boys WR tap 2 room 138	NAI075	0.0008	Passed	0.0920	Passed
Nelson Whynder Elementary School	Boys WR tap 3 room 138	NMD527	0.0004	Passed	0.0160	Passed
Nelson Whynder Elementary School	Fountain #1 by room 138	NMD528	0.0009	Passed	0.0100	Passed
Nelson Whynder Elementary School	Fountain #2 by room 138	NMD529	0.0055	Exceeds Limit	0.0150	Passed
Nelson Whynder Elementary School	JC tap (caretaker office)	NAI079	0.0031	Passed	0.4700	Passed
Nelson Whynder Elementary School	Girls WR tap 1 room 140	NAI085	0.0006	Passed	0.0920	Passed
Nelson Whynder Elementary School	Girls WR tap 2 room 140	NAI086	0.0007	Passed	0.1500	Passed
Nelson Whynder Elementary School	Girls WR tap 3 room 140	NAI087	0.0000	Passed	0.2300	Passed
Nelson Whynder Elementary School	CR tap room 158	NAI088	0.0048	Passed	0.9000	Passed
Nelson Whynder Elementary School	Fountain by gym entrance	NAI089	0.0000	Passed	2.0000	Passed
Nelson Whynder Elementary School	Girls locker room tap	NAI090	0.0041	Passed	0.1900	Passed
Nelson Whynder Elementary School	Gym office WR tap	NAI091	0.0043	Passed	0.2900	Passed
Nelson Whynder Elementary School	Cafe/Kitchen tap 1 (door off the main gym)	NMD524	0.0004	Passed	0.0200	Passed
Nelson Whynder Elementary School	Cafe/Kitchen tap 2 (door off the main gym)	NMD525	0.0004	Passed	0.0240	Passed
Nelson Whynder Elementary School	Cafe/Kitchen tap 3 (door off the main gym)	NMD526	0.0007	Passed	0.0300	Passed
Nelson Whynder Elementary School	Cafe/Kitchen tap 4 (door off the main gym)	NAI096	0.0013	Passed	0.2900	Passed
Nelson Whynder Elementary School	Boys locker room tap	NAI097	0.0310	Exceeds Limit	0.5100	Passed
Nelson Whynder Elementary School	GN WR tap (by learning skills Rm)	NAI098	0.0190	Exceeds Limit	0.4200	Passed
Nelson Whynder Elementary School	GN WR tap (by learning skills Rm)	NAI099	0.0100	Exceeds Limit	0.2900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Nelson Whynder Elementary School	CR tap left of room 149	NAI100	0.0074	Exceeds Limit	0.5700	Passed
Nelson Whynder Elementary School	CR tap room 149	NAI101	0.0021	Passed	0.6100	Passed
Nelson Whynder Elementary School	CR tap room 148	NAI102	0.0016	Passed	0.3400	Passed
Nelson Whynder Elementary School	CR tap room 137	NAI103	0.0110	Exceeds Limit	3.8000	Exceeds Limit
Nelson Whynder Elementary School	CR tap room 134	NAI104	0.0009	Passed	1.7000	Passed
Nelson Whynder Elementary School	CR tap room 131	NAI105	0.0031	Passed	0.8400	Passed
Nelson Whynder Elementary School	Learning centre kitchen tap room 129	NAI107	0.0000	Passed	0.2100	Passed
Nelson Whynder Elementary School	Learning centre WR tap room 129	NAI108	0.0011	Passed	0.1800	Passed
Nelson Whynder Elementary School	Fountain by room 108	NAI109	0.0012	Passed	0.5500	Passed
Ocean View Elementary School	2nd floor boys WR tap 1	MYA659	0.0130	Exceeds Limit	0.6500	Passed
Ocean View Elementary School	2nd floor boys WR tap 2	MYA660	0.0023	Passed	0.4700	Passed
Ocean View Elementary School	2nd floor boys WR tap 3	MYA661	0.0007	Passed	0.2400	Passed
Ocean View Elementary School	Sink room	MYA662	0.0011	Passed	0.4200	Passed
Ocean View Elementary School	Fountain Between WR's	MYA663	0.0360	Exceeds Limit	0.5000	Passed
Ocean View Elementary School	2nd floor girls WR tap 1	MYA664	0.0790	Exceeds Limit	1.4000	Passed
Ocean View Elementary School	2nd floor girls WR tap 2	MYA665	0.0200	Exceeds Limit	0.7000	Passed
Ocean View Elementary School	2nd floor girls WR tap 3	MYA666	0.0066	Exceeds Limit	0.2000	Passed
Ocean View Elementary School	Art room tap 1	MYA667	0.0062	Exceeds Limit	0.1100	Passed
Ocean View Elementary School	Art room tap 2	MYA668	0.0140	Exceeds Limit	0.1100	Passed
Ocean View Elementary School	2nd floor girls WR tap 1	MYA670	0.0053	Exceeds Limit	0.2000	Passed
Ocean View Elementary School	2nd floor girls WR tap 2	MYA671	0.0063	Exceeds Limit	0.1500	Passed
Ocean View Elementary School	2nd floor girls WR tap 3	MYA672	0.0140	Exceeds Limit	0.2100	Passed
Ocean View Elementary School	JC tap between WR's	MYA673	0.0024	Passed	0.2900	Passed
Ocean View Elementary School	2nd floor boys WR tap 1	MYA674	0.0013	Passed	0.2300	Passed
Ocean View Elementary School	2nd floor boys WR tap 2	MYA675	0.0011	Passed	0.2000	Passed
Ocean View Elementary School	2nd floor boys WR tap 3	MYA676	0.0008	Passed	0.2600	Passed
Ocean View Elementary School	Gym office tap	MYA677	0.0058	Exceeds Limit	0.2200	Passed
Ocean View Elementary School	GN WR tap near gym	MYA678	0.0026	Passed	0.1100	Passed
Ocean View Elementary School	Learning centre WR tap	MYA679	0.0019	Passed	0.0790	Passed
Ocean View Elementary School	1st floor caretaker room tap 1	MYA681	0.0021	Passed	0.1100	Passed
Ocean View Elementary School	1st floor caretaker room tap 2	MYA682	0.0012	Passed	0.1200	Passed
Ocean View Elementary School	Fountain by room 103	MYA683	0.0780	Exceeds Limit	12.0000	Exceeds Limit
Ocean View Elementary School	CR WR tap room 103	MYA684	0.0013	Passed	0.0900	Passed
Ocean View Elementary School	CR tap room 103	MYA685	0.0013	Passed	0.0670	Passed
Ocean View Elementary School	CR WR tap room 105	MYA686	0.0012	Passed	0.0670	Passed
Ocean View Elementary School	CR tap room 105	MYA687	0.0031	Passed	0.0660	Passed
Ocean View Elementary School	CR WR tap room 107	MYA688	0.0006	Passed	0.0500	Passed
Ocean View Elementary School	CR tap room 107	MYA689	0.0013	Passed	0.0590	Passed
Ocean View Elementary School	1st floor boys WR tap 1	MYA690	0.0018	Passed	0.2300	Passed
Ocean View Elementary School	1st floor boys WR tap 2	MYA703	0.0018	Passed	0.1300	Passed
Ocean View Elementary School	1st floor boys WR tap 3	MYA704	0.0009	Passed	0.0510	Passed
Ocean View Elementary School	1st floor boys WR tap 4	MYA705	0.0008	Passed	0.0660	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Ocean View Elementary School	1st floor boys WR tap 5	MYA706	0.0012	Passed	0.0570	Passed
Ocean View Elementary School	JC tap between WR's	MYA707	0.0000	Passed	0.0150	Passed
Ocean View Elementary School	Fountain between WR's	NMV194	0.0004	Passed	0.0630	Passed
Ocean View Elementary School	1st floor Girls WR tap 1	MYA709	0.0180	Exceeds Limit	0.1400	Passed
Ocean View Elementary School	1st floor Girls WR tap 2	MYA710	0.0089	Exceeds Limit	0.0670	Passed
Ocean View Elementary School	1st floor Girls WR tap 3	MYA711	0.0038	Passed	0.0480	Passed
Ocean View Elementary School	1st floor Girls WR tap 4	MYA712	0.0016	Passed	0.0300	Passed
Ocean View Elementary School	1st floor Girls WR tap 5	MYA714	0.0021	Passed	0.0140	Passed
Ocean View Elementary School	Staff room kitchen tap	MYA715	0.0000	Passed	0.0570	Passed
Ocean View Elementary School	Staff room WR #1 tap	MYA716	0.0015	Passed	0.0920	Passed
Ocean View Elementary School	Staff room WR #2 tap	MYA717	0.0007	Passed	0.0550	Passed
Ocean View Elementary School	Sick room tap	MYA718	0.0041	Passed	0.5500	Passed
Ocean View Elementary School	CR WR tap room 112	MYA719	0.0056	Exceeds Limit	0.1300	Passed
Ocean View Elementary School	CR tap room 112	MYA720	0.0000	Passed	0.0800	Passed
Ocean View Elementary School	CR WR tap room 110	MYA721	0.0008	Passed	0.1000	Passed
Ocean View Elementary School	CR tap room 110	MYA722	0.0016	Passed	0.2100	Passed
Ocean View Elementary School	Fountain by room 110	NMV196	0.0008	Passed	0.1500	Passed
O'Connell Drive Elementary School	Library WR tap room 191	MXK240	0.0008	Passed	0.0920	Passed
O'Connell Drive Elementary School	JC tap room 181	MXK241	0.0012	Passed	0.0840	Passed
O'Connell Drive Elementary School	CR WR tap room 175	MXK242	0.0031	Passed	0.1800	Passed
O'Connell Drive Elementary School	CR tap room 177A	MXK243	0.0019	Passed	0.0870	Passed
O'Connell Drive Elementary School	CR tap room 173	MXK244	0.0870	Exceeds Limit	0.7300	Passed
O'Connell Drive Elementary School	CR WR tap room 174	MXK245	0.0014	Passed	0.1000	Passed
O'Connell Drive Elementary School	Boys WR tap 1 room 166	MXK246	0.0006	Passed	0.0390	Passed
O'Connell Drive Elementary School	Boys WR tap 2 room 166	MXK247	0.0000	Passed	0.0170	Passed
O'Connell Drive Elementary School	Girls WR tap 1 room 167	MXK248	0.0000	Passed	0.0210	Passed
O'Connell Drive Elementary School	Girls WR tap 2 room 167	MXK249	0.0000	Passed	0.0200	Passed
O'Connell Drive Elementary School	Fountain by Library	MXK250	0.0024	Passed	0.3700	Passed
O'Connell Drive Elementary School	Cafe/Kitchen tap 1 (by door)	MXK251	0.0013	Passed	0.0820	Passed
O'Connell Drive Elementary School	Cafe/Kitchen tap 2	MXK252	0.0008	Passed	0.2000	Passed
O'Connell Drive Elementary School	Boys CR WR tap room 156	MXK253	0.0010	Passed	0.0470	Passed
O'Connell Drive Elementary School	Girls CR WR tap room 159	MXK254	0.0016	Passed	0.1700	Passed
O'Connell Drive Elementary School	Gym office WR tap room 161	MXK255	0.0006	Passed	0.0530	Passed
O'Connell Drive Elementary School	Music room tap room 149	MXK256	0.0000	Passed	0.0290	Passed
O'Connell Drive Elementary School	CR tap room 140	MXK257	0.0039	Passed	0.2700	Passed
O'Connell Drive Elementary School	CR WR tap room 139	MXK258	0.0090	Exceeds Limit	0.4800	Passed
O'Connell Drive Elementary School	Girls WR tap 1 room 137	MXK259	0.0014	Passed	0.1800	Passed
O'Connell Drive Elementary School	Girls WR tap 2 room 137	MXK260	0.0000	Passed	0.0910	Passed
O'Connell Drive Elementary School	Girls WR tap 3 room 137	MXK261	0.0000	Passed	0.0710	Passed
O'Connell Drive Elementary School	Boys WR tap 1 room 135	MXK262	0.0009	Passed	0.1700	Passed
O'Connell Drive Elementary School	Boys WR tap 2 room 135	MXK263	0.0000	Passed	0.0810	Passed
O'Connell Drive Elementary School	Boys WR tap 3 room 135	MXK264	0.0000	Passed	0.0590	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
O'Connell Drive Elementary School	Fountain right of boys WR	NKI348	0.0004	Passed	0.0310	Passed
O'Connell Drive Elementary School	JC tap room 126	MXK266	0.0013	Passed	0.1700	Passed
O'Connell Drive Elementary School	Staff room kitchen tap room 115A	MXK267	0.0000	Passed	0.0160	Passed
O'Connell Drive Elementary School	Main office WR #1 tap room 114	MXK268	0.0000	Passed	0.0230	Passed
O'Connell Drive Elementary School	Main office WR #2 tap room 113	MXK269	0.0010	Passed	0.0280	Passed
O'Connell Drive Elementary School	Main office WR #3 room 111	MXK584	0.0019	Passed	0.0480	Passed
Oldfield Consolidated School	Teachers room 16 tap	MWG681	0.0000	Passed	0.0026	Passed
Oldfield Consolidated School	Staff WR tap room 14	MWG682	0.0000	Passed	0.0024	Passed
Oldfield Consolidated School	Girls WR tap 1 room 12	MWG683	0.0000	Passed	0.0045	Passed
Oldfield Consolidated School	Girls WR tap 2 room 12	MWG684	0.0000	Passed	0.0027	Passed
Oldfield Consolidated School	Girls WR tap 3 room 12	MWG685	0.0000	Passed	0.0031	Passed
Oldfield Consolidated School	Girls WR tap 4 room 12	MWG686	0.0000	Passed	0.0026	Passed
Oldfield Consolidated School	JC tap room 10	MWG687	0.0017	Passed	0.0041	Passed
Oldfield Consolidated School	Boys WR tap 1 room 8	MWG688	0.0000	Passed	0.0034	Passed
Oldfield Consolidated School	Boys WR tap 2 room 8	MWG689	0.0000	Passed	0.0050	Passed
Oldfield Consolidated School	Boys WR tap 3 room 8	MWG690	0.0005	Passed	0.0078	Passed
Oldfield Consolidated School	Learning centre tap room 6	MWG691	0.0000	Passed	0.0026	Passed
Oxford School	3rd floor girls WR tap 1 (East)	MSZ272	0.0021	Passed	0.4200	Passed
Oxford School	3rd floor girls WR tap 2 (East)	MSZ273	0.0044	Passed	0.2800	Passed
Oxford School	3rd floor staff WR tap	MSZ274	0.0008	Passed	0.0220	Passed
Oxford School	Fountain by room 303	MSZ275	0.0000	Passed	0.1100	Passed
Oxford School	3rd floor staff WR 2 tap	MSZ276	0.0059	Exceeds Limit	0.0490	Passed
Oxford School	3rd floor boys WR tap 1 (East)	MSZ277	0.0016	Passed	0.0690	Passed
Oxford School	3rd floor boys WR tap 2 (East)	MSZ278	0.0040	Passed	0.2000	Passed
Oxford School	JC tap by room 305	MSZ279	0.0011	Passed	0.0560	Passed
Oxford School	Staff room tap room 312	MSZ280	0.0018	Passed	0.3300	Passed
Oxford School	3rd floor Boys WR tap 1 (West)	MSZ281	0.0000	Passed	0.0430	Passed
Oxford School	3rd floor Boys WR tap 2 (West)	MSZ296	0.0007	Passed	0.0560	Passed
Oxford School	3rd floor Boys WR tap 3 (West)	MSZ297	0.0005	Passed	0.0480	Passed
Oxford School	Fountain by room 317	MSZ298	0.0000	Passed	0.4700	Passed
Oxford School	3rd floor girls WR tap 1 (West)	MSZ299	0.0020	Passed	0.0460	Passed
Oxford School	3rd floor girls WR tap 2 (West)	MSZ300	0.0000	Passed	0.0470	Passed
Oxford School	3rd floor girls WR tap 3 (West)	MSZ301	0.0020	Passed	0.1500	Passed
Oxford School	CR WR tap room 314	MSZ302	0.0000	Passed	0.0660	Passed
Oxford School	2nd floor boys WR tap 1 (East)	MSZ303	0.0096	Exceeds Limit	0.0520	Passed
Oxford School	2nd floor boys WR tap 2 (East)	MSZ304	0.0000	Passed	0.0032	Passed
Oxford School	Art room tap room 202	MSZ305	0.0170	Exceeds Limit	0.5200	Passed
Oxford School	Family studies tap 1 room 204	MSZ306	0.0000	Passed	0.2300	Passed
Oxford School	Family studies tap 2 room 204	MSZ307	0.0000	Passed	0.1900	Passed
Oxford School	Family studies tap 3 room 204	MSZ308	0.0048	Passed	0.2100	Passed
Oxford School	Family studies tap 4 room 204	MSZ309	0.0007	Passed	0.0380	Passed
Oxford School	JC tap by room 206	MSZ310	0.0018	Passed	0.0270	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Oxford School	Fountain by room 206	MSZ311	0.0000	Passed	0.2600	Passed
Oxford School	2nd floor girls WR tap 1 (East)	MSZ312	0.0009	Passed	0.1500	Passed
Oxford School	2nd floor girls WR tap 2 (East)	MSZ313	0.0006	Passed	0.1600	Passed
Oxford School	2nd floor JC tap beside room 206	MSZ314	0.0500	Exceeds Limit	1.4000	Passed
Oxford School	2nd floor staff WR tap 1 by room 210	MSZ315	0.0007	Passed	0.1400	Passed
Oxford School	2nd floor staff WR tap 2 by room 210	MSZ316	0.0016	Passed	0.4400	Passed
Oxford School	2nd floor staff WR tap 3 by room 210	MSZ317	0.0035	Passed	0.3400	Passed
Oxford School	2nd floor boys WR tap 1 by room 217	MSZ318	0.0010	Passed	0.0690	Passed
Oxford School	2nd floor boys WR tap 2 by room 217	MSZ319	0.0008	Passed	0.0610	Passed
Oxford School	2nd floor boys WR tap 3 by room 217	MSZ320	0.0000	Passed	0.0490	Passed
Oxford School	JC tap by room 217	MSZ321	0.0000	Passed	0.0520	Passed
Oxford School	Fountain by room 217	MSZ322	0.0006	Passed	0.5400	Passed
Oxford School	Girls WR tap 1 by room 215	MSZ323	0.0000	Passed	0.0410	Passed
Oxford School	Girls WR tap 2 by room 215	MSZ324	0.0020	Passed	0.1000	Passed
Oxford School	Girls WR tap 3 by room 215	MSZ325	0.0012	Passed	0.1200	Passed
Oxford School	Gym kitchen tap	MSZ326	0.0000	Passed	0.2300	Passed
Oxford School	Fountain by gym	MSZ328	0.0005	Passed	0.5500	Passed
Oxford School	Gym girls locker room tap	MSZ329	0.0006	Passed	0.2300	Passed
Oxford School	Basement boiler room tap	MSZ330	0.0011	Passed	0.5600	Passed
Oxford School	1st floor boys WR tap 1 by room 104	MSZ331	0.0044	Passed	0.8000	Passed
Oxford School	1st floor boys WR tap 2 by room 104	MSZ332	0.0000	Passed	0.0590	Passed
Oxford School	staff room kitchen tap room 109	MSZ333	0.0000	Passed	0.0380	Passed
Oxford School	staff WR tap room 109	MSZ334	0.0000	Passed	0.0220	Passed
Oxford School	Boys WR tap 1 by room 111	MSZ335	0.0011	Passed	0.0900	Passed
Oxford School	Boys WR tap 2 by room 111	MSZ336	0.0010	Passed	0.1100	Passed
Oxford School	Boys WR tap 3 by room 111	MSZ337	0.0006	Passed	0.0640	Passed
Oxford School	1st floor JC tap by room 111	MSZ338	0.0009	Passed	0.0790	Passed
Oxford School	Fountain by room 111	MSZ339	0.0007	Passed	0.0840	Passed
Oxford School	1st floor girls WR tap 1 by room 111	MSZ340	0.0030	Passed	0.2600	Passed
Oxford School	1st floor girls WR tap 2 by room 111	MSZ341	0.0007	Passed	0.1200	Passed
Oxford School	1st floor girls WR tap 3 by room 111	MSZ342	0.0007	Passed	0.0480	Passed
Oxford School	1st floor office tap	MSZ343	0.0000	Passed	0.0180	Passed
Oxford School	Gym boys locker room tap	MSZ344	0.0013	Passed	0.2700	Passed
Oyster Pond Academy	CR tap 1 room 2201	NAH599	0.0015	Passed	0.2100	Passed
Oyster Pond Academy	CR tap 2 room 2201	NAH600	0.0035	Passed	0.6400	Passed
Oyster Pond Academy	Staff WR tap room 2106	NAH601	0.0035	Passed	0.8600	Passed
Oyster Pond Academy	CR WR tap room 2303	NAH602	0.0057	Exceeds Limit	0.7800	Passed
Oyster Pond Academy	Girls WR tap 1 by room 2104	NAH603	0.0180	Exceeds Limit	0.6900	Passed
Oyster Pond Academy	Girls WR tap 2 by room 2104	NAH604	0.0370	Exceeds Limit	1.2000	Passed
Oyster Pond Academy	Girls WR tap 3 by room 2104	NAH605	0.0320	Exceeds Limit	0.9500	Passed
Oyster Pond Academy	JC tap room 2104	NAH606	0.0710	Exceeds Limit	0.9900	Passed
Oyster Pond Academy	Boys WR tap 1 by room 2104	NAH607	0.0340	Exceeds Limit	0.6400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Oyster Pond Academy	Boys WR tap 2 by room 2104	NAH608	0.0150	Exceeds Limit	0.8900	Passed
Oyster Pond Academy	Boys WR tap 3 by room 2104	NAH609	0.0220	Exceeds Limit	1.0000	Passed
Oyster Pond Academy	Fountain by boys WR	NKI426	0.0041	Passed	1.0000	Passed
Oyster Pond Academy	CR tap 1 room 2203	NAH611	0.0026	Passed	1.5000	Passed
Oyster Pond Academy	CR tap 2 room 2203	NAH612	0.0012	Passed	3.2000	Exceeds Limit
Oyster Pond Academy	CR tap 3 room 2203	NAH613	0.0018	Passed	2.2000	Exceeds Limit
Oyster Pond Academy	CR tap 4 room 2203	NAH614	0.0018	Passed	3.2000	Exceeds Limit
Oyster Pond Academy	Boys WR tap 1 by room 2114	NAH615	0.2100	Exceeds Limit	0.8100	Passed
Oyster Pond Academy	Boys WR tap 2 by room 2114	NAH616	0.0620	Exceeds Limit	2.2000	Exceeds Limit
Oyster Pond Academy	Boys WR tap 3 by room 2114	NAH617	0.0700	Exceeds Limit	2.6000	Exceeds Limit
Oyster Pond Academy	JC tap room 2114	NAH618	0.0530	Exceeds Limit	0.9100	Passed
Oyster Pond Academy	Girls WR tap 1 by room 2114	NAH620	0.2700	Exceeds Limit	2.8000	Exceeds Limit
Oyster Pond Academy	Girls WR tap 2 by room 2114	NAH621	0.1300	Exceeds Limit	2.1000	Exceeds Limit
Oyster Pond Academy	Girls WR tap 3 by room 2114	NAH622	0.0380	Exceeds Limit	1.1000	Passed
Oyster Pond Academy	Fountain by girls WR	NAH623	0.0047	Passed	1.7000	Passed
Oyster Pond Academy	Staff WR tap room 2111	NAH624	0.0056	Exceeds Limit	0.0980	Passed
Oyster Pond Academy	CR tap 1 room 2209	NAH625	0.0034	Passed	0.4900	Passed
Oyster Pond Academy	CR tap 2 room 2209	NAH626	0.0079	Exceeds Limit	0.4500	Passed
Oyster Pond Academy	CR tap 3 room 2209	NAH627	0.0033	Passed	1.5000	Passed
Oyster Pond Academy	CR tap 4 room 2209	NAH628	0.0023	Passed	1.1000	Passed
Oyster Pond Academy	CR tap 5 room 2209	NAH629	0.0034	Passed	0.4300	Passed
Oyster Pond Academy	CR tap room 1422	NAH641	0.0000	Passed	0.5700	Passed
Oyster Pond Academy	Single compartment sink 1 tap room 1420	NAH642	0.0031	Passed	1.1000	Passed
Oyster Pond Academy	Triple compartment sink tap room 1420	NKI428	0.0048	Passed	1.0000	Passed
Oyster Pond Academy	Single compartment sink 2 tap room 1420	NAH645	0.0015	Passed	1.4000	Passed
Oyster Pond Academy	JC tap room 1421	NAH647	0.0490	Exceeds Limit	1.2000	Passed
Oyster Pond Academy	Laundry tub tap room 1424	NAH648	0.0089	Exceeds Limit	1.5000	Passed
Oyster Pond Academy	GN WR tap room 1303	NAH650	0.0023	Passed	0.3600	Passed
Oyster Pond Academy	CR tap room 1301	NAH651	0.0013	Passed	1.9000	Passed
Oyster Pond Academy	CR tap room 1307	NAH653	0.0083	Exceeds Limit	1.6000	Passed
Oyster Pond Academy	CR tap room 1309	NAH654	0.0220	Exceeds Limit	16.0000	Exceeds Limit
Oyster Pond Academy	CR tap room 1313	NAH680	0.0040	Passed	4.2000	Exceeds Limit
Oyster Pond Academy	CR tap room 1314	NAH681	0.0015	Passed	1.8000	Passed
Oyster Pond Academy	CR tap room 1310	NAH682	0.0018	Passed	2.1000	Exceeds Limit
Oyster Pond Academy	CR tap room 1308	NAH683	0.0027	Passed	1.1000	Passed
Oyster Pond Academy	CR WR tap room 1306	NAH684	0.0016	Passed	0.7200	Passed
Oyster Pond Academy	CR WR tap room 1305	NAH685	0.0033	Passed	0.9500	Passed
Oyster Pond Academy	CR tap room 1302	NAH686	0.0033	Passed	0.9400	Passed
Oyster Pond Academy	Girls WR tap 1 by room 1133	NAH687	0.0230	Exceeds Limit	0.7100	Passed
Oyster Pond Academy	Girls WR tap 2 by room 1133	NAH688	0.0480	Exceeds Limit	1.9000	Passed
Oyster Pond Academy	Girls WR tap 3 by room 1133	NAH689	0.0490	Exceeds Limit	2.5000	Exceeds Limit
Oyster Pond Academy	JC tap room 1133	NAH698	0.0061	Exceeds Limit	0.8400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Oyster Pond Academy	Boys WR tap 1 by room 1133	NAH699	0.1300	Exceeds Limit	1.0000	Passed
Oyster Pond Academy	Boys WR tap 2 by room 1133	NAH704	0.0750	Exceeds Limit	2.2000	Exceeds Limit
Oyster Pond Academy	Boys WR tap 3 by room 1133	NAH712	0.1000	Exceeds Limit	3.2000	Exceeds Limit
Oyster Pond Academy	Fountain by boys WR	NAH713	0.0120	Exceeds Limit	5.0000	Exceeds Limit
Oyster Pond Academy	Staff WR tap room 1132	NAH714	0.0027	Passed	3.1000	Exceeds Limit
Oyster Pond Academy	CR tap room 1129	NAH715	0.0032	Passed	1.1000	Passed
Oyster Pond Academy	Staff WR tap room 1109	NAH716	0.0100	Exceeds Limit	4.6000	Exceeds Limit
Oyster Pond Academy	CR tap room 1113	NAH717	0.0017	Passed	3.4000	Exceeds Limit
Oyster Pond Academy	Staff WR tap room 1115	NAH718	0.0027	Passed	5.3000	Exceeds Limit
Oyster Pond Academy	Staff WR tap room 1114	NAH730	0.0026	Passed	2.5000	Exceeds Limit
Oyster Pond Academy	CR tap room 1122	NAH731	0.0170	Exceeds Limit	0.1500	Passed
Oyster Pond Academy	CR WR tap room 1205	NAH732	0.0044	Passed	1.6000	Passed
Oyster Pond Academy	CR tap room 1203	NAH733	0.0037	Passed	1.5000	Passed
Oyster Pond Academy	Laundry tub tap room 1201	NAH734	0.0051	Exceeds Limit	3.2000	Exceeds Limit
Oyster Pond Academy	Girls WR tap 1 by room 1125	NAH735	0.0370	Exceeds Limit	0.9900	Passed
Oyster Pond Academy	Girls WR tap 2 by room 1125	NAH736	0.0290	Exceeds Limit	1.4000	Passed
Oyster Pond Academy	Girls WR tap 3 by room 1125	NAH737	0.0730	Exceeds Limit	0.9500	Passed
Oyster Pond Academy	JC tap room 1125	NAH738	0.0670	Exceeds Limit	2.7000	Exceeds Limit
Oyster Pond Academy	Boys WR tap 1 by room 1125	NAH739	0.1100	Exceeds Limit	0.8500	Passed
Oyster Pond Academy	Boys WR tap 2 by room 1125	NAH740	0.0890	Exceeds Limit	1.2000	Passed
Oyster Pond Academy	Boys WR tap 3 by room 1125	NAH741	0.0770	Exceeds Limit	0.9800	Passed
Oyster Pond Academy	Fountain by boys WR	NKI428	0.0037	Passed	0.9500	Passed
Oyster Pond Academy	Fountain by gym entrance	NAH743	0.0007	Passed	2.3000	Exceeds Limit
Oyster Pond Academy	CR tap 1 room 1413	NAH744	0.0780	Exceeds Limit	0.2500	Passed
Oyster Pond Academy	CR tap 2 room 1413	NAH745	0.0610	Exceeds Limit	0.3400	Passed
Oyster Pond Academy	CR tap 1 room 1410	NAH746	0.1100	Exceeds Limit	1.2000	Passed
Oyster Pond Academy	CR tap 2 room 1410	NAH747	0.0880	Exceeds Limit	0.4000	Passed
Oyster Pond Academy	CR WR tap room 1404	NAH751	0.0930	Exceeds Limit	2.4000	Exceeds Limit
Park West School	Main office WR tap room 1090	MQJ269	0.0000	Passed	0.0340	Passed
Park West School	Kitchen hand sink room 1080	MQJ270	0.0039	Passed	0.1200	Passed
Park West School	Kitchen MKE sink room 1080	MQJ271	0.0000	Passed	0.0044	Passed
Park West School	Kitchen hand dish room 1080	MQJ272	0.0000	Passed	0.0045	Passed
Park West School	Girls WR tap room 1067	MQJ273	0.0025	Passed	0.3300	Passed
Park West School	Boys WR tap room 1068	MQJ274	0.0000	Passed	0.0910	Passed
Park West School	CR tap 1 room 1069	MQJ275	0.0000	Passed	0.1100	Passed
Park West School	CR tap 2 room 1069	MQJ276	0.0000	Passed	0.0760	Passed
Park West School	Music room tap room 1070	MQJ277	0.0000	Passed	0.0780	Passed
Park West School	Library work room tap room 1041	MQJ278	0.0000	Passed	0.3400	Passed
Park West School	CR tap room 1014	MQJ279	0.0000	Passed	0.2400	Passed
Park West School	CR tap room 1013	MQJ280	0.0000	Passed	0.0420	Passed
Park West School	CR tap room 1016	MQJ281	0.0000	Passed	0.1800	Passed
Park West School	CR tap room 1012	MQJ282	0.0000	Passed	0.1900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Park West School	CR tap room 1011	MQJ283	0.0000	Passed	0.1100	Passed
Park West School	Fountain by room 1048	MQJ284	0.0000	Passed	0.1500	Passed
Park West School	Girls WR tap 1 room 1048	MQJ285	0.0000	Passed	0.1600	Passed
Park West School	Girls WR tap 2 room 1048	MQJ286	0.0000	Passed	0.1200	Passed
Park West School	Girls WR tap 3 room 1048	MQJ287	0.0000	Passed	0.1300	Passed
Park West School	Girls WR tap 4 room 1048	MQJ288	0.0000	Passed	0.1300	Passed
Park West School	GN WR tap room 1047	MQJ291	0.0000	Passed	0.1400	Passed
Park West School	JC tap room 1046	MQJ292	0.0000	Passed	0.5500	Passed
Park West School	CR tap room 1027	MQJ293	0.0000	Passed	0.0440	Passed
Park West School	CR tap room 1026	MQJ294	0.0000	Passed	0.2400	Passed
Park West School	CR tap room 1025	MQJ295	0.0000	Passed	0.1900	Passed
Park West School	CR tap room 1021	MQJ296	0.0000	Passed	0.1600	Passed
Park West School	GN WR tap room 1029	MQJ297	0.0000	Passed	0.2000	Passed
Park West School	CR tap room 1034	MQJ298	0.0000	Passed	0.2200	Passed
Park West School	GN WR tap room 1036	MQJ300	0.0000	Passed	0.2400	Passed
Park West School	CR tap room 1032	MQJ304	0.0000	Passed	0.1700	Passed
Park West School	CR tap room 1031	MQJ305	0.0000	Passed	0.2000	Passed
Park West School	Boys WR tap 1 room 1043	MQJ306	0.0000	Passed	0.2500	Passed
Park West School	Boys WR tap 2 room 1043	MQJ307	0.0000	Passed	0.1600	Passed
Park West School	Boys WR tap 3 room 1043	MQJ308	0.0023	Passed	0.1900	Passed
Park West School	Boys WR tap 4 room 1043	MQJ309	0.0000	Passed	0.1500	Passed
Park West School	Fountain by room 1061	MQJ310	0.0000	Passed	0.1300	Passed
Park West School	Gym office WR tap	MQJ311	0.0000	Passed	0.1200	Passed
Park West School	Boys locker room tap 1 room 1058	MQJ312	0.0000	Passed	0.0860	Passed
Park West School	Boys locker room tap 2 room 1058	MQJ313	0.0000	Passed	0.2300	Passed
Park West School	Girls locker room tap 1 room 1058	MQJ318	0.0000	Passed	0.2000	Passed
Park West School	Girls locker room tap 2 room 1058	MQJ319	0.0000	Passed	0.1800	Passed
Park West School	CR tap room 2026	MQJ320	0.0000	Passed	0.1500	Passed
Park West School	CR tap room 2027	MQJ321	0.0000	Passed	0.2400	Passed
Park West School	CR tap 1 room 2028	MQJ322	0.0000	Passed	0.1700	Passed
Park West School	CR tap 2 room 2028	MQJ323	0.0000	Passed	0.1700	Passed
Park West School	CR tap 1 room 2029	MQJ324	0.0000	Passed	0.7700	Passed
Park West School	CR tap 2 room 2029	MQJ325	0.0000	Passed	0.2300	Passed
Park West School	CR tap 3 room 2029	MQJ326	0.0000	Passed	0.1000	Passed
Park West School	CR tap 1 room 2036	MQJ327	0.0000	Passed	0.1200	Passed
Park West School	CR tap 2 room 2036	MQJ328	0.0000	Passed	0.1700	Passed
Park West School	CR tap room 2037	MQJ329	0.0000	Passed	0.0940	Passed
Park West School	CR tap room 2038	MQJ330	0.0000	Passed	0.2300	Passed
Park West School	CR tap 1 room 2039	MQJ331	0.0023	Passed	0.3400	Passed
Park West School	JC tap room 2064	MQJ333	0.0000	Passed	0.2200	Passed
Park West School	GN WR tap room 2065	MQJ334	0.0000	Passed	0.0290	Passed
Park West School	Fountain by room 2065	MQJ335	0.0006	Passed	0.2400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Park West School	Fountain by room 2026	MQJ336	0.0000	Passed	0.1600	Passed
Park West School	CR tap room 2046	MQJ337	0.0000	Passed	0.2100	Passed
Park West School	CR tap room 2047	MQJ338	0.0000	Passed	0.2100	Passed
Park West School	CR tap room 2048	MQJ339	0.0000	Passed	0.3400	Passed
Park West School	CR tap room 2049	MQJ340	0.0000	Passed	0.2200	Passed
Park West School	Staff room WR tap room 2074	MQJ341	0.0028	Passed	0.0580	Passed
Park West School	Staff room kitchen tap room 2075	MQJ342	0.0000	Passed	0.0760	Passed
Park West School	Staff room WR tap room 2073	MQJ343	0.0000	Passed	0.1600	Passed
Park West School	CR tap room 2071	MQJ344	0.0000	Passed	0.0690	Passed
Park West School	Girls WR tap 1 room 2056	MQJ345	0.0000	Passed	0.1700	Passed
Park West School	Girls WR tap 2 room 2056	MQJ346	0.0000	Passed	0.2000	Passed
Park West School	Girls WR tap 3 room 2056	MQJ347	0.0008	Passed	0.1800	Passed
Park West School	Girls WR tap 2 room 2056	MQJ348	0.0000	Passed	0.1200	Passed
Park West School	Girls WR tap 3 room 2056	MQJ349	0.0000	Passed	0.1500	Passed
Park West School	Girls WR tap 4 room 2056	MQJ350	0.0000	Passed	0.1200	Passed
Park West School	Boys WR tap 1 room 2055	MQJ351	0.0000	Passed	0.1000	Passed
Park West School	Boys WR tap 2 room 2055	MQJ352	0.0005	Passed	0.1200	Passed
Park West School	Boys WR tap 3 room 2055	MQJ353	0.0000	Passed	0.1100	Passed
Park West School	Boys WR tap 4 room 2055	MQJ354	0.0000	Passed	0.0980	Passed
Park West School	Food lab tap 1 room 2012	MQJ355	0.0007	Passed	0.1200	Passed
Park West School	Food lab tap 2 room 2012	MQJ356	0.0000	Passed	0.2300	Passed
Park West School	Food lab tap 3 room 2012	MQJ357	0.0000	Passed	0.1000	Passed
Park West School	Food lab tap 4 room 2012	MQJ358	0.0000	Passed	0.1700	Passed
Park West School	CR tap room 1033	NES598	0.0000	Passed	0.2100	Passed
Park West School	CR tap 2 room 2039	NES599	0.0000	Passed	0.1100	Passed
Porters Lake Elementary School	Main office WR tap room 169	MXS508	0.0026	Passed	0.2500	Passed
Porters Lake Elementary School	Fountain by room 168	MXS509	0.0014	Passed	0.1500	Passed
Porters Lake Elementary School	CR tap room 164	MXS510	0.0007	Passed	0.3000	Passed
Porters Lake Elementary School	CR WR tap room 163	MXS511	0.0006	Passed	0.2000	Passed
Porters Lake Elementary School	CR WR tap room 162	MXS512	0.0011	Passed	0.2500	Passed
Porters Lake Elementary School	CR tap room 161	MXS513	0.0034	Passed	0.3200	Passed
Porters Lake Elementary School	CR tap room 160	MXS514	0.0027	Passed	0.5300	Passed
Porters Lake Elementary School	CR tap room 158	MXS515	0.0007	Passed	0.0850	Passed
Porters Lake Elementary School	CR tap room 155	MXS516	0.0049	Passed	0.0990	Passed
Porters Lake Elementary School	CR tap room 153	MXS517	0.0016	Passed	0.1600	Passed
Porters Lake Elementary School	CR tap room 152	MXS520	0.0018	Passed	0.3300	Passed
Porters Lake Elementary School	CR tap room 150	MXS521	0.0040	Passed	0.2900	Passed
Porters Lake Elementary School	JC tap room 147	MXS522	0.0011	Passed	0.1100	Passed
Porters Lake Elementary School	Arts/stage CR tap 1 room 178	MXS523	0.0010	Passed	0.0530	Passed
Porters Lake Elementary School	Arts/stage CR tap 2 room 178	MXS524	0.0000	Passed	0.0530	Passed
Porters Lake Elementary School	Girls WR tap 1 by room 145	MXS525	0.0028	Passed	0.2300	Passed
Porters Lake Elementary School	Girls WR tap 2 by room 145	MXS526	0.0540	Exceeds Limit	0.8400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Porters Lake Elementary School	Girls WR tap 3 by room 145	MXS527	0.0190	Exceeds Limit	1.1000	Passed
Porters Lake Elementary School	Boys WR tap 1 by room 146	MXS528	0.0040	Passed	0.1600	Passed
Porters Lake Elementary School	Boys WR tap 2 by room 146	MXS529	0.0026	Passed	0.1200	Passed
Porters Lake Elementary School	Boys WR tap 3 by room 146	MXS530	0.0019	Passed	0.1100	Passed
Porters Lake Elementary School	JC tap room 142	MXS531	0.0025	Passed	0.1200	Passed
Porters Lake Elementary School	JC tap room 138	MXS532	0.0038	Passed	0.2500	Passed
Porters Lake Elementary School	Gym office WR tap room 161	MXS533	0.0032	Passed	0.2000	Passed
Porters Lake Elementary School	Boys locker room tap 1	MXS534	0.0094	Exceeds Limit	0.3100	Passed
Porters Lake Elementary School	Boys locker room tap 2	MXS535	0.0240	Exceeds Limit	0.9700	Passed
Porters Lake Elementary School	Girls locker room tap 1	MXS536	0.0160	Exceeds Limit	0.4100	Passed
Porters Lake Elementary School	Girls locker room tap 2	MXS537	0.0096	Exceeds Limit	0.2900	Passed
Porters Lake Elementary School	Cafe/Kitchen tap 1 (by door)	MXS538	0.0085	Exceeds Limit	0.1800	Passed
Porters Lake Elementary School	Cafe/Kitchen tap 2 (Big Sink)	MXS539	0.0017	Passed	0.1000	Passed
Porters Lake Elementary School	Cafe/Kitchen tap 3	MXS542	0.0074	Exceeds Limit	0.1500	Passed
Porters Lake Elementary School	Cafe/Kitchen tap 4	MXS543	0.0070	Exceeds Limit	0.1500	Passed
Porters Lake Elementary School	Recycle room kitchen tap room 192	MXS544	0.0041	Passed	0.1200	Passed
Porters Lake Elementary School	Recycle room wash-up tap room 192	MXS545	0.0006	Passed	0.0450	Passed
Porters Lake Elementary School	Fountain by room 192	MXS546	0.0012	Passed	0.1400	Passed
Porters Lake Elementary School	Boys WR tap 1 by library	MXS547	0.0040	Passed	0.2300	Passed
Porters Lake Elementary School	Boys WR tap 2 by library	MXS548	0.0037	Passed	0.1600	Passed
Porters Lake Elementary School	Boys WR tap 3 by library	MXS549	0.0160	Exceeds Limit	0.5800	Passed
Porters Lake Elementary School	JC tap by fountain/boys WR	MXS550	0.0021	Passed	0.1200	Passed
Porters Lake Elementary School	Fountain between WR's	MXS551	0.0013	Passed	0.1400	Passed
Porters Lake Elementary School	Girls WR tap 1 by seminar room	MXS554	0.0110	Exceeds Limit	0.3200	Passed
Porters Lake Elementary School	Girls WR tap 2 by seminar room	MXS555	0.0065	Exceeds Limit	0.2500	Passed
Porters Lake Elementary School	Girls WR tap 3 by seminar room	MXS556	0.0480	Exceeds Limit	1.2000	Passed
Porters Lake Elementary School	Girls WR tap 4 by seminar room	MXS557	0.0100	Exceeds Limit	0.2500	Passed
Porters Lake Elementary School	Staff room tap room 129	MXS558	0.0006	Passed	0.1400	Passed
Porters Lake Elementary School	Staff room WR #1 tap room 125	MXS559	0.0022	Passed	0.1900	Passed
Porters Lake Elementary School	Staff room WR #1 tap room 126	MXS560	0.0013	Passed	0.1700	Passed
Porters Lake Elementary School	GN WR tap room 109	MXS561	0.0200	Exceeds Limit	0.4300	Passed
Porters Lake Elementary School	CR tap room 108	MXS562	0.0012	Passed	0.1200	Passed
Porters Lake Elementary School	Library tap room 106	MXS563	0.0027	Passed	0.1500	Passed
Portland Estates Elementary School	Gym locker room WR tap room 1077	NCB105	0.0000	Passed	1.4000	Passed
Portland Estates Elementary School	Gym office WR tap room 1073	NCB106	0.0009	Passed	0.3100	Passed
Portland Estates Elementary School	Kitchen tap 1 room 1066	NCB107	0.0009	Passed	0.6600	Passed
Portland Estates Elementary School	Kitchen tap 2 room 1066	NCB108	0.0006	Passed	0.0810	Passed
Portland Estates Elementary School	Kitchen tap 3 room 1066	NCB109	0.0011	Passed	0.7100	Passed
Portland Estates Elementary School	Kitchen tap 4 room 1066	NCB110	0.0000	Passed	0.2900	Passed
Portland Estates Elementary School	JC tap room 1059	NCB111	0.0000	Passed	0.0570	Passed
Portland Estates Elementary School	Music room tap room 1062	NCB112	0.0000	Passed	1.5000	Passed
Portland Estates Elementary School	Art room tap 1 room 1063	NCB113	0.0007	Passed	0.9500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Portland Estates Elementary School	Art room tap 2 room 1063	NCB114	0.0009	Passed	0.2500	Passed
Portland Estates Elementary School	Recycle room tap room 1055	NCB115	0.0022	Passed	0.1800	Passed
Portland Estates Elementary School	CR tap room 1036	NCB116	0.0000	Passed	0.7500	Passed
Portland Estates Elementary School	CR tap room 1037	NCB117	0.0018	Passed	0.2900	Passed
Portland Estates Elementary School	GN WR tap room 1041	NCB118	0.0007	Passed	0.7100	Passed
Portland Estates Elementary School	CR tap room 1038	NCB119	0.0000	Passed	0.3900	Passed
Portland Estates Elementary School	CR tap room 1039	NCB120	0.0009	Passed	0.3000	Passed
Portland Estates Elementary School	Office health room tap room 1021	NCB121	0.0010	Passed	0.2200	Passed
Portland Estates Elementary School	Office WR tap room 1018	NCB122	0.0019	Passed	0.1900	Passed
Portland Estates Elementary School	Fountain by room 1025	NCB123	0.0000	Passed	0.2800	Passed
Portland Estates Elementary School	Female WR room 1050 tap 1	NCB124	0.0007	Passed	0.2400	Passed
Portland Estates Elementary School	Female WR room 1050 tap 2	NCB126	0.0006	Passed	0.3400	Passed
Portland Estates Elementary School	Female WR room 1050 tap 3	NCB127	0.0006	Passed	0.2800	Passed
Portland Estates Elementary School	male WR room 1049 tap 1	NCB128	0.0000	Passed	0.2500	Passed
Portland Estates Elementary School	male WR room 1049 tap 2	NCB129	0.0007	Passed	0.4300	Passed
Portland Estates Elementary School	male WR room 1049 tap 3	NCB130	0.0006	Passed	0.3800	Passed
Portland Estates Elementary School	Fountain by room 1049	NCB131	0.0000	Passed	0.1500	Passed
Portland Estates Elementary School	Lab storage room 1047 tap	NCB132	0.0007	Passed	0.2900	Passed
Portland Estates Elementary School	Female WR tap 1 room 1046	NCB133	0.0012	Passed	0.1200	Passed
Portland Estates Elementary School	Female WR tap 2 room 1046	NCB134	0.0063	Exceeds Limit	0.4600	Passed
Portland Estates Elementary School	Male WR tap 1 room 1045	NCB135	0.0006	Passed	0.1400	Passed
Portland Estates Elementary School	Male WR tap 2 room 1045	NCB136	0.0020	Passed	0.1900	Passed
Portland Estates Elementary School	Fountain right of room 1045	NCB137	0.0012	Passed	0.3400	Passed
Portland Estates Elementary School	CR tap room 2030	NCB138	0.0000	Passed	0.2600	Passed
Portland Estates Elementary School	CR tap room 2031	NCB140	0.0006	Passed	0.2600	Passed
Portland Estates Elementary School	CR tap room 2032	NCB142	0.0000	Passed	0.4100	Passed
Portland Estates Elementary School	CR tap room 2033	NCB144	0.0000	Passed	0.4400	Passed
Portland Estates Elementary School	CR tap room 2017	NCB146	0.0009	Passed	0.2200	Passed
Portland Estates Elementary School	CR tap room 2018	NCB148	0.0006	Passed	0.5700	Passed
Portland Estates Elementary School	CR tap room 2019	NCB149	0.0130	Exceeds Limit	0.4700	Passed
Portland Estates Elementary School	CR tap room 2020	NCB150	0.0000	Passed	0.5400	Passed
Portland Estates Elementary School	Staff room WR tap room 2009	NCB151	0.0031	Passed	0.4500	Passed
Portland Estates Elementary School	Staff room WR tap room 2008	NCB152	0.0017	Passed	0.3500	Passed
Portland Estates Elementary School	Staff room kitchen tap room 2007	NCB153	0.0005	Passed	0.1900	Passed
Portland Estates Elementary School	Male WR tap 1 room 2026	NCB154	0.0006	Passed	0.3100	Passed
Portland Estates Elementary School	Male WR tap 2 room 2026	NCB155	0.0009	Passed	0.2900	Passed
Portland Estates Elementary School	Male WR tap 3 room 2026	NCB156	0.0005	Passed	0.2400	Passed
Portland Estates Elementary School	Fountain right of room 2026	NCB157	0.0000	Passed	0.2300	Passed
Portland Estates Elementary School	Fountain by room 2017	NCB158	0.0000	Passed	0.3300	Passed
Portland Estates Elementary School	Female WR tap 1 room 2025	NCB159	0.0069	Exceeds Limit	0.4100	Passed
Portland Estates Elementary School	Female WR tap 2 room 2025	NCB160	0.0009	Passed	0.3600	Passed
Portland Estates Elementary School	Female WR tap 3 room 2025	NCB162	0.0026	Passed	0.3200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Prince Andrew High School	2nd Flr Male SR WR Tap	MXH491	0.0009	Passed	0.1200	Passed
Prince Andrew High School	2nd Flr Female SR WR Tap	MXH492	0.0065	Exceeds Limit	0.2600	Passed
Prince Andrew High School	2nd Flr SR tap	MXH493	0.0000	Passed	0.0940	Passed
Prince Andrew High School	2nd Flr JC	MXH494	0.0000	Passed	0.1100	Passed
Prince Andrew High School	2nd Flr Male Staff WR	MXH495	0.0090	Exceeds Limit	0.1500	Passed
Prince Andrew High School	2nd Flr Boys WR Tap 1	MXH496	0.0100	Exceeds Limit	0.3000	Passed
Prince Andrew High School	2nd Flr Boys WR Tap 2	MXH497	0.0960	Exceeds Limit	1.2000	Passed
Prince Andrew High School	2nd Flr Boys WR Tap 3	MXH498	0.0320	Exceeds Limit	0.4700	Passed
Prince Andrew High School	2nd Flr Boys WR Tap 4	MXH499	0.0023	Passed	0.5800	Passed
Prince Andrew High School	2nd Flr Female Staff WR	MXH500	0.0031	Passed	0.0540	Passed
Prince Andrew High School	2nd Flr Girls WR Tap 1	MXH501	0.0420	Exceeds Limit	0.8300	Passed
Prince Andrew High School	2nd Flr Girls WR Tap 2	MXH502	0.1500	Exceeds Limit	0.7700	Passed
Prince Andrew High School	2nd Flr Girls WR Tap 3	MXH503	0.0110	Exceeds Limit	0.5600	Passed
Prince Andrew High School	2nd Flr Girls WR Tap 4	MXH504	0.0076	Exceeds Limit	0.8800	Passed
Prince Andrew High School	CR 232 tap	MXH505	0.0047	Passed	0.1200	Passed
Prince Andrew High School	Fountain by Rm 232	MXH506	0.0250	Exceeds Limit	0.6400	Passed
Prince Andrew High School	CR 230 tap	MXH507	0.0340	Exceeds Limit	1.5000	Passed
Prince Andrew High School	Chem lab tap 1 room 228	MXH508	0.0008	Passed	1.9000	Passed
Prince Andrew High School	Chem lab tap 2 room 228	MXH509	0.0092	Exceeds Limit	2.9000	Exceeds Limit
Prince Andrew High School	Chem lab tap 3 room 228	MXH510	0.0072	Exceeds Limit	2.6000	Exceeds Limit
Prince Andrew High School	Chem lab tap 4 room 228	MXH511	0.0018	Passed	0.8400	Passed
Prince Andrew High School	Chem lab tap 5 room 228	MXH512	0.0010	Passed	1.1000	Passed
Prince Andrew High School	Chem lab tap 6 room 228	MXH513	0.0000	Passed	0.5600	Passed
Prince Andrew High School	Chem lab tap 7 room 228	MXH514	0.0012	Passed	0.9800	Passed
Prince Andrew High School	Chem lab tap 8 room 228	MXH515	0.0007	Passed	1.2000	Passed
Prince Andrew High School	Chem lab tap 9 room 228	MXH516	0.0000	Passed	1.5000	Passed
Prince Andrew High School	Chem lab tap 10 room 228	MXH517	0.0000	Passed	1.2000	Passed
Prince Andrew High School	CR tap 1 room 226	MXH518	0.0058	Exceeds Limit	1.1000	Passed
Prince Andrew High School	CR tap 2 room 226	MXH519	0.0000	Passed	0.5700	Passed
Prince Andrew High School	CR tap 1 room 225	MXH520	0.0007	Passed	0.5100	Passed
Prince Andrew High School	CR tap 2 room 225	MXH521	0.0012	Passed	0.6100	Passed
Prince Andrew High School	Youth room tap room 219	MXH522	0.0027	Passed	0.1400	Passed
Prince Andrew High School	Music room tap room 218	MXH523	0.0000	Passed	0.0880	Passed
Prince Andrew High School	Fountain left of room 217	MXH524	0.0000	Passed	0.2600	Passed
Prince Andrew High School	CR tap left of room 217	MXH525	0.0040	Passed	1.6000	Passed
Prince Andrew High School	CR tap room 211	MXH526	0.0170	Exceeds Limit	0.6600	Passed
Prince Andrew High School	Fine arts office #5 WR tap	MXH527	0.0270	Exceeds Limit	0.2100	Passed
Prince Andrew High School	Fine arts office #4 WR tap	MXH528	0.0046	Passed	0.1800	Passed
Prince Andrew High School	2nd floor girls WR tap 1	MXH529	0.0034	Passed	1.3000	Passed
Prince Andrew High School	2nd floor girls WR tap 2	MXH530	0.0120	Exceeds Limit	0.3600	Passed
Prince Andrew High School	2nd floor girls WR tap 3	MXH531	0.0160	Exceeds Limit	0.5400	Passed
Prince Andrew High School	2nd floor Girls staff WR tap	MXH532	0.0120	Exceeds Limit	0.3100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Prince Andrew High School	2nd floor Fountain between WR's	MXH533	0.0110	Exceeds Limit	0.1300	Passed
Prince Andrew High School	2nd floor Fountain between WR's	MXH534	0.0064	Exceeds Limit	0.1400	Passed
Prince Andrew High School	2nd floor Boys staff WR tap	MXH535	0.0075	Exceeds Limit	0.1600	Passed
Prince Andrew High School	2nd floor Boys WR tap 1	MXH536	0.0420	Exceeds Limit	0.7500	Passed
Prince Andrew High School	2nd floor Boys WR tap 2	MXH537	0.0150	Exceeds Limit	0.2600	Passed
Prince Andrew High School	2nd floor Boys WR tap 3	MXH538	0.0056	Exceeds Limit	0.1800	Passed
Prince Andrew High School	CR tap room 229	MXH539	0.0015	Passed	0.1900	Passed
Prince Andrew High School	Science lab tap 1 room 231	MXH540	0.0040	Passed	0.4100	Passed
Prince Andrew High School	Science lab tap 2 room 231	MXH541	0.0180	Exceeds Limit	0.6200	Passed
Prince Andrew High School	Science lab tap 3 room 231	MXH542	0.0210	Exceeds Limit	1.3000	Passed
Prince Andrew High School	Science lab tap 4 room 231	MXH543	0.0190	Exceeds Limit	1.4000	Passed
Prince Andrew High School	Science lab tap 5 room 231	MXH544	0.0180	Exceeds Limit	1.3000	Passed
Prince Andrew High School	Science lab tap 6 room 231	MXH545	0.0140	Exceeds Limit	0.4800	Passed
Prince Andrew High School	Science lab tap 7 room 231	MXH546	0.0062	Exceeds Limit	0.6800	Passed
Prince Andrew High School	Science lab tap 8 room 231	MXH547	0.0089	Exceeds Limit	0.8700	Passed
Prince Andrew High School	Science lab tap 9 room 231	MXH548	0.0060	Exceeds Limit	1.3000	Passed
Prince Andrew High School	Science lab tap 10 room 231	MXH549	0.0021	Passed	0.7300	Passed
Prince Andrew High School	Science lab tap 11 room 231	MXH550	0.0069	Exceeds Limit	0.4500	Passed
Prince Andrew High School	Science lab tap 12 room 231	MXH551	0.0062	Exceeds Limit	0.9600	Passed
Prince Andrew High School	CR kitchen sink tap room 108	MXH552	0.0000	Passed	0.3700	Passed
Prince Andrew High School	CR WR #1 tap room 108	MXH553	0.0006	Passed	0.3500	Passed
Prince Andrew High School	CR WR #2 tap room 108	MXH554	0.0005	Passed	0.4200	Passed
Prince Andrew High School	CR WR #3 tap room 108	MXH555	0.0000	Passed	0.4000	Passed
Prince Andrew High School	1st floor boys staff WR tap	MXH556	0.0011	Passed	0.0700	Passed
Prince Andrew High School	1st floor boys WR tap 1	MXH557	0.0008	Passed	0.0850	Passed
Prince Andrew High School	1st floor boys WR tap 2	MXH558	0.0012	Passed	0.1200	Passed
Prince Andrew High School	1st floor boys WR tap 3	MXH559	0.0010	Passed	0.0550	Passed
Prince Andrew High School	1st floor boys WR tap 4	MXH560	0.0007	Passed	0.0790	Passed
Prince Andrew High School	1st floor girls staff WR tap	MXH561	0.0023	Passed	0.0440	Passed
Prince Andrew High School	1st floor girls WR tap 1	MXH562	0.0017	Passed	0.1100	Passed
Prince Andrew High School	1st floor girls WR tap 2	MXH563	0.0022	Passed	0.0850	Passed
Prince Andrew High School	1st floor girls WR tap 3	MXH564	0.0015	Passed	0.0850	Passed
Prince Andrew High School	1st floor girls WR tap 4	MXH565	0.0011	Passed	0.0770	Passed
Prince Andrew High School	1st floor boiler room tap	MXH567	0.0017	Passed	0.1400	Passed
Prince Andrew High School	1st floor caretaker room tap	NLS558	0.0009	Passed	0.0470	Passed
Prince Andrew High School	CR tap 1 room 127	MXH569	0.0011	Passed	1.2000	Passed
Prince Andrew High School	CR tap 2 room 127	MXH570	0.0000	Passed	0.8800	Passed
Prince Andrew High School	CR tap 3 room 127	MXH571	0.0028	Passed	0.4800	Passed
Prince Andrew High School	1st floor Cafeteria tap 1	MXH572	0.0032	Passed	0.5900	Passed
Prince Andrew High School	1st floor Cafeteria tap 2	MXH573	0.0033	Passed	1.2000	Passed
Prince Andrew High School	1st floor Cafeteria tap 3	NLS559	0.0011	Passed	0.1500	Passed
Prince Andrew High School	CR tap room 125	MXH575	0.0022	Passed	0.7300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Prince Andrew High School	CR tap room 124	MXH576	0.0012	Passed	0.7100	Passed
Prince Andrew High School	Main office WR #1 tap	MXH577	0.0067	Exceeds Limit	0.0670	Passed
Prince Andrew High School	Main office WR #2 tap	MXH578	0.0021	Passed	0.0440	Passed
Prince Andrew High School	Fountain by room 116	NLS561	0.0013	Passed	0.1600	Passed
Prince Andrew High School	1st floor JC tap by room 116	MXH580	0.0050	Passed	0.8100	Passed
Prince Andrew High School	Fountain near room 124	MXH581	0.0260	Exceeds Limit	0.2500	Passed
Prince Andrew High School	GN WR tap 1 near room 124	MXH582	0.0360	Exceeds Limit	0.6000	Passed
Prince Andrew High School	GN WR tap 2 near room 124	MXH583	0.0026	Passed	0.0850	Passed
Prince Andrew High School	1st floor staff WR tap by room 125	MXH584	0.0097	Exceeds Limit	0.1300	Passed
Prince Andrew High School	1st floor staff WR tap by room 125	MXH585	0.0028	Passed	0.0800	Passed
Prince Andrew High School	CR tap 1 room 128	MXH586	0.0021	Passed	0.6200	Passed
Prince Andrew High School	CR tap 2 room 128	MXH587	0.0056	Exceeds Limit	0.3700	Passed
Prince Andrew High School	CR tap 3 room 128	MXH588	0.0090	Exceeds Limit	1.8000	Passed
Prince Andrew High School	CR tap 4 room 128	MXH589	0.0041	Passed	1.0000	Passed
Prince Andrew High School	CR tap 5 room 128	MXH590	0.0022	Passed	1.0000	Passed
Prince Andrew High School	Girls locker room back tap	MXH591	0.0140	Exceeds Limit	0.6100	Passed
Prince Andrew High School	Girls locker room tap 1	MXH592	0.0460	Exceeds Limit	0.4500	Passed
Prince Andrew High School	Girls locker room tap 2	MXH593	0.0036	Passed	0.2400	Passed
Prince Andrew High School	Girls locker room tap 3	MXH594	0.0088	Exceeds Limit	0.0760	Passed
Prince Andrew High School	Gym office 11 WR tap	MXH595	0.0660	Exceeds Limit	1.7000	Passed
Prince Andrew High School	Fountain in gym	MXH596	0.0009	Passed	0.2500	Passed
Prince Andrew High School	Boys locker room tap 1	MXH597	0.0330	Exceeds Limit	0.7200	Passed
Prince Andrew High School	Boys locker room tap 2	MXH598	0.0350	Exceeds Limit	0.4100	Passed
Prince Andrew High School	Boys locker room tap 3	MXH599	0.0017	Passed	0.1500	Passed
Prince Andrew High School	Gym office 1 WR tap	MXH600	0.0015	Passed	0.0370	Passed
Prince Andrew High School	Gym office 12 WR tap	MXH601	0.0019	Passed	0.0480	Passed
Prince Andrew High School	1st floor Fountain by boiler room	NBS158	0.0006	Passed	1.0000	Passed
Prospect Road Elementary School	Staff room tap room 113	MUM404	0.0110	Exceeds Limit	2.8000	Exceeds Limit
Prospect Road Elementary School	Staff room WR tap room 113	MUM405	0.0130	Exceeds Limit	2.8000	Exceeds Limit
Prospect Road Elementary School	Fountain by room 110	MUM406	0.0180	Exceeds Limit	4.7000	Exceeds Limit
Prospect Road Elementary School	Girls WR tap 1	MUM407	0.0075	Exceeds Limit	2.6000	Exceeds Limit
Prospect Road Elementary School	Girls WR tap 2	MUM408	0.0130	Exceeds Limit	1.9000	Passed
Prospect Road Elementary School	Girls WR tap 3	MUM409	0.0210	Exceeds Limit	2.2000	Exceeds Limit
Prospect Road Elementary School	JC tap between WR's	MUM410	0.0017	Passed	3.5000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 1	MUM411	0.0320	Exceeds Limit	5.0000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 2	MUM412	0.0190	Exceeds Limit	5.6000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 3	MUM413	0.0160	Exceeds Limit	4.7000	Exceeds Limit
Prospect Road Elementary School	CR tap room 108	MUM424	0.0160	Exceeds Limit	1.4000	Passed
Prospect Road Elementary School	Staff WR tap across from JC	MUM425	0.0120	Exceeds Limit	17.0000	Exceeds Limit
Prospect Road Elementary School	Mechanical room ta[MUM426	0.0380	Exceeds Limit	6.4000	Exceeds Limit
Prospect Road Elementary School	Girls WR tap 1	MUM427	0.0910	Exceeds Limit	1.6000	Passed
Prospect Road Elementary School	Girls WR tap 2	MUM428	0.0730	Exceeds Limit	7.1000	Exceeds Limit

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Prospect Road Elementary School	Girls WR tap 3	MUM429	0.0680	Exceeds Limit	8.8000	Exceeds Limit
Prospect Road Elementary School	Girls WR tap 4	MUM430	0.0260	Exceeds Limit	14.0000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 1	MUM431	0.0230	Exceeds Limit	12.0000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 2	MUM432	0.0150	Exceeds Limit	13.0000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 3	MUM433	0.0150	Exceeds Limit	4.9000	Exceeds Limit
Prospect Road Elementary School	Boys WR tap 4	MUM434	0.0340	Exceeds Limit	4.1000	Exceeds Limit
Prospect Road Elementary School	Teachers lounge tap room 123A	MUM435	0.3700	Exceeds Limit	1.8000	Passed
Ridgecliff Middle School	CR tap room 1095	NAM767	0.0000	Passed	0.2600	Passed
Ridgecliff Middle School	CR tap 1 room 1092	NAM768	0.0034	Passed	0.6400	Passed
Ridgecliff Middle School	CR tap 2 room 1092	NAM769	0.0014	Passed	0.3400	Passed
Ridgecliff Middle School	Science lab tap 1 room 1086	NAM770	0.0016	Passed	1.1000	Passed
Ridgecliff Middle School	Science lab tap 2 room 1086	NAM771	0.0032	Passed	0.3100	Passed
Ridgecliff Middle School	Science lab tap 3 room 1086	NAM772	0.0009	Passed	1.0000	Passed
Ridgecliff Middle School	Science lab tap 4 room 1086	NAM773	0.0039	Passed	0.8900	Passed
Ridgecliff Middle School	Science lab tap 5 room 1086	NAM774	0.0018	Passed	0.5500	Passed
Ridgecliff Middle School	Science lab tap 1 room 1085	NAM775	0.0032	Passed	0.7100	Passed
Ridgecliff Middle School	Science lab tap 2 room 1085	NAM776	0.0041	Passed	0.5800	Passed
Ridgecliff Middle School	Science lab tap 3 room 1085	NAM777	0.0047	Passed	0.6800	Passed
Ridgecliff Middle School	Science lab tap 4 room 1085	NAM778	0.0029	Passed	0.3300	Passed
Ridgecliff Middle School	Science lab tap 5 room 1085	NAM779	0.0033	Passed	0.2200	Passed
Ridgecliff Middle School	Science lab tap 46room 1085	NAM780	0.0031	Passed	0.1700	Passed
Ridgecliff Middle School	Learning centre WR tap room 1081	NAM781	0.0006	Passed	0.3000	Passed
Ridgecliff Middle School	Learning centre tap room 1079	NAM782	0.0000	Passed	0.4900	Passed
Ridgecliff Middle School	CR tap room 1076	NAM783	0.0007	Passed	0.3200	Passed
Ridgecliff Middle School	CR tap 1 room 1072	NAM784	0.0010	Passed	0.3800	Passed
Ridgecliff Middle School	CR tap 2 room 1072	NAM785	0.0013	Passed	0.3000	Passed
Ridgecliff Middle School	JC tap room 1100	NAM786	0.0021	Passed	0.2000	Passed
Ridgecliff Middle School	Fountain right of room 1100	NAM787	0.0000	Passed	0.1400	Passed
Ridgecliff Middle School	GN WR tap room 1101	NAM788	0.0006	Passed	0.1900	Passed
Ridgecliff Middle School	Music room tap room 1064	NAM789	0.0019	Passed	1.5000	Passed
Ridgecliff Middle School	Art room tap room 1061	NAM790	0.0000	Passed	0.7000	Passed
Ridgecliff Middle School	Fountain by room 1109	NAM791	0.0000	Passed	0.2700	Passed
Ridgecliff Middle School	Girls WR tap 1 by room 1072	NAM792	0.0005	Passed	0.4400	Passed
Ridgecliff Middle School	Girls WR tap 2 by room 1072	NAM793	0.0020	Passed	0.3500	Passed
Ridgecliff Middle School	Girls WR tap 3 by room 1072	NAM794	0.0060	Exceeds Limit	0.3100	Passed
Ridgecliff Middle School	Girls WR tap 4 by room 1072	NAM795	0.0043	Passed	0.3500	Passed
Ridgecliff Middle School	Male WR tap 1 by room 1103	NAM796	0.0023	Passed	0.1900	Passed
Ridgecliff Middle School	Male WR tap2 by room 1103	NAM797	0.0020	Passed	0.2200	Passed
Ridgecliff Middle School	Male WR tap 3 by room 1103	NAM798	0.0008	Passed	0.2200	Passed
Ridgecliff Middle School	Male WR tap 4 by room 1103	NAM799	0.0000	Passed	0.2100	Passed
Ridgecliff Middle School	Sick room tap room 1026	NAM800	0.0027	Passed	0.2700	Passed
Ridgecliff Middle School	Office WR tap room 1025	NAM801	0.0014	Passed	0.2200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Ridgecliff Middle School	Family studies tap 1 room 1029	NAM802	0.0014	Passed	0.4300	Passed
Ridgecliff Middle School	Family studies tap 2 room 1029	NAM803	0.0014	Passed	0.3100	Passed
Ridgecliff Middle School	Family studies tap 3 room 1029	NAM804	0.0011	Passed	0.2300	Passed
Ridgecliff Middle School	Family studies tap 4 room 1029	NAM805	0.0014	Passed	0.4000	Passed
Ridgecliff Middle School	JC tap room 1035	NAM806	0.0031	Passed	0.2000	Passed
Ridgecliff Middle School	Mech room tap room 1039	NAM807	0.0014	Passed	0.3200	Passed
Ridgecliff Middle School	Kitchen tap 1 room 1056	NAM808	0.0110	Exceeds Limit	0.3800	Passed
Ridgecliff Middle School	Kitchen tap 2 room 1056	NAM809	0.0005	Passed	0.3200	Passed
Ridgecliff Middle School	Kitchen tap 3 room 1056	NAM810	0.0008	Passed	0.6400	Passed
Ridgecliff Middle School	Female WR tap 1 room 1043	NAM811	0.0019	Passed	0.5100	Passed
Ridgecliff Middle School	Female WR tap 2 room 1043	NAM812	0.0006	Passed	0.2500	Passed
Ridgecliff Middle School	Gym office WR tap room 1046	NAM813	0.0000	Passed	0.4400	Passed
Ridgecliff Middle School	Gym office WR tap room 1048	NAM814	0.0000	Passed	0.5000	Passed
Ridgecliff Middle School	Boys WR tap 1 room 1050	NAM815	0.0012	Passed	0.5200	Passed
Ridgecliff Middle School	Boys WR tap 2 room 1050	NAM816	0.0140	Exceeds Limit	0.8200	Passed
Ridgecliff Middle School	Recycle room tap room 1038	NAM817	0.0058	Exceeds Limit	0.2600	Passed
Ridgecliff Middle School	GN WR tap room 1037	NAM818	0.0009	Passed	0.1500	Passed
Ridgecliff Middle School	CR tap room 2065	NAM819	0.0000	Passed	0.5600	Passed
Ridgecliff Middle School	CR tap 1 room 2061	NAM820	0.0058	Exceeds Limit	0.8400	Passed
Ridgecliff Middle School	CR tap 2 room 2061	NAM821	0.0023	Passed	0.3600	Passed
Ridgecliff Middle School	CR tap room 2058	NAM822	0.0014	Passed	0.7700	Passed
Ridgecliff Middle School	CR tap 1 room 2053	NAM823	0.0007	Passed	0.8700	Passed
Ridgecliff Middle School	CR tap 2 room 2053	NAM824	0.0006	Passed	0.3100	Passed
Ridgecliff Middle School	CR tap room 2050	NAM825	0.0012	Passed	0.4500	Passed
Ridgecliff Middle School	CR tap 1 room 2046	NAM826	0.0000	Passed	0.8400	Passed
Ridgecliff Middle School	CR tap 2 room 2046	NAM827	0.0010	Passed	0.4800	Passed
Ridgecliff Middle School	GN WR tap room 2072	NAM828	0.0018	Passed	0.2900	Passed
Ridgecliff Middle School	Fountain by room 2072	NAM829	0.0000	Passed	0.8200	Passed
Ridgecliff Middle School	JC tap by room 2072	NAM830	0.0048	Passed	0.3900	Passed
Ridgecliff Middle School	Girls WR tap 1 by room 2046	NAM831	0.0000	Passed	0.2800	Passed
Ridgecliff Middle School	Girls WR tap 2 by room 2046	NAM832	0.0008	Passed	0.3300	Passed
Ridgecliff Middle School	Girls WR tap 3 by room 2046	NAM833	0.0013	Passed	0.3500	Passed
Ridgecliff Middle School	Girls WR tap 4 by room 2046	NAM834	0.0010	Passed	0.1800	Passed
Ridgecliff Middle School	Library tap room 2021	NAM835	0.0010	Passed	0.2200	Passed
Ridgecliff Middle School	Fountain by room 2036	NAM836	0.0000	Passed	2.1000	Exceeds Limit
Ridgecliff Middle School	JC tap room 2036	NAM837	0.0022	Passed	0.1600	Passed
Ridgecliff Middle School	Staff room WR 1 room 2025	NAM838	0.0000	Passed	0.2000	Passed
Ridgecliff Middle School	Staff room WR 2 room 2025	NAM839	0.0006	Passed	0.1800	Passed
Ridgecliff Middle School	Staff room kitchen tap room 2025	NAM840	0.0000	Passed	0.3000	Passed
Ridgecliff Middle School	Tech ed tap room 2034	NAM842	0.0008	Passed	0.2600	Passed
Robert K. Turner Elementary School	Kitchen tap across from room 201	MUV980	0.0200	Exceeds Limit	0.6700	Passed
Robert K. Turner Elementary School	Boys WR tap 1 across from room 204	MUV981	0.0081	Exceeds Limit	0.0099	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Robert K. Turner Elementary School	Boys WR tap 2 across from room 204	MUV982	0.0053	Exceeds Limit	0.0210	Passed
Robert K. Turner Elementary School	Boys WR tap 3 across from room 204	NMD779	0.0007	Passed	0.0120	Passed
Robert K. Turner Elementary School	Boys WR tap 4 across from room 204	NMD780	0.0018	Passed	0.0070	Passed
Robert K. Turner Elementary School	Girls WR tap 1 across from room 205	MUV985	0.0038	Passed	0.0099	Passed
Robert K. Turner Elementary School	Girls WR tap 2 across from room 205	MUV986	0.0043	Passed	0.0120	Passed
Robert K. Turner Elementary School	Girls WR tap 3 across from room 205	MUV987	0.0110	Exceeds Limit	0.0320	Passed
Robert K. Turner Elementary School	Girls WR tap 4 across from room 205	MUV988	0.0630	Exceeds Limit	0.1200	Passed
Robert K. Turner Elementary School	Fountain across from room 207	MUV989	0.0670	Exceeds Limit	0.2000	Passed
Robert K. Turner Elementary School	JC tap beside fountain	MUV993	0.0000	Passed	0.0087	Passed
Robert K. Turner Elementary School	Fountain across from staff room	NMD781	0.0004	Passed	0.0140	Passed
Robert K. Turner Elementary School	Boys WR tap 1 across from library	MUV995	0.0220	Exceeds Limit	0.0700	Passed
Robert K. Turner Elementary School	Boys WR tap 2 across from library	MUV996	0.0075	Exceeds Limit	0.0680	Passed
Robert K. Turner Elementary School	Boys WR tap 3 across from library	MUV997	0.0063	Exceeds Limit	0.0200	Passed
Robert K. Turner Elementary School	Girls WR tap 1 across from library	MUV998	0.3400	Exceeds Limit	0.1300	Passed
Robert K. Turner Elementary School	Girls WR tap 2 across from library	MUV999	0.0044	Passed	0.0180	Passed
Robert K. Turner Elementary School	Girls WR tap 3 across from library	MUW000	0.0076	Exceeds Limit	0.0610	Passed
Robert K. Turner Elementary School	Fountain across from room 102	MUW001	0.0047	Passed	0.0830	Passed
Robert K. Turner Elementary School	JC tap beside fountain	MUW002	0.0033	Passed	0.1100	Passed
Robert K. Turner Elementary School	GN WR tap room 105	MUW010	0.0020	Passed	0.2000	Passed
Robert K. Turner Elementary School	GN WR tap room 104	MUW011	0.0085	Exceeds Limit	0.1200	Passed
Robert K. Turner Elementary School	Staff room kitchen tap	MUW012	0.0007	Passed	0.0280	Passed
Robert K. Turner Elementary School	GN staff WR 1	MUW013	0.0089	Exceeds Limit	0.0420	Passed
Robert K. Turner Elementary School	GN staff WR 2	MUW014	0.0042	Passed	0.0110	Passed
Rockingham Elementary School	Boys WR tap 1 room 57	MUD705	0.0290	Exceeds Limit	0.1100	Passed
Rockingham Elementary School	Boys WR tap 2 room 57	MUD706	0.0340	Exceeds Limit	0.1400	Passed
Rockingham Elementary School	JC tap room 58	MUD707	1.1000	Exceeds Limit	0.1300	Passed
Rockingham Elementary School	Girls WR tap 1 room 56	MUD708	0.0110	Exceeds Limit	0.1700	Passed
Rockingham Elementary School	Girls WR tap 2 room 56	MUD709	0.6900	Exceeds Limit	0.6200	Passed
Rockingham Elementary School	CR tap room 55	MUD710	0.0017	Passed	0.6800	Passed
Rockingham Elementary School	Fountain beside room 53	NIU578	0.0022	Passed	0.0270	Passed
Rockingham Elementary School	Lavatory sink tap room 53	MUD712	0.0890	Exceeds Limit	0.3700	Passed
Rockingham Elementary School	Girls WR tap 1 room 48	MUD713	0.0670	Exceeds Limit	0.1900	Passed
Rockingham Elementary School	Girls WR tap 2 room 48	MUD714	0.0041	Passed	0.1700	Passed
Rockingham Elementary School	Boys WR tap 1 room 47	MUD719	0.0190	Exceeds Limit	0.1200	Passed
Rockingham Elementary School	Boys WR tap 2 room 47	MUD720	0.0110	Exceeds Limit	0.6400	Passed
Rockingham Elementary School	CR tap room 26	MUD721	0.0049	Passed	0.1800	Passed
Rockingham Elementary School	Fountain beside room 29	NIU579	0.0028	Passed	0.0380	Passed
Rockingham Elementary School	Girls WR tap 1 room 29	MUD723	0.0071	Exceeds Limit	0.1600	Passed
Rockingham Elementary School	Girls WR tap 2 room 29	MUD724	0.0046	Passed	0.0630	Passed
Rockingham Elementary School	Boys WR tap 1 room 30	MUD725	0.0061	Exceeds Limit	0.0920	Passed
Rockingham Elementary School	Boys WR tap 2 room 30	MUD726	0.0069	Exceeds Limit	0.0330	Passed
Rockingham Elementary School	Staff WR inside room 33	MUD727	0.0006	Passed	0.0270	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Rockingham Elementary School	Staff WR inside room 33	MUD728	0.0024	Passed	0.2400	Passed
Rockingham Elementary School	Staff room kitchen tap room 33	MUD733	0.0026	Passed	0.5900	Passed
Rockingham Elementary School	JC tap by room 33	MUD734	0.0310	Exceeds Limit	0.1200	Passed
Rockingham Elementary School	CR tap room 36	MUD735	0.0120	Exceeds Limit	0.1200	Passed
Rockingham Elementary School	Fountain beside room 39	NIU580	0.0013	Passed	0.0290	Passed
Rockingham Elementary School	Girls WR tap 1 room 39	MUD737	0.0250	Exceeds Limit	0.1900	Passed
Rockingham Elementary School	Girls WR tap 2 room 39	MUD738	0.0067	Exceeds Limit	0.0380	Passed
Rockingham Elementary School	Boys WR tap 1 room 40	MUD739	0.0011	Passed	0.4800	Passed
Rockingham Elementary School	Boys WR tap 2 room 40	MUD740	0.0007	Passed	0.0900	Passed
Rockingham Elementary School	JC tap room 43	MUD741	0.0000	Passed	0.0930	Passed
Rockingham Elementary School	Fountain between room 22 and 23	MUD742	0.0000	Passed	0.9900	Passed
Rockingham Elementary School	Cafeteria/kitchen handwashing tap	MUD743	0.0029	Passed	0.3100	Passed
Rockingham Elementary School	Cafeteria/kitchen double compartment sink tap	MUD744	0.0170	Exceeds Limit	0.6700	Passed
Rockingham Elementary School	Fountain by room 50	MUD745	0.0140	Exceeds Limit	0.4800	Passed
Rockingham Elementary School	Basin tap room 6	MUD746	0.0051	Exceeds Limit	0.1400	Passed
Rockingham Elementary School	Basin tap room 10	MUD747	0.0200	Exceeds Limit	0.2100	Passed
Rockingham Elementary School	Girls WR tap 1 room 11	MUD748	0.0910	Exceeds Limit	1.3000	Passed
Rockingham Elementary School	Girls WR tap 2 room 11	MUD749	0.0040	Passed	0.2200	Passed
Rockingham Elementary School	Girls WR tap 3 room 11	MUD750	0.0000	Passed	0.0140	Passed
Rockingham Elementary School	Girls WR tap 4 room 11	MUD751	0.0018	Passed	0.2900	Passed
Rockingham Elementary School	Fountain by room 11	MUD752	0.0012	Passed	0.1100	Passed
Rockingham Elementary School	JC tap by room 12	MUD767	0.0007	Passed	0.0500	Passed
Rockingham Elementary School	Boys WR tap 1 room 12	MUD768	0.0015	Passed	0.0670	Passed
Rockingham Elementary School	Boys WR tap 2 room 12	MUD769	0.0022	Passed	0.0270	Passed
Rockingham Elementary School	Boys WR tap 3 room 12	MUD770	0.0028	Passed	0.0380	Passed
Rockingham Elementary School	Boys WR tap 4 room 12	MUD771	0.0013	Passed	0.0290	Passed
Rockingstone Heights School	Kitchen sink tap 1 room 300	MUQ707	0.0000	Passed	0.1800	Passed
Rockingstone Heights School	Kitchen sink tap 2 room 300	MUQ708	0.0000	Passed	0.4100	Passed
Rockingstone Heights School	Kitchen sink tap 3 room 300	MUQ709	0.0000	Passed	0.0980	Passed
Rockingstone Heights School	Kitchen sink tap 4 room 300	MUQ710	0.0000	Passed	0.0700	Passed
Rockingstone Heights School	Boys WR tap 1 across from room 302	MUQ711	0.0013	Passed	0.1500	Passed
Rockingstone Heights School	Boys WR tap 2 across from room 302	MUQ712	0.0540	Exceeds Limit	0.0970	Passed
Rockingstone Heights School	Boys WR tap 3 across from room 302	MUQ713	0.0100	Exceeds Limit	0.1100	Passed
Rockingstone Heights School	JC tap beside boys WR	MUQ714	0.0010	Passed	0.0510	Passed
Rockingstone Heights School	Fountain Across from room 303	MUQ715	0.0008	Passed	0.0730	Passed
Rockingstone Heights School	Staff WR beside girls WR	MUQ716	0.0012	Passed	0.0500	Passed
Rockingstone Heights School	Girls WR tap 1 beside room 309	MUQ717	0.0068	Exceeds Limit	0.0340	Passed
Rockingstone Heights School	Girls WR tap 2 beside room 309	MUQ718	0.0021	Passed	0.0240	Passed
Rockingstone Heights School	Girls WR tap 3 beside room 309	MUQ719	0.0027	Passed	0.0340	Passed
Rockingstone Heights School	Boys WR tap 1 across from room 202	MUQ721	0.0017	Passed	0.0720	Passed
Rockingstone Heights School	Boys WR tap 2 across from room 202	MUQ722	0.0030	Passed	0.0680	Passed
Rockingstone Heights School	Boys WR tap 3 across from room 202	MUQ723	0.0026	Passed	0.0430	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Rockingstone Heights School	JC tap beside boys WR	MUQ724	0.0140	Exceeds Limit	0.1000	Passed
Rockingstone Heights School	Fountain beside girls WR	MUQ725	0.0066	Exceeds Limit	0.4300	Passed
Rockingstone Heights School	Gym cafeteria kitchen tap	MUQ726	0.0007	Passed	0.0260	Passed
Rockingstone Heights School	Girls WR tap 2 across from room 203	MUQ727	0.0022	Passed	0.0120	Passed
Rockingstone Heights School	Girls WR tap 3 across from room 203	MUQ728	0.0100	Exceeds Limit	0.0410	Passed
Rockingstone Heights School	GN WR tap by girls WR	MUQ729	0.0000	Passed	0.0045	Passed
Rockingstone Heights School	Staff male WR tap in staff room	MUQ730	0.0120	Exceeds Limit	0.0480	Passed
Rockingstone Heights School	Staff female WR tap in staff room	MUQ731	0.0110	Exceeds Limit	0.0340	Passed
Rockingstone Heights School	Staff room kitchen tap	MUQ732	0.0015	Passed	0.0770	Passed
Rockingstone Heights School	Boys WR tap 1 beside caretaker room	MUQ733	0.0018	Passed	0.0630	Passed
Rockingstone Heights School	Boys WR tap 2 beside caretaker room	MUQ734	0.0041	Passed	0.0650	Passed
Rockingstone Heights School	Boys WR tap 3 beside caretaker room	MUQ735	0.0110	Exceeds Limit	0.0830	Passed
Rockingstone Heights School	JC tap caretaker room	MUQ736	0.0000	Passed	0.0210	Passed
Rockingstone Heights School	Fountain across from room 103	MUQ737	0.0015	Passed	0.2600	Passed
Rockingstone Heights School	Staff GN WR tap by Girls WR	MUQ738	0.0006	Passed	0.0150	Passed
Rockingstone Heights School	Girls WR tap 1 by staff WR	MUQ739	0.0009	Passed	0.1400	Passed
Rockingstone Heights School	Girls WR tap 2 by staff WR	MUQ740	0.0090	Exceeds Limit	0.0710	Passed
Rockingstone Heights School	Girls WR tap 3 by staff WR	MUQ741	0.0760	Exceeds Limit	0.0660	Passed
Rockingstone Heights School	Gym office WR tap (across Girls WR)	MUQ742	0.1400	Exceeds Limit	0.4700	Passed
Rockingstone Heights School	Gym office WR tap (across Boys WR)	MUQ743	0.0081	Exceeds Limit	0.0700	Passed
Rockingstone Heights School	Gym cafeteria handwashing tap	MUQ745	0.0005	Passed	0.8600	Passed
Rockingstone Heights School	Staff WR inside main office	MUQ746	0.0750	Exceeds Limit	0.0790	Passed
Rockingstone Heights School	Art room tap 1 room 100	MUQ747	0.1200	Exceeds Limit	0.3100	Passed
Rockingstone Heights School	Art room tap 2 room 100	MUQ748	0.2800	Exceeds Limit	0.0900	Passed
Rockingstone Heights School	Youth health centre tap	MUQ749	0.0009	Passed	0.0120	Passed
Rockingstone Heights School	CR tap room 102	MUQ750	0.0000	Passed	0.3300	Passed
Rockingstone Heights School	CR tap room 103	MUQ751	0.0000	Passed	0.3100	Passed
Rockingstone Heights School	CR tap room 105	MUQ752	0.0011	Passed	0.2900	Passed
Rockingstone Heights School	GN WR tap 1 by room 203	NAK426	0.0021	Passed	0.0400	Passed
Rocky Lake Elementary	Boys WR tap 1 room 303	MSA057	0.0180	Exceeds Limit	0.3100	Passed
Rocky Lake Elementary	Boys WR tap 2 room 303	MSA058	0.0089	Exceeds Limit	0.2300	Passed
Rocky Lake Elementary	Boys WR tap 3 room 303	MSA059	0.0100	Exceeds Limit	0.1100	Passed
Rocky Lake Elementary	Boys WR tap 4 room 303	MSA060	0.0016	Passed	0.0330	Passed
Rocky Lake Elementary	Boys WR tap 5 room 303	MSA061	0.0013	Passed	0.0280	Passed
Rocky Lake Elementary	Staff WR tap by room 303	MSA062	0.0014	Passed	0.0330	Passed
Rocky Lake Elementary	JC tap by room 303	MSA063	0.0000	Passed	0.0270	Passed
Rocky Lake Elementary	fountain by room 303	MSA064	0.0007	Passed	0.0740	Passed
Rocky Lake Elementary	Girls WR tap 1 room 305	MSA065	0.0056	Exceeds Limit	0.2100	Passed
Rocky Lake Elementary	Girls WR tap 2 room 305	MSA066	0.0019	Passed	0.1500	Passed
Rocky Lake Elementary	Girls WR tap 3 room 305	MSA067	0.0008	Passed	0.0830	Passed
Rocky Lake Elementary	Girls WR tap 4 room 305	MSA068	0.0006	Passed	0.0370	Passed
Rocky Lake Elementary	Girls WR tap 5 room 305	MSA069	0.0008	Passed	0.0340	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Rocky Lake Elementary	Lounge kitchen sink tap	MSA070	0.0091	Exceeds Limit	0.3000	Passed
Rocky Lake Elementary	Kitchen - Kitchen sink tap 1	MSA071	0.0110	Exceeds Limit	0.1500	Passed
Rocky Lake Elementary	Kitchen - Kitchen sink tap 2	MSA072	0.0009	Passed	0.0320	Passed
Rocky Lake Elementary	Kitchen - Kitchen sink tap 3	MSA073	0.0006	Passed	0.0250	Passed
Rocky Lake Elementary	Kitchen - Kitchen sink tap 4	MSA074	0.0029	Passed	0.1100	Passed
Rocky Lake Elementary	Boys WR tap 1 room 203	MSA075	0.0071	Exceeds Limit	0.1900	Passed
Rocky Lake Elementary	Boys WR tap 2 room 203	MSA076	0.0009	Passed	0.0380	Passed
Rocky Lake Elementary	Boys WR tap 3 room 203	MSA077	0.0000	Passed	0.0220	Passed
Rocky Lake Elementary	Boys WR tap 4 room 203	MSA078	0.0017	Passed	0.0210	Passed
Rocky Lake Elementary	Staff WR tap by room 203	MSA079	0.0018	Passed	0.0340	Passed
Rocky Lake Elementary	JC tap by room 203	MSA080	0.0000	Passed	0.0200	Passed
Rocky Lake Elementary	Fountain by room 203	MSA081	0.0043	Passed	0.0660	Passed
Rocky Lake Elementary	Girls WR tap 1 by room 205	MSA082	0.0290	Exceeds Limit	0.1900	Passed
Rocky Lake Elementary	Girls WR tap 2 by room 205	MSA083	0.0049	Passed	0.0350	Passed
Rocky Lake Elementary	Girls WR tap 3 by room 205	MSA084	0.0000	Passed	0.0250	Passed
Rocky Lake Elementary	Girls WR tap 4 by room 205	MSA085	0.0000	Passed	0.0230	Passed
Rocky Lake Elementary	Girls WR tap 5 by room 205	MSA086	0.0007	Passed	0.0240	Passed
Rocky Lake Elementary	CR tap room 205	MSA087	0.0011	Passed	0.0240	Passed
Rocky Lake Elementary	GN WR tap by elevator	MSA088	0.0000	Passed	0.0180	Passed
Rocky Lake Elementary	Kitchen bar sink tap	MSA089	0.0064	Exceeds Limit	0.3200	Passed
Rocky Lake Elementary	Kitchen triple compartment sink tap 1	MSA090	0.0014	Passed	0.2000	Passed
Rocky Lake Elementary	Kitchen triple compartment sink tap 2	MSA091	0.0029	Passed	0.2700	Passed
Rocky Lake Elementary	Kitchen triple compartment sink tap 3	MSA092	0.0013	Passed	0.1500	Passed
Rocky Lake Elementary	Cafeteria laundry tap	MSA093	0.0008	Passed	0.0900	Passed
Rocky Lake Elementary	Girls WR tap 1 room 5	MSA094	0.0023	Passed	0.1100	Passed
Rocky Lake Elementary	Girls WR tap 2 room 5	MSA095	0.0024	Passed	0.1100	Passed
Rocky Lake Elementary	WR off girls WR tap room 5	MSA096	0.7300	Exceeds Limit	1.4000	Passed
Rocky Lake Elementary	WR tap in office by exit	MSA097	0.0037	Passed	0.0400	Passed
Rocky Lake Elementary	Fountain in main lobby	MSA098	0.0028	Passed	0.0830	Passed
Rocky Lake Elementary	Lab tap 1 room 100	MSA099	0.0200	Exceeds Limit	0.3400	Passed
Rocky Lake Elementary	Lab tap 2 room 100	MSA100	0.0220	Exceeds Limit	0.2100	Passed
Rocky Lake Elementary	Lab tap 1 room 102	MSA101	0.0063	Exceeds Limit	0.1900	Passed
Rocky Lake Elementary	Lab tap 2 room 102	MSA102	0.0026	Passed	0.0570	Passed
Rocky Lake Elementary	Caretaker room tap room 105	MSA103	0.0000	Passed	0.0520	Passed
Rocky Lake Elementary	Staff WR tap room 103	MSA104	0.0000	Passed	0.0200	Passed
Rocky Lake Elementary	Staff room kitchen tap room 103	MSA105	0.0000	Passed	0.0200	Passed
Rocky Lake Elementary	Boys WR tap 1 in basement	MSA106	0.0047	Passed	0.1700	Passed
Rocky Lake Elementary	Boys WR tap 2 in basement	MSA107	0.0012	Passed	0.0300	Passed
Rocky Lake Elementary	Boiler room tap	MSQ477	0.0004	Passed	0.0240	Passed
Rocky Lake Elementary	Fountain in Makerspace	MSQ478	0.0069	Exceeds Limit	0.1900	Passed
Rocky Lake Elementary	Laundry Tub in Makerspace tap	MSQ479	0.0008	Passed	0.0250	Passed
Rocky Lake Junior High School	Learning centre tap room 301	MSG714	0.0036	Passed	0.0250	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Rocky Lake Junior High School	GN WR tap room 329	MSG715	0.0007	Passed	0.0330	Passed
Rocky Lake Junior High School	Sick room tap by room 329	MSG716	0.0047	Passed	0.2100	Passed
Rocky Lake Junior High School	Boys WR tap 1 by room 301	MSG717	0.0018	Passed	0.0460	Passed
Rocky Lake Junior High School	Boys WR tap 2 by room 301	MSG718	0.0006	Passed	0.0120	Passed
Rocky Lake Junior High School	Boys WR tap 3 by room 301	MSG719	0.0013	Passed	0.0100	Passed
Rocky Lake Junior High School	JC tap by boys WR	MSG720	0.0013	Passed	0.0130	Passed
Rocky Lake Junior High School	Fountain between WR's	MSG721	0.0015	Passed	0.3800	Passed
Rocky Lake Junior High School	Girls WR tap 1 by fountain	MSG722	0.0017	Passed	0.0670	Passed
Rocky Lake Junior High School	Girls WR tap 2 by fountain	MSG723	0.0008	Passed	0.0140	Passed
Rocky Lake Junior High School	Girls WR tap 3 by fountain	MSG724	0.0014	Passed	0.0300	Passed
Rocky Lake Junior High School	Girls WR tap 4 by fountain	MSG725	0.0035	Passed	0.0270	Passed
Rocky Lake Junior High School	Staff room kitchen tap	MSG726	0.0017	Passed	0.0760	Passed
Rocky Lake Junior High School	Staff room mens WR tap	MSG727	0.0000	Passed	0.0075	Passed
Rocky Lake Junior High School	Staff room female WR tap 1	MSG728	0.0940	Exceeds Limit	0.4100	Passed
Rocky Lake Junior High School	Staff room female WR tap 2	MSG729	0.0032	Passed	0.0180	Passed
Rocky Lake Junior High School	Learning centre WR tap room 219B	MSG730	0.0000	Passed	0.0079	Passed
Rocky Lake Junior High School	Biology room tap 1 room 205	MSG731	0.0000	Passed	0.2000	Passed
Rocky Lake Junior High School	Biology room tap 2 room 205	MSG732	0.0000	Passed	0.1900	Passed
Rocky Lake Junior High School	Biology room tap 3 room 205	MSG733	0.0000	Passed	0.1800	Passed
Rocky Lake Junior High School	Biology room tap 4 room 205	MSG734	0.0008	Passed	0.1500	Passed
Rocky Lake Junior High School	Biology room tap 5 room 205	MSG735	0.0009	Passed	0.1100	Passed
Rocky Lake Junior High School	Biology room tap 6 room 205	MSG736	0.0000	Passed	0.9100	Passed
Rocky Lake Junior High School	CR tap room 205	MSG737	0.0000	Passed	1.1000	Passed
Rocky Lake Junior High School	Chemistry lab tap 1 room 203	MSG738	0.0580	Exceeds Limit	0.1500	Passed
Rocky Lake Junior High School	Chemistry lab tap 2 room 203	MSG739	0.0082	Exceeds Limit	0.1800	Passed
Rocky Lake Junior High School	Chemistry lab tap 3 room 203	MSG740	0.0630	Exceeds Limit	0.3300	Passed
Rocky Lake Junior High School	Chemistry lab tap 4 room 203	MSG741	0.0230	Exceeds Limit	0.4500	Passed
Rocky Lake Junior High School	Chemistry lab tap 1 room 203 (prep room)	MSG742	0.1100	Exceeds Limit	0.8600	Passed
Rocky Lake Junior High School	JC tap by room 203	MSG743	0.0006	Passed	0.0700	Passed
Rocky Lake Junior High School	Chemistry lab tap 1 room 202	MSG744	0.0110	Exceeds Limit	0.0710	Passed
Rocky Lake Junior High School	Chemistry lab tap 2 room 202	MSG745	0.0072	Exceeds Limit	0.0970	Passed
Rocky Lake Junior High School	Chemistry lab tap 1 room 201	MSG746	0.1200	Exceeds Limit	0.8700	Passed
Rocky Lake Junior High School	Chemistry lab tap 2 room 201	MSG747	0.0038	Passed	0.0550	Passed
Rocky Lake Junior High School	Chemistry lab tap 3 room 201	MSG748	0.0043	Passed	0.1300	Passed
Rocky Lake Junior High School	Chemistry lab tap 4 room 201	MSG749	0.0043	Passed	0.0530	Passed
Rocky Lake Junior High School	Boys WR tap 1 connected to gym	MSG750	0.0015	Passed	0.0960	Passed
Rocky Lake Junior High School	Boys WR tap 2 connected to gym	MSG751	0.0010	Passed	0.0510	Passed
Rocky Lake Junior High School	Boys WR tap 3 connected to gym	MSG752	0.0025	Passed	0.1900	Passed
Rocky Lake Junior High School	Fountain between WR's	MSG753	0.0024	Passed	0.5000	Passed
Rocky Lake Junior High School	Girls WR tap 1 connected to gym	MSG754	0.0082	Exceeds Limit	0.1600	Passed
Rocky Lake Junior High School	Girls WR tap 2 connected to gym	MSG755	0.0130	Exceeds Limit	0.0240	Passed
Rocky Lake Junior High School	Girls WR tap 3 connected to gym	MSG756	0.0024	Passed	0.0096	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Rocky Lake Junior High School	Girls WR tap 4 connected to gym	MSG757	0.0010	Passed	0.0069	Passed
Rocky Lake Junior High School	D. Arsenault room tap in gym	MSG758	0.0280	Exceeds Limit	1.2000	Passed
Rocky Lake Junior High School	J. Neuvaon room tap in gym	MSG759	0.0110	Exceeds Limit	0.5400	Passed
Rocky Lake Junior High School	Main office staff WR tap	MSG760	0.0011	Passed	0.0300	Passed
Rocky Lake Junior High School	Vice Principal room tap	MSG761	0.0028	Passed	0.0560	Passed
Rocky Lake Junior High School	Staff photocopy room tap	MSG762	0.0520	Exceeds Limit	0.3600	Passed
Rocky Lake Junior High School	Cafeteria hand washing sink tap	NMO585	0.0006	Passed	0.0090	Passed
Rocky Lake Junior High School	Cafeteria bar sink tap	MSG764	0.0000	Passed	0.0220	Passed
Rocky Lake Junior High School	Cafeteria triple sink tap 1	MSG765	0.0000	Passed	0.0370	Passed
Rocky Lake Junior High School	Cafeteria triple sink tap 2	MSG766	0.0000	Passed	0.0180	Passed
Rocky Lake Junior High School	Cafeteria JC tap	MSG767	0.0120	Exceeds Limit	0.4200	Passed
Rocky Lake Junior High School	Fountain beside cafeteria	NMO584	0.0011	Passed	0.4600	Passed
Rocky Lake Junior High School	Girls WR tap 1 beside cafeteria	MSG769	0.0069	Exceeds Limit	0.2900	Passed
Rocky Lake Junior High School	Girls WR tap 2 beside cafeteria	MSG770	0.0008	Passed	0.0160	Passed
Rocky Lake Junior High School	Girls WR tap 3 beside cafeteria	MSG771	0.0010	Passed	0.0110	Passed
Rocky Lake Junior High School	Girls WR tap 4 beside cafeteria	MSG772	0.0012	Passed	0.0110	Passed
Rocky Lake Junior High School	GN WR tap by girls WR	MSG773	0.0010	Passed	0.3100	Passed
Rocky Lake Junior High School	JC tap beside boys WR	MTA205	0.0005	Passed	0.0340	Passed
Rocky Lake Junior High School	Boys WR tap 1 by room 103	MTA206	0.0000	Passed	0.0200	Passed
Rocky Lake Junior High School	Boys WR tap 2 by room 103	MTA207	0.0100	Exceeds Limit	0.0440	Passed
Rocky Lake Junior High School	Boys WR tap 3 by room 103	MTA208	0.0008	Passed	0.0170	Passed
Rocky Lake Junior High School	CR tap room 103	MTA209	0.0000	Passed	0.0110	Passed
Rocky Lake Junior High School	Boiler room tap	MTA210	0.0000	Passed	0.0200	Passed
Rocky Lake Junior High School	JC tap room 106	MTA211	0.0140	Exceeds Limit	0.6600	Passed
Rocky Lake Junior High School	Triple compartment sink tap 1 room 105	MTA212	0.0056	Exceeds Limit	0.2800	Passed
Rocky Lake Junior High School	Triple compartment sink tap 2 room 105	MTA213	0.0012	Passed	0.2200	Passed
Rocky Lake Junior High School	CR tap room 104	MTA214	0.0000	Passed	0.9000	Passed
Ross Road School	Staff room WR tap room 111	MXZ638	0.0000	Passed	0.0260	Passed
Ross Road School	Girls WR tap 1 by room 111	MXZ639	0.0034	Passed	0.1200	Passed
Ross Road School	Girls WR tap 2 by room 111	MXZ640	0.0006	Passed	0.0280	Passed
Ross Road School	Boys WR tap 1 by room 111	MXZ641	0.0053	Exceeds Limit	0.0480	Passed
Ross Road School	Boys WR tap 2 by room 111	MXZ642	0.0043	Passed	0.2400	Passed
Ross Road School	GN WR tap by room 107	MXZ643	0.0026	Passed	0.1800	Passed
Ross Road School	JC tap by room 108	MXZ644	0.0008	Passed	0.2000	Passed
Ross Road School	Girls WR tap 1 near room 111	MXZ645	0.0025	Passed	0.2200	Passed
Ross Road School	Girls WR tap 2 near room 111	MXZ646	0.0018	Passed	0.2100	Passed
Ross Road School	Girls WR tap 3 near room 111	MXZ647	0.0030	Passed	0.2000	Passed
Ross Road School	JC tap by boys WR	MXZ648	0.0006	Passed	0.0260	Passed
Ross Road School	1st floor boys WR tap 1 near room 120	MXZ649	0.0009	Passed	0.2400	Passed
Ross Road School	1st floor boys WR tap 2 near room 120	MXZ650	0.0027	Passed	0.1800	Passed
Ross Road School	1st floor boys WR tap 3 near room 120	MXZ651	0.0006	Passed	0.0470	Passed
Ross Road School	Fountain by boys WR	MXZ652	0.0000	Passed	0.9300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Ross Road School	Family studies tap 1 room 120	MXZ653	0.0016	Passed	0.4200	Passed
Ross Road School	Family studies tap 2 room 120	MXZ654	0.0028	Passed	0.2800	Passed
Ross Road School	Family studies tap 3 room 120	MXZ655	0.0039	Passed	0.5900	Passed
Ross Road School	Family studies tap 4 room 120	MXZ656	0.0019	Passed	0.1100	Passed
Ross Road School	Family studies tap 5 room 120	NMD621	0.0009	Passed	0.0270	Passed
Ross Road School	CR tap room 128	MXZ658	0.0850	Exceeds Limit	0.8900	Passed
Ross Road School	JC tap room 135	MXZ659	0.0011	Passed	0.0560	Passed
Ross Road School	Fountain by room 135	MXZ660	0.0120	Exceeds Limit	1.2000	Passed
Ross Road School	Tech Ed. Room tap	MXZ661	0.0009	Passed	0.3300	Passed
Ross Road School	Gym Area tap room 138	MXZ662	0.0077	Exceeds Limit	0.3100	Passed
Ross Road School	Boys locker room tap room 140	MXZ663	0.0087	Exceeds Limit	0.4000	Passed
Ross Road School	Girls locker room tap room 141	MXZ664	0.0012	Passed	0.9300	Passed
Ross Road School	Gym office tap room 139	MXZ665	0.0009	Passed	0.1200	Passed
Ross Road School	CR tap room 134	MXZ666	0.0007	Passed	0.1400	Passed
Ross Road School	CR tap room 133	MXZ667	0.0016	Passed	0.1300	Passed
Ross Road School	Cafeteria/Kitchen tap 1	MXZ668	0.0035	Passed	0.3700	Passed
Ross Road School	Cafeteria/Kitchen tap 2	MXZ669	0.0025	Passed	0.4300	Passed
Ross Road School	Cafeteria/Kitchen tap 3	NMD623	0.0004	Passed	0.0650	Passed
Ross Road School	Cafeteria/Kitchen tap 4	NMD624	0.0035	Passed	0.0890	Passed
Ross Road School	Staff room tap room 216	MXZ672	0.0032	Passed	0.1600	Passed
Ross Road School	GN WR tap room 217	MXZ673	0.0019	Passed	0.0870	Passed
Ross Road School	Girls WR tap 1 by room 217	MXZ674	0.0040	Passed	0.1800	Passed
Ross Road School	Girls WR tap 2 by room 217	MXZ675	0.0050	Passed	0.1600	Passed
Ross Road School	Girls WR tap 3 by room 217	MXZ676	0.0051	Exceeds Limit	0.1500	Passed
Ross Road School	JC tap room 214	MXZ677	0.0005	Passed	0.0500	Passed
Ross Road School	Fountain by room 214	MXZ678	0.0036	Passed	0.6300	Passed
Ross Road School	Boys WR tap 1 by room 214	MXZ679	0.0072	Exceeds Limit	0.4400	Passed
Ross Road School	Boys WR tap 2 by room 214	MXZ680	0.0130	Exceeds Limit	0.2100	Passed
Ross Road School	Boys WR tap 3 by room 214	MXZ681	0.0049	Passed	0.1500	Passed
Sackville Heights Elementary School	Boys Locker room tap in gym	MYH123	0.0000	Passed	0.0240	Passed
Sackville Heights Elementary School	Girls Locker room tap in gym	MYH124	0.0008	Passed	0.4200	Passed
Sackville Heights Elementary School	Gym office WR tap	MYH125	0.0000	Passed	0.0470	Passed
Sackville Heights Elementary School	Kitchen/Cafeteria tap 1 room 1066	MYH126	0.0290	Exceeds Limit	0.9600	Passed
Sackville Heights Elementary School	Kitchen/Cafeteria tap 2 room 1066	MYH127	0.0013	Passed	0.2600	Passed
Sackville Heights Elementary School	Kitchen/Cafeteria tap 3 room 1066	MYH128	0.0006	Passed	0.0580	Passed
Sackville Heights Elementary School	JC tap room 1059	MYH129	0.0000	Passed	0.0400	Passed
Sackville Heights Elementary School	Music room tap by room 1059	MYH130	0.0000	Passed	0.1600	Passed
Sackville Heights Elementary School	Art room tap room 1063	MYH131	0.0000	Passed	0.3900	Passed
Sackville Heights Elementary School	Recycle room tap room 1055	MYH132	0.0000	Passed	0.0600	Passed
Sackville Heights Elementary School	CR tap room 1036	MYH133	0.0000	Passed	0.6100	Passed
Sackville Heights Elementary School	CR tap room 1037	MYH134	0.0008	Passed	0.1200	Passed
Sackville Heights Elementary School	CR tap room 1038	MYH135	0.0005	Passed	0.1400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sackville Heights Elementary School	CR tap room 1039	MYH136	0.0006	Passed	0.2100	Passed
Sackville Heights Elementary School	GN WR tap room 1041	MYH137	0.0006	Passed	0.1600	Passed
Sackville Heights Elementary School	CR tap room 1025	MYH138	0.0006	Passed	0.1100	Passed
Sackville Heights Elementary School	CR tap room 1026	MYH139	0.0000	Passed	0.0520	Passed
Sackville Heights Elementary School	GN WR tap room 1031	MYH140	0.0006	Passed	0.0890	Passed
Sackville Heights Elementary School	CR tap room 1027	MYH141	0.0000	Passed	0.0420	Passed
Sackville Heights Elementary School	CR tap room 1028	MYH142	0.0000	Passed	0.0640	Passed
Sackville Heights Elementary School	GN WR tap room 1022	MYH143	0.0000	Passed	0.0440	Passed
Sackville Heights Elementary School	Main office sick room tap room 1021	MYH144	0.0000	Passed	0.0860	Passed
Sackville Heights Elementary School	Main office WR tap room 1018	MYH145	0.0000	Passed	0.0410	Passed
Sackville Heights Elementary School	Fountain by room 150	MYH146	0.0017	Passed	0.9800	Passed
Sackville Heights Elementary School	Girls WR tap 1 room 1050	MYH147	0.0013	Passed	0.3200	Passed
Sackville Heights Elementary School	Girls WR tap 2 room 1050	MYH148	0.0019	Passed	0.1800	Passed
Sackville Heights Elementary School	Girls WR tap 3 room 1050	MYH149	0.0023	Passed	0.1700	Passed
Sackville Heights Elementary School	Boys WR tap 1 room 1049	MYH150	0.0006	Passed	0.1300	Passed
Sackville Heights Elementary School	Boys WR tap 2 room 1049	MYH151	0.0059	Exceeds Limit	0.2500	Passed
Sackville Heights Elementary School	Boys WR tap 3 room 1049	MYH152	0.0005	Passed	0.1700	Passed
Sackville Heights Elementary School	Fountain right of room 1049	MYH153	0.0000	Passed	0.1100	Passed
Sackville Heights Elementary School	Library storage room tap room 1047	MYH154	0.0035	Passed	0.2400	Passed
Sackville Heights Elementary School	Girls WR tap 1 room 1046	MYH155	0.0021	Passed	0.2000	Passed
Sackville Heights Elementary School	Girls WR tap 2 room 1046	MYH156	0.0014	Passed	0.1500	Passed
Sackville Heights Elementary School	Boys WR tap 1 room 1045	MYH157	0.0017	Passed	0.1800	Passed
Sackville Heights Elementary School	Boys WR tap 2 room 1045	MYH158	0.0034	Passed	0.3200	Passed
Sackville Heights Elementary School	Fountain right of room 1045	MYH159	0.0000	Passed	0.0940	Passed
Sackville Heights Elementary School	CR tap room 2030	MYH160	0.0000	Passed	0.3600	Passed
Sackville Heights Elementary School	CR tap room 2031	MYH161	0.0000	Passed	0.2400	Passed
Sackville Heights Elementary School	CR tap room 2032	MYH162	0.0000	Passed	0.2400	Passed
Sackville Heights Elementary School	CR tap room 2033	MYH163	0.0010	Passed	0.8300	Passed
Sackville Heights Elementary School	CR tap room 2017	MYH164	0.0005	Passed	0.0850	Passed
Sackville Heights Elementary School	CR tap room 2018	MYH165	0.0009	Passed	0.2100	Passed
Sackville Heights Elementary School	CR tap room 2019	MYH166	0.0007	Passed	0.1200	Passed
Sackville Heights Elementary School	CR tap room 2020	MYH167	0.0010	Passed	0.1300	Passed
Sackville Heights Elementary School	Staff room WR #1 tap room 2009	MYH168	0.0009	Passed	0.0820	Passed
Sackville Heights Elementary School	Staff room WR #2 tap room 2008	MYH169	0.0000	Passed	0.0510	Passed
Sackville Heights Elementary School	Staff room kitchen tap room 2007	MYH170	0.0010	Passed	0.1000	Passed
Sackville Heights Elementary School	JC tap room 2040	MYH171	0.0000	Passed	0.0740	Passed
Sackville Heights Elementary School	Fountain by room 2017	MYH172	0.0000	Passed	0.2800	Passed
Sackville Heights Elementary School	Girls WR tap 1 room 2025	MYH173	0.0005	Passed	0.2000	Passed
Sackville Heights Elementary School	Girls WR tap 2 room 2025	MYH174	0.0011	Passed	0.1800	Passed
Sackville Heights Elementary School	Girls WR tap 3 room 2025	MYH175	0.0015	Passed	0.2000	Passed
Sackville Heights Elementary School	Boys WR tap 1 room 2026	MYH176	0.0012	Passed	0.1300	Passed
Sackville Heights Elementary School	Boys WR tap 2 room 2026	MYH177	0.0024	Passed	0.2100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sackville Heights Elementary School	Boys WR tap 3 room 2026	MYH178	0.0010	Passed	0.0810	Passed
Sackville Heights Elementary School	Fountain by room 2026	MYH179	0.0000	Passed	0.0510	Passed
Sackville Heights Junior High School	Laundry tub tap room 243	MTV818	0.0000	Passed	0.1200	Passed
Sackville Heights Junior High School	Art room tap 1 room 235	MTV819	0.0006	Passed	0.3200	Passed
Sackville Heights Junior High School	Art room tap 2 room 235	MTV820	0.0005	Passed	0.2400	Passed
Sackville Heights Junior High School	Girls WR tap 1 beside room 230	MTV821	0.0530	Exceeds Limit	0.3000	Passed
Sackville Heights Junior High School	Girls WR tap 2 beside room 230	MTV822	0.0027	Passed	0.5000	Passed
Sackville Heights Junior High School	Girls WR tap 3 beside room 230	MTV823	0.0000	Passed	0.1600	Passed
Sackville Heights Junior High School	Girls WR tap 4 beside room 230	MTV824	0.0000	Passed	0.1300	Passed
Sackville Heights Junior High School	JC tap by girls WR	MTV825	0.0000	Passed	0.0430	Passed
Sackville Heights Junior High School	Fountain between WR's	MTV826	0.0000	Passed	0.1900	Passed
Sackville Heights Junior High School	Boys WR tap 1 by telecom 3	MTV827	0.0000	Passed	0.2900	Passed
Sackville Heights Junior High School	Boys WR tap 2 by telecom 3	MTV833	0.0007	Passed	0.2100	Passed
Sackville Heights Junior High School	Boys WR tap 3 by telecom 3	MTV834	0.0000	Passed	0.2300	Passed
Sackville Heights Junior High School	Boys WR tap 4 by telecom 3	MTV835	0.0000	Passed	0.1800	Passed
Sackville Heights Junior High School	Sci room tap 1 by boys WR	MTV836	0.0007	Passed	0.1300	Passed
Sackville Heights Junior High School	Sci room tap 2 by boys WR	MTV837	0.0013	Passed	0.2000	Passed
Sackville Heights Junior High School	Family studies tap 1 room 222	MTV838	0.0000	Passed	0.1500	Passed
Sackville Heights Junior High School	Family studies tap 2 room 222	MTV839	0.0000	Passed	0.0810	Passed
Sackville Heights Junior High School	Family studies tap 3 room 222	MTV840	0.0000	Passed	0.0730	Passed
Sackville Heights Junior High School	Family studies tap 4 room 222	MTV841	0.0000	Passed	0.0450	Passed
Sackville Heights Junior High School	GN WR tap in room 214C	MTV842	0.0000	Passed	0.2200	Passed
Sackville Heights Junior High School	GN WR tap room 216 in room 214C	MTV859	0.0000	Passed	0.0390	Passed
Sackville Heights Junior High School	CR tap room 214C	MTV860	0.0000	Passed	0.1300	Passed
Sackville Heights Junior High School	Girls WR tap 1 beside room 207A	MTV861	0.0076	Exceeds Limit	0.6300	Passed
Sackville Heights Junior High School	Girls WR tap 2 beside room 207A	MTV862	0.0043	Passed	0.2700	Passed
Sackville Heights Junior High School	Fountain by Girls WR	MTV863	0.0000	Passed	0.8900	Passed
Sackville Heights Junior High School	JC tap between WR's	MTV864	0.0013	Passed	0.0590	Passed
Sackville Heights Junior High School	Boys WR tap 1 by room 203	MTV865	0.0000	Passed	0.1400	Passed
Sackville Heights Junior High School	Boys WR tap 2 by room 203	MTV866	0.0000	Passed	0.0810	Passed
Sackville Heights Junior High School	Laundry tub tap room 248	MTV867	0.0016	Passed	0.1000	Passed
Sackville Heights Junior High School	cafeteria single compartment sink tap	MTV868	0.0006	Passed	0.5200	Passed
Sackville Heights Junior High School	cafeteria double compartment sink tap	MTV869	0.0000	Passed	0.0480	Passed
Sackville Heights Junior High School	cafeteria eye washing sink tap	MTV870	0.0000	Passed	0.0930	Passed
Sackville Heights Junior High School	cafeteria hand washing sink tap	MTV871	0.0000	Passed	0.2100	Passed
Sackville Heights Junior High School	Music room tap room 161	MTV872	0.0000	Passed	0.4400	Passed
Sackville Heights Junior High School	JC tap room 154	MTV873	0.0000	Passed	0.2100	Passed
Sackville Heights Junior High School	CR tap room 141	MTV874	0.0240	Exceeds Limit	1.3000	Passed
Sackville Heights Junior High School	Girls WR tap 1 by room 151	MTV875	0.0038	Passed	0.1600	Passed
Sackville Heights Junior High School	Girls WR tap 2 by room 151	MTV876	0.0000	Passed	0.2300	Passed
Sackville Heights Junior High School	Girls WR tap 3 by room 151	MTV877	0.0000	Passed	0.1600	Passed
Sackville Heights Junior High School	Girls WR tap 4 by room 151	MTV878	0.0000	Passed	0.1400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sackville Heights Junior High School	Staff WR tap in Girls WR room 139	MTV886	0.0000	Passed	0.0590	Passed
Sackville Heights Junior High School	Fountain by room 135	MTV887	0.0000	Passed	0.2300	Passed
Sackville Heights Junior High School	JC tap room 135	MTV888	0.0000	Passed	0.0230	Passed
Sackville Heights Junior High School	Boys WR tap 1 by room 135	MTV889	0.0011	Passed	0.1600	Passed
Sackville Heights Junior High School	Boys WR tap 2 by room 135	MTV890	0.0000	Passed	0.2200	Passed
Sackville Heights Junior High School	Boys WR tap 3 by room 135	MTV891	0.0000	Passed	0.1500	Passed
Sackville Heights Junior High School	Boys WR tap 4 by room 135	MTV892	0.0009	Passed	0.2400	Passed
Sackville Heights Junior High School	GN WR tap room 131B in room 132B	MTV893	0.0000	Passed	0.3600	Passed
Sackville Heights Junior High School	Kitchen tap room 132B	MTV894	0.0000	Passed	0.0550	Passed
Sackville Heights Junior High School	Sick room GN WR tap room 132B	MTV895	0.0000	Passed	0.2700	Passed
Sackville Heights Junior High School	Main office GN WR tap room 121	MTV910	0.0000	Passed	0.2100	Passed
Sackville Heights Junior High School	Main office GN WR tap room 122	MTV911	0.0000	Passed	0.2700	Passed
Sackville Heights Junior High School	Wood working room tap room 111	MTV912	0.0006	Passed	0.2900	Passed
Sackville Heights Junior High School	Girls WR tap 1 by Wood shop	MTV913	0.0000	Passed	0.1000	Passed
Sackville Heights Junior High School	Girls WR tap 2 by Wood shop	MTV914	0.0000	Passed	0.0810	Passed
Sackville Heights Junior High School	Girls WR tap 3 by Wood shop	MTV915	0.0019	Passed	0.0830	Passed
Sackville Heights Junior High School	Girls WR tap 4 by Wood shop	MTV916	0.0006	Passed	0.0930	Passed
Sackville Heights Junior High School	Girls WR tap 5 by Wood shop	MTV917	0.0000	Passed	0.0760	Passed
Sackville Heights Junior High School	JC tap room 107	MUD544	0.0014	Passed	0.0560	Passed
Sackville Heights Junior High School	Room 106 tap	NND050	0.0004	Passed	0.0140	Passed
Sackville Heights Junior High School	Boys WR tap 1 by room 103	MUD545	0.0000	Passed	0.1900	Passed
Sackville Heights Junior High School	Boys WR tap 2 by room 103	MUD546	0.0017	Passed	0.2100	Passed
Sackville Heights Junior High School	Boys WR tap 3 by room 103	MUD547	0.0000	Passed	0.1700	Passed
Sackville Heights Junior High School	Boys WR tap 4 by room 103	MUD548	0.0000	Passed	0.1700	Passed
Sackville Heights Junior High School	Boys WR tap 5 by room 103	MUD549	0.0000	Passed	0.1200	Passed
Sackville Heights Junior High School	Girls locker room tap 1 in gym	MUD550	0.0013	Passed	0.2200	Passed
Sackville Heights Junior High School	Girls locker room tap 2 in gym	MUD551	0.0006	Passed	0.4500	Passed
Sackville Heights Junior High School	Boys locker room tap 1 in gym	MUD552	0.0007	Passed	0.1500	Passed
Sackville Heights Junior High School	Boys locker room tap 2 in gym	MUD553	0.0000	Passed	0.1200	Passed
Sackville Heights Junior High School	Gym office WR tap room 170A	MUD554	0.0000	Passed	0.4000	Passed
Sackville Heights Junior High School	Fountain across from boys WR	MUD555	0.0000	Passed	0.2000	Passed
Sackville Heights Junior High School	Fountain by gym main doors	MUD556	0.0010	Passed	0.3100	Passed
Sackville High School	Chem lab tap 1 room 304	MSP782	0.0058	Exceeds Limit	0.7400	Passed
Sackville High School	Chem lab tap 2 room 304	MSP783	0.0093	Exceeds Limit	0.6800	Passed
Sackville High School	Chem lab tap 3 room 304	MSP784	0.0054	Exceeds Limit	0.6700	Passed
Sackville High School	Chem lab tap 4 room 304	MSP785	0.0070	Exceeds Limit	0.7000	Passed
Sackville High School	Chem lab tap 5 room 304	MSP786	0.0043	Passed	0.6100	Passed
Sackville High School	Chem storage room tap room 305	MSP787	0.0080	Exceeds Limit	0.2200	Passed
Sackville High School	Chem storage room tap room 306	MSP788	0.0060	Exceeds Limit	0.1700	Passed
Sackville High School	Chem lab tap 1 room 307	MSP789	0.0130	Exceeds Limit	1.1000	Passed
Sackville High School	Chem lab tap 2 room 307	MSP790	0.0260	Exceeds Limit	0.4900	Passed
Sackville High School	Chem lab tap 3 room 307	MSP791	0.0048	Passed	0.8900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sackville High School	Chem lab tap 4 room 307	MSP870	0.0063	Exceeds Limit	0.7300	Passed
Sackville High School	Chem lab tap 5 room 307	MSP871	0.0039	Passed	0.2300	Passed
Sackville High School	Physics lab tap 1 room 309	MSP872	0.0070	Exceeds Limit	1.4000	Passed
Sackville High School	Physics lab tap 2 room 309	MSP873	0.0450	Exceeds Limit	0.8600	Passed
Sackville High School	CR tap room 310	MSP874	0.0069	Exceeds Limit	0.4500	Passed
Sackville High School	CR tap room 311	MSP875	0.0860	Exceeds Limit	1.5000	Passed
Sackville High School	CR tap 1 room 312	MSP876	0.0210	Exceeds Limit	0.7600	Passed
Sackville High School	CR tap 2 room 312	MSP877	0.0049	Passed	0.5800	Passed
Sackville High School	CR tap 3 room 312	MSP878	0.0090	Exceeds Limit	0.1500	Passed
Sackville High School	Cr tap 1 room 313	MSP879	0.0028	Passed	0.2600	Passed
Sackville High School	Cr tap 2 room 313	MSP880	0.0098	Exceeds Limit	0.9700	Passed
Sackville High School	CR tap room 321	MSP881	0.0043	Passed	0.8600	Passed
Sackville High School	CR tap room 325	MSP882	0.0044	Passed	0.1200	Passed
Sackville High School	Storage room tap room 325	MSP883	0.0210	Exceeds Limit	0.4100	Passed
Sackville High School	GN WR tap 1 by room 325	MSP884	0.0018	Passed	0.2800	Passed
Sackville High School	GN WR tap 2 by room 325	MSP885	0.0017	Passed	0.3600	Passed
Sackville High School	GN WR tap 3 by room 325	MSP886	0.0016	Passed	0.1300	Passed
Sackville High School	GN WR tap 4 by room 325	MSP887	0.0013	Passed	0.0690	Passed
Sackville High School	Electrical room tap room 326	MSP888	0.0010	Passed	0.0450	Passed
Sackville High School	Fountain by room 326	MSP889	0.0000	Passed	0.6700	Passed
Sackville High School	Boys staff WR tap	MSP890	0.0022	Passed	0.0820	Passed
Sackville High School	Girls staff WR tap	MSP891	0.0019	Passed	0.0660	Passed
Sackville High School	CR tap 1 room 234	MSP892	0.0041	Passed	0.4000	Passed
Sackville High School	CR tap 2 room 234	MSP893	0.0018	Passed	0.1700	Passed
Sackville High School	CR WR 1 tap room 234	MSP894	0.0023	Passed	0.2200	Passed
Sackville High School	CR WR 2 tap room 234	MSP895	0.0011	Passed	0.1500	Passed
Sackville High School	Staff room tap 1 room 238	NJH104	0.0037	Passed	0.0460	Passed
Sackville High School	Staff room WR tap room 238	MSP897	0.0062	Exceeds Limit	0.1500	Passed
Sackville High School	Girls WR tap 1 by room 238	MSP898	0.0011	Passed	0.0470	Passed
Sackville High School	Girls WR tap 2 by room 238	MSP899	0.0000	Passed	0.0310	Passed
Sackville High School	Girls WR tap 3 by room 238	MSP915	0.0000	Passed	0.0230	Passed
Sackville High School	Girls WR tap 4 by room 238	MSP916	0.0000	Passed	0.0170	Passed
Sackville High School	JC tap between WR's	MSP917	0.0006	Passed	0.0380	Passed
Sackville High School	Fountain between WR's	MSP918	0.0000	Passed	0.5800	Passed
Sackville High School	Boys WR tap 1 by boiler room	MSP919	0.0009	Passed	0.0650	Passed
Sackville High School	Boys WR tap 2 by boiler room	MSP920	0.0000	Passed	0.0150	Passed
Sackville High School	Boys WR tap 3 by boiler room	MSP921	0.0007	Passed	0.0120	Passed
Sackville High School	Boys WR tap 4 by boiler room	MSP922	0.0000	Passed	0.0120	Passed
Sackville High School	JC office tap	MSP923	0.0041	Passed	0.2600	Passed
Sackville High School	Boiler room tap	MSP924	0.0000	Passed	0.0044	Passed
Sackville High School	Boys locker room tap	MSP934	0.0021	Passed	0.0960	Passed
Sackville High School	Girls locker room tap	MSP935	0.0034	Passed	0.1400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sackville High School	3rd Floor JC	MSQ363	0.0033	Passed	0.2900	Passed
Sackville High School	GN WR tap 1 by stairs	MSQ365	0.0024	Passed	0.3500	Passed
Sackville High School	GN WR tap 2 by stairs	MSQ366	0.0010	Passed	0.0520	Passed
Sackville High School	GN WR tap 3 by stairs	MSQ367	0.0023	Passed	0.1500	Passed
Sackville High School	GN WR tap 4 by stairs	MSQ368	0.0022	Passed	0.1000	Passed
Sackville High School	Gym fountain	MSQ369	0.0013	Passed	0.0900	Passed
Sackville High School	Gym Office 1 tap	MSQ372	0.0012	Passed	0.2500	Passed
Sackville High School	Gym Office 2 tap	MSQ373	0.0028	Passed	1.6000	Passed
Sackville High School	Fountain by room 204	MSQ374	0.0009	Passed	0.0930	Passed
Sackville High School	Boys WR tap 1 across from cafeteria	MTN371	0.0130	Exceeds Limit	0.5500	Passed
Sackville High School	Boys WR tap 2 across from cafeteria	MTN372	0.0008	Passed	0.0120	Passed
Sackville High School	Boys WR tap 3 across from cafeteria	MTN373	0.0007	Passed	0.0066	Passed
Sackville High School	Boys WR tap 4 across from cafeteria	MTN374	0.0006	Passed	0.0700	Passed
Sackville High School	SR tap	MSQ375	0.0018	Passed	0.1600	Passed
Sackville High School	Fountain between room 104 and 105	MTN427	0.0160	Exceeds Limit	1.4000	Passed
Sackville High School	Fountain beside cafeteria	MTN428	0.0220	Exceeds Limit	0.9400	Passed
Sackville High School	Kitchen cafeteria tap 1 (triple sink)	MTN429	0.0140	Exceeds Limit	0.1300	Passed
Sackville High School	Kitchen cafeteria tap 2 (triple sink)	MTN430	0.0014	Passed	0.1000	Passed
Sackville High School	Kitchen cafeteria hand washing tap	MTN431	0.0120	Exceeds Limit	0.7500	Passed
Sackville High School	Wood shop tap	MTN432	0.0019	Passed	0.1400	Passed
Sackville High School	GN WR tap between art and wood room	MTN433	0.0010	Passed	0.1400	Passed
Sackville High School	Art room sink tap 1	MTN434	0.0071	Exceeds Limit	0.5500	Passed
Sackville High School	Art room sink tap 2	MTN435	0.0022	Passed	0.2100	Passed
Sackville High School	Skilled trades room tap 1	MTN436	0.0051	Exceeds Limit	0.7400	Passed
Sackville High School	Art room tap room 129	MTN448	0.0048	Passed	0.2100	Passed
Sackville High School	Electronic room across from cafeteria	MTN449	0.0047	Passed	0.1100	Passed
Sackville High School	Girls WR tap 1 across from cafeteria	MTN450	0.0590	Exceeds Limit	0.2000	Passed
Sackville High School	Girls WR tap 2 across from cafeteria	MTN451	0.4600	Exceeds Limit	0.7500	Passed
Sackville High School	Girls WR tap 3 across from cafeteria	MTN452	0.0140	Exceeds Limit	0.2400	Passed
Sackville High School	Girls WR tap 4 across from cafeteria	MTN453	0.0300	Exceeds Limit	0.0560	Passed
Sackville High School	JC tap between WR's	MTN454	0.0012	Passed	0.0590	Passed
Sackville High School	Fountain by boys WR	MTN455	0.0010	Passed	0.4400	Passed
Saint Mary's Elementary School	Staff room tap 1	MTP607	0.0009	Passed	0.0630	Passed
Saint Mary's Elementary School	Staff room tap 2	MTP608	0.0041	Passed	0.1000	Passed
Saint Mary's Elementary School	CR tap room 206	MTP609	0.0036	Passed	0.0630	Passed
Saint Mary's Elementary School	CR tap room 205	MTP610	0.0330	Exceeds Limit	0.0600	Passed
Saint Mary's Elementary School	JC tap room 204	MTP611	0.0005	Passed	0.0380	Passed
Saint Mary's Elementary School	Fountain by JC	MTP612	0.0000	Passed	0.0400	Passed
Saint Mary's Elementary School	1st floor girls WR tap 1	MTP613	0.0008	Passed	0.0840	Passed
Saint Mary's Elementary School	1st floor girls WR tap 2	MTP614	0.0000	Passed	0.0140	Passed
Saint Mary's Elementary School	1st floor girls WR tap 3	MTP615	0.0000	Passed	0.0062	Passed
Saint Mary's Elementary School	1st floor girls WR tap 4	MTP616	0.0000	Passed	0.0054	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Saint Mary's Elementary School	Staff WR in gym	MTP617	0.0000	Passed	0.0320	Passed
Saint Mary's Elementary School	1st floor boys WR tap 1	MTP618	0.0006	Passed	0.0420	Passed
Saint Mary's Elementary School	1st floor boys WR tap 2	MTP619	0.0000	Passed	0.0150	Passed
Saint Mary's Elementary School	1st floor boys WR tap 3	MTP620	0.0000	Passed	0.0056	Passed
Saint Mary's Elementary School	Maintenance closet tap room 110	MTP621	0.0021	Passed	0.0580	Passed
Sambro Elementary School	FOUNTAIN BY ROOM 202	MRV116	0.0009	Passed	0.0260	Passed
Sambro Elementary School	STAFF W/R TAP	MRV117	0.0031	Passed	0.7100	Passed
Sambro Elementary School	STAFF KITCHEN TAP	MRV118	0.0022	Passed	0.7500	Passed
Sambro Elementary School	STAFF ROOM TAP	MRV119	0.0019	Passed	0.8100	Passed
Sambro Elementary School	JANITORS TAP W/ STAFF ROOM	MRV120	0.0018	Passed	0.7100	Passed
Sambro Elementary School	GIRLS W/R TAP 1	MRV121	0.0092	Exceeds Limit	2.4000	Exceeds Limit
Sambro Elementary School	GIRLS W/R TAP 2	MRV122	0.0100	Exceeds Limit	2.5000	Exceeds Limit
Sambro Elementary School	GIRLS W/R TAP 3	MRV123	0.0082	Exceeds Limit	2.4000	Exceeds Limit
Sambro Elementary School	BOYS W/R TAP 1	MRV124	0.0022	Passed	1.2000	Passed
Sambro Elementary School	BOYS W/R TAP 1	MRV125	0.0140	Exceeds Limit	4.7000	Exceeds Limit
Sambro Elementary School	BOYS W/R TAP 2	MRV126	0.0054	Exceeds Limit	1.4000	Passed
Sambro Elementary School	BOYS W/R TAP 3	MRV127	0.0029	Passed	1.2000	Passed
Sambro Elementary School	FOUNTAIN BY ROOM 112	MRV128	0.0009	Passed	0.1400	Passed
Sambro Elementary School	CLASS ROOM W/R 110 TAP	MRV129	0.0033	Passed	1.9000	Passed
Seaside Elementary School	3rd floor boys WR tap 1	MYZ230	0.0035	Passed	0.2400	Passed
Seaside Elementary School	3rd floor boys WR tap 2	MYZ231	0.0080	Exceeds Limit	0.3000	Passed
Seaside Elementary School	JC tap in between WR's	MYZ232	0.0036	Passed	0.1300	Passed
Seaside Elementary School	Fountain in between WR's	MYZ233	0.0000	Passed	0.3200	Passed
Seaside Elementary School	3rd floor Girls WR tap 1	MYZ234	0.0029	Passed	0.0840	Passed
Seaside Elementary School	3rd floor Girls WR tap 2	MYZ235	0.0019	Passed	0.0690	Passed
Seaside Elementary School	Staff room tap 1 room 308	MYZ236	0.0000	Passed	0.0250	Passed
Seaside Elementary School	Staff room tap 2 room 308	MYZ237	0.0013	Passed	0.0340	Passed
Seaside Elementary School	Staff room tap 3 room 308	MYZ238	0.0013	Passed	0.1200	Passed
Seaside Elementary School	Cafeteria/Kitchen tap 1 (2nd floor)	MYZ239	0.0025	Passed	0.1700	Passed
Seaside Elementary School	Cafeteria/Kitchen tap 2 (2nd floor)	NMV190	0.0004	Passed	0.0330	Passed
Seaside Elementary School	Cafeteria/Kitchen tap 3 (2nd floor)	NMV191	0.0013	Passed	0.0360	Passed
Seaside Elementary School	Fountain by kitchen	MYZ290	0.0034	Passed	0.0380	Passed
Seaside Elementary School	Boys WR tap 1	MYZ291	0.0000	Passed	0.0079	Passed
Seaside Elementary School	Boys WR tap 2	MYZ292	0.0065	Exceeds Limit	0.0580	Passed
Seaside Elementary School	JC tap by girls WR	MYZ293	0.0013	Passed	0.4800	Passed
Seaside Elementary School	Girls WR tap 1 by office	MYZ294	0.0064	Exceeds Limit	0.3100	Passed
Seaside Elementary School	Girls WR tap 2 by office	MYZ296	0.0028	Passed	0.2300	Passed
Seaside Elementary School	Office WR tap	MYZ297	0.0017	Passed	0.0770	Passed
Seaside Elementary School	Boys WR tap 1 by office	MYZ298	0.0040	Passed	0.0840	Passed
Seaside Elementary School	Boys WR tap 2 by office	MYZ320	0.0027	Passed	0.1200	Passed
Seaside Elementary School	Girls WR tap 1 by office	MYZ321	0.0065	Exceeds Limit	0.4100	Passed
Seaside Elementary School	Girls WR tap 2 by office	MYZ322	0.0064	Exceeds Limit	0.1900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Shannon Park Elementary School	Girls WR tap 1 by room 4	MYA331	0.0072	Exceeds Limit	0.0820	Passed
Shannon Park Elementary School	Girls WR tap 2 by room 4	MYA332	0.0021	Passed	0.0220	Passed
Shannon Park Elementary School	Girls WR tap 3 by room 4	MYA333	0.0019	Passed	0.0190	Passed
Shannon Park Elementary School	Girls WR tap 4 by room 4	MYA334	0.0021	Passed	0.0190	Passed
Shannon Park Elementary School	GN WR tap room 3	MYA335	0.0650	Exceeds Limit	0.4300	Passed
Shannon Park Elementary School	JC tap by room 3	MYA336	0.0000	Passed	0.0040	Passed
Shannon Park Elementary School	Girls WR tap 1 by room 5	MYA338	0.0170	Exceeds Limit	0.0810	Passed
Shannon Park Elementary School	Girls WR tap 2 by room 5	MYA339	0.0420	Exceeds Limit	0.1800	Passed
Shannon Park Elementary School	Girls WR tap 3 by room 5	MYA340	0.0260	Exceeds Limit	0.1500	Passed
Shannon Park Elementary School	Boys WR tap 1 left of room 6	MYA341	0.0400	Exceeds Limit	0.2700	Passed
Shannon Park Elementary School	Boys WR tap 2 left of room 6	MYA342	0.0140	Exceeds Limit	0.1100	Passed
Shannon Park Elementary School	Boys gym locker room tap 1	MYA343	0.0057	Exceeds Limit	0.0330	Passed
Shannon Park Elementary School	Boys gym locker room tap 2	MYA344	0.0011	Passed	0.0095	Passed
Shannon Park Elementary School	Boys gym locker room tap 3	MYA345	0.0007	Passed	0.0089	Passed
Shannon Park Elementary School	Boys gym locker room tap 4	MYA346	0.0008	Passed	0.0100	Passed
Shannon Park Elementary School	Girls gym locker room tap 1	MYA347	0.0093	Exceeds Limit	0.1700	Passed
Shannon Park Elementary School	Girls gym locker room tap 2	MYA348	0.0043	Passed	0.0930	Passed
Shannon Park Elementary School	Girls gym locker room tap 3	MYA349	0.0032	Passed	0.1000	Passed
Shannon Park Elementary School	Girls gym locker room tap 4	MYA350	0.0041	Passed	0.0900	Passed
Shannon Park Elementary School	Girls WR tap 1 left of room 17	MYA351	0.0040	Passed	0.0280	Passed
Shannon Park Elementary School	Girls WR tap 2 left of room 17	MYA352	0.0080	Exceeds Limit	0.0900	Passed
Shannon Park Elementary School	Girls WR tap 3 left of room 17	MYA353	0.0093	Exceeds Limit	0.0200	Passed
Shannon Park Elementary School	Boys WR tap 1 left of room 17	MYA354	0.0010	Passed	0.0260	Passed
Shannon Park Elementary School	Boys WR tap 2 left of room 17	MYA355	0.0018	Passed	0.0400	Passed
Shannon Park Elementary School	Boys WR tap 3 left of room 17	MYA356	0.0980	Exceeds Limit	0.3800	Passed
Shannon Park Elementary School	JC tap by room 25	MYA357	0.0000	Passed	0.0240	Passed
Shannon Park Elementary School	Boys WR tap 1 by room 25	MYA358	0.0150	Exceeds Limit	0.1700	Passed
Shannon Park Elementary School	Boys WR tap 2 by room 25	MYA359	0.0110	Exceeds Limit	0.1200	Passed
Shannon Park Elementary School	Boys WR tap 3 by room 25	MYA360	0.0024	Passed	0.1500	Passed
Shannon Park Elementary School	GN WR tap across from room 25	MYA361	0.0036	Passed	0.0670	Passed
Shannon Park Elementary School	GN WR tap across from room 26	MYA362	0.0014	Passed	0.0760	Passed
Shannon Park Elementary School	Girls WR tap 1 left of room 27	MYA363	0.0140	Exceeds Limit	0.3800	Passed
Shannon Park Elementary School	Girls WR tap 2 left of room 27	MYA364	0.0049	Passed	0.1400	Passed
Shannon Park Elementary School	Girls WR tap 3 left of room 27	MYA365	0.0036	Passed	0.0900	Passed
Shannon Park Elementary School	Girls WR tap 4 left of room 27	MYA366	0.0006	Passed	0.0270	Passed
Shannon Park Elementary School	CR tap room 27	MYA367	0.0100	Exceeds Limit	0.2500	Passed
Shannon Park Elementary School	Boys WR tap 1 by room 208	MYA368	0.0200	Exceeds Limit	0.1300	Passed
Shannon Park Elementary School	Boys WR tap 2 by room 208	MYA369	0.0009	Passed	0.0160	Passed
Shannon Park Elementary School	Boys WR tap 3 by room 208	MYA370	0.0019	Passed	0.0340	Passed
Shannon Park Elementary School	JC tap by room 208	MYA371	0.0000	Passed	0.0170	Passed
Shannon Park Elementary School	GN WR tap across from room 207	MYA372	0.0011	Passed	0.0310	Passed
Shannon Park Elementary School	Girls WR tap 1 by room 207	MYA373	0.0088	Exceeds Limit	0.0970	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Shannon Park Elementary School	Girls WR tap 2 by room 207	MYA374	0.0024	Passed	0.0150	Passed
Shannon Park Elementary School	Girls WR tap 3 by room 207	MYA375	0.0720	Exceeds Limit	0.6400	Passed
Shannon Park Elementary School	Caretaker WR tap room 18	MYA376	0.0015	Passed	0.0520	Passed
Shannon Park Elementary School	JC tap by room 18	MYA377	0.0008	Passed	0.0280	Passed
Shannon Park Elementary School	CR tap room 165	MYA378	0.2000	Exceeds Limit	1.4000	Passed
Shannon Park Elementary School	Main office WR tap room 12	MYA379	0.0130	Exceeds Limit	0.1200	Passed
Shannon Park Elementary School	Fountain by room 4	MYH184	0.0007	Passed	0.5100	Passed
Shannon Park Elementary School	Fountain left of room 10	MYH185	0.0310	Exceeds Limit	1.7000	Passed
Shannon Park Elementary School	1st floor fountain left of room 137	MYH186	0.0000	Passed	1.6000	Passed
Shannon Park Elementary School	Fountain left of room 17	MYH187	0.0000	Passed	0.2900	Passed
Shannon Park Elementary School	Fountain by room 25	MYH188	0.0008	Passed	0.0560	Passed
Shannon Park Elementary School	Boys WR tap across from room 25	MYH189	0.0021	Passed	0.2100	Passed
Shannon Park Elementary School	2nd floor fountain by room 208	MYH190	0.0023	Passed	0.0770	Passed
Shatford Memorial Elementary School	1st floor GN WR tap by room 2	MUQ753	0.0022	Passed	0.4200	Passed
Shatford Memorial Elementary School	CR tap room 1	MUQ754	0.0010	Passed	0.1200	Passed
Shatford Memorial Elementary School	Fountain by room 1	MUQ755	0.0024	Passed	0.1400	Passed
Shatford Memorial Elementary School	Staff room WR tap room 3	MUQ756	0.0017	Passed	0.5800	Passed
Shatford Memorial Elementary School	Staff room tap room 3	MUQ757	0.0010	Passed	0.5100	Passed
Shatford Memorial Elementary School	Boys WR tap 1	MUQ758	0.0030	Passed	0.0810	Passed
Shatford Memorial Elementary School	Boys WR tap 2	MUQ759	0.0011	Passed	0.0650	Passed
Shatford Memorial Elementary School	JC tap	MUQ760	0.0009	Passed	0.0600	Passed
Shatford Memorial Elementary School	Fountain by WR's	MUQ761	0.0011	Passed	0.0860	Passed
Shatford Memorial Elementary School	Girls WR tap 1	MUQ762	0.0032	Passed	0.1300	Passed
Shatford Memorial Elementary School	Girls WR tap 2	MUQ763	0.0014	Passed	0.0710	Passed
Shatford Memorial Elementary School	CR 1 WR tap 1	MUQ764	0.0014	Passed	0.1500	Passed
Shatford Memorial Elementary School	CR 1 WR tap 2	MUQ765	0.0008	Passed	0.0790	Passed
Shatford Memorial Elementary School	Storage room 2 tap (wash tub)	MUQ766	0.0190	Exceeds Limit	0.2400	Passed
Shatford Memorial Elementary School	GN WR 2 tap	MUQ767	0.2100	Exceeds Limit	0.5000	Passed
Shatford Memorial Elementary School	JC tap	MUQ768	0.0034	Passed	0.5100	Passed
Shatford Memorial Elementary School	Fountain by boys WR	MUQ769	0.0130	Exceeds Limit	0.9300	Passed
Shatford Memorial Elementary School	Boys WR 5 tap 1	MUQ770	0.0076	Exceeds Limit	0.5400	Passed
Shatford Memorial Elementary School	Boys WR 5 tap 2	MUQ771	0.0021	Passed	0.5700	Passed
Shatford Memorial Elementary School	Girls WR 9 tap 1	MUQ772	0.0036	Passed	0.3600	Passed
Shatford Memorial Elementary School	Girls WR 9 tap 2	MUQ773	0.0020	Passed	0.2700	Passed
Shatford Memorial Elementary School	1st floor kitchen tap	MUQ774	0.0074	Exceeds Limit	0.0900	Passed
Sir Charles Tupper Elementary School	Staff room tap 1	MTO616	0.0000	Passed	0.0110	Passed
Sir Charles Tupper Elementary School	Staff room tap 2	MTO617	0.0000	Passed	0.0100	Passed
Sir Charles Tupper Elementary School	Staff room tap 3	MTO618	0.0000	Passed	0.0110	Passed
Sir Charles Tupper Elementary School	JC tap by staff room	MTO619	0.0008	Passed	0.0910	Passed
Sir Charles Tupper Elementary School	Staff GN WR tap by boys WR	MTO620	0.0000	Passed	0.0200	Passed
Sir Charles Tupper Elementary School	Boys WR tap 1 near staff room	MTO621	0.0048	Passed	0.5600	Passed
Sir Charles Tupper Elementary School	Boys WR tap 2 near staff room	MTO622	0.0000	Passed	0.0440	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sir Charles Tupper Elementary School	Boys WR tap 3 near staff room	MTO623	0.0000	Passed	0.0340	Passed
Sir Charles Tupper Elementary School	Boys WR tap 4 near staff room	MTO624	0.0000	Passed	0.0280	Passed
Sir Charles Tupper Elementary School	Boys WR tap 5 near staff room	MTO625	0.0000	Passed	0.0280	Passed
Sir Charles Tupper Elementary School	Fountain #1	MTO627	0.0013	Passed	0.1100	Passed
Sir Charles Tupper Elementary School	Fountain #2	MTO628	0.0007	Passed	0.2000	Passed
Sir Charles Tupper Elementary School	Resource room WR tap	MTO629	0.0000	Passed	0.0600	Passed
Sir Charles Tupper Elementary School	Principals office WR tap room 209	MTO630	0.0000	Passed	0.0300	Passed
Sir Charles Tupper Elementary School	JC tap by office	MTO631	0.0000	Passed	0.0220	Passed
Sir Charles Tupper Elementary School	Fountain by office	MTO632	0.0068	Exceeds Limit	0.4100	Passed
Sir Charles Tupper Elementary School	Girls WR tap 1 after office	MTO633	0.0000	Passed	0.1300	Passed
Sir Charles Tupper Elementary School	Girls WR tap 2 after office	MTO634	0.0007	Passed	0.0660	Passed
Sir Charles Tupper Elementary School	Girls WR tap 3 after office	MTO635	0.0000	Passed	0.0400	Passed
Sir Charles Tupper Elementary School	Girls WR tap 4 after office	MTO636	0.0000	Passed	0.0530	Passed
Sir Charles Tupper Elementary School	Girls WR tap 5 after office	MTO639	0.0000	Passed	0.1000	Passed
Sir Charles Tupper Elementary School	Sink tap in the hallway	MTO640	0.0014	Passed	0.0990	Passed
Sir Charles Tupper Elementary School	GN WR tap room 1	MTO641	0.0000	Passed	0.0270	Passed
Sir Charles Tupper Elementary School	JC tap after room 1	MTO642	0.0000	Passed	0.0240	Passed
Sir Charles Tupper Elementary School	Girls WR tap 1 after room 1	MTO643	0.0009	Passed	0.0160	Passed
Sir Charles Tupper Elementary School	Girls WR tap 2 after room 1	MTO644	0.0009	Passed	0.0150	Passed
Sir Charles Tupper Elementary School	Fountain by girls WR	MTO645	0.0000	Passed	0.8900	Passed
Sir Charles Tupper Elementary School	Boys WR tap 1 before art room	MTO646	0.0000	Passed	0.0085	Passed
Sir Charles Tupper Elementary School	Boys WR tap 2 before art room	MTO647	0.0000	Passed	0.0067	Passed
Sir Charles Tupper Elementary School	Art room tap	MTO648	0.0000	Passed	0.0400	Passed
Sir John A. Macdonald High School	2nd floor fountain	MUV835	0.0000	Passed	0.7100	Passed
Sir John A. Macdonald High School	2nd floor girls WR tap 1	MUV836	0.0029	Passed	0.4700	Passed
Sir John A. Macdonald High School	2nd floor girls WR tap 2	MUV837	0.0069	Exceeds Limit	0.5600	Passed
Sir John A. Macdonald High School	2nd floor boys WR tap 1	MUV838	0.0021	Passed	0.1700	Passed
Sir John A. Macdonald High School	2nd floor boys WR tap 2	MUV839	0.0009	Passed	0.1400	Passed
Sir John A. Macdonald High School	2nd floor staff WR tap	MUV840	0.0025	Passed	0.1300	Passed
Sir John A. Macdonald High School	2nd floor JC tap	MUV841	0.0000	Passed	0.1300	Passed
Sir John A. Macdonald High School	Science Lab tap 1 room 2056	MUV842	0.0052	Exceeds Limit	0.3900	Passed
Sir John A. Macdonald High School	Science Lab tap 2 room 2056	MUV843	0.0018	Passed	0.1600	Passed
Sir John A. Macdonald High School	Science Lab tap 3 room 2056	MUV844	0.0055	Exceeds Limit	0.1200	Passed
Sir John A. Macdonald High School	Science Lab tap 4 room 2056	MUV845	0.0069	Exceeds Limit	0.1400	Passed
Sir John A. Macdonald High School	Science Lab tap 5 room 2056	MUV846	0.0006	Passed	0.0930	Passed
Sir John A. Macdonald High School	Chem lab tap 1 room 2062	MUV847	0.0014	Passed	0.2100	Passed
Sir John A. Macdonald High School	Chem lab tap 2 room 2062	MUV848	0.0500	Exceeds Limit	0.2300	Passed
Sir John A. Macdonald High School	Chem lab tap 3 room 2062	MUV849	0.0014	Passed	0.2300	Passed
Sir John A. Macdonald High School	Chem lab tap 4 room 2062	MUV850	0.0005	Passed	0.1700	Passed
Sir John A. Macdonald High School	Chem lab tap 5 room 2062	MUV851	0.0072	Exceeds Limit	0.2400	Passed
Sir John A. Macdonald High School	Chem lab tap 6 room 2062	MUV852	0.1200	Exceeds Limit	0.7600	Passed
Sir John A. Macdonald High School	Chem lab tap 7 room 2062	MUV853	0.0017	Passed	0.2100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sir John A. Macdonald High School	Chem lab tap 8 room 2062	MUV854	0.0088	Exceeds Limit	0.2600	Passed
Sir John A. Macdonald High School	Chem lab tap 9 room 2062	MUV855	0.0029	Passed	0.1400	Passed
Sir John A. Macdonald High School	Chem lab tap 10 room 2062	MUV856	0.0250	Exceeds Limit	0.1300	Passed
Sir John A. Macdonald High School	Chem lab prep room tap room 2064	MUV857	0.0019	Passed	0.0460	Passed
Sir John A. Macdonald High School	Chem lab tap 1 room 2067	MUV858	0.0069	Exceeds Limit	0.1900	Passed
Sir John A. Macdonald High School	Chem lab tap 2 room 2067	MUV859	0.0077	Exceeds Limit	0.1800	Passed
Sir John A. Macdonald High School	Chem lab tap 3 room 2067	MUV860	0.0050	Passed	0.2600	Passed
Sir John A. Macdonald High School	Chem lab tap 4 room 2067	MUV861	0.0350	Exceeds Limit	0.5400	Passed
Sir John A. Macdonald High School	Chem lab tap 5 room 2067	MUV862	0.0096	Exceeds Limit	0.1500	Passed
Sir John A. Macdonald High School	Chem lab tap 6 room 2067	MUV863	0.0042	Passed	0.2000	Passed
Sir John A. Macdonald High School	Chem lab tap 7 room 2067	MUV864	0.0007	Passed	0.4300	Passed
Sir John A. Macdonald High School	Chem lab tap 9 room 2067	MUV866	0.0075	Exceeds Limit	0.1600	Passed
Sir John A. Macdonald High School	Biology Lab tap 1 room 2068	MUV868	0.0072	Exceeds Limit	0.2900	Passed
Sir John A. Macdonald High School	Biology Lab tap 2 room 2068	MUV869	0.0007	Passed	0.3200	Passed
Sir John A. Macdonald High School	Biology Lab tap 3 room 2068	MUV870	0.0079	Exceeds Limit	0.3500	Passed
Sir John A. Macdonald High School	Biology Lab tap 4 room 2068	MUV871	0.0030	Passed	0.4000	Passed
Sir John A. Macdonald High School	Biology Lab tap 5 room 2068	MUV872	0.0028	Passed	0.3000	Passed
Sir John A. Macdonald High School	Chem lab tap 8 room 2067	MWG705	0.0019	Passed	0.3400	Passed
Sir John A. Macdonald High School	Chem lab tap 10 room 2067	MWG706	0.0010	Passed	0.2600	Passed
Sir John A. Macdonald High School	Skilled trades room WR tap	MWG707	0.0014	Passed	0.2500	Passed
Sir John A. Macdonald High School	Skilled trades Janitors tap	MWG708	0.0036	Passed	0.2200	Passed
Sir John A. Macdonald High School	Skilled trades wash sink tap	MWG709	0.0018	Passed	0.3800	Passed
Sir John A. Macdonald High School	Science Lab tap 1 room 2066	MWH956	0.0073	Exceeds Limit	0.3100	Passed
Sir John A. Macdonald High School	Science Lab tap 2 room 2066	MWH957	0.0035	Passed	0.2300	Passed
Sir John A. Macdonald High School	Science Lab tap 3 room 2066	MWH958	0.0069	Exceeds Limit	0.5600	Passed
Sir John A. Macdonald High School	Science Lab tap 4 room 2066	MWH959	0.0067	Exceeds Limit	0.5200	Passed
Sir John A. Macdonald High School	Science Lab tap 3 room 2063	MWH960	0.0074	Exceeds Limit	0.3600	Passed
Sir John A. Macdonald High School	Science Lab tap 4 room 2063	MWH961	0.0048	Passed	0.5400	Passed
Sir John A. Macdonald High School	Science Lab tap 5 room 2063	MWH962	0.0069	Exceeds Limit	0.3400	Passed
Sir John A. Macdonald High School	Science Lab tap 1 room 2058	MWH963	0.0300	Exceeds Limit	0.5600	Passed
Sir John A. Macdonald High School	Science Lab tap 2 room 2058	MWH964	0.0160	Exceeds Limit	0.4900	Passed
Sir John A. Macdonald High School	Science Lab tap 3 room 2058	MWH965	0.0028	Passed	0.2100	Passed
Sir John A. Macdonald High School	Science Lab tap 4 room 2058	MWH966	0.0052	Exceeds Limit	0.3100	Passed
Sir John A. Macdonald High School	Science Lab tap 5 room 2058	MWH967	0.0064	Exceeds Limit	0.4300	Passed
Sir John A. Macdonald High School	Physics lab tap 1 room 2057	MWH968	0.0075	Exceeds Limit	0.1900	Passed
Sir John A. Macdonald High School	Physics lab tap 2 room 2057	MWH969	0.0022	Passed	0.1300	Passed
Sir John A. Macdonald High School	Physics lab tap 3 room 2057	MWH970	0.0069	Exceeds Limit	0.4200	Passed
Sir John A. Macdonald High School	Physics lab tap 4 room 2057	MWH971	0.0089	Exceeds Limit	0.4300	Passed
Sir John A. Macdonald High School	Physics lab tap 5 room 2057	MWH972	0.0018	Passed	0.2000	Passed
Sir John A. Macdonald High School	Nutrition Lab tap 1 room 2055	MWH973	0.0000	Passed	0.1800	Passed
Sir John A. Macdonald High School	Nutrition Lab tap 2 room 2055	MWH974	0.0006	Passed	0.1400	Passed
Sir John A. Macdonald High School	Nutrition Lab tap 3 room 2055	MWH975	0.0000	Passed	0.1400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sir John A. Macdonald High School	Nutrition Lab tap 4 room 2055	MWH976	0.0000	Passed	0.1700	Passed
Sir John A. Macdonald High School	Kitchen tap 1 room 2045	MWH977	0.0009	Passed	0.1400	Passed
Sir John A. Macdonald High School	Kitchen tap 2 room 2045	MWH978	0.0007	Passed	0.0100	Passed
Sir John A. Macdonald High School	Kitchen tap 3 room 2045	MWH979	0.0019	Passed	0.0230	Passed
Sir John A. Macdonald High School	Kitchen tap 4 room 2045	MWH980	0.0012	Passed	0.0130	Passed
Sir John A. Macdonald High School	Kitchen tap 5 room 2045	MWH981	0.0023	Passed	0.6600	Passed
Sir John A. Macdonald High School	Library tap	MWH982	0.0000	Passed	0.4100	Passed
Sir John A. Macdonald High School	Youth centre WR tap room 1021	MWH983	0.0020	Passed	0.1700	Passed
Sir John A. Macdonald High School	1st floor Male WR tap 1	MWH984	0.0150	Exceeds Limit	0.3700	Passed
Sir John A. Macdonald High School	1st floor Male WR tap 2	MWH985	0.0007	Passed	0.1700	Passed
Sir John A. Macdonald High School	Staff WR tap	MWH986	0.0021	Passed	0.1800	Passed
Sir John A. Macdonald High School	JC tap by room 1016	MWH987	0.0014	Passed	0.1900	Passed
Sir John A. Macdonald High School	CR tap room 1016	MWH988	0.0083	Exceeds Limit	0.2100	Passed
Sir John A. Macdonald High School	Staff WR tap	MWH989	0.0210	Exceeds Limit	0.4600	Passed
Sir John A. Macdonald High School	1st floor girls WR tap 1	MWH990	0.0000	Passed	0.2000	Passed
Sir John A. Macdonald High School	1st floor girls WR tap 2	MWH991	0.0011	Passed	0.4100	Passed
Sir John A. Macdonald High School	Gym office WR tap	MWH992	0.0035	Passed	0.3200	Passed
Sir John A. Macdonald High School	Fountain by gym	NMW041	0.0004	Passed	0.0700	Passed
Sir John A. Macdonald High School	Gym office WR tap	MWH994	0.0011	Passed	0.1500	Passed
Sir John A. Macdonald High School	Girls WR tap 1 by cafeteria	MWH995	0.0021	Passed	0.0900	Passed
Sir John A. Macdonald High School	Girls WR tap 2 by cafeteria	MWH996	0.0012	Passed	0.1500	Passed
Sir John A. Macdonald High School	Fountain by cafeteria	MWH997	0.0007	Passed	0.7400	Passed
Sir John A. Macdonald High School	Boys WR tap 1 by cafeteria	MWH999	0.0014	Passed	0.1300	Passed
Sir John A. Macdonald High School	Boys WR tap 2 by cafeteria	MWI000	0.0008	Passed	0.1100	Passed
Sir John A. Macdonald High School	Tech Ed. Tap room 1088	MWI001	0.0048	Passed	0.3000	Passed
Sir John A. Macdonald High School	CR tap room 1109	MWI003	0.0010	Passed	0.1600	Passed
Sir John A. Macdonald High School	Staff kitchen tap 1101	MWI004	0.0007	Passed	0.1200	Passed
Sir John A. Macdonald High School	Staff WR 1 tap room 1101	MWI005	0.0009	Passed	0.1700	Passed
Sir John A. Macdonald High School	Staff WR 2 tap room 1101	MWI006	0.0015	Passed	0.1800	Passed
Sir John A. Macdonald High School	Admin WR tap room 1040	MWI007	0.0010	Passed	0.0900	Passed
Sir John A. Macdonald High School	Chem Lab tap 8 room 2067	NAO679	0.0022	Passed	0.1700	Passed
Sir John A. Macdonald High School	Chem Lab tap 10 room 2067	NAO680	0.0082	Exceeds Limit	0.2900	Passed
Sir John A. Macdonald High School	Chem Lab tap 1 room 2063	NAO681	0.0074	Exceeds Limit	0.4100	Passed
Sir John A. Macdonald High School	Chem Lab tap 2 room 2063	NAO682	0.0064	Exceeds Limit	0.3600	Passed
Sir John A. Macdonald High School	Girls locker room tap room 1031	NAO683	0.0140	Exceeds Limit	0.4000	Passed
Sir John A. Macdonald High School	Boys locker room tap room 1032	NAO684	0.0083	Exceeds Limit	0.2300	Passed
Sir John A. Macdonald High School	Gym office WR tap room 1033	NAO685	0.0370	Exceeds Limit	0.6100	Passed
Sir John A. Macdonald High School	Fountain by room 1033	NAO686	0.0000	Passed	0.4100	Passed
Sir John A. Macdonald High School	Admin WR tap room 1040	NAO687	0.0028	Passed	0.1000	Passed
Sir Robert Borden Junior High School	2nd floor TR tap	NMD774	0.0007	Passed	0.5800	Passed
Sir Robert Borden Junior High School	CR tap room 201	MWG491	0.0120	Exceeds Limit	0.1500	Passed
Sir Robert Borden Junior High School	Art room tap room 202	MWG492	0.0180	Exceeds Limit	0.3400	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sir Robert Borden Junior High School	CR tap room 203	NMD776	0.0007	Passed	0.0250	Passed
Sir Robert Borden Junior High School	JC tap in air heating room	MWG494	0.0019	Passed	0.0520	Passed
Sir Robert Borden Junior High School	Fountain across from room 218	NMD773	0.0028	Passed	0.0190	Passed
Sir Robert Borden Junior High School	Female staff WR in girls WR	MWG496	0.1900	Exceeds Limit	0.3800	Passed
Sir Robert Borden Junior High School	2nd floor Girls WR tap 1	MWG497	0.8200	Exceeds Limit	1.3000	Passed
Sir Robert Borden Junior High School	2nd floor Girls WR tap 2	MWG498	0.4400	Exceeds Limit	1.3000	Passed
Sir Robert Borden Junior High School	2nd floor Girls WR tap 3	MWG499	0.0360	Exceeds Limit	0.2200	Passed
Sir Robert Borden Junior High School	2nd floor Girls WR tap 4	MWG500	0.1200	Exceeds Limit	0.4100	Passed
Sir Robert Borden Junior High School	2nd floor male staff WR	MWG501	0.1900	Exceeds Limit	0.1200	Passed
Sir Robert Borden Junior High School	2nd floor male WR tap 1	MWG502	0.0021	Passed	0.1100	Passed
Sir Robert Borden Junior High School	2nd floor male WR tap 2	MWG503	0.0800	Exceeds Limit	0.2300	Passed
Sir Robert Borden Junior High School	2nd floor male WR tap 3	MWG504	0.0370	Exceeds Limit	0.2900	Passed
Sir Robert Borden Junior High School	WR 1 tap inside guidance room	MWG505	0.0870	Exceeds Limit	0.4300	Passed
Sir Robert Borden Junior High School	WR 2 tap inside guidance room	MWG506	0.0980	Exceeds Limit	0.3400	Passed
Sir Robert Borden Junior High School	Wood shop tap	MWG507	0.5900	Exceeds Limit	2.1000	Exceeds Limit
Sir Robert Borden Junior High School	CR tap room beside wood shop	MWG508	0.0210	Exceeds Limit	0.7400	Passed
Sir Robert Borden Junior High School	Science room tap	MWG509	0.0180	Exceeds Limit	1.5000	Passed
Sir Robert Borden Junior High School	Cafeteria/kitchen single compartment sink tap	NMD077	0.0006	Passed	0.0600	Passed
Sir Robert Borden Junior High School	Cafeteria/kitchen double compartment sink tap	NMD078	0.0006	Passed	0.0590	Passed
Sir Robert Borden Junior High School	Girls gym teacher WR tap	MWG512	0.0600	Exceeds Limit	1.0000	Passed
Sir Robert Borden Junior High School	Boys gym teacher WR tap	MWG513	0.0160	Exceeds Limit	0.4800	Passed
Sir Robert Borden Junior High School	Fountain beside boys WR	MWG514	0.0440	Exceeds Limit	0.3200	Passed
Sir Robert Borden Junior High School	Boys staff WR beside boys WR	MWG515	0.0059	Exceeds Limit	0.1600	Passed
Sir Robert Borden Junior High School	1st floor boys WR tap 1	MWG516	0.0018	Passed	0.0520	Passed
Sir Robert Borden Junior High School	1st floor boys WR tap 2	MWG517	0.0045	Passed	0.1900	Passed
Sir Robert Borden Junior High School	1st floor boys WR tap 3	MWG518	0.0028	Passed	0.1600	Passed
Sir Robert Borden Junior High School	JC tap by boys WR	MWG519	0.0043	Passed	0.0210	Passed
Sir Robert Borden Junior High School	Fountain by 1st floor girls WR	MWG520	0.0037	Passed	0.1800	Passed
Sir Robert Borden Junior High School	1st floor girls WR tap 1	MWG521	0.0022	Passed	0.3300	Passed
Sir Robert Borden Junior High School	1st floor girls WR tap 2	MWG522	0.0120	Exceeds Limit	0.3400	Passed
Sir Robert Borden Junior High School	1st floor girls WR tap 3	MWG523	0.0040	Passed	0.2100	Passed
Sir Robert Borden Junior High School	1st floor girls WR tap 4	MWG524	0.0100	Exceeds Limit	0.1900	Passed
Sir Robert Borden Junior High School	Female staff WR in girls WR	MWG525	0.0025	Passed	0.0390	Passed
Smokey Drive Elementary School	Staff room WR #2 tap	MOM564	0.0023	Passed	0.0370	Passed
Smokey Drive Elementary School	Staff room kitchen tap	MOM565	0.0042	Passed	0.1000	Passed
Smokey Drive Elementary School	CR tap room 3	MOM566	0.0330	Exceeds Limit	0.2700	Passed
Smokey Drive Elementary School	Fountain by room 3	MOM567	0.0012	Passed	0.1800	Passed
Smokey Drive Elementary School	Boys WR tap 1	MOM568	0.0046	Passed	0.0470	Passed
Smokey Drive Elementary School	Boys WR tap 2	MOM569	0.0020	Passed	0.0380	Passed
Smokey Drive Elementary School	Boys WR tap 3	MOM570	0.0020	Passed	0.0340	Passed
Smokey Drive Elementary School	Girls WR Tap 1	MOM571	0.0043	Passed	0.0400	Passed
Smokey Drive Elementary School	Girls WR Tap 2	MOM572	0.0180	Exceeds Limit	0.0940	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Smokey Drive Elementary School	Girls WR Tap 3	MOM573	0.0340	Exceeds Limit	0.0900	Passed
Smokey Drive Elementary School	CR tap room 212	MOM607	0.0110	Exceeds Limit	0.1400	Passed
Smokey Drive Elementary School	Fountain by room 205	MOM608	0.0027	Passed	0.3600	Passed
Smokey Drive Elementary School	Boys WR Tap 1	MOM609	0.0069	Exceeds Limit	0.0390	Passed
Smokey Drive Elementary School	Boys WR Tap 2	MOM610	0.0000	Passed	0.0044	Passed
Smokey Drive Elementary School	Boys WR Tap 3	MOM611	0.0049	Passed	0.0210	Passed
Smokey Drive Elementary School	Boys WR Tap 4	MOM612	0.0073	Exceeds Limit	0.0240	Passed
Smokey Drive Elementary School	Girls WR Tap 1	MOM613	0.0061	Exceeds Limit	0.0310	Passed
Smokey Drive Elementary School	Girls WR Tap 2	MOM614	0.0063	Exceeds Limit	0.2700	Passed
Smokey Drive Elementary School	Girls WR Tap 3	MOM615	0.0063	Exceeds Limit	0.0540	Passed
Smokey Drive Elementary School	Girls WR Tap 4	MOM616	0.0400	Exceeds Limit	0.1500	Passed
Smokey Drive Elementary School	JC tap	MOM617	0.0005	Passed	0.0300	Passed
Smokey Drive Elementary School	CR WR tap room 101	MQK077	0.0018	Passed	0.1200	Passed
Smokey Drive Elementary School	CR WR tap room 102	MQK078	0.0060	Exceeds Limit	0.0750	Passed
Smokey Drive Elementary School	JC tap by room 102	MQK079	0.0000	Passed	0.0320	Passed
Smokey Drive Elementary School	Fountain by room 104	MQK080	0.0000	Passed	0.0250	Passed
South Woodside School	JC tap room 7	MYH220	0.0033	Passed	0.2600	Passed
South Woodside School	CR tap 1 (multi-purpose room)	MYH222	0.0082	Exceeds Limit	0.3000	Passed
South Woodside School	CR tap 2 (multi-purpose room)	MYH223	0.0160	Exceeds Limit	0.8700	Passed
South Woodside School	Boys WR tap 1 in Rec centre	MYH224	0.0008	Passed	0.0940	Passed
South Woodside School	Boys WR tap 2 in Rec centre	MYH225	0.0016	Passed	0.0890	Passed
South Woodside School	Girls WR tap 1 in Rec centre	MYH226	0.0024	Passed	0.4900	Passed
South Woodside School	Girls WR tap 2 in Rec centre	MYH227	0.0029	Passed	0.5200	Passed
South Woodside School	Fountain in rec centre	MYH228	0.0007	Passed	0.6200	Passed
South Woodside School	Staff WR tap room 14	MYH232	0.0078	Exceeds Limit	0.3200	Passed
South Woodside School	Staff WR tap room 15	MYH233	0.0007	Passed	0.3500	Passed
South Woodside School	Hand Washing sink in room 17	MYH234	0.0013	Passed	0.3100	Passed
South Woodside School	CR tap room 28	MYH235	0.0000	Passed	0.1100	Passed
South Woodside School	CR tap room 33	MYH236	0.0000	Passed	0.1000	Passed
South Woodside School	CR tap room 36	MYH237	0.0017	Passed	0.9600	Passed
South Woodside School	Girls WR tap 1 room 34	MYH238	0.0016	Passed	0.1700	Passed
South Woodside School	Girls WR tap 2 room 34	MYH239	0.0008	Passed	0.1600	Passed
South Woodside School	Girls WR tap 3 room 34	MYH240	0.0026	Passed	0.1500	Passed
South Woodside School	Girls WR tap 4 room 34	MYH241	0.0013	Passed	0.1200	Passed
South Woodside School	Girls WR tap 5 room 34	MYH242	0.0100	Exceeds Limit	0.1900	Passed
South Woodside School	Fountain by room 32	NMK032	0.0008	Passed	0.0170	Passed
South Woodside School	JC tap room 32	MYH244	0.0000	Passed	0.0390	Passed
South Woodside School	Boys WR tap 1 room 31	MYH245	0.0010	Passed	0.2200	Passed
South Woodside School	Boys WR tap 2 room 31	MYH246	0.0031	Passed	0.1700	Passed
South Woodside School	Boys WR tap 3 room 31	MYH247	0.0017	Passed	0.2500	Passed
South Woodside School	Fountain by room 26	NMK033	0.0004	Passed	0.0680	Passed
South Woodside School	GN WR tap room 5	MYH249	0.0021	Passed	0.3000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
South Woodside School	Library tap room 3	NBT449	0.7500	Exceeds Limit	1.0000	Passed
South Woodside School	Caretaker tap room 5	NBT450	0.0080	Exceeds Limit	0.1500	Passed
South Woodside School	Staff room kitchen tap room 9	NMK034	0.0004	Passed	0.0200	Passed
South Woodside School	Boys WR tap 1 near room 26	NBT453	0.1400	Exceeds Limit	1.1000	Passed
South Woodside School	Boys WR tap 2 near room 26	NBT454	0.0530	Exceeds Limit	0.8200	Passed
South Woodside School	Boys WR tap 3 near room 26	NBT455	0.0035	Passed	0.3900	Passed
Southdale - North Woodside Elementary School	Fountain by Rm 18	NNS331	0.0600	Exceeds Limit	3.6000	Exceeds Limit
Southdale - North Woodside Elementary School	CR WR tap room 23	NNS332	0.0032	Passed	0.0440	Passed
Southdale - North Woodside Elementary School	CR tap Room 23	NNS333	0.0010	Passed	0.0520	Passed
Southdale - North Woodside Elementary School	Fountain by Rm 22	NNS334	0.0069	Exceeds Limit	0.9400	Passed
Southdale - North Woodside Elementary School	Boys WR tap 1 by Rm 22	NNS335	0.0810	Exceeds Limit	1.3000	Passed
Southdale - North Woodside Elementary School	Boys WR tap 2 by Rm 22	NNS336	0.3200	Exceeds Limit	2.5000	Exceeds Limit
Southdale - North Woodside Elementary School	Boys WR tap 3 by Rm 22	NNS337	0.7400	Exceeds Limit	3.5000	Exceeds Limit
Southdale - North Woodside Elementary School	Girls WR tap 1 by Rm 22	NNS338	0.0270	Exceeds Limit	0.7100	Passed
Southdale - North Woodside Elementary School	Girls WR tap 2 by Rm 22	NNS339	0.0390	Exceeds Limit	0.8000	Passed
Southdale - North Woodside Elementary School	Girls WR tap 3 by Rm 22	NNS340	0.0860	Exceeds Limit	1.8000	Passed
Southdale - North Woodside Elementary School	JC tap by Girls WR	NNS341	0.0006	Passed	0.0410	Passed
Springvale Elementary School	Fountain by room 304	MSA197	0.0024	Passed	0.9300	Passed
Springvale Elementary School	Boys WR tap 1 by room 304	MSA198	0.0007	Passed	0.0480	Passed
Springvale Elementary School	Boys WR tap 2 by room 304	MSA199	0.0007	Passed	0.0440	Passed
Springvale Elementary School	Boys WR tap 3 by room 304	MSA200	0.0007	Passed	0.0460	Passed
Springvale Elementary School	WR tap in social worker room	MSA201	0.0014	Passed	0.1400	Passed
Springvale Elementary School	WR tap in early literacy room	MSA202	0.0008	Passed	0.0690	Passed
Springvale Elementary School	JC tap by room 314	MSA203	0.0065	Exceeds Limit	0.1400	Passed
Springvale Elementary School	CR tap room 314	MSA204	0.0010	Passed	0.1800	Passed
Springvale Elementary School	Girls WR tap 1 by room 309	MSA205	0.0044	Passed	0.1500	Passed
Springvale Elementary School	Girls WR tap 2 by room 309	MSA206	0.0008	Passed	0.0920	Passed
Springvale Elementary School	GN WR tap room 308	MSA208	0.0040	Passed	0.0580	Passed
Springvale Elementary School	Staff room kitchen tap room 204	MSA209	0.0006	Passed	0.0510	Passed
Springvale Elementary School	Fountain by room 204	MSA210	0.0014	Passed	0.4700	Passed
Springvale Elementary School	Girls WR tap 1 by room 204	MSA211	0.0045	Passed	0.2300	Passed
Springvale Elementary School	Girls WR tap 2 by room 204	MSA212	0.0010	Passed	0.0440	Passed
Springvale Elementary School	Girls WR tap 3 by room 204	MSA213	0.0004	Passed	0.0260	Passed
Springvale Elementary School	Boys WR tap 1 by gym	MSA214	0.0000	Passed	0.0360	Passed
Springvale Elementary School	Boys WR tap 2 by gym	MSA215	0.0004	Passed	0.0330	Passed
Springvale Elementary School	JC tap by room 207	MSA216	0.0006	Passed	0.0190	Passed
Springvale Elementary School	Fountain by gym	MSA218	0.0004	Passed	0.1800	Passed
Springvale Elementary School	CR tap room 103	MSA219	0.0016	Passed	0.4400	Passed
Springvale Elementary School	Crawl space under stairs tap	MSA220	0.0007	Passed	0.3000	Passed
Springvale Elementary School	Boys WR tap room 103	MSA221	0.0024	Passed	0.0780	Passed
Springvale Elementary School	Girls WR tap by room 103	MSA222	0.0011	Passed	0.0580	Passed
Springvale Elementary School	CR tap room 106	MSA223	0.0049	Passed	0.2100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Springvale Elementary School	CR tap room 109	MSA224	0.0013	Passed	0.2200	Passed
Springvale Elementary School	Fountain by stairs	MSA225	0.0030	Passed	0.4900	Passed
Springvale Elementary School	Principals office tap room 218	MSP495	0.0032	Passed	0.0600	Passed
Springvale Elementary School	Girls WR tap 3 by room 309	NFE850	0.0040	Passed	0.0410	Passed
St. Agnes Junior High School	Science lab tap 1 room 10	MSA281	0.0024	Passed	0.2100	Passed
St. Agnes Junior High School	Science lab tap 2 room 10	MSA282	0.0060	Exceeds Limit	0.1300	Passed
St. Agnes Junior High School	Girls WR tap 1	MSA283	0.0055	Exceeds Limit	0.0280	Passed
St. Agnes Junior High School	Girls WR tap 2	MSA284	0.0014	Passed	0.0240	Passed
St. Agnes Junior High School	Girls WR tap 3	MSA285	0.0010	Passed	0.0170	Passed
St. Agnes Junior High School	Girls WR tap 4	MSA286	0.0006	Passed	0.0160	Passed
St. Agnes Junior High School	JC tap	MSA287	0.0000	Passed	0.0031	Passed
St. Agnes Junior High School	staff WR tap	MSA288	0.0000	Passed	0.0110	Passed
St. Agnes Junior High School	GN WR tap	MSA289	0.0068	Exceeds Limit	0.0430	Passed
St. Agnes Junior High School	Boys WR tap 1	MSA290	0.0035	Passed	0.1400	Passed
St. Agnes Junior High School	Boys WR tap 2	MSA291	0.0014	Passed	0.0900	Passed
St. Agnes Junior High School	Boys WR tap 3	MSA292	0.0000	Passed	0.0150	Passed
St. Agnes Junior High School	Boys WR tap 4	MSA293	0.0000	Passed	0.0087	Passed
St. Agnes Junior High School	Staff learning centre tap	MSA294	0.0011	Passed	0.0720	Passed
St. Agnes Junior High School	Staff learning centre WR tap	MSA295	0.0009	Passed	0.0500	Passed
St. Agnes Junior High School	Fountain by staff room	MSA296	0.0020	Passed	0.2700	Passed
St. Agnes Junior High School	Art room tap 1 room 3	MSA297	0.0010	Passed	0.3100	Passed
St. Agnes Junior High School	Art room tap 2 room 3	MSA298	0.0000	Passed	0.0710	Passed
St. Agnes Junior High School	Fountain by gym hall	MSA299	0.0017	Passed	0.1200	Passed
St. Agnes Junior High School	Girls locker room tap 1	MSA300	0.0110	Exceeds Limit	0.2100	Passed
St. Agnes Junior High School	Girls locker room tap 2	MSA301	0.0013	Passed	0.0290	Passed
St. Agnes Junior High School	Boys Locker room tap 1	MSA302	0.0068	Exceeds Limit	0.1200	Passed
St. Agnes Junior High School	Boys Locker room tap 2	MSA303	0.0027	Passed	0.0560	Passed
St. Agnes Junior High School	Library tap , 2nd door on the left	MSA304	0.0057	Exceeds Limit	0.2800	Passed
St. Agnes Junior High School	Tech ed tap room 15	MSA305	0.0021	Passed	0.0510	Passed
St. Agnes Junior High School	Family studies tap 1 room 15	NKX251	0.0007	Passed	0.0280	Passed
St. Agnes Junior High School	Family studies tap 2 room 15	MSA307	0.0021	Passed	0.0720	Passed
St. Agnes Junior High School	Family studies tap 3 room 15	NKX252	0.0012	Passed	0.0250	Passed
St. Agnes Junior High School	Family studies tap 4 room 15	NKX253	0.0013	Passed	0.0290	Passed
St. Agnes Junior High School	CR tap room 16	NKX254	0.0010	Passed	0.0310	Passed
St. Agnes Junior High School	CR tap room 18	MSA311	0.0032	Passed	0.0820	Passed
St. Agnes Junior High School	2nd floor girls WR tap 1	MSA312	0.0035	Passed	0.0740	Passed
St. Agnes Junior High School	2nd floor girls WR tap 2	MSA313	0.0012	Passed	0.0570	Passed
St. Agnes Junior High School	2nd floor girls WR tap 3	MSA314	0.0038	Passed	0.0190	Passed
St. Agnes Junior High School	2nd floor girls WR tap 4	MSA315	0.0032	Passed	0.0250	Passed
St. Agnes Junior High School	2nd floor girls WR tap 5	MSA316	0.0014	Passed	0.0110	Passed
St. Agnes Junior High School	2nd floor boys WR tap 1	MSA317	0.0010	Passed	0.0089	Passed
St. Agnes Junior High School	2nd floor boys WR tap 2	MSA318	0.0008	Passed	0.0086	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Agnes Junior High School	2nd floor boys WR tap 3	MSA319	0.0006	Passed	0.0086	Passed
St. Agnes Junior High School	2nd floor boys WR tap 4	MSA320	0.0006	Passed	0.0097	Passed
St. Agnes Junior High School	2nd floor boys WR tap 5	MSA339	0.0015	Passed	0.1200	Passed
St. Agnes Junior High School	JC tap 2nd floor	MSA340	0.0021	Passed	0.0930	Passed
St. Agnes Junior High School	2nd floor female staff WR tap	MSA341	0.0006	Passed	0.0230	Passed
St. Agnes Junior High School	2nd floor male staff WR tap	MSA342	0.0000	Passed	0.0230	Passed
St. Agnes Junior High School	2nd floor Resource room tap room 19	MSA343	0.0007	Passed	0.0170	Passed
St. Catherine's Elementary School	Staff WR tap room 216	MSG967	0.0004	Passed	0.0150	Passed
St. Catherine's Elementary School	Principals office tap room 218	MSG968	0.0004	Passed	0.0061	Passed
St. Catherine's Elementary School	Boys WR tap 1 room 229	NJI590	0.0004	Passed	0.0160	Passed
St. Catherine's Elementary School	Boys WR tap 2 room 229	MSG970	0.0025	Passed	0.1300	Passed
St. Catherine's Elementary School	Boys WR tap 3 room 229	MSG971	0.0024	Passed	0.0560	Passed
St. Catherine's Elementary School	Boys staff WR by room 229	MSG972	0.0020	Passed	0.0260	Passed
St. Catherine's Elementary School	Fountain outside boys WR	NJI589	0.0004	Passed	0.0012	Passed
St. Catherine's Elementary School	Girls WR tap 1 room 227	MSG974	0.0032	Passed	0.1400	Passed
St. Catherine's Elementary School	Girls WR tap 2 room 227	MSG975	0.0004	Passed	0.0130	Passed
St. Catherine's Elementary School	Girls WR tap 3 room 227	MSG976	0.0023	Passed	0.0330	Passed
St. Catherine's Elementary School	Girls WR tap 4 room 227	MSG977	0.0004	Passed	0.0048	Passed
St. Catherine's Elementary School	CR tap room 221	NJI591	0.0004	Passed	0.0160	Passed
St. Catherine's Elementary School	VP office tap room 217	MSG979	0.0010	Passed	0.0750	Passed
St. Catherine's Elementary School	Boys WR tap 1 room 215B	MSG980	0.0004	Passed	0.0250	Passed
St. Catherine's Elementary School	Boys WR tap 2 room 215B	MSG981	0.0004	Passed	0.0270	Passed
St. Catherine's Elementary School	Fountain after boys WR	MSG982	0.0030	Passed	0.4500	Passed
St. Catherine's Elementary School	Girls WR tap 1 room 215A	MSG983	0.0004	Passed	0.0620	Passed
St. Catherine's Elementary School	Girls WR tap 2 room 215A	MSG984	0.0004	Passed	0.0260	Passed
St. Catherine's Elementary School	JC tap by room 204	MSG985	0.0004	Passed	0.0040	Passed
St. Catherine's Elementary School	CR tap room 204	MSG986	0.0004	Passed	0.0360	Passed
St. Catherine's Elementary School	CR tap room 210	MSG987	0.0007	Passed	0.1600	Passed
St. Catherine's Elementary School	GN WR tap room 212	MSG988	0.0004	Passed	0.1200	Passed
St. Catherine's Elementary School	Fountain by gym	MSG989	0.0004	Passed	0.1200	Passed
St. Catherine's Elementary School	Girls WR tap 1 by room 106A	MSG990	0.0040	Passed	0.6700	Passed
St. Catherine's Elementary School	Girls WR tap 2 by room 106A	MSG991	0.0004	Passed	0.1000	Passed
St. Catherine's Elementary School	JC tap room 106A	MSG992	0.0004	Passed	0.0054	Passed
St. Catherine's Elementary School	Boys WR tap 1 room 108	MSG993	0.0004	Passed	0.0160	Passed
St. Catherine's Elementary School	Boys WR tap 2 room 108	MSG994	0.0004	Passed	0.0160	Passed
St. Catherine's Elementary School	Teachers WR tap room 108B	MSG995	0.0004	Passed	0.0051	Passed
St. Catherine's Elementary School	Pottery room 110 tap 1	MSG996	0.0004	Passed	0.0260	Passed
St. Catherine's Elementary School	Pottery room 110 tap 2	MSG997	0.0004	Passed	0.0230	Passed
St. Catherine's Elementary School	Boys WR tap 1 room 119	MSG998	0.0009	Passed	0.0880	Passed
St. Catherine's Elementary School	Boys WR tap 2 room 119	MSG999	0.0004	Passed	0.0200	Passed
St. Catherine's Elementary School	Boys WR tap 3 room 119	MSH000	0.0004	Passed	0.0150	Passed
St. Catherine's Elementary School	Male staff WR room 119	MSH001	0.0007	Passed	0.0070	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Catherine's Elementary School	Fountain between WR's	MSH002	0.0012	Passed	0.1600	Passed
St. Catherine's Elementary School	Girls staff WR room 117	MSH003	0.0000	Passed	0.0077	Passed
St. Catherine's Elementary School	Girls WR tap 1 room 117	MSH004	0.0000	Passed	0.0200	Passed
St. Catherine's Elementary School	Girls WR tap 2 room 117	MSH005	0.0000	Passed	0.0180	Passed
St. Catherine's Elementary School	Girls WR tap 3 room 117	MSH006	0.0000	Passed	0.0210	Passed
St. Catherine's Elementary School	CR tap room 107	MSH007	0.0000	Passed	0.0220	Passed
St. Catherine's Elementary School	Boiler room tap	MSH008	0.0008	Passed	0.0340	Passed
St. Catherine's Elementary School	Fountain after room 107	MSH009	0.0099	Exceeds Limit	1.6000	Passed
St. Joseph's-Alexander McKay Elementary School	JC tap room 207	MSP017	0.0010	Passed	0.0250	Passed
St. Joseph's-Alexander McKay Elementary School	Girls WR tap 1 by room 207	MSP018	0.0010	Passed	0.0510	Passed
St. Joseph's-Alexander McKay Elementary School	Girls WR tap 2 by room 207	MSP019	0.0000	Passed	0.0310	Passed
St. Joseph's-Alexander McKay Elementary School	Girls WR tap 3 by room 207	MSP020	0.0008	Passed	0.0280	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain by room 203	MSP021	0.0004	Passed	0.4700	Passed
St. Joseph's-Alexander McKay Elementary School	Staff WR tap room 205	MSP022	0.0069	Exceeds Limit	0.1400	Passed
St. Joseph's-Alexander McKay Elementary School	Staff room sink room 205	MSP023	0.0010	Passed	0.0420	Passed
St. Joseph's-Alexander McKay Elementary School	Boys WR tap 1 room 212	MSP024	0.0014	Passed	0.2500	Passed
St. Joseph's-Alexander McKay Elementary School	Boys WR tap 2 room 212	MSP025	0.0028	Passed	0.2300	Passed
St. Joseph's-Alexander McKay Elementary School	Boys WR tap 3 room 212	MSP026	0.0019	Passed	0.1600	Passed
St. Joseph's-Alexander McKay Elementary School	Boys WR tap 4 room 212	MSP027	0.0028	Passed	0.0870	Passed
St. Joseph's-Alexander McKay Elementary School	Staff room tap room 313	MSP028	0.0022	Passed	0.2000	Passed
St. Joseph's-Alexander McKay Elementary School	JC tap by room 306	MSP029	0.0004	Passed	0.0410	Passed
St. Joseph's-Alexander McKay Elementary School	CR tap room 306	MSP030	0.0004	Passed	0.0440	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain after room 306	MSP031	0.0045	Passed	0.7600	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain before room 302	MSP032	0.0049	Passed	0.3300	Passed
St. Joseph's-Alexander McKay Elementary School	CR tap room 302	MSP033	0.0038	Passed	0.1500	Passed
St. Joseph's-Alexander McKay Elementary School	Pre primary room tap	MSP034	0.0007	Passed	0.0690	Passed
St. Joseph's-Alexander McKay Elementary School	GN staff WR tap	MSP035	0.0028	Passed	0.0820	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain after room 401	MSP036	0.0013	Passed	0.5400	Passed
St. Joseph's-Alexander McKay Elementary School	Boys WR tap 1 by room 405	MSP037	0.0470	Exceeds Limit	0.2100	Passed
St. Joseph's-Alexander McKay Elementary School	Boys WR tap 2 by room 405	MSP038	0.0170	Exceeds Limit	0.1500	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain after boys WR	MSP039	0.2600	Exceeds Limit	27.0000	Exceeds Limit
St. Joseph's-Alexander McKay Elementary School	Girls WR tap 1 before room 406	MSP040	0.0045	Passed	0.1200	Passed
St. Joseph's-Alexander McKay Elementary School	Girls WR tap 2 before room 406	MSP041	0.0040	Passed	0.1100	Passed
St. Joseph's-Alexander McKay Elementary School	JC tap before room 406	MSP042	0.0004	Passed	0.0550	Passed
St. Joseph's-Alexander McKay Elementary School	Kitchen tap 1 room 406	NLK076	0.0045	Passed	0.1200	Passed
St. Joseph's-Alexander McKay Elementary School	GN WR tap 1 room 406	MSP044	0.0000	Passed	0.0012	Passed
St. Joseph's-Alexander McKay Elementary School	GN WR tap room 403	MSP045	0.0000	Passed	0.0170	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain after room 510	MSP046	0.0004	Passed	0.1900	Passed
St. Joseph's-Alexander McKay Elementary School	Caretakers office tap 1	MSP047	0.0070	Exceeds Limit	0.0220	Passed
St. Joseph's-Alexander McKay Elementary School	Caretakers office tap 2	MSP048	0.0004	Passed	0.0690	Passed
St. Joseph's-Alexander McKay Elementary School	Fountain outside room 103	NLK075	0.0004	Passed	0.0020	Passed
St. Margaret's Bay Elementary School	Girls WR tap 1 room 136	MPB504	0.0007	Passed	0.2000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Margaret's Bay Elementary School	Girls WR tap 2 room 136	MPB505	0.0017	Passed	0.1300	Passed
St. Margaret's Bay Elementary School	Girls WR tap 3 room 136	MPB506	0.0015	Passed	0.1500	Passed
St. Margaret's Bay Elementary School	boys WR Tap 1 room 134	MPB507	0.0076	Exceeds Limit	0.2900	Passed
St. Margaret's Bay Elementary School	boys WR Tap 2 room 134	MPB508	0.0012	Passed	0.1600	Passed
St. Margaret's Bay Elementary School	boys WR Tap 3 room 134	MPB509	0.0016	Passed	0.2100	Passed
St. Margaret's Bay Elementary School	Fountain by room 137	NMW035	0.0010	Passed	0.0500	Passed
St. Margaret's Bay Elementary School	Office WR tap room 184	MPB511	0.0010	Passed	0.2300	Passed
St. Margaret's Bay Elementary School	Health room tap room 189	MPB512	0.0024	Passed	0.2300	Passed
St. Margaret's Bay Elementary School	CR tap room 107	MPB513	0.0006	Passed	0.1300	Passed
St. Margaret's Bay Elementary School	GN WR tap room 108	MPB514	0.0029	Passed	0.2400	Passed
St. Margaret's Bay Elementary School	GN WR tap room 109	MPB515	0.0020	Passed	0.1400	Passed
St. Margaret's Bay Elementary School	CR tap room 110	MPB516	0.0012	Passed	0.1800	Passed
St. Margaret's Bay Elementary School	CR tap room 115 tap 1	MPB517	0.0006	Passed	0.1400	Passed
St. Margaret's Bay Elementary School	CR tap room 115 tap 2	MPB518	0.0011	Passed	0.1800	Passed
St. Margaret's Bay Elementary School	GN WR tap room 119	MPB519	0.0011	Passed	0.1300	Passed
St. Margaret's Bay Elementary School	Fountain by room 118	MPB520	0.0026	Passed	0.2600	Passed
St. Margaret's Bay Elementary School	CR kitchen tap room 118A	MPB521	0.0019	Passed	0.1300	Passed
St. Margaret's Bay Elementary School	CR tap 1 room 123	MPB522	0.0004	Passed	0.1800	Passed
St. Margaret's Bay Elementary School	CR tap 2 room 123	MPB523	0.0010	Passed	0.1900	Passed
St. Margaret's Bay Elementary School	CR tap room 154	MPB524	0.0008	Passed	0.1800	Passed
St. Margaret's Bay Elementary School	CR tap room 155	MPB525	0.0008	Passed	0.1600	Passed
St. Margaret's Bay Elementary School	CR room 157 tap 1	MPB526	0.0010	Passed	0.1500	Passed
St. Margaret's Bay Elementary School	CR room 157 tap 2	MPB527	0.0016	Passed	0.2200	Passed
St. Margaret's Bay Elementary School	Fountain by room 157	MPB528	0.0005	Passed	0.1700	Passed
St. Margaret's Bay Elementary School	Girls WR tap 1 room 164	MPB529	0.0035	Passed	0.1800	Passed
St. Margaret's Bay Elementary School	Girls WR tap 2 room 164	MPB530	0.0032	Passed	0.1600	Passed
St. Margaret's Bay Elementary School	Girls WR tap 3 room 164	MPB531	0.0023	Passed	0.2400	Passed
St. Margaret's Bay Elementary School	Boys WR tap 1 room 166	MPB532	0.0034	Passed	0.1400	Passed
St. Margaret's Bay Elementary School	Boys WR tap 2 room 166	MPB559	0.0018	Passed	0.1900	Passed
St. Margaret's Bay Elementary School	Boys WR tap 3 room 166	MPB560	0.0054	Exceeds Limit	0.1800	Passed
St. Margaret's Bay Elementary School	CR tap room 172	MPB565	0.0023	Passed	0.1500	Passed
St. Margaret's Bay Elementary School	CR tap room 170	MPB566	0.0014	Passed	0.1200	Passed
St. Margaret's Bay Elementary School	CR tap room 171	MPB567	0.0015	Passed	0.0990	Passed
St. Margaret's Bay Elementary School	CR tap room 174	MPB568	0.0450	Exceeds Limit	0.3200	Passed
St. Margaret's Bay Elementary School	CR tap room 179	MPB569	0.0012	Passed	0.1400	Passed
St. Margaret's Bay Elementary School	CR tap room 180	MPB570	0.0013	Passed	0.2100	Passed
St. Margaret's Bay Elementary School	WR tap 1 room 149	MPB575	0.0046	Passed	0.2700	Passed
St. Margaret's Bay Elementary School	WR tap 2 room 149	MPB581	0.0006	Passed	0.1000	Passed
St. Margaret's Bay Elementary School	WR tap 3 room 149	MPB582	0.0057	Exceeds Limit	0.2200	Passed
St. Margaret's Bay Elementary School	CR tap room 183	MPB583	0.0013	Passed	0.1600	Passed
St. Margaret's Bay Elementary School	CR tap room 139	MPB584	0.0015	Passed	0.3000	Passed
St. Margaret's Bay Elementary School	CR tap room 144	MPB585	0.0020	Passed	0.3300	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Margaret's Bay Elementary School	CR tap room 145	MPB586	0.0020	Passed	0.1800	Passed
St. Margaret's Bay Elementary School	CR tap room 133	MPB587	0.3000	Exceeds Limit	0.6200	Passed
St. Margaret's Bay Elementary School	CR tap room 1033	MPB591	0.0005	Passed	0.2400	Passed
St. Stephen's Elementary School	CR tap room 205	MSG933	0.0000	Passed	0.0720	Passed
St. Stephen's Elementary School	Girls WR tap 1 opposite room 16	MSG934	0.0000	Passed	0.1100	Passed
St. Stephen's Elementary School	Girls WR tap 2 opposite room 16	MSG935	0.0010	Passed	0.1200	Passed
St. Stephen's Elementary School	Girls WR tap 3 opposite room 16	MSG936	0.0018	Passed	0.1400	Passed
St. Stephen's Elementary School	Female staff WR tap	MSG937	0.0004	Passed	0.0430	Passed
St. Stephen's Elementary School	Fountain by room 16	MSG938	0.0026	Passed	0.4600	Passed
St. Stephen's Elementary School	JC tap opposite room 16	MSG939	0.0004	Passed	0.0370	Passed
St. Stephen's Elementary School	Male staff WR opposite room 14	MSG940	0.0070	Exceeds Limit	0.0390	Passed
St. Stephen's Elementary School	Boys WR tap 1 by room 14	MSG941	0.0004	Passed	0.0390	Passed
St. Stephen's Elementary School	Boys WR tap 2 by room 14	MSG942	0.0004	Passed	0.0390	Passed
St. Stephen's Elementary School	Gym office WR tap	MSG944	0.4400	Exceeds Limit	0.0360	Passed
St. Stephen's Elementary School	Gym office WR tap	MSG945	0.0004	Passed	0.0300	Passed
St. Stephen's Elementary School	PTA tap by gym	MSG946	0.0043	Passed	0.2400	Passed
St. Stephen's Elementary School	Boys WR tap 1 by gym	MSG947	0.0079	Exceeds Limit	0.3700	Passed
St. Stephen's Elementary School	Boys WR tap 2 by gym	MSG948	0.0013	Passed	0.1300	Passed
St. Stephen's Elementary School	Fountain by gym	MSG949	0.0036	Passed	0.1600	Passed
St. Stephen's Elementary School	JC tap by gym	MSG950	0.0004	Passed	0.0150	Passed
St. Stephen's Elementary School	Girls WR tap 1 by gym	MSG951	0.0000	Passed	0.0350	Passed
St. Stephen's Elementary School	Girls WR tap 2 by gym	MSG952	0.0000	Passed	0.0270	Passed
St. Stephen's Elementary School	CR tap room 1	MSG953	0.0000	Passed	0.0330	Passed
St. Stephen's Elementary School	Boys WR tap 1 by room 9	MSG956	0.0000	Passed	0.0130	Passed
St. Stephen's Elementary School	Boys WR tap 2 by room 9	MSG957	0.0000	Passed	0.0130	Passed
St. Stephen's Elementary School	Male staff WR tap by room 9	MSG958	0.0000	Passed	0.0060	Passed
St. Stephen's Elementary School	JC tap by room 7	MSG959	0.0000	Passed	0.0074	Passed
St. Stephen's Elementary School	Fountain across from room 7	NLV915	0.0088	Exceeds Limit	0.6300	Passed
St. Stephen's Elementary School	female staff WR tap by room 7	MSG961	0.0006	Passed	0.1700	Passed
St. Stephen's Elementary School	Girls WR tap 1 by room 7	MSG962	0.0022	Passed	0.0440	Passed
St. Stephen's Elementary School	Girls WR tap 2 by room 7	MSG963	0.0000	Passed	0.0200	Passed
St. Stephen's Elementary School	Fountain	MSP292	0.0000	Passed	0.0240	Passed
St. Stephen's Elementary School	GIRLS W/R TAP 3	MSP293	0.0000	Passed	0.1400	Passed
St. Stephen's Elementary School	STAFF W/R TAP	MSP294	0.0000	Passed	0.0290	Passed
St. Stephen's Elementary School	GEN W/R TAP	MSP295	0.0000	Passed	0.0390	Passed
St. Stephen's Elementary School	VP W/R TAP	MSP296	0.0000	Passed	0.0510	Passed
Sunnyside - Eaglewood Drive	CR tap room 207	MRU935	0.0009	Passed	0.0930	Passed
Sunnyside - Eaglewood Drive	Boys WR tap 1	MRU936	0.0000	Passed	0.0120	Passed
Sunnyside - Eaglewood Drive	Boys WR tap 2	MRU937	0.0000	Passed	0.0170	Passed
Sunnyside - Eaglewood Drive	JC tap across from room 202	MRU938	0.0000	Passed	0.0072	Passed
Sunnyside - Eaglewood Drive	Girls WR tap 1	MRU939	0.0000	Passed	0.0230	Passed
Sunnyside - Eaglewood Drive	Girls WR tap 2	MRU940	0.0000	Passed	0.0160	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sunnyside - Eaglewood Drive	Staff WR tap in staff room	MRU941	0.0000	Passed	0.0450	Passed
Sunnyside - Eaglewood Drive	Staff room kitchen tap	MRU942	0.0000	Passed	0.0630	Passed
Sunnyside - Eaglewood Drive	Music room tap	MRU943	0.0018	Passed	1.0000	Passed
Sunnyside - Eaglewood Drive	Work staff room tap	MRU944	0.0013	Passed	0.0440	Passed
Sunnyside - Eaglewood Drive	Work staff only room kitchen tap	MRU945	0.0012	Passed	1.3000	Passed
Sunnyside - Eaglewood Drive	staff WR	MRU946	0.0000	Passed	0.0058	Passed
Sunnyside - Eaglewood Drive	Boys WR tap 1 across from room 102	MRU947	0.0000	Passed	0.1200	Passed
Sunnyside - Eaglewood Drive	Boys WR tap 2 across from room 102	MRU948	0.0005	Passed	0.0440	Passed
Sunnyside - Eaglewood Drive	JC tap	MRU949	0.0010	Passed	0.0089	Passed
Sunnyside - Eaglewood Drive	Fountain by JC	MRU950	0.0000	Passed	0.0500	Passed
Sunnyside - Eaglewood Drive	Girls WR tap 1 across from room 103	MRU951	0.0000	Passed	0.0210	Passed
Sunnyside - Eaglewood Drive	Girls WR tap 2 across from room 103	MRU952	0.0000	Passed	0.0170	Passed
Sunnyside - Eaglewood Drive	main office tap	MRU953	0.0000	Passed	0.5100	Passed
Sunnyside - Fort Sackville	Boys WR tap 1	MRM803	0.0000	Passed	0.0620	Passed
Sunnyside - Fort Sackville	Boys WR tap 2	MRM804	0.0023	Passed	0.0670	Passed
Sunnyside - Fort Sackville	Staff kitchen tap	MRM805	0.0000	Passed	0.0590	Passed
Sunnyside - Fort Sackville	Pre primary WR tap 1	MRM806	0.0007	Passed	0.3500	Passed
Sunnyside - Fort Sackville	Pre primary WR tap 2	MRM807	0.0000	Passed	0.1000	Passed
Sunnyside - Fort Sackville	Storage room WR tap	MRM808	0.0011	Passed	0.1800	Passed
Sunnyside - Fort Sackville	JC tap	MRM809	0.0000	Passed	0.0570	Passed
Sunnyside - Fort Sackville	Fountain by JC	MRM810	0.0013	Passed	0.4700	Passed
Sunnyside - Fort Sackville	Girls WR tap 1	MRM811	0.0000	Passed	0.1600	Passed
Sunnyside - Fort Sackville	Girls WR tap 2	MRM812	0.0000	Passed	0.0610	Passed
Sycamore Lane Elementary School	2nd floor boys WR tap 1	MRD949	0.0093	Exceeds Limit	0.3000	Passed
Sycamore Lane Elementary School	2nd floor boys WR tap 2	MRD950	0.0046	Passed	0.2000	Passed
Sycamore Lane Elementary School	2nd floor boys WR tap 3	MRD951	0.0180	Exceeds Limit	0.2900	Passed
Sycamore Lane Elementary School	JC tap room 211	MRD952	0.0004	Passed	0.0066	Passed
Sycamore Lane Elementary School	Fountain by room 211	NJG794	0.0033	Passed	0.0920	Passed
Sycamore Lane Elementary School	Girls WR tap 1 room 211	MRD954	0.0068	Exceeds Limit	0.6500	Passed
Sycamore Lane Elementary School	Girls WR tap 2 room 211	MRD955	0.0086	Exceeds Limit	0.0840	Passed
Sycamore Lane Elementary School	Girls WR tap 3 room 211	MRD956	0.0027	Passed	0.0220	Passed
Sycamore Lane Elementary School	Girls WR tap 4 room 211	MRD957	0.0039	Passed	0.0380	Passed
Sycamore Lane Elementary School	Boys WR tap 1 room 110	MRD958	0.0066	Exceeds Limit	0.1900	Passed
Sycamore Lane Elementary School	Boys WR tap 2 room 110	MRD959	0.0008	Passed	0.0300	Passed
Sycamore Lane Elementary School	Boys WR tap 3 room 110	MRD960	0.0370	Exceeds Limit	0.5200	Passed
Sycamore Lane Elementary School	JC tap room 111	MRD961	0.0004	Passed	0.0063	Passed
Sycamore Lane Elementary School	Fountain by room 111	MRD962	0.0012	Passed	0.2800	Passed
Sycamore Lane Elementary School	Girls WR tap 1 room 112	MRD963	0.0340	Exceeds Limit	0.2200	Passed
Sycamore Lane Elementary School	Girls WR tap 2 room 112	MRD964	0.0140	Exceeds Limit	0.0620	Passed
Sycamore Lane Elementary School	Girls WR tap 3 room 112	MRD965	0.0160	Exceeds Limit	0.0940	Passed
Sycamore Lane Elementary School	Girls WR tap 4 room 112	MRD966	0.0047	Passed	0.0150	Passed
Sycamore Lane Elementary School	GN WR tap room 1036	MRD967	0.0036	Passed	0.1500	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Sycamore Lane Elementary School	CR tap room 101	MRD968	0.0006	Passed	0.0082	Passed
Sycamore Lane Elementary School	CR WR tap room 101	MRD969	0.0004	Passed	0.0088	Passed
Sycamore Lane Elementary School	Fountain by caretaker room	MRD970	0.0035	Passed	0.3600	Passed
Sycamore Lane Elementary School	Mechanical room tap room 121	MRD971	0.0004	Passed	0.0160	Passed
Sycamore Lane Elementary School	GN WR tap main office	MRD972	0.0080	Exceeds Limit	0.0690	Passed
Sycamore Lane Elementary School	Womens WR tap 1 main office	MRD973	0.0047	Passed	0.5900	Passed
Sycamore Lane Elementary School	Womens WR tap 2 main office	MRD974	0.0018	Passed	0.2100	Passed
Sycamore Lane Elementary School	Staff room kitchen tap	NJG795	0.0007	Passed	0.0170	Passed
Tallahassee Community School	JC tap inside fan room	MVY786	0.0021	Passed	0.2100	Passed
Tallahassee Community School	2nd floor boys WR tap 1 by storage room	MVY787	0.0067	Exceeds Limit	0.0990	Passed
Tallahassee Community School	2nd floor boys WR tap 2 by storage room	MVY788	0.0032	Passed	0.1300	Passed
Tallahassee Community School	2nd floor boys WR tap 3 by storage room	MVY789	0.0083	Exceeds Limit	0.1000	Passed
Tallahassee Community School	2nd floor boys WR tap 4 by storage room	MVY790	0.0120	Exceeds Limit	0.1300	Passed
Tallahassee Community School	Fountain beside boys WR	MVY791	0.0008	Passed	0.2800	Passed
Tallahassee Community School	CR tap 1 room 213	MVY792	0.0041	Passed	0.8900	Passed
Tallahassee Community School	CR tap 2 room 213	MVY793	0.1400	Exceeds Limit	0.0570	Passed
Tallahassee Community School	Fountain beside girls WR	MVY794	0.0040	Passed	0.6800	Passed
Tallahassee Community School	2nd floor Girls WR tap 1 by elevator	MVY795	0.0040	Passed	0.0580	Passed
Tallahassee Community School	2nd floor Girls WR tap 2 by elevator	MVY796	0.0210	Exceeds Limit	0.1200	Passed
Tallahassee Community School	2nd floor Girls WR tap 3 by elevator	MVY797	0.0024	Passed	0.1500	Passed
Tallahassee Community School	2nd floor Girls WR tap 4 by elevator	MVY798	0.0033	Passed	0.1000	Passed
Tallahassee Community School	2nd floor Girls WR tap 5 by elevator	MVY799	0.0004	Passed	0.0390	Passed
Tallahassee Community School	CR tap room 1	MVY800	0.0015	Passed	0.3200	Passed
Tallahassee Community School	Fountain beside service room	MVY801	0.0007	Passed	0.3100	Passed
Tallahassee Community School	Boys WR tap 1 in rec centre	MVY802	0.0088	Exceeds Limit	0.2100	Passed
Tallahassee Community School	Boys WR tap 2 in rec centre	MVY803	0.0019	Passed	0.2200	Passed
Tallahassee Community School	Sink tap in rec centre kitchen	MVY804	0.0000	Passed	0.0980	Passed
Tallahassee Community School	Girls WR tap 1 in rec centre	MVY805	0.0000	Passed	0.1200	Passed
Tallahassee Community School	Girls WR tap 2 in rec centre	MVY806	0.0004	Passed	0.0300	Passed
Tallahassee Community School	Fountain in dance studio	MVY807	0.0014	Passed	0.0310	Passed
Tallahassee Community School	Sink tap inside infant room	MVY808	0.0004	Passed	0.4700	Passed
Tallahassee Community School	Sink tap inside infant room	MVY809	0.0006	Passed	0.4200	Passed
Tallahassee Community School	Girls Locker room tap 1 in rec centre	MVY810	0.0010	Passed	0.3800	Passed
Tallahassee Community School	Girls Locker room tap 2 in rec centre	MVY811	0.0240	Exceeds Limit	0.3500	Passed
Tallahassee Community School	Girls Locker room tap 3 in rec centre	MVY812	0.0240	Exceeds Limit	0.2600	Passed
Tallahassee Community School	Fountain beside south gym entrance	MVY813	0.0085	Exceeds Limit	0.1300	Passed
Tallahassee Community School	south gym office WR tap	MVY814	0.0046	Passed	0.1900	Passed
Tallahassee Community School	Boys locker room tap 1 in rec centre	MVY815	0.0240	Exceeds Limit	0.2300	Passed
Tallahassee Community School	Boys locker room tap 2 in rec centre	MVY816	0.0055	Exceeds Limit	0.1200	Passed
Tallahassee Community School	Boys locker room tap 3 in rec centre	MVY817	0.0032	Passed	0.0490	Passed
Tallahassee Community School	Kitchen tap in toddler room	MVY818	0.0008	Passed	0.4800	Passed
Tallahassee Community School	GN WR tap 1 in toddler room	MVY819	0.0092	Exceeds Limit	0.1900	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Tallahassee Community School	GN WR tap 2 in toddler room	MVY820	0.0014	Passed	0.0330	Passed
Tallahassee Community School	Boys WR tap 1 beside girls WR	MVY821	0.0058	Exceeds Limit	0.0680	Passed
Tallahassee Community School	Boys WR tap 2 beside girls WR	MVY822	0.0590	Exceeds Limit	0.0560	Passed
Tallahassee Community School	Fountain in between gym and boys locker room	MVY823	0.0000	Passed	0.4100	Passed
Tallahassee Community School	Music room sink tap room 110	MVY824	0.1300	Exceeds Limit	0.6800	Passed
Tallahassee Community School	JC tap inside the mech room	MVY825	0.0000	Passed	0.0190	Passed
Tallahassee Community School	Fountain beside guidance room	MVY826	0.0021	Passed	0.3800	Passed
Tallahassee Community School	CR tap room 104	MVY827	0.0055	Exceeds Limit	0.4000	Passed
Tallahassee Community School	CR tap room 102	MVY828	0.0073	Exceeds Limit	0.7400	Passed
Tallahassee Community School	GN WR tap in room 103	MVY829	0.0110	Exceeds Limit	0.2600	Passed
Tallahassee Community School	GN WR tap in room 105	MVY830	0.2100	Exceeds Limit	0.1600	Passed
Tallahassee Community School	CR tap room 105	MVY831	0.0024	Passed	0.4000	Passed
Tallahassee Community School	Cafeteria double compartment sink	NND025	0.0040	Passed	0.0140	Passed
Tallahassee Community School	Cafeteria hand washing sink	NND026	0.0040	Passed	0.0090	Passed
Tallahassee Community School	Girls WR tap 1 across from library	MVY834	0.0280	Exceeds Limit	0.1800	Passed
Tallahassee Community School	Girls WR tap 2 across from library	MVY835	0.0250	Exceeds Limit	0.2800	Passed
Tallahassee Community School	Girls WR tap 3 across from library	MVY836	0.0450	Exceeds Limit	0.2200	Passed
Tallahassee Community School	Boys WR tap 1 across from mech room	MVY837	0.0230	Exceeds Limit	0.1800	Passed
Tallahassee Community School	Boys WR tap 2 across from mech room	MVY838	0.0280	Exceeds Limit	0.0850	Passed
Tallahassee Community School	Boys WR tap 3 across from mech room	MVY839	0.0120	Exceeds Limit	0.0860	Passed
Tallahassee Community School	Boys WR tap 4 across from mech room	MVY840	0.0490	Exceeds Limit	0.1300	Passed
Tallahassee Community School	Fountain beside cafeteria	MVY841	0.0000	Passed	1.0000	Passed
Tallahassee Community School	CR WR tap room 113	MVY842	0.0055	Exceeds Limit	0.2300	Passed
Tallahassee Community School	CR tap room 113	MVY843	0.0054	Exceeds Limit	0.2900	Passed
Tallahassee Community School	CR WR tap room 115	MVY844	0.0072	Exceeds Limit	0.1000	Passed
Tallahassee Community School	CR tap 1 room 115	MVY845	0.0000	Passed	0.0670	Passed
Tallahassee Community School	CR tap 2 room 115	MVY846	0.0033	Passed	0.3500	Passed
Tallahassee Community School	CR tap room 116	MVY847	0.4100	Exceeds Limit	0.5800	Passed
Tallahassee Community School	CR tap room 114	MVY848	0.0038	Passed	0.4300	Passed
Tallahassee Community School	Staff room kitchen tap	MVY849	0.0022	Passed	0.1900	Passed
Tallahassee Community School	Staff room WR tap 1	MVY850	0.0032	Passed	0.1300	Passed
Tallahassee Community School	Staff room WR tap 2	MVY851	0.0021	Passed	0.0950	Passed
Tantallon Junior Elementary School	CR tap room 103	MUW181	0.0120	Exceeds Limit	1.7000	Passed
Tantallon Junior Elementary School	CR tap room 104	MUW182	0.0035	Passed	1.6000	Passed
Tantallon Junior Elementary School	CR tap room 105	MUW183	0.0580	Exceeds Limit	0.8500	Passed
Tantallon Junior Elementary School	Boys WR tap 1	MUW184	0.0009	Passed	1.6000	Passed
Tantallon Junior Elementary School	Boys WR tap 2	MUW185	0.0074	Exceeds Limit	1.7000	Passed
Tantallon Junior Elementary School	Boys WR tap 3	MUW186	0.0013	Passed	1.6000	Passed
Tantallon Junior Elementary School	JC tap room 109	MUW187	0.0088	Exceeds Limit	0.3100	Passed
Tantallon Junior Elementary School	Girls WR tap 1	MUW188	0.0065	Exceeds Limit	0.6200	Passed
Tantallon Junior Elementary School	Girls WR tap 2	MUW189	0.0014	Passed	0.8200	Passed
Tantallon Junior Elementary School	Girls WR tap 3	MUW190	0.0030	Passed	0.5100	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Tantallon Junior Elementary School	CR tap room 115	MUW191	0.0057	Exceeds Limit	2.6000	Exceeds Limit
Tantallon Junior Elementary School	Staff room tap	MUW192	0.0008	Passed	0.4300	Passed
Tantallon Junior Elementary School	Staff WR 1 tap	MUW193	0.0014	Passed	0.4000	Passed
Tantallon Junior Elementary School	Staff WR 2 tap	MUW194	0.0008	Passed	0.4700	Passed
Tantallon Junior Elementary School	2nd floor girls WR tap 1	MUW195	0.0230	Exceeds Limit	0.8200	Passed
Tantallon Junior Elementary School	2nd floor girls WR tap 2	MUW196	0.0200	Exceeds Limit	1.0000	Passed
Tantallon Junior Elementary School	2nd floor girls WR tap 3	MUW197	0.0046	Passed	1.6000	Passed
Tantallon Junior Elementary School	2nd floor JC tap	MUW198	0.0044	Passed	1.2000	Passed
Tantallon Junior Elementary School	2nd floor boys WR tap 1	MUW199	0.0018	Passed	0.6200	Passed
Tantallon Junior Elementary School	2nd floor boys WR tap 2	MUW200	0.0013	Passed	0.7900	Passed
Tantallon Junior Elementary School	CR tap room 212	MUW208	1.8000	Exceeds Limit	1.9000	Passed
Tantallon Senior Elementary School	Cafeteria tap 1	MUV724	0.0032	Passed	1.5000	Passed
Tantallon Senior Elementary School	Cafeteria tap 2	NNS753	0.0010	Passed	0.6600	Passed
Tantallon Senior Elementary School	Cafeteria tap 3	NNS754	0.0010	Passed	0.6300	Passed
Tantallon Senior Elementary School	Boys WR tap 1	MUV727	0.0056	Exceeds Limit	1.4000	Passed
Tantallon Senior Elementary School	Boys WR tap 2	MUV728	0.0050	Passed	1.9000	Passed
Tantallon Senior Elementary School	Boys WR tap 3	MUV729	0.0100	Exceeds Limit	1.5000	Passed
Tantallon Senior Elementary School	Fountain by boys WR	MUV730	0.0140	Exceeds Limit	1.2000	Passed
Tantallon Senior Elementary School	Staff WR	MUV731	0.0050	Passed	2.5000	Exceeds Limit
Tantallon Senior Elementary School	Staff WR	MUV732	0.0070	Exceeds Limit	2.4000	Exceeds Limit
Tantallon Senior Elementary School	Girls WR tap 1	MUV733	0.0220	Exceeds Limit	0.6900	Passed
Tantallon Senior Elementary School	Girls WR tap 2	MUV734	0.0061	Exceeds Limit	2.1000	Exceeds Limit
Tantallon Senior Elementary School	Girls WR tap 3	MUV735	0.0120	Exceeds Limit	2.0000	Passed
Tantallon Senior Elementary School	JC tap	MUV736	0.0120	Exceeds Limit	2.4000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor Staff room tap 1	MUV737	0.0016	Passed	3.1000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor Staff room tap 2	MUV738	0.0270	Exceeds Limit	0.8800	Passed
Tantallon Senior Elementary School	2nd floor Staff room tap 3	MUV739	0.0300	Exceeds Limit	1.8000	Passed
Tantallon Senior Elementary School	2nd floor boys staff WR tap	MUV740	0.0110	Exceeds Limit	2.0000	Passed
Tantallon Senior Elementary School	2nd floor boys WR tap 1	MUV741	0.0084	Exceeds Limit	3.8000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor boys WR tap 2	MUV742	0.0099	Exceeds Limit	3.0000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor boys WR tap 3	MUV743	0.0065	Exceeds Limit	2.7000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor boys WR tap 4	MUV744	0.0083	Exceeds Limit	1.7000	Passed
Tantallon Senior Elementary School	2nd floor JC tap	MUV745	0.0052	Exceeds Limit	2.8000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor fountain	MUV746	0.0150	Exceeds Limit	0.9100	Passed
Tantallon Senior Elementary School	Girls WR tap 1 room 229	MUV747	0.0220	Exceeds Limit	0.9600	Passed
Tantallon Senior Elementary School	Girls WR tap 2 room 229	MUV748	0.0039	Passed	4.6000	Exceeds Limit
Tantallon Senior Elementary School	Girls WR tap 3 room 229	MUV749	0.0068	Exceeds Limit	3.0000	Exceeds Limit
Tantallon Senior Elementary School	2nd floor Learning Centre tap 1	NNS755	0.0018	Passed	0.4000	Passed
Tantallon Senior Elementary School	2nd floor Learning Centre tap 2	NNS756	0.0021	Passed	0.3700	Passed
Tantallon Senior Elementary School	2nd floor Learning Centre tap 3	NNS757	0.0022	Passed	0.3800	Passed
Upper Musquodoboit Consolidated Elementary School	Cafeteria tap	MYZ361	0.0005	Passed	0.0410	Passed
Upper Musquodoboit Consolidated Elementary School	Staff kitchen tap 1	MYZ362	0.0260	Exceeds Limit	0.1200	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Upper Musquodoboit Consolidated Elementary School	Staff kitchen tap 2	MYZ363	0.0000	Passed	0.0220	Passed
Upper Musquodoboit Consolidated Elementary School	Staff WR tap	MYZ364	0.0015	Passed	0.0270	Passed
Upper Musquodoboit Consolidated Elementary School	Girls WR tap 1	MYZ365	0.0025	Passed	0.0340	Passed
Upper Musquodoboit Consolidated Elementary School	Girls WR tap 2	MYZ366	0.0009	Passed	0.0270	Passed
Upper Musquodoboit Consolidated Elementary School	Girls WR tap 3	MYZ367	0.0006	Passed	0.0130	Passed
Upper Musquodoboit Consolidated Elementary School	JC tap between WR's	MYZ368	0.0011	Passed	0.0920	Passed
Upper Musquodoboit Consolidated Elementary School	Boys WR tap 1	MYZ369	0.0017	Passed	0.1400	Passed
Upper Musquodoboit Consolidated Elementary School	Boys WR tap 2	MYZ370	0.0010	Passed	0.1100	Passed
Upper Musquodoboit Consolidated Elementary School	Boys WR tap 3	MYZ379	0.0005	Passed	0.0890	Passed
Upper Musquodoboit Consolidated Elementary School	CR tap room 4	MYZ380	0.0005	Passed	0.0610	Passed
Waverley Memorial Elementary School	Girls WR tap 1 by staircase	MSP675	0.0014	Passed	0.3100	Passed
Waverley Memorial Elementary School	Girls WR tap 2 by staircase	MSP676	0.0012	Passed	0.3000	Passed
Waverley Memorial Elementary School	Girls WR tap 3 by staircase	MSP677	0.0008	Passed	0.2900	Passed
Waverley Memorial Elementary School	Fountain by staircase	MSP678	0.0000	Passed	0.5100	Passed
Waverley Memorial Elementary School	JC tap room 216	MSP679	0.0000	Passed	0.0940	Passed
Waverley Memorial Elementary School	Staff WR tap room 214	MSP680	0.0000	Passed	0.1300	Passed
Waverley Memorial Elementary School	Special needs WR tap room 213	MSP681	0.0000	Passed	0.0680	Passed
Waverley Memorial Elementary School	Boys WR tap 1 room 212.1	MSP682	0.0000	Passed	0.4700	Passed
Waverley Memorial Elementary School	Boys WR tap 2 room 212.1	MSP683	0.0000	Passed	0.2900	Passed
Waverley Memorial Elementary School	Boys WR tap 3 room 212.1	MSP684	0.0009	Passed	0.3100	Passed
Waverley Memorial Elementary School	Laundry tap room 220	MSP685	0.0000	Passed	0.1800	Passed
Waverley Memorial Elementary School	CR tap 1 room 201	MSP686	0.0000	Passed	0.6900	Passed
Waverley Memorial Elementary School	CR tap 2 room 201	MSP687	0.0000	Passed	0.9600	Passed
Waverley Memorial Elementary School	CR tap room 202	MSP688	0.0000	Passed	0.1600	Passed
Waverley Memorial Elementary School	CR tap room 203	MSP689	0.0000	Passed	0.0340	Passed
Waverley Memorial Elementary School	CR tap room 204	MSP690	0.0000	Passed	0.0600	Passed
Waverley Memorial Elementary School	CR tap room 205	MSP691	0.0000	Passed	0.5700	Passed
Waverley Memorial Elementary School	Girls WR tap 1 by staircase	MSP692	0.0005	Passed	0.6000	Passed
Waverley Memorial Elementary School	Girls WR tap 2 by staircase	MSP693	0.0000	Passed	0.9300	Passed
Waverley Memorial Elementary School	Girls WR tap 3 by staircase	MSP694	0.0000	Passed	0.4200	Passed
Waverley Memorial Elementary School	Staff WR tap room 120	MSP695	0.0000	Passed	0.1400	Passed
Waverley Memorial Elementary School	Staff WR tap room 119	MSP696	0.0000	Passed	0.0770	Passed
Waverley Memorial Elementary School	Boys WR tap 1 by room 118.1	MSP697	0.0007	Passed	0.4700	Passed
Waverley Memorial Elementary School	Boys WR tap 2 by room 118.1	MSP698	0.0000	Passed	0.4200	Passed
Waverley Memorial Elementary School	Boys WR tap 3 by room 118.1	MSP699	0.0006	Passed	0.3300	Passed
Waverley Memorial Elementary School	JC tap room 118.1	MSP700	0.0000	Passed	0.0590	Passed
Waverley Memorial Elementary School	CR tap room 108	MSP701	0.0000	Passed	0.1000	Passed
Waverley Memorial Elementary School	CR tap room 109	MSP702	0.0000	Passed	0.3600	Passed
Waverley Memorial Elementary School	GN WR tap room 110.2	MSP703	0.0000	Passed	0.4600	Passed
Waverley Memorial Elementary School	CR tap room 110	MSP704	0.0000	Passed	0.3800	Passed
Waverley Memorial Elementary School	Fountain by room 110	MSP705	0.0000	Passed	0.3800	Passed
Waverley Memorial Elementary School	GN WR tap room 111.1	MSP706	0.0000	Passed	0.4000	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Waverley Memorial Elementary School	CR tap room 111	MSP707	0.0000	Passed	0.1900	Passed
Waverley Memorial Elementary School	Staff room kitchen tap room 112	MSP708	0.0000	Passed	0.3900	Passed
Waverley Memorial Elementary School	GN WR tap room 114.1B	MSP709	0.0000	Passed	0.6300	Passed
Waverley Memorial Elementary School	CR tap room 114	MSP710	0.0000	Passed	0.8900	Passed
Waverley Memorial Elementary School	Girls locker room tap room 104.2	MSP711	0.0019	Passed	0.5600	Passed
Waverley Memorial Elementary School	Boys locker room tap room 104.5	MSP712	0.0024	Passed	0.5200	Passed
Waverley Memorial Elementary School	CR tap room 103.2	MSP713	0.0000	Passed	0.2400	Passed
Waverley Memorial Elementary School	Fountain by room 103.1A	MSP714	0.0000	Passed	0.2100	Passed
Waverley Memorial Elementary School	JC tap room 102.1	MSP715	0.0000	Passed	0.1800	Passed
Waverley Memorial Elementary School	Kitchen sink tap room 102.1	MSP716	0.0000	Passed	0.1300	Passed
Waverley Memorial Elementary School	Triple sink tap room 102.1	MSP717	0.0000	Passed	0.2400	Passed
Waverley Memorial Elementary School	Hand wash sink tap in cafeteria kitchen	MTA424	0.0000	Passed	0.1400	Passed
Waverley Memorial Elementary School	Fountain beside room 103.1A	MTA425	0.0000	Passed	0.2200	Passed
Waverley Memorial Elementary School	Main office tap room 101.4B	MTA426	0.0005	Passed	0.8600	Passed
Westmount Elementary School	Fountain by room 8	MOS547	0.0024	Passed	0.3600	Passed
Westmount Elementary School	Fountain by room 6	MOS548	0.0007	Passed	0.1500	Passed
Westmount Elementary School	Staff WR by room 6	MOS549	0.0011	Passed	0.1800	Passed
Westmount Elementary School	Boys WR tap 1 by room 6	MOS550	0.0006	Passed	0.2300	Passed
Westmount Elementary School	Boys WR tap 2 by room 6	MOS551	0.0013	Passed	0.1300	Passed
Westmount Elementary School	Boys WR tap 3 by room 6	MOS552	0.0019	Passed	0.1600	Passed
Westmount Elementary School	Staff WR tap by room 5	MOS553	0.0026	Passed	0.2100	Passed
Westmount Elementary School	Girls WR Tap 1 by room 5	MOS554	0.0034	Passed	0.1400	Passed
Westmount Elementary School	Girls WR Tap 2 by room 5	NJI782	0.0000	Passed	0.0030	Passed
Westmount Elementary School	Girls WR Tap 3 by room 5	MOS556	0.0031	Passed	0.1700	Passed
Westmount Elementary School	Girls WR Tap 4 by room 5	MOS557	0.0015	Passed	0.0470	Passed
Westmount Elementary School	CR tap room 8	MOS558	0.0014	Passed	0.1000	Passed
Westmount Elementary School	CR tap 1 room 9	NJI779	0.0000	Passed	0.0090	Passed
Westmount Elementary School	CR tap 2 room 9	MOS560	0.0026	Passed	0.2300	Passed
Westmount Elementary School	CR tap room 10	NJI780	0.0000	Passed	0.0100	Passed
Westmount Elementary School	CR tap room 6	MOS562	0.0012	Passed	0.1300	Passed
Westmount Elementary School	JC tap by room 6	MOS563	0.0019	Passed	0.1600	Passed
Westmount Elementary School	CR tap room 2	MOS564	0.0023	Passed	0.0600	Passed
Westmount Elementary School	Fountain by caretaker room	MOS565	0.0010	Passed	0.4300	Passed
Westmount Elementary School	Caretaker room tap	MPB690	0.0004	Passed	0.0890	Passed
Westmount Elementary School	Art room tap	MPB691	0.0017	Passed	0.4500	Passed
Westmount Elementary School	Gym office tap	MPB692	0.0037	Passed	0.1600	Passed
Westmount Elementary School	JC tap by room 17	MPB693	0.0007	Passed	0.0370	Passed
Westmount Elementary School	Fountain by room 17	NJI778	0.0017	Passed	0.0710	Passed
Westmount Elementary School	Staff WR tap by room 17	MPB695	0.0004	Passed	0.0470	Passed
Westmount Elementary School	Boys WR tap 1 by room 17	MPB696	0.0007	Passed	0.1900	Passed
Westmount Elementary School	Boys WR tap 2 by room 17	MPB697	0.0009	Passed	0.2300	Passed
Westmount Elementary School	Boys WR tap 3 by room 17	MPB698	0.0023	Passed	0.2600	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Westmount Elementary School	Fountain by room 18	MPB699	0.0004	Passed	0.2400	Passed
Westmount Elementary School	Staff WR tap by room 18	MPB700	0.0022	Passed	0.3200	Passed
Westmount Elementary School	Girls WR tap 1 by room 18	MPB701	0.0040	Passed	0.1500	Passed
Westmount Elementary School	Girls WR tap 2 by room 18	MPB702	0.0032	Passed	0.0800	Passed
Westmount Elementary School	Girls WR tap 3 by room 18	MPB703	0.0011	Passed	0.1400	Passed
Westmount Elementary School	GN WR tap by gym	MPB704	0.0014	Passed	0.0390	Passed
Westmount Elementary School	Staff WR #1 tap by gym	MPB705	0.0022	Passed	0.1300	Passed
Westmount Elementary School	Staff WR #2 tap by gym	MPB706	0.0009	Passed	0.0960	Passed
Westmount Elementary School	Main office WR tap	MPB707	0.0011	Passed	0.4800	Passed
Westmount Elementary School	Principal's office WR tap	NJI781	0.0000	Passed	0.0160	Passed
William King Elementary School	Boys WR Tap 1 room 153	MQS659	0.0017	Passed	3.0000	Exceeds Limit
William King Elementary School	Boys WR Tap 2 room 153	MQS660	0.0015	Passed	0.2400	Passed
William King Elementary School	Boys WR Tap 3 room 153	MQS661	0.0012	Passed	0.2200	Passed
William King Elementary School	Fountain by room 153	MQS662	0.0000	Passed	0.3900	Passed
William King Elementary School	Girls WR Tap 1 room 155	MQS663	0.0000	Passed	0.2900	Passed
William King Elementary School	Girls WR Tap 2 room 155	MQS664	0.0000	Passed	0.0320	Passed
William King Elementary School	Girls WR Tap 3 room 155	MQS665	0.0140	Exceeds Limit	2.5000	Exceeds Limit
William King Elementary School	CR tap room 159	MQS666	0.0042	Passed	0.3000	Passed
William King Elementary School	CR tap room 161	MQS667	0.0004	Passed	0.7400	Passed
William King Elementary School	CR WR tap room 161	MQS668	0.0025	Passed	0.5600	Passed
William King Elementary School	CR tap room 158	MQS669	0.0047	Passed	0.4400	Passed
William King Elementary School	GN WR tap room 158	MQS670	0.0060	Exceeds Limit	0.1200	Passed
William King Elementary School	JC tap room 154	MQS671	0.0000	Passed	0.0320	Passed
William King Elementary School	Boys locker room tap 1 room 149	MQS672	0.0006	Passed	0.1700	Passed
William King Elementary School	Boys locker room tap 2 room 149	MQS673	0.0000	Passed	0.1200	Passed
William King Elementary School	Boys locker room tap 3 room 149	MQS674	0.0008	Passed	0.1200	Passed
William King Elementary School	Gym office WR tap	MQS675	0.0012	Passed	0.1200	Passed
William King Elementary School	Girls locker room tap 1	MQS676	0.0010	Passed	0.3800	Passed
William King Elementary School	Girls locker room tap 2	MQS677	0.0006	Passed	0.1500	Passed
William King Elementary School	Girls locker room tap 3	MQS678	0.0024	Passed	0.8300	Passed
William King Elementary School	CR tap room 137	MQS679	0.0021	Passed	0.1000	Passed
William King Elementary School	Kitchen three compartment sink tap room 135	MQS680	0.0000	Passed	0.0520	Passed
William King Elementary School	Kitchen sink tap room 135	MQS681	0.0000	Passed	0.4700	Passed
William King Elementary School	Fountain outside room 135 (lower fountain)	MQS682	0.0130	Exceeds Limit	0.4000	Passed
William King Elementary School	Fountain outside room 135 (upper fountain)	MQS683	0.7500	Exceeds Limit	1.3000	Passed
William King Elementary School	JC tap room 130	MQS684	0.0000	Passed	0.0970	Passed
William King Elementary School	CR WR tap room 122	MQS685	0.0000	Passed	0.0780	Passed
William King Elementary School	CR tap room 122	MQS686	0.0000	Passed	0.0950	Passed
William King Elementary School	CR tap room 108	MQS687	0.0029	Passed	0.3100	Passed
William King Elementary School	CR tap room 107	MQS688	0.0005	Passed	0.4900	Passed
William King Elementary School	Boys WR tap 1 room 115	MQS689	0.0000	Passed	0.3700	Passed
William King Elementary School	Boys WR tap 2 room 115	MQS690	0.0000	Passed	0.1700	Passed

Halifax Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
William King Elementary School	Boys WR tap 3 room 115	MQS691	0.0000	Passed	0.1100	Passed
William King Elementary School	JC tap room 116	MQS692	0.0000	Passed	0.2400	Passed
William King Elementary School	Fountain by room 116	MQS693	0.0012	Passed	0.3800	Passed
William King Elementary School	Girls WR tap 1 room 117	MQS694	0.0000	Passed	0.2000	Passed
William King Elementary School	Girls WR tap 2 room 117	MQS695	0.0000	Passed	0.0910	Passed
William King Elementary School	Girls WR tap 3 room 117	MQS696	0.0000	Passed	0.3000	Passed
William King Elementary School	CR tap room 119	MQS697	0.0000	Passed	0.1400	Passed
William King Elementary School	CR tap room 129	MQS698	0.0013	Passed	0.0960	Passed
William King Elementary School	CR WR tap room 125	MQS699	0.0007	Passed	0.1800	Passed
William King Elementary School	CR WR tap room 126	MQS700	0.0000	Passed	0.0610	Passed