

# Water Test Results

Strait Regional Centre for Education



## Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate remediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

## Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

## Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

[www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html](http://www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html)

Copper:

[www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3](http://www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3)

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Antigonish Education Centre	Fountain 1-Main Entrance	ACO11310	0.0000	Passed	0.0150	Passed
Antigonish Education Centre	Fountain 2-Grade 1-2 Wing	ACO11311	0.0000	Passed	0.0360	Passed
Antigonish Education Centre	Fountain 3-Pre-Primary	ACO11312	0.0000	Passed	0.0210	Passed
Antigonish Education Centre	Fountain 4-by stairwell-2nd floor	ACO11313	0.0007	Passed	0.0430	Passed
Antigonish Education Centre	Fountain 5-Wing 3 on 2nd floor	ACO11314	0.0000	Passed	0.0180	Passed
Antigonish Education Centre	Fountain 6-Wing 4 - on 2d floor	ACO11315	0.0000	Passed	0.0570	Passed
Antigonish Education Centre	Food Prep 1-2nd floor-YSF-Rm 2108	ACO11316	0.0000	Passed	0.0190	Passed
Antigonish Education Centre	Food Prep 2-Rm 1005-next to door	ACO11317	0.0000	Passed	0.0180	Passed
Antigonish Education Centre	Food Prep-3-Rm 1005-back corner	ACO11318	0.0006	Passed	0.0120	Passed
Antigonish Education Centre	Food Prep 4-Rm 1113-Staff Room	ACO11319	0.0000	Passed	0.0180	Passed
Antigonish Education Centre	Food Prep 5-Rm 1311-Pre-primary	ACO11320	0.0000	Passed	0.0200	Passed
Antigonish Education Centre	Food Prep 6-Rm 1317-Pre-primary	ACO11321	0.0000	Passed	0.0170	Passed
Antigonish Education Centre	Food Prep 7-Rm 1318-Pre-primary	ACO11322	0.0000	Passed	0.0200	Passed
Antigonish Education Centre	Food Prep 8-Rm 1319-Pre-primary	ACO11323	0.0000	Passed	0.0410	Passed
Bayview Education Centre	Fountain 1 - Nearest to Building Entrance	ACO11448	0.0000	Passed	0.2500	Passed
Bayview Education Centre	Fountain 2 - 1st Floor	ACO11449	0.0000	Passed	0.1100	Passed
Bayview Education Centre	Fountain 3 - 2nd Floor	ACO11450	0.0000	Passed	0.1700	Passed
Bayview Education Centre	Fountain 4 - 2nd Floor	ACO11451	0.0000	Passed	0.1600	Passed
Bayview Education Centre	Food Prep 1 - Cafeteria/Kitchen Room 1302 (double sink)	ACO11452	0.0046	Passed	0.2400	Passed
Bayview Education Centre	Food Prep 2 - Cafeteria/Kitchen Room 1302 (dish rinsing sink)	ACO11453	0.0052	Exceeds Limit	0.0460	Passed
Bayview Education Centre	Food Prep 3 - Cafeteria/Kitchen Room 1302 (hand washing sink)	ACO11454	0.0032	Passed	0.1500	Passed
Bayview Education Centre	Food Prep 4 - Staff Lounge	ACO11455	0.0000	Passed	0.1200	Passed
Bayview Education Centre	Food Prep 5 - Daycare Pre Primary	ACO11456	0.0012	Passed	0.2000	Passed
Bayview Education Centre	Food Prep 6 - YSF	ACO11457	0.0016	Passed	0.1100	Passed
Bayview Education Centre	Fountain 5 - Gym Fountain	ACO11668	0.0000	Passed	0.2900	Passed
Cape Breton Highlands Education Centre/Academy	Fountain 1 - Next to Pre-Primary room 1203	ACO11458	0.0000	Passed	0.0890	Passed
Cape Breton Highlands Education Centre/Academy	Fountain 2 - Down the Hall From Teachers Lounge	ACO11459	0.0000	Passed	0.0190	Passed
Cape Breton Highlands Education Centre/Academy	Fountain 3 - Gym Hallway 1501	ACO11460	0.0021	Passed	0.0280	Passed
Cape Breton Highlands Education Centre/Academy	Fountain 4 - Before Family Studies	ACO11461	0.0000	Passed	0.0710	Passed
Cape Breton Highlands Education Centre/Academy	Fountain 5 - End of Hall Road Side	ACO11462	0.0076	Exceeds Limit	0.1500	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 1 - Cafeteria Kitchen Handwashing Sink	ACO11463	0.0020	Passed	0.1700	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 2 - Cafeteria Kitchen Dish Rinse Station	ACO11464	0.0025	Passed	0.1200	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 3 - Cafeteria Kitchen next to toaster	ACO11465	0.0130	Exceeds Limit	0.1100	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 4 - YSF room 1202	ACO11466	0.0031	Passed	0.0600	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 5 - Pre-Primary	ACO11467	0.0012	Passed	0.0820	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 6 - Staff Lunchroom	ACO11468	0.0005	Passed	0.0430	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 7 - Family Studies - 1st sink against the wall	ACO11469	0.0019	Passed	0.1500	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 8 - Family Studies - 2nd sink against wall	ACO11470	0.0020	Passed	0.1100	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 9 - Family Studies - Island Sink hallway side	ACO11471	0.0018	Passed	0.1100	Passed
Cape Breton Highlands Education Centre/Academy	Food Prep 10 - Cafeteria Kitchen island sink wall side	ACO11472	0.0023	Passed	0.2200	Passed
Chedabucto Education Centre/ Guysborough Academy	Fountain 1 - across from YSF ROOM 20	ACO11394	0.0000	Passed	1.8000	Passed
Chedabucto Education Centre/ Guysborough Academy	Fountain 2 - outside of Gr. 2 & 3 classrooms	ACO11395	0.0005	Passed	0.8500	Passed

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Chedabucto Education Centre/ Guysborough Academy	Fountain 3 - next to room 126	ACO11396	0.0000	Passed	1.9000	Passed
Chedabucto Education Centre/ Guysborough Academy	Fountain 4 - across from MultiMedia Room	ACO11397	0.0000	Passed	1.5000	Passed
Chedabucto Education Centre/ Guysborough Academy	Fountain 5 - across from Rec. Office	ACO11398	0.0000	Passed	2.2000	Exceeds Limit
Chedabucto Education Centre/ Guysborough Academy	Food Prep 1-YSF room 132-by window	ACO11399	0.0005	Passed	2.5000	Exceeds Limit
Chedabucto Education Centre/ Guysborough Academy	Food Prep 2-YSF room 132-3rd in the room	ACO11400	0.0000	Passed	2.0000	Passed
Chedabucto Education Centre/ Guysborough Academy	Food Prep 3-YSF room 132-2nd in the room	ACO11401	0.0015	Passed	2.1000	Exceeds Limit
Chedabucto Education Centre/ Guysborough Academy	Food Prep 4-YSF room 132-1st in the room	ACO11402	0.0006	Passed	1.9000	Passed
Chedabucto Education Centre/ Guysborough Academy	Food Prep 5-Cafeteria Kitchen	ACO11403	0.0009	Passed	4.3000	Exceeds Limit
Chedabucto Education Centre/ Guysborough Academy	Food Prep 6 - Room 25 Staff Room	ACO11613	0.0000	Passed	0.1200	Passed
Chedabucto Education Centre/ Guysborough Academy	Food Prep 7 - YSF Room 113 Kitchen Tap	ACO11614	0.0000	Passed	2.7000	Exceeds Limit
Dalbrae Academy	Fountain 1 - outside of staff room	ACO11473	0.0000	Passed	0.0940	Passed
Dalbrae Academy	Fountain 2 - Gymnasium	ACO11474	0.0000	Passed	0.0970	Passed
Dalbrae Academy	Fountain 3 - Blue Wing	ACO11475	0.0000	Passed	0.1200	Passed
Dalbrae Academy	Fountain 4 - Green Wing	ACO11476	0.0000	Passed	0.0750	Passed
Dalbrae Academy	Fountain 5 - Red Wing	ACO11477	0.0000	Passed	0.1300	Passed
Dalbrae Academy	Food Prep 1-Admin. Room Sink	ACO11478	0.0016	Passed	0.1500	Passed
Dalbrae Academy	Food Prep 2-Staff Room	ACO11479	0.0000	Passed	0.0740	Passed
Dalbrae Academy	Food Prep 3 -Cafeteria Kitchen -sink against wall	ACO11533	0.0000	Passed	0.0720	Passed
Dalbrae Academy	Food Prep 4-Cafeteria Kitchen - sink center island	ACO11657	0.0007	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Fountain 1 - Staff Room - Refill Station	ACO11327	0.0000	Passed	0.0050	Passed
Dr John Hugh Gillis Regional High School	Fountain 1 - Staff Room - Refill Station	ACO11327	0.0075	Exceeds Limit	0.3600	Passed
Dr John Hugh Gillis Regional High School	Fountain 2 - Wing 4 by Music Room 2123	ACO11328	0.0000	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Fountain 2 - Wing 4 by Music Room 2123	ACO11328	0.0041	Passed	0.3100	Passed
Dr John Hugh Gillis Regional High School	Fountain 3 - Refill Station - next to room 2014	ACO11329	0.0000	Passed	0.0980	Passed
Dr John Hugh Gillis Regional High School	Fountain 3 - Refill Station - next to room 2014	ACO11329	0.0010	Passed	0.1800	Passed
Dr John Hugh Gillis Regional High School	Fountain 4 - Grade 12 area next to washrooms	ACO11330	0.0000	Passed	0.1800	Passed
Dr John Hugh Gillis Regional High School	Fountain 4 - Grade 12 area next to washrooms	ACO11330	0.0010	Passed	0.2800	Passed
Dr John Hugh Gillis Regional High School	Fountain 5 - Gym -next to boys change room	ACO11331	0.0006	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Fountain 5 - Gym -next to boys change room	ACO11331	0.0007	Passed	0.2300	Passed
Dr John Hugh Gillis Regional High School	Fountain 6 - Gym - next to girls change room	ACO11332	0.0000	Passed	0.0970	Passed
Dr John Hugh Gillis Regional High School	Fountain 6 - Gym - next to girls change room	ACO11332	0.0011	Passed	0.1700	Passed
Dr John Hugh Gillis Regional High School	Fountain 7 - Grade 10 area next to washrooms	ACO11333	0.0000	Passed	0.0520	Passed
Dr John Hugh Gillis Regional High School	Food Prep 1 - Community Living	ACO11334	0.0000	Passed	0.0620	Passed
Dr John Hugh Gillis Regional High School	Food Prep 5 - Second Floor Cooking Lab - individual sink 2103	ACO11338	0.0047	Passed	0.1300	Passed
Dr John Hugh Gillis Regional High School	Food Prep 6 - Second Floor Cooking Lab - first on left 2103	ACO11339	0.0019	Passed	0.1200	Passed
Dr John Hugh Gillis Regional High School	Food Prep 7 - Second Floor Cooking Lab - second on left 2103	ACO11340	0.0006	Passed	0.1000	Passed
Dr John Hugh Gillis Regional High School	Food Prep 8 - Second Floor Cooking Lab - second on right 2103	ACO11341	0.0009	Passed	0.1500	Passed
Dr John Hugh Gillis Regional High School	Food Prep 9 - Second Floor Cooking Lab - first on right 2103	ACO11342	0.0006	Passed	0.1400	Passed
Dr John Hugh Gillis Regional High School	Food Prep 10 - Cafeteria Kitchen small room	ACO11343	0.0000	Passed	0.2300	Passed
Dr John Hugh Gillis Regional High School	Food Prep 11 - Cafeteria Kitchen large room	ACO11344	0.0000	Passed	0.0760	Passed
Dr John Hugh Gillis Regional High School	Food Prep 4 - Second Floor Kitchen - Dishwashing Stn 2104	ACO11539	0.0740	Exceeds Limit	0.2900	Passed
Dr John Hugh Gillis Regional High School	Food Prep 3 - Second Floor Kitchen room 2104	ACO11561	0.0004	Passed	0.3200	Passed

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dr John Hugh Gillis Regional High School	Food Prep 3 - Second Floor Kitchen room 2104	ACO11561	0.2100	Exceeds Limit	0.2700	Passed
Dr John Hugh Gillis Regional High School	Food Prep 2 - Second Floor Old Office # 2040	ACO11562	0.0090	Exceeds Limit	0.0090	Passed
Dr John Hugh Gillis Regional High School	Gym Female Washroom Tap 1	ACO11570	0.0016	Passed	0.0430	Passed
Dr John Hugh Gillis Regional High School	Gym Male Washroom Tap 1	ACO11571	0.0018	Passed	0.0680	Passed
Dr John Hugh Gillis Regional High School	Locker Room 1 - Washroom Tap 2	ACO11572	0.0015	Passed	0.1400	Passed
Dr John Hugh Gillis Regional High School	Locker Room 1 - Washroom Tap 1	ACO11573	0.0020	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Locker Room 2 - Washroom Tap	ACO11574	0.0025	Passed	0.2300	Passed
Dr John Hugh Gillis Regional High School	Locker Room 3 - Washroom Tap 1	ACO11575	0.0000	Passed	0.0880	Passed
Dr John Hugh Gillis Regional High School	Locker Room 3 - Washroom Tap 2	ACO11576	0.0009	Passed	0.1800	Passed
Dr John Hugh Gillis Regional High School	Locker Room 4 - Washroom Tap	ACO11577	0.0022	Passed	0.2000	Passed
Dr John Hugh Gillis Regional High School	Janitors Room Tap - Main Hallway	ACO11578	0.0000	Passed	0.0980	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Main Hallway - Tap 3	ACO11581	0.0032	Passed	0.2200	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 10 Hallway - Tap 1	ACO11582	0.0010	Passed	0.0820	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Main Hallway - Tap 2	ACO11583	0.0008	Passed	0.1000	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 9 Hallway - Tap 2	ACO11584	0.0024	Passed	0.2000	Passed
Dr John Hugh Gillis Regional High School	Auto Shop Tap - 1st floor	ACO11585	0.0000	Passed	0.1300	Passed
Dr John Hugh Gillis Regional High School	Wood Shop Tap	ACO11586	0.0230	Exceeds Limit	0.0610	Passed
Dr John Hugh Gillis Regional High School	Boiler Room Tap - Auto Shop Hallway	ACO11587	0.0310	Exceeds Limit	1.7000	Passed
Dr John Hugh Gillis Regional High School	Community Living Washroom - Auto Shop Hallway - Tap 1	ACO11588	0.0017	Passed	0.1200	Passed
Dr John Hugh Gillis Regional High School	Community Living Washroom - Auto Shop Hallway - Tap 2	ACO11589	0.0000	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 10 Hallway - Tap 1	ACO11590	0.0025	Passed	0.1900	Passed
Dr John Hugh Gillis Regional High School	Gender Neutral Washroom Tap	ACO11591	0.0000	Passed	0.1200	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 9 Hallway - Tap 3	ACO11592	0.0007	Passed	0.2300	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Auto Shop Hallway - Tap 1	ACO11593	0.0006	Passed	0.0390	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Auto Shop Hallway - Tap 2	ACO11594	0.0011	Passed	0.0720	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 10 Hallway - Tap 2	ACO11595	0.0047	Passed	0.2200	Passed
Dr John Hugh Gillis Regional High School	Janitors Room Tap - Auto Shop Hallway	ACO11596	0.0016	Passed	0.0920	Passed
Dr John Hugh Gillis Regional High School	Trades Room Tap	ACO11597	0.0017	Passed	0.0690	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 9 Hallway - Tap 1	ACO11598	0.0010	Passed	0.1800	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 9 Hallway - Tap 2	ACO11599	0.0010	Passed	0.2800	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Auto Shop Hallway - Tap 3	ACO11600	0.0010	Passed	0.0740	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 10 Hallway - Tap 2	ACO11601	0.0010	Passed	0.0940	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 9 Hallway - Tap 1	ACO11602	0.0033	Passed	0.2500	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 10 Hallway - Tap 3	ACO11618	0.0025	Passed	0.2600	Passed
Dr John Hugh Gillis Regional High School	Janitors Washroom Tap - Grade 9 Hallway	ACO11619	0.0023	Passed	0.0430	Passed
Dr John Hugh Gillis Regional High School	Trades Building Tap - Back Exterior of School	ACO11620	0.0011	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Cafeteria Kitchen - Room 2100 - Handwashing Sink	ACO11621	0.0007	Passed	0.1900	Passed
Dr John Hugh Gillis Regional High School	Main Office Handwashing Sink	ACO11622	0.0010	Passed	0.2300	Passed
Dr John Hugh Gillis Regional High School	Classroom 2102 Tap - Sewing Room	ACO11623	0.0090	Exceeds Limit	0.1200	Passed
Dr John Hugh Gillis Regional High School	Classroom 2100 Tap - Special Needs	ACO11624	0.0010	Passed	0.2200	Passed
Dr John Hugh Gillis Regional High School	Classroom 2198 Tap	ACO11625	0.0011	Passed	0.1400	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Main Hallway 2nd Floor - Tap 1	ACO11626	0.0062	Exceeds Limit	0.2200	Passed

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Dr John Hugh Gillis Regional High School	Girls Washroom - Main Hallway 2nd Floor - Tap 2	ACO11627	0.0037	Passed	0.1700	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Main Hallway 2nd Floor - Tap 3	ACO11628	0.0029	Passed	0.3100	Passed
Dr John Hugh Gillis Regional High School	Music Room 2123 Tap	ACO11629	0.0000	Passed	0.2000	Passed
Dr John Hugh Gillis Regional High School	Staff Washroom - Main Hallway 2nd Floor	ACO11630	0.0020	Passed	0.1300	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Main Hallway 2nd Floor - Tap 1	ACO11631	0.0021	Passed	0.1300	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Main Hallway - Tap 1	ACO11632	0.0021	Passed	0.1600	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Main Hallway 2nd Floor - Tap 3	ACO11633	0.0011	Passed	0.2000	Passed
Dr John Hugh Gillis Regional High School	Classroom 2191 Tap	ACO11634	0.0023	Passed	0.2200	Passed
Dr John Hugh Gillis Regional High School	Art Room 2084 - Tap 1	ACO11636	0.0005	Passed	0.1600	Passed
Dr John Hugh Gillis Regional High School	Art Room 2084 - Tap 2	ACO11637	0.0008	Passed	0.1200	Passed
Dr John Hugh Gillis Regional High School	Art Room 2085 - Tap 1	ACO11638	0.0490	Exceeds Limit	3.8000	Exceeds Limit
Dr John Hugh Gillis Regional High School	Art Room 2085 - Tap 2	ACO11639	0.0014	Passed	0.1800	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 9 Hallway - Tap 3	ACO11641	0.0030	Passed	0.2000	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 10 Hallway - Tap 3	ACO11642	0.0022	Passed	0.1500	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 1	ACO11643	0.0056	Exceeds Limit	0.2000	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 2	ACO11644	0.0027	Passed	0.1700	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 3	ACO11645	0.0016	Passed	0.2000	Passed
Dr John Hugh Gillis Regional High School	Janitors Room Tap - Grade 11 Hallway 2nd Floor	ACO11646	0.0005	Passed	0.1100	Passed
Dr John Hugh Gillis Regional High School	Guidance Office Tap - Grade 11 Hallway 2nd Floor	ACO11647	0.0000	Passed	0.2500	Passed
Dr John Hugh Gillis Regional High School	Doctor's Tap - Grade 12 Hallway 2nd Floor	ACO11648	0.0350	Exceeds Limit	0.5600	Passed
Dr John Hugh Gillis Regional High School	Dr Office Washroom Tap	ACO11649	0.0007	Passed	0.0460	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 11 Hallway 2nd Floor - Tap 1	ACO11650	0.0015	Passed	0.1600	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 12 Hallway 2nd Floor - Tap 2	ACO11651	0.0510	Exceeds Limit	0.3400	Passed
Dr John Hugh Gillis Regional High School	Boys Washroom - Grade 12 Hallway 2nd Floor - Tap 3	ACO11652	0.0026	Passed	0.2200	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 1	ACO11653	0.0035	Passed	0.3400	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 2	ACO11654	0.0075	Exceeds Limit	0.3600	Passed
Dr John Hugh Gillis Regional High School	Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 3	ACO11655	0.0041	Passed	0.3100	Passed
Dr John Hugh Gillis Regional High School	Janitor Room Grade 12 Hallway	ACO11656	0.0013	Passed	0.0570	Passed
Dr John Hugh Gillis Regional High School	School Plus Classroom - Female Washroom	ACO11658	0.0043	Passed	0.1800	Passed
Dr John Hugh Gillis Regional High School	School Plus Classroom - Male Washroom	ACO11659	0.0046	Passed	0.1500	Passed
Dr John Hugh Gillis Regional High School	Staff Washroom - 2nd floor by Music Room	ACO11660	0.0008	Passed	0.0960	Passed
East Antigonish Education Centre/Academy	Food Prep 1-2nd floor-YSF-room # 2108	ACO11316	0.0000	Passed	0.0190	Passed
East Antigonish Education Centre/Academy	Food Prep 2-Rm 1005-closest to door	ACO11317	0.0000	Passed	0.0180	Passed
East Antigonish Education Centre/Academy	Food Prep-3-Rm 1005-back corner	ACO11318	0.0033	Passed	0.0120	Passed
East Antigonish Education Centre/Academy	Food Prep 4-Rm 1113-Staff Room	ACO11319	0.0021	Passed	0.0180	Passed
East Antigonish Education Centre/Academy	Food Prep 5-Room 1311-Pre-primary	ACO11320	0.0000	Passed	0.0200	Passed
East Antigonish Education Centre/Academy	Food Prep 6-Room 1317-Pre-primary	ACO11321	0.0000	Passed	0.0170	Passed
East Antigonish Education Centre/Academy	Food Prep 7-Room 1318-Pre-primary	ACO11322	0.0000	Passed	0.0200	Passed
East Antigonish Education Centre/Academy	Food Prep 8-Room 1319-Pre-primary	ACO11323	0.0007	Passed	0.0410	Passed
East Antigonish Education Centre/Academy	Fountain 1 - Early Years Hallway - next to Grade 4	ACO11345	0.0000	Passed	0.1000	Passed
East Antigonish Education Centre/Academy	Fountain 2 - Elementary Wing	ACO11346	0.0000	Passed	0.1100	Passed
East Antigonish Education Centre/Academy	Fountain 3 - Bottle Refill Stn. Gym hallway	ACO11347	0.0000	Passed	0.1000	Passed



## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
East Antigonish Education Centre/Academy	Fountain 4 - 2nd floor - Sr. Wing 10-12	ACO11348	0.0000	Passed	0.1100	Passed
East Antigonish Education Centre/Academy	Fountain 5 - South Wing - Grade 5 -6	ACO11349	0.0000	Passed	0.1500	Passed
East Antigonish Education Centre/Academy	Fountain 6 - North Wing	ACO11350	0.0000	Passed	0.2000	Passed
East Antigonish Education Centre/Academy	Food Prep 9 - Family Studies - 2nd sink to the right	ACO11606	0.0000	Passed	0.1100	Passed
East Antigonish Education Centre/Academy	Food Prep 10 - Family Studies - 3rd sink to the right	ACO11607	0.0006	Passed	0.0770	Passed
East Antigonish Education Centre/Academy	Food Prep 11 - Family Studies - 4th sink to the right	ACO11608	0.0008	Passed	0.1600	Passed
East Antigonish Education Centre/Academy	Food Prep 12 - Family Studies - sink against the wall	ACO11609	0.0007	Passed	0.1700	Passed
East Richmond Education Centre	Fountain 1 - Wing 1 - by room 149	ACO11425	0.0000	Passed	0.0570	Passed
East Richmond Education Centre	Food Prep 1 - Cafeteria Kitchen Sink by Storage Room	ACO11426	0.0006	Passed	0.0900	Passed
East Richmond Education Centre	Food Prep 2 - Cafeteria Kitchen - Prewash Station	ACO11427	0.0067	Exceeds Limit	0.2200	Passed
East Richmond Education Centre	Food Prep 3 - Cafeteria Kitchen sink next to entry	ACO11428	0.0160	Exceeds Limit	0.1900	Passed
East Richmond Education Centre	Food Prep 4 - Cafeteria Kitchen - handwashing	ACO11429	0.0028	Passed	0.1400	Passed
East Richmond Education Centre	Food Prep 5 - Family Studies - by window	ACO11430	0.0000	Passed	0.1200	Passed
East Richmond Education Centre	Food Prep 6 - Family Studies - by door entry	ACO11431	0.0000	Passed	0.1700	Passed
East Richmond Education Centre	Food Prep 7 - Family Studies - centre sinks	ACO11432	0.0007	Passed	0.1200	Passed
East Richmond Education Centre	Food Prep 8 - Day Care Tap 1	ACO11662	0.0007	Passed	0.1300	Passed
East Richmond Education Centre	Food Prep 9 - Day Care Tap 2	ACO11663	0.0000	Passed	0.0810	Passed
East Richmond Education Centre	Food Prep 11 - Pre Primary Tap	ACO11664	0.0130	Exceeds Limit	0.7600	Passed
East Richmond Education Centre	Fountain 2 - Wing 1 - by room 165	ACO11665	0.0000	Passed	0.2700	Passed
East Richmond Education Centre	Fountain 3 - Wing 2 - by room 178	ACO11666	0.0079	Exceeds Limit	0.2700	Passed
East Richmond Education Centre	Fountain 4 - Gym	ACO11667	0.0009	Passed	0.3100	Passed
East Richmond Education Centre	Food Prep 10 - Day Care Small Sink	ACO11671	0.0007	Passed	0.1300	Passed
Fanning Education Centre/ Canso Academy	Fountain 1 - Main Entrance - Bottle Refill Station	ACO11404	0.0000	Passed	0.7800	Passed
Fanning Education Centre/ Canso Academy	Fountain 2 - By room 123	ACO11405	0.0000	Passed	0.3500	Passed
Fanning Education Centre/ Canso Academy	Fountain 3 - By room 137	ACO11406	0.0000	Passed	0.5100	Passed
Fanning Education Centre/ Canso Academy	Fountain 4 - Wing 7-9	ACO11407	0.0000	Passed	0.7800	Passed
Fanning Education Centre/ Canso Academy	Fountain 5 - Wing 10-12	ACO11408	0.0000	Passed	0.3500	Passed
Fanning Education Centre/ Canso Academy	Food Prep 1 - Cafeteria Room 151 - double sink	ACO11409	0.0005	Passed	1.8000	Passed
Fanning Education Centre/ Canso Academy	Food Prep 2 - Cafeteria Kitchen room 117 - single sink	ACO11410	0.0028	Passed	1.4000	Passed
Fanning Education Centre/ Canso Academy	Food Prep 3 - Cafeteria Kitchen room 117 - double sink	ACO11411	0.0000	Passed	1.9000	Passed
Fanning Education Centre/ Canso Academy	Food Prep 4 - Multi-purpose room 114 - single sink	ACO11412	0.0015	Passed	0.4100	Passed
Fanning Education Centre/ Canso Academy	Food Prep 5 - Multi-purpose room 114 - island sink	ACO11413	0.0007	Passed	0.6000	Passed
Fanning Education Centre/ Canso Academy	Food Prep 6 - Staff Room 102	ACO11610	0.0000	Passed	0.2800	Passed
Fanning Education Centre/ Canso Academy	Food Prep 7 - Cafeteria Room 113 Tap	ACO11611	0.0000	Passed	1.0000	Passed
Fanning Education Centre/ Canso Academy	Food Prep 8 - Janitors Staff Room 151	ACO11612	0.0000	Passed	0.5100	Passed
Felix Marchand Education Centre	Food Prep 1 -Staff Lunchroom	ACO11433	0.0032	Passed	0.0260	Passed
H.M. MacDonald Elementary School	Fountain 1 - Next to Girls washroom	ACO11356	0.0000	Passed	0.0870	Passed
H.M. MacDonald Elementary School	Fountain 2 - Next to Janitors Storage room	ACO11357	0.0031	Passed	0.0830	Passed
H.M. MacDonald Elementary School	Food Prep 1-Lunch Room	ACO11358	0.0025	Passed	0.0660	Passed
Inverness Education Centre/Academy	Fountain 1 - Entrance	ACO11480	0.0000	Passed	0.0660	Passed
Inverness Education Centre/Academy	Fountain 2 - Back of School	ACO11481	0.0000	Passed	0.0300	Passed
Inverness Education Centre/Academy	Fountain 3 - Upstairs	ACO11482	0.0000	Passed	0.1600	Passed

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Inverness Education Centre/Academy	Food Prep 1 - Staff Lounge	ACO11483	0.0001	Passed	0.0620	Passed
Inverness Education Centre/Academy	Food Prep 2 - FST Class	ACO11484	0.0004	Passed	0.0870	Passed
Pleasant Bay School	Food Prep 1 - Lunch Room	ACO11485	0.0019	Passed	0.0690	Passed
Pleasant Bay School	Sample Location 2 - Water Source	ACO11534	0.4000	Exceeds Limit	4.1000	Exceeds Limit
Pleasant Bay School	Sample Location 3 - Boys Washroom Upstairs	ACO11535	0.0017	Passed	0.2400	Passed
Pleasant Bay School	Sample Location 4 - Girls Washroom Upstairs	ACO11536	0.0022	Passed	0.1700	Passed
Pleasant Bay School	Sample Location 5 - Washroom Downstairs	ACO11537	0.0200	Exceeds Limit	0.1500	Passed
Richmond Education Centre/Academy	Fountain 1 - Main Floor Near Room 1800	ACO11434	0.0000	Passed	0.2900	Passed
Richmond Education Centre/Academy	Fountain 2 - Near Room 1000	ACO11435	0.0005	Passed	0.3000	Passed
Richmond Education Centre/Academy	Fountain 3 - Near Room 1101	ACO11436	0.0000	Passed	0.4700	Passed
Richmond Education Centre/Academy	Fountain 4 - Second Floor Away From Cooking Lab	ACO11437	0.0000	Passed	0.4600	Passed
Richmond Education Centre/Academy	Fountain 5 - 2nd Floor Near Cooking Lab	ACO11438	0.0000	Passed	0.4600	Passed
Richmond Education Centre/Academy	Food Prep 1 - Cafeteria Kitchen-main sink	ACO11439	0.0013	Passed	0.2900	Passed
Richmond Education Centre/Academy	Food Prep 2 - Cafeteria Kitchen-food prep	ACO11440	0.0015	Passed	0.2000	Passed
Richmond Education Centre/Academy	Food Prep 3 - Cafeteria Kitchen-by entry door	ACO11441	0.0000	Passed	0.1700	Passed
Richmond Education Centre/Academy	Food Prep 4 - YSF Cooking Lab - room 1807	ACO11442	0.0014	Passed	0.2600	Passed
Richmond Education Centre/Academy	Food Prep 5 - YSF Cooking Lab - room 1807	ACO11443	0.0000	Passed	0.1600	Passed
Richmond Education Centre/Academy	Food Prep 6 - Teacher Staff Room 1608	ACO11444	0.0000	Passed	0.2800	Passed
Richmond Education Centre/Academy	Food Prep 7 - 2nd Floor Cooking Lab Room 2013 - 1st Wall Sink	ACO11445	0.0015	Passed	0.1200	Passed
Richmond Education Centre/Academy	Food Prep 8 - 2nd Floor Cooking Lab Room 2013 - 2nd Wall Sink	ACO11446	0.0012	Passed	0.2300	Passed
Richmond Education Centre/Academy	Food Prep 9 - 2nd Floor Cooking Lab Room 2013 - Island Sink	ACO11447	0.0009	Passed	0.2900	Passed
St. Andrew Junior School	Fountain 1 - Corridor 011 by elevator	ACO11377	0.0000	Passed	0.0500	Passed
St. Andrew Junior School	Fountain 2 - Corridor 011 by Janitor's Closet	ACO11378	0.0000	Passed	0.0540	Passed
St. Andrew Junior School	Fountain 3 - Corridor 061 outside of Tech Ed	ACO11379	0.0000	Passed	0.2100	Passed
St. Andrew Junior School	Fountain 4 - Outside Science Room 228	ACO11381	0.0013	Passed	0.0650	Passed
St. Andrew Junior School	Food Prep 1 - Nutrition Room # 207 separate sink	ACO11383	0.0490	Exceeds Limit	0.0870	Passed
St. Andrew Junior School	Food Prep 2 - Nutrition Room # 207 1st on the left	ACO11384	0.0200	Exceeds Limit	0.0490	Passed
St. Andrew Junior School	Food Prep 3 - Nutrition Room # 207 - 1st on the right	ACO11385	0.0110	Exceeds Limit	0.0510	Passed
St. Andrew Junior School	Food Prep 4 - Nutrition Room # 207 2nd on the right	ACO11386	0.0160	Exceeds Limit	0.0520	Passed
St. Andrew Junior School	Food Prep 5 - Nutrition Room # 207 2nd on the left	ACO11387	0.0140	Exceeds Limit	0.0350	Passed
St. Andrew Junior School	Food Prep 6 - YSF Room # 218	ACO11388	0.0012	Passed	0.2900	Passed
St. Andrew Junior School	Food Prep 7 - Special Needs Room # 233	ACO11389	0.0400	Exceeds Limit	0.0530	Passed
St. Andrew Junior School	Food Prep 8 - YSF Room # 101	ACO11390	0.0025	Passed	0.1700	Passed
St. Andrew Junior School	Food Prep 9 - Class Room # 116	ACO11391	0.0007	Passed	0.0850	Passed
St. Andrew Junior School	Food Prep 10 - Cafeteria Kitchen		0.0007	Passed	0.0360	Passed
St. Andrew's Consolidated School	Fountain 1 - Front Entrance outside room 3	ACO11360	0.0000	Passed	0.0220	Passed
St. Andrew's Consolidated School	Fountain 2 - Outside room 152	ACO11361	0.0035	Passed	0.2900	Passed
St. Andrew's Consolidated School	Fountain 3 - Outside room 153	ACO11362	0.0032	Passed	0.3000	Passed
St. Andrew's Consolidated School	Fountain 4 - Hallway 111	ACO11363	0.0000	Passed	0.1100	Passed
St. Andrew's Consolidated School	Fountain 5 - Room 113 Grade Primary porcelaine fountain	ACO11364	0.0090	Exceeds Limit	0.4300	Passed
St. Andrew's Consolidated School	Fountain 6 - Room 101 Grade primary porcelaine fountain	ACO11365	0.0021	Passed	0.3100	Passed
St. Andrew's Consolidated School	Food Prep 1 - Room 128 - Cafeteria Kitchen - centre sink	ACO11366	0.0009	Passed	0.0480	Passed

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Andrew's Consolidated School	Food Prep 2 - Room 128 - Cafeteria Kitchen - handwashing	ACO11367	0.0016	Passed	0.0420	Passed
St. Andrew's Consolidated School	Food Prep 3 - Room 128 - Cafeteria Kitchen - prep sink	ACO11368	0.0029	Passed	0.0250	Passed
St. Andrew's Consolidated School	Food Prep 4 - Room 128 - Cafeteria Kitchen - Dishwashing	ACO11369	0.0005	Passed	0.2500	Passed
St. Andrew's Consolidated School	Food Prep 5 - Room 101 - Primary	ACO11370	0.0005	Passed	0.0720	Passed
St. Andrew's Consolidated School	Food Prep 6 - Room 113 - Grade Primary	ACO11371	0.0010	Passed	0.1500	Passed
St. Andrew's Consolidated School	Food Prep 7 - Room 116 - Grade 1 kitchen sink	ACO11372	0.0074	Exceeds Limit	0.1400	Passed
St. Andrew's Consolidated School	Food Prep 8 - Room 117 - Grade 1 kitchen sink	ACO11373	0.0070	Exceeds Limit	0.1300	Passed
St. Andrew's Consolidated School	Food Prep 9 - Room 126A - Pre-Primary	ACO11374	0.0020	Passed	0.0880	Passed
St. Andrew's Consolidated School	Food Prep 10 - Room 127 - Student Services	ACO11375	0.0026	Passed	0.1400	Passed
St. Andrew's Consolidated School	Food Prep 11 Room 138 - Staff Room	ACO11376	0.0002	Passed	0.1200	Passed
St. Mary's Education Centre/Academy	Fountain 1 - Outside of room 168	ACO11415	0.0000	Passed	0.0018	Passed
St. Mary's Education Centre/Academy	Fountain 2 - Main Entrance	ACO11416	0.0000	Passed	0.1500	Passed
St. Mary's Education Centre/Academy	Fountain 3 - Main Hall - 2nd floor	ACO11417	0.0000	Passed	0.1300	Passed
St. Mary's Education Centre/Academy	Food Prep 1 - Family Studies - 1st sink - individual	ACO11418	0.0012	Passed	0.3800	Passed
St. Mary's Education Centre/Academy	Food Prep 2 - island sink - 1st to the left	ACO11419	0.0007	Passed	0.0033	Passed
St. Mary's Education Centre/Academy	Food Prep 3 - island sink - 1st to the right	ACO11420	0.0000	Passed	0.0033	Passed
St. Mary's Education Centre/Academy	Food Prep 4 - island sink - 2nd to the right	ACO11421	0.0000	Passed	0.0030	Passed
St. Mary's Education Centre/Academy	Food Prep 5 - island sink - 2nd to the left	ACO11422	0.0000	Passed	0.0034	Passed
St. Mary's Education Centre/Academy	Food Prep 6 - Staff Room 109	ACO11423	0.0000	Passed	0.0045	Passed
St. Mary's Education Centre/Academy	Food Prep 7 - Cafeteria Kitchen room 113	ACO11424	0.0079	Exceeds Limit	0.1100	Passed
St. Mary's Education Centre/Academy	Food Prep 8 - Room 111 Cafeteria Eating Area - sink	ACO11615	0.4500	Exceeds Limit	0.1600	Passed
St. Mary's Education Centre/Academy	Food Prep 10 - Room 118 YSF Kitchen Sink	ACO11616	0.0084	Exceeds Limit	0.5100	Passed
St. Mary's Education Centre/Academy	Food Prep 9 - Room 113 Cafeteria Kitchen Sink	ACO11617	0.0007	Passed	0.0160	Passed
Strait Area Education and Recreation Centre	Fountain 2 - By the Library	ACO11487	0.0000	Passed	0.0510	Passed
Strait Area Education and Recreation Centre	Fountain 3 - Next to 3rd Floor Washrooms	ACO11488	0.0000	Passed	0.0470	Passed
Strait Area Education and Recreation Centre	Food Prep 6 - Teachers Staff Lunch Room 208	ACO11494	0.0015	Passed	0.0950	Passed
Strait Area Education and Recreation Centre	Food Prep 8 - Teen Health Room 305	ACO11496	0.0012	Passed	0.5600	Passed
Strait Area Education and Recreation Centre	Fountain 1 - In the Gym	ACO11525	0.0000	Passed	0.1000	Passed
Strait Area Education and Recreation Centre	Food Prep 1 - Food Lab 1st Sink on door side of 1st Island	ACO11526	0.0018	Passed	0.0380	Passed
Strait Area Education and Recreation Centre	Food Prep 2 - Food Lab room 252 - against the wall	ACO11527	0.0013	Passed	0.0370	Passed
Strait Area Education and Recreation Centre	Food Prep 3 - Cafeteria Kitchen Triple Sink	ACO11528	0.0000	Passed	0.0690	Passed
Strait Area Education and Recreation Centre	Food Prep 4 - Daycare Sink Right of Dishwasher	ACO11529	0.0000	Passed	0.1400	Passed
Strait Area Education and Recreation Centre	Food Prep 5 - YSF Double Sink (Rm 246)	ACO11530	0.0042	Passed	0.0890	Passed
Strait Area Education and Recreation Centre	Food Prep 7 - Cafeteria Kitchen Dish Rinse Station	ACO11531	0.0100	Exceeds Limit	0.2500	Passed
Strait Area Education and Recreation Centre	Fountain 4 - 2nd floor hallway	ACO11669	0.0000	Passed	0.0590	Passed
Strait Area Education and Recreation Centre	Food Prep 9 - Staff room 2nd Floor	ACO11670	0.0000	Passed	0.2900	Passed
Tamarac Education Centre	Fountain 1 - Before YSF	ACO11497	0.0000	Passed	0.0400	Passed
Tamarac Education Centre	Fountain 2 - Next to Gym	ACO11498	0.0000	Passed	0.0290	Passed
Tamarac Education Centre	Fountain 3 - Outside Classroom 2017	ACO11499	0.0000	Passed	0.0500	Passed
Tamarac Education Centre	Fountain 4 - Upstairs	ACO11500	0.0000	Passed	0.0220	Passed
Tamarac Education Centre	Fountain 5 - Outside Upstairs Washroom	ACO11501	0.0000	Passed	0.0250	Passed
Tamarac Education Centre	Food Prep 1 - Cafeteria Sink at Doorway	ACO11502	0.0010	Passed	0.0280	Passed

## Strait Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Tamarac Education Centre	Food Prep 2 - Dish Rinse Station	ACO11503	0.0000	Passed	0.0390	Passed
Tamarac Education Centre	Food Prep 3 - Sink at Center Prep Station	ACO11504	0.0000	Passed	0.0200	Passed
Tamarac Education Centre	Food Prep 4 - Left Wall in YSF	ACO11505	0.0000	Passed	0.0240	Passed
Tamarac Education Centre	Food Prep 5 - Teachers Lounge	ACO11506	0.0010	Passed	0.0400	Passed
Tamarac Education Centre	Food Prep 6 - First on Right Wall by Classroom Entrance	ACO11507	0.0000	Passed	0.0260	Passed
Whycocomagh Education Centre	Fountain 1 - Washroom Across From Cafeteria	ACO11508	0.0000	Passed	0.4400	Passed
Whycocomagh Education Centre	Fountain 2 - Outside Family Studies	ACO11509	0.0000	Passed	0.3900	Passed
Whycocomagh Education Centre	Fountain 3 - Server Room 156	ACO11510	0.0000	Passed	0.2900	Passed
Whycocomagh Education Centre	Food Prep 1 Cafeteria Kitchen Sink	ACO11511	0.0008	Passed	0.4500	Passed
Whycocomagh Education Centre	Food Prep 2 - Double Sink Next to Dishwasher	ACO11512	0.0012	Passed	0.3900	Passed
Whycocomagh Education Centre	Food Prep 3 - Day Care Small Sink	ACO11513	0.0000	Passed	0.3700	Passed
Whycocomagh Education Centre	Food Prep 4 - Day Care Double Sink	ACO11514	0.0000	Passed	0.2800	Passed
Whycocomagh Education Centre	Food Prep 5 - Family Studies Hall Side Double Sink	ACO11515	0.0007	Passed	0.3200	Passed
Whycocomagh Education Centre	Food Prep 6 - 1st Sink Island Door Side	ACO11516	0.0057	Exceeds Limit	0.3600	Passed
Whycocomagh Education Centre	Food Prep 7 - Island Sink Window Side	ACO11517	0.0044	Passed	0.3500	Passed
Whycocomagh Education Centre	Food Prep 8 - Pre Primary	ACO11518	0.0008	Passed	0.3700	Passed
Whycocomagh Education Centre	Food Prep 9 - Wall Sink Window Side	ACO11519	0.0014	Passed	0.3100	Passed
Whycocomagh Education Centre	Food Prep 10 - Staff Room	ACO11520	0.0007	Passed	0.3900	Passed