

Water Test Results

Conseil scolaire acadien provincial (CSAP)



Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate remediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html

Copper:

www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Beaubassin	Boys washroom 227 Faucet #2	19-2492A	0.0010	Passed	0.0850	Passed
École Beaubassin	Faucet 203	19-2492B	0.0011	Passed	0.0649	Passed
École Beaubassin	Corridor Fountain 228/227	19-2492C	0.0004	Passed	0.0419	Passed
École Beaubassin	Class 118	19-2492D	0.0005	Passed	0.0715	Passed
École Beaubassin	Faucet 216	19-2492E	0.0025	Passed	0.1067	Passed
École Beaubassin	Wash faucet 218b	19-2492F	0.0009	Passed	0.0656	Passed
École Beaubassin	Kitchen faucet middle room	19-2493A	0.0009	Passed	0.0580	Passed
École Beaubassin	Toilet 136 #3	19-2493B	0.0021	Passed	0.0929	Passed
École Beaubassin	Faucet 211	19-2493C	0.0012	Passed	0.1233	Passed
École Beaubassin	Toilet 136 #1	19-2493D	0.0010	Passed	0.0731	Passed
École Beaubassin	Faucet 217	19-2493E	0.0011	Passed	0.1178	Passed
École Beaubassin	Girls washroom 228 faucet #1	19-2493F	0.0013	Passed	0.0816	Passed
École Beaubassin	Toilet 107	19-2494A	0.0015	Passed	0.0543	Passed
École Beaubassin	Toilet 137 #1	19-2494B	0.0012	Passed	0.0533	Passed
École Beaubassin	Toilette cote de 167	19-2494C	0.0012	Passed	0.0527	Passed
École Beaubassin	Recycling 150	19-2494D	0.0026	Passed	0.0852	Passed
École Beaubassin	Girls washroom 228 faucet #2	19-2494E	0.0010	Passed	0.0897	Passed
École Beaubassin	Faucet 204	19-2494F	0.0021	Passed	0.1573	Passed
École Beaubassin	Boys washroom 227 faucet #1	19-2495A	0.0012	Passed	0.1003	Passed
École Beaubassin	Toilet 157	19-2495B	0.0022	Passed	0.1605	Passed
École Beaubassin	Toilet 137 #2	19-2495C	0.0012	Passed	0.0590	Passed
École Beaubassin	Toilet 156	19-2495D	0.0017	Passed	0.0864	Passed
École Beaubassin	Washroom 123A	19-2495E	0.0012	Passed	0.0642	Passed
École Beaubassin	Kitchen 123	19-2495F	0.0010	Passed	0.0447	Passed
École Beaubassin	Toilet 110	19-2496A	0.0010	Passed	0.0540	Passed
École Beaubassin	Toilet 130	19-2496B	0.0038	Passed	0.0655	Passed
École Beaubassin	Corridor faucet 234/233	19-2496C	0.0015	Passed	0.0700	Passed
École Beaubassin	Kitchen faucet dish station	19-2496D	0.0035	Passed	0.0949	Passed
École Beaubassin	Fountain beside gym	19-2496E	0.0013	Passed	0.0579	Passed
École Beaubassin	Girls washroom 234 faucet #1	19-2496F	0.0008	Passed	0.0677	Passed
École Beaubassin	Staff lounge kitchen	19-2497A	0.0005	Passed	0.0341	Passed
École Beaubassin	Toilet 136 #2	19-2497B	0.0016	Passed	0.0749	Passed
École Beaubassin	Toilet 129C	19-2497C	0.0015	Passed	0.0409	Passed
École Beaubassin	Administration washroom	19-2497D	0.0012	Passed	0.0644	Passed
École Beaubassin	Washroom 106	19-2497E	0.0014	Passed	0.0681	Passed
École Beaubassin	Girls washroom 234 faucet #2	19-2497F	0.0051	Exceeds limits	0.1284	Passed
École Beaubassin	Class 132	19-2498A	0.0016	Passed	0.0423	Passed
École Beaubassin	Faucet 210	19-2498B	0.0016	Passed	0.0840	Passed
École Beaubassin	Washroom 104	19-2498C	0.0010	Passed	0.0371	Passed
École Beaubassin	Boys washroom 233 faucet	19-2498D	0.0010	Passed	0.0676	Passed
École Beaubassin	Fountain 131 "pret"	19-2498E	0.0012	Passed	0.1399	Passed
École Beaubassin	Toilet 131	19-2498F	0.0010	Passed	0.0600	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Beaubassin	Kitchen faucet close to door	19-2499A	0.0021	Passed	0.1635	Passed
École Beaubassin	Library faucet	19-2499B	0.0086	Exceeds limits	0.1904	Passed
École Beaubassin	Toilet 129E	19-2499C	0.0012	Passed	0.0824	Passed
École Beaubassin	Toilet 137 #3	19-2499D	0.0013	Passed	0.0775	Passed
École Beaubassin	Class 132	19-2499E	0.0025	Passed	0.0727	Passed
École Beaubassin	Boys washroom 233 faucet #2	19-2499F	0.0013	Passed	0.0995	Passed
École Beaubassin	Library faucet BB	19-2612A	0.0096	Exceeds limits	0.1242	Passed
École Beaubassin	Library faucet BB - 5 mins	19-2612B	0.0096	Exceeds limits	0.0385	Passed
École Beaubassin	Washroom 234 BB sink #2	19-2612C	0.0005	Passed	0.0978	Passed
École Beaubassin	Washroom 234 BB sink #2 - 5 mins	19-2612D	0.0002	Passed	0.0296	Passed
École Beaubassin	Library Tap	19-2755A	0.0083	Exceeds limits	0.3581	Passed
École Beaubassin	Library Tap - 3 min.	19-2755B	0.0003	Passed	0.0648	Passed
École Bois-Joli	Pre School Sink	19-2408A	0.0000	Passed	0.0749	Passed
École Bois-Joli	Pre School Kitchen	19-2408B	0.0001	Passed	0.0844	Passed
École Bois-Joli	Gym fountain	19-2408C	0.0000	Passed	0.0893	Passed
École Bois-Joli	Cafeteria sink	19-2408D	0.0006	Passed	0.1633	Passed
École Bois-Joli	Cafeteria dish tub	19-2408E	0.0017	Passed	0.2727	Passed
École Bois-Joli	Cafeteria dish spray	19-2408F	0.0005	Passed	0.1265	Passed
École Bois-Joli	Fountain 128	19-2408G	0.0000	Passed	0.1781	Passed
École Bois-Joli	Fountain 136	19-2408H	0.0000	Passed	0.1665	Passed
École Bois-Joli	Fountain 233	19-2408I	0.0001	Passed	0.2096	Passed
École Bois-Joli	Staff kitchen sink	19-2408J	0.0003	Passed	0.2957	Passed
École Bois-Joli	Fountain 227	19-2408K	0.0001	Passed	0.0823	Passed
École Bois-Joli	Staff Sink 129	19-2408L	0.0003	Passed	0.2094	Passed
École Bois-Joli	Class 204	19-2541A	0.0025	Passed	0.1508	Passed
École Bois-Joli	Toilet 155	19-2541B	0.0024	Passed	0.3318	Passed
École Bois-Joli	Toilet 136	19-2541C	0.0019	Passed	0.1638	Passed
École Bois-Joli	Toilet 234 #1	19-2541D	0.0006	Passed	0.1271	Passed
École Bois-Joli	Toilet 228 #2	19-2541E	0.0005	Passed	0.1352	Passed
École Bois-Joli	Toilet 130 #2	19-2541F	0.0000	Passed	0.0888	Passed
École Bois-Joli	Class 118 #2	19-2542A	0.0006	Passed	0.3448	Passed
École Bois-Joli	Class 210	19-2542B	0.0013	Passed	0.1331	Passed
École Bois-Joli	Toilet 227 #2	19-2542C	0.0002	Passed	0.1491	Passed
École Bois-Joli	Toilet 228 #1	19-2542D	0.0006	Passed	0.1333	Passed
École Bois-Joli	Class 124 #1	19-2542E	0.0008	Passed	0.1518	Passed
École Bois-Joli	Toilet 227 #1	19-2542F	0.0000	Passed	0.1208	Passed
École Bois-Joli	Toilet 226 A	19-2543A	0.0009	Passed	0.1884	Passed
École Bois-Joli	Toilet 131 #3	19-2543B	0.0008	Passed	0.1317	Passed
École Bois-Joli	Toilet 155	19-2543C	0.0010	Passed	0.1797	Passed
École Bois-Joli	Class 203	19-2543D	0.0005	Passed	0.0862	Passed
École Bois-Joli	Toilet 234	19-2543E	0.0009	Passed	0.1001	Passed
École Bois-Joli	Toilet 137	19-2543F	0.0006	Passed	0.1888	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Bois-Joli	Class 211	19-2544A	0.0010	Passed	0.1373	Passed
École Bois-Joli	Class 217	19-2544B	0.0001	Passed	0.1597	Passed
École Bois-Joli	Class 124	19-2544C	0.0011	Passed	0.1167	Passed
École Bois-Joli	Class 136	19-2544D	0.0010	Passed	0.1391	Passed
École Bois-Joli	Toilet 233	19-2544E	0.0011	Passed	0.1357	Passed
École Bois-Joli	Toilet 137	19-2544F	0.0013	Passed	0.1333	Passed
École Bois-Joli	Toilet 170	19-2545A	0.0011	Passed	0.1253	Passed
École Bois-Joli	Toilet 130 #1	19-2545B	0.0013	Passed	0.1378	Passed
École Bois-Joli	Toilet 233 #2	19-2545C	0.0011	Passed	0.1490	Passed
École Bois-Joli	Classe 111 #1	19-2545D	0.0011	Passed	0.1463	Passed
École Bois-Joli	Toilet 104	19-2545E	0.0020	Passed	0.1048	Passed
École Bois-Joli	Class 118 #1	19-2545F	0.0012	Passed	0.0368	Passed
École Bois-Joli	Toilet 131 #1	19-2546A	0.0014	Passed	0.1203	Passed
École Bois-Joli	Class 216	19-2546B	0.0012	Passed	0.1221	Passed
École Bois-Joli	Class 111	19-2546C	0.0012	Passed	0.0711	Passed
École Bois-Joli	Toilet #2	19-2546D	0.0014	Passed	0.0968	Passed
École Bois-Joli	Toilet 130 #3	19-2546E	0.0007	Passed	0.0954	Passed
École Pubnico-Ouest	#31 - Kitchen	19-2455A	0.0250	Exceeds limits	5.6280	Exceeds Limit
École Pubnico-Ouest	#32 - Girls washroom small board	19-2455B	0.0238	Exceeds limits	0.6222	Passed
École Pubnico-Ouest	#33 - Girls washroom small board	19-2455C	0.0127	Exceeds limits	0.8886	Passed
École Pubnico-Ouest	#34 - Staff lounge small board	19-2455D	0.0860	Exceeds limits	6.7090	Exceeds Limit
École Pubnico-Ouest	#35 - Janitor room small board	19-2455E	0.0893	Exceeds limits	5.8450	Exceeds Limit
École Pubnico-Ouest	#36 - Boys washroom small board	19-2455F	0.0452	Exceeds limits	2.1470	Exceeds Limit
École Pubnico-Ouest	#37 - Boys washroom small board	19-2455G	0.0661	Exceeds limits	0.7927	Passed
École Pubnico-Ouest	#38 - Staff toilet upstairs	19-2455H	0.0819	Exceeds limits	4.7490	Exceeds Limit
École Pubnico-Ouest	#39 - Staff toilet upstairs	19-2455I	0.0866	Exceeds limits	3.1200	Exceeds Limit
École Pubnico-Ouest	#40 - Janitor room hall upstairs	19-2455J	0.3761	Exceeds limits	0.1616	Passed
École Pubnico-Ouest	#41 - Boys washroom large board	19-2456A	0.0270	Exceeds limits	3.2250	Exceeds Limit
École Pubnico-Ouest	#42 - Boys washroom large board	19-2456B	0.1346	Exceeds limits	4.4650	Exceeds Limit
École Pubnico-Ouest	#43 - Boys washroom large board	19-2456C	0.0324	Exceeds limits	3.6140	Exceeds Limit
École Pubnico-Ouest	#44 - Janitor room large board	19-2456D	0.0718	Exceeds limits	5.0520	Exceeds Limit
École Pubnico-Ouest	#45 - Girls washroom large board	19-2456E	0.0525	Exceeds limits	3.1790	Exceeds Limit
École Pubnico-Ouest	#46 - Girls washroom large board	19-2456F	0.0356	Exceeds limits	3.6420	Exceeds Limit
École Pubnico-Ouest	#47 - Girls washroom large board	19-2456G	0.0555	Exceeds limits	4.9640	Exceeds Limit
École Pubnico-Ouest	Girls locker room	19-2536A	0.1838	Exceeds limits	2.1430	Exceeds Limit
École Pubnico-Ouest	Small fountain upstairs	19-2536B	0.0243	Exceeds limits	6.3710	Exceeds Limit
École Pubnico-Ouest	Fountain resource	19-2536C	0.0108	Exceeds limits	3.7040	Exceeds Limit
École Pubnico-Ouest	Fountain resource stag	19-2536D	0.0099	Exceeds limits	1.3180	Passed
École Pubnico-Ouest	High step fountain	19-2536E	0.0788	Exceeds limits	7.8260	Exceeds Limit
École Pubnico-Ouest	Fountain 3/4	19-2536F	0.0072	Exceeds limits	1.2540	Passed
École Pubnico-Ouest	Office fountain	19-2537A	0.0132	Exceeds limits	0.6280	Passed
École Pubnico-Ouest	Water tank boiler room	19-2537B	0.0043	Passed	0.0306	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Pubnico-Ouest	Cafeteria fountain stag	19-2537C	0.0491	Exceeds limits	8.6080	Exceeds Limit
École Pubnico-Ouest	Cafeteria fountain	19-2537D	0.0107	Exceeds limits	1.2870	Passed
École Pubnico-Ouest	High step fountain stag	19-2537E	0.0101	Exceeds limits	1.3170	Passed
École Pubnico-Ouest	Grandir program fountain stag	19-2537F	0.2299	Exceeds limits	5.0010	Exceeds Limit
École Pubnico-Ouest	Fountain stag 3/4	19-2540A	0.0292	Exceeds limits	8.1450	Exceeds Limit
École Pubnico-Ouest	Girls fountain stag	19-2540B	0.0682	Exceeds limits	8.6560	Exceeds Limit
École Pubnico-Ouest	Small fountain upstairs stag	19-2540C	0.0115	Exceeds limits	3.7790	Exceeds Limit
École Pubnico-Ouest	Office fountain stag	19-2540D	0.1340	Exceeds limits	4.8460	Exceeds Limit
École Pubnico-Ouest	Grandir program fountain	19-2540E	0.0286	Exceeds limits	7.1160	Exceeds Limit
École Rose-des-Vents	Fountain C1060	19-2468A	0.0088	Exceeds limits	0.3913	Passed
École Rose-des-Vents	Fountain 2230	19-2468B	0.0097	Exceeds limits	0.5255	Passed
École Rose-des-Vents	2100	19-2468C	0.0103	Exceeds limits	0.6328	Passed
École Rose-des-Vents	2201	19-2468D	0.0143	Exceeds limits	0.2755	Passed
École Rose-des-Vents	1320	19-2468E	0.0088	Exceeds limits	0.5386	Passed
École Rose-des-Vents	1030	19-2468F	0.0075	Exceeds limits	0.4695	Passed
École Rose-des-Vents	Fountain 1090	19-2468G	0.0056	Exceeds limits	0.6660	Passed
École Rose-des-Vents	2150	19-2469A	0.0081	Exceeds limits	0.4813	Passed
École Rose-des-Vents	2080	19-2469B	0.0088	Exceeds limits	0.5296	Passed
École Rose-des-Vents	Fountain (gym)	19-2469C	0.0072	Exceeds limits	0.5013	Passed
École Rose-des-Vents	2170	19-2469D	0.0076	Exceeds limits	0.3924	Passed
École Rose-des-Vents	Fountain 1330	19-2469E	0.0062	Exceeds limits	0.3903	Passed
École Rose-des-Vents	1310	19-2469F	0.0093	Exceeds limits	0.3162	Passed
École Rose-des-Vents	Kitchen AFU	19-2469G	0.0068	Exceeds limits	0.4129	Passed
École Rose-des-Vents	2020	19-2470A	0.0090	Exceeds limits	0.4238	Passed
École Rose-des-Vents	2082	19-2470B	0.0195	Exceeds limits	0.5552	Passed
École Rose-des-Vents	2102	19-2470C	0.0084	Exceeds limits	0.4665	Passed
École Rose-des-Vents	2151	19-2470D	0.0060	Exceeds limits	0.3874	Passed
École Rose-des-Vents	2220 (3)	19-2470E	0.0096	Exceeds limits	0.3706	Passed
École Rose-des-Vents	2250 (7)	19-2470F	0.0150	Exceeds limits	0.3763	Passed
École Rose-des-Vents	1071 (1)	19-2471A	0.0105	Exceeds limits	0.3433	Passed
École Rose-des-Vents	2220 (2)	19-2471B	0.0124	Exceeds limits	0.4555	Passed
École Rose-des-Vents	2250 (4)	19-2471C	0.0093	Exceeds limits	0.3264	Passed
École Rose-des-Vents	2250 (2)	19-2471D	0.0135	Exceeds limits	0.4175	Passed
École Rose-des-Vents	2250 (1)	19-2471E	0.0103	Exceeds limits	0.4271	Passed
École Rose-des-Vents	2081	19-2471F	0.0095	Exceeds limits	0.4702	Passed
École Rose-des-Vents	Grandir en Français	19-2474A	0.0054	Exceeds limits	0.4999	Passed
École Rose-des-Vents	1330	19-2474B	0.0077	Exceeds limits	0.3424	Passed
École Rose-des-Vents	1080 (1)	19-2474C	0.0118	Exceeds limits	0.3011	Passed
École Rose-des-Vents	1321	19-2474D	0.0076	Exceeds limits	0.4569	Passed
École Rose-des-Vents	1071 (2)	19-2474E	0.0156	Exceeds limits	0.3520	Passed
École Rose-des-Vents	1281	19-2474F	0.0074	Exceeds limits	0.3681	Passed
École Rose-des-Vents	Lab	19-2475A	0.0078	Exceeds limits	0.3027	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Rose-des-Vents	Grandir en Français (2)	19-2475B	0.0071	Exceeds limits	0.7167	Passed
École Rose-des-Vents	1073 (3)	19-2475C	0.0113	Exceeds limits	0.4080	Passed
École Rose-des-Vents	1190 (1)	19-2475D	0.0085	Exceeds limits	0.3834	Passed
École Rose-des-Vents	1190 (2)	19-2475E	0.0094	Exceeds limits	0.3965	Passed
École Rose-des-Vents	2171	19-2475F	0.0088	Exceeds limits	0.4503	Passed
École Rose-des-Vents	2250 (3)	19-2476A	0.0139	Exceeds limits	0.4769	Passed
École Rose-des-Vents	1080 (3)	19-2476B	0.0127	Exceeds limits	0.4483	Passed
École Rose-des-Vents	1080 (2)	19-2476C	0.0119	Exceeds limits	0.3959	Passed
École Rose-des-Vents	2030	19-2476D	0.0131	Exceeds limits	0.3883	Passed
École Rose-des-Vents	1015	19-2476E	0.0073	Exceeds limits	0.5062	Passed
École Rose-des-Vents	AFV (1)	19-2476F	0.0065	Exceeds limits	0.3957	Passed
École Rose-des-Vents	Grandir en Français	19-2476G	0.0070	Exceeds limits	0.4426	Passed
École Rose-des-Vents	Cafeteria fountain	19-2554A	0.0237	Exceeds limits	0.6166	Passed
École Rose-des-Vents	Gym fountain	19-2554B	0.0032	Passed	0.5957	Passed
École Rose-des-Vents	Fountain 1080	19-2554C	0.0471	Exceeds limits	14.8900	Exceeds Limit
École Rose-des-Vents	Main entrance	19-2554D	0.0882	Exceeds limits	1.5620	Passed
École Rose-des-Vents	Fountain 1330	19-2554E	0.0222	Exceeds limits	0.9572	Passed
École Rose-des-Vents	Second fountain	19-2554F	0.0030	Passed	0.6654	Passed
École Rose-des-Vents	Main entrance	19-2554G	0.1244	Exceeds limits	1.4010	Passed
École Rose-des-Vents	Flush entrance - 20 min	19-2662A	0.0079	Exceeds limits	0.0080	Passed
École Rose-des-Vents	Flush entrance - 30 min	19-2662B	0.0092	Exceeds limits	0.0252	Passed
École Rose-des-Vents	Recycling room - 132	19-2662C	0.0082	Exceeds limits	0.0456	Passed
École Rose-des-Vents	Kitchen faucet	19-2662D	0.0088	Exceeds limits	0.0701	Passed
École Rose-des-Vents	TWR Main faucet - 1st	19-2662E	0.0127	Exceeds limits	0.5125	Passed
École Rose-des-Vents	WR Man Faucet - 2nd	19-2662F	0.0113	Exceeds limits	0.3761	Passed
École acadienne de Pomquet	Storage tank	20-0764A	0.0025	Passed	0.0043	Passed
École acadienne de Pomquet	Gym washroom fountain	20-0764B	0.0000	Passed	0.4169	Passed
École acadienne de Pomquet	Kitchen sink, right	20-0764C	0.0000	Passed	0.1079	Passed
École acadienne de Pomquet	Kitchen sink, left	20-0764D	0.0000	Passed	0.1209	Passed
École acadienne de Pomquet	Pre softener	20-0764E	0.0000	Passed	0.0250	Passed
École acadienne de Pomquet	HS Wing fountain	20-0764F	0.0015	Passed	0.8281	Passed
École acadienne de Pomquet	Home EC #1 sink	20-0764G	0.0000	Passed	0.3241	Passed
École acadienne de Pomquet	Home EC #2 sink	20-0764H	0.0000	Passed	0.1034	Passed
École acadienne de Pomquet	Home EC #3 sink	20-0764I	0.0000	Passed	0.2276	Passed
École acadienne de Pomquet	Home EC #4 sink	20-0764J	0.0011	Passed	0.3395	Passed
École acadienne de Pomquet	Elementary fountain	20-0764K	0.0118	Exceeds limits	0.6252	Passed
École acadienne de Pomquet	Pre-School (162) sink	20-0764L	0.0000	Passed	0.3232	Passed
École acadienne de Pomquet	Pre-School (101) sink	20-0764M	0.0000	Passed	0.1028	Passed
École acadienne de Pomquet	Staff room sink	20-0764N	0.0001	Passed	0.0959	Passed
École acadienne de Pomquet	Water Distrib. (staff)	20-0764O	0.0000	Passed	0.0000	Passed
École acadienne de Truro	Entrance	20-0749A	0.0000	Passed	0.0025	Passed
École acadienne de Truro	2nd level fountain left	20-0749B	0.0000	Passed	0.2716	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École acadienne de Truro	2nd level fountain right	20-0749C	0.0000	Passed	0.3842	Passed
École acadienne de Truro	Sink kitchen	20-0749D	0.0000	Passed	2.4510	Exceeds Limit
École acadienne de Truro	Family study	20-0749E	0.0001	Passed	2.9720	Exceeds Limit
École acadienne de Truro	Kitchen sink	20-0749F	0.0018	Passed	6.6730	Exceeds Limit
École acadienne de Truro	Staff room sink	20-0749G	0.0000	Passed	2.6500	Exceeds Limit
École acadienne de Truro	Fountain 1st level	20-0749H	0.0046	Passed	0.4083	Passed
École acadienne de Truro	New corridor	20-0749I	0.0000	Passed	0.7013	Passed
École acadienne de Truro	Lower level fountain elementary wing	20-0749J	0.0037	Passed	0.6537	Passed
École acadienne de Truro	Upper level new fountain elementary wing	20-0749K	0.0016	Passed	0.4945	Passed
École acadienne de Truro	Upper level fountain elementary wing	20-0749L	0.0015	Passed	0.4389	Passed
École acadienne de Truro	Lower new wing	20-0749M	0.0000	Passed	0.8922	Passed
École acadienne de Truro	Upper new wing	20-0749N	0.0003	Passed	0.8659	Passed
École acadienne de Truro	Day care	20-0749O	0.0013	Passed	5.4240	Exceeds Limit
École acadienne de Truro	GF sink	20-0749P	0.0053	Exceeds limits	1.1850	Passed
École Beau-Port		20-0765A	0.0195	Exceeds limits	0.2508	Passed
École Beau-Port	DS Fountain music	20-0765B	0.0056	Exceeds limits	0.7612	Passed
École Beau-Port	Pre-primary sink right	20-0765C	0.0013	Passed	0.0633	Passed
École Beau-Port	Pre-primary sink left	20-0765D	0.0033	Passed	0.0641	Passed
École Beau-Port	DS fountain pre-primary	20-0765E	0.0414	Exceeds limits	0.1823	Passed
École Beau-Port	Cafeteria fountain	20-0765F	0.0191	Exceeds limits	1.3520	Passed
École Beau-Port	Cafeteria kitchen sink right	20-0765G	0.0175	Exceeds limits	0.1218	Passed
École Beau-Port	Cafeteria kitchen sink right	20-0765H	0.0098	Exceeds limits	0.1292	Passed
École Beau-Port	Smoothie bar sink	20-0765I	0.0076	Exceeds limits	0.1329	Passed
École Beau-Port	Home EC sink - Access	20-0765J	0.0032	Passed	0.0882	Passed
École Beau-Port	Home EC back right sink	20-0765K	0.0005	Passed	0.1056	Passed
École Beau-Port	Home EC sink cafeteria door	20-0765L	0.0001	Passed	0.1049	Passed
École Beau-Port	Day care kitchen sink left	20-0765M	0.0000	Passed	0.0638	Passed
École Beau-Port	Day care kitchen sink right	20-0765N	0.0010	Passed	0.0648	Passed
École Beau-Port	Staff room sink	20-0765O	0.0000	Passed	0.0953	Passed
École Beau-Port	US fountain 221	20-0765P	0.0176	Exceeds limits	1.2580	Passed
École Beau-Port	US fountain 205	20-0765Q	0.0030	Passed	0.7997	Passed
École des Beaux-Marais	Boiler Room	20-0736A	0.5973	Exceeds limits	2.2460	Exceeds Limit
École des Beaux-Marais	Staff	20-0736B	0.0149	Exceeds limits	0.2620	Passed
École des Beaux-Marais	GF Class	20-0736C	0.0021	Passed	0.1140	Passed
École des Beaux-Marais	Main st Fountain	20-0736D	0.0000	Passed	0.0552	Passed
École des Beaux-Marais	2nd Fountain	20-0736E	0.0000	Passed	0.8359	Passed
École des Beaux-Marais	1st Tony Fountain	20-0736F	0.0002	Passed	0.1520	Passed
École des Beaux-Marais	Main	20-1711A	0.0134	Exceeds limits	15.2800	Exceeds Limit
École des Beaux-Marais	Main - 5 minutes	20-1711B	0.0015	Passed	0.0338	Passed
École des Beaux-Marais	Staff faucet	20-1711C	0.0107	Exceeds limits	0.1520	Passed
École Belleville	Main	20-0730A	0.1096	Exceeds limits	0.2213	Passed
École Belleville	Primary	20-0730B	0.0255	Exceeds limits	0.0155	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Belleville	First year	20-0730C	0.0157	Exceeds limits	0.0416	Passed
École Belleville	Kitchen beside dishwasher	20-0730D	0.0041	Passed	0.0384	Passed
École Belleville	Kitchen beside stove	20-0730E	0.0062	Exceeds limits	0.0152	Passed
École Belleville	Grandir en Français	20-0730F	0.0382	Exceeds limits	0.0161	Passed
École Belleville	Grandir en Français 114	20-0730G	0.0171	Exceeds limits	0.0263	Passed
École Belleville	Teachers Lounge	20-0730H	0.0099	Exceeds limits	0.0284	Passed
École Belleville	Gym fountain	20-0730I	0.0010	Passed	0.0116	Passed
École Belleville	Fountain for older children	20-0730J	0.0039	Passed	0.0243	Passed
École Belleville	Fountain for younger children	20-0730K	0.0006	Passed	0.0107	Passed
École du Carrefour	Main 1137	20-0739A	0.1019	Exceeds limits	0.3030	Passed
École du Carrefour	Kitchen 1132	20-0739B	0.0031	Passed	0.1955	Passed
École du Carrefour	Fountain 1140	20-0739C	0.0260	Exceeds limits	0.9522	Passed
École du Carrefour	Central fountain	20-0739D	0.0000	Passed	0.1155	Passed
École du Carrefour	Kitchen 1096	20-0739E	0.0000	Passed	0.1432	Passed
École du Carrefour	Faucet #1 day care 1121A	20-0739F	0.0000	Passed	0.1780	Passed
École du Carrefour	#2 day care 1121A	20-0739G	0.0003	Passed	0.1795	Passed
École du Carrefour	Cafeteria #1	20-0739H	0.0006	Passed	0.1121	Passed
École du Carrefour	Cafeteria #2	20-0739I	0.0030	Passed	0.3961	Passed
École du Carrefour	Library 1081	20-0739J	0.0007	Passed	0.3434	Passed
École du Carrefour	Gym for boys	20-0739K	0.0006	Passed	0.4243	Passed
École du Carrefour	Gym for girls	20-0739L	0.0002	Passed	0.4294	Passed
École du Carrefour	Faucet 1011	20-0739M	0.0042	Passed	0.3813	Passed
École du Carrefour	Faucet 1010	20-0739N	0.0020	Passed	0.2021	Passed
École du Carrefour	Faucet 1029	20-0739O	0.0011	Passed	0.4548	Passed
École du Carrefour	Faucet 1027	20-0740A	0.0048	Passed	0.5852	Passed
École du Carrefour	Faucet 2016	20-0740B	0.0007	Passed	0.3874	Passed
École du Carrefour	Faucet 2017	20-0740C	0.0036	Passed	0.6290	Passed
École du Carrefour	Faucet 2013	20-0740D	0.0000	Passed	0.1176	Passed
École du Carrefour	Faucet 2005	20-0740E	0.0000	Passed	0.2191	Passed
École du Carrefour	Faucet 2036	20-0740F	0.0054	Exceeds limits	0.5285	Passed
École du Carrefour	Faucet Pavillon only	20-0740G	0.0000	Passed	0.0211	Passed
École du Carrefour	Faucet kitchen	20-0740H	0.0000	Passed	0.0101	Passed
École du Carrefour	Pavillon #1	20-0740I	0.0004	Passed	0.0163	Passed
École du Carrefour	Pavillon #2	20-0740J	0.0012	Passed	0.0393	Passed
École du Carrefour	Pavillon #3	20-0740K	0.0004	Passed	0.0351	Passed
École du Carrefour	Pavillon #4	20-0740L	0.0010	Passed	0.0288	Passed
École du Carrefour	Main	20-1575A	0.0167	Exceeds limits	0.0146	Passed
École du Carrefour	Main - 5 minutes	20-1575B	0.0012	Passed	0.0179	Passed
École du Carrefour	Fountain 1140	20-1575C	0.0014	Passed	0.0106	Passed
École secondaire du Sommet	Main	20-0743A	0.0050	Passed	0.0584	Passed
École secondaire du Sommet	Fountain corridor skilled trades	20-0743B	0.0001	Passed	0.1042	Passed
École secondaire du Sommet	Gym fountain	20-0743C	0.0000	Passed	0.1288	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École secondaire du Sommet	Teachers room	20-0743D	0.0000	Passed	0.1698	Passed
École secondaire du Sommet	Faucet 1103	20-0743E	0.0000	Passed	0.1645	Passed
École secondaire du Sommet	Fountain 1106	20-0743F	0.0000	Passed	0.1012	Passed
École secondaire du Sommet	Cafeteria Island	20-0743G	0.0000	Passed	0.0901	Passed
École secondaire du Sommet	Cafeteria Faucet bin	20-0743H	0.0004	Passed	0.1073	Passed
École secondaire du Sommet	Day care kitchen	20-0743I	0.0000	Passed	0.0979	Passed
École secondaire du Sommet	Day care kitchen #2	20-0743J	0.0000	Passed	0.1155	Passed
École secondaire du Sommet	Day care 1033	20-0743K	0.0004	Passed	0.2822	Passed
École secondaire du Sommet	Day care 1037	20-0743L	0.0000	Passed	0.1522	Passed
École secondaire du Sommet	6F - 1035	20-0743M	0.0007	Passed	0.2516	Passed
École secondaire du Sommet	6F - 1031	20-0743N	0.0000	Passed	0.2405	Passed
École secondaire du Sommet	Family 2019 #1	20-0743O	0.0004	Passed	0.1767	Passed
École secondaire du Sommet	Family 2019 #2	20-0743P	0.0004	Passed	0.1314	Passed
École secondaire du Sommet	Family 2019 #3	20-0743Q	0.0004	Passed	0.1678	Passed
École secondaire du Sommet	Family 2019 #4	20-0743R	0.0003	Passed	0.1546	Passed
École secondaire du Sommet	Fountain 2026	20-0743S	0.0000	Passed	0.1410	Passed
École secondaire du Sommet	Fountain 2015	20-0743T	0.0004	Passed	0.1096	Passed
École secondaire de Clare	Library	20-0752A	0.0042	Passed	0.2833	Passed
École secondaire de Clare	Fountain 237	20-0752B	0.0014	Passed	0.4228	Passed
École secondaire de Clare	Cafeteria	20-0752C	0.0014	Passed	0.2553	Passed
École secondaire de Clare	Fountain 211	20-0752D	0.0018	Passed	1.5620	Passed
École secondaire de Clare	Gym fountain	20-0752E	0.0000	Passed	0.1729	Passed
École secondaire de Clare	Office fountain	20-0752F	0.0017	Passed	0.4940	Passed
École secondaire de Clare	Home EC 1	20-0752G	0.0045	Passed	0.2763	Passed
École secondaire de Clare	Home EC 2	20-0752H	0.0048	Passed	0.4287	Passed
École secondaire de Clare	Teacher Staff	20-0752I	0.0041	Passed	0.3780	Passed
École secondaire de Clare	Office	20-0752J	0.0001	Passed	0.4395	Passed
École secondaire de Clare	Janitor Mildred	20-0752K	0.0098	Exceeds limits	0.4369	Passed
École secondaire de Clare	Centre	20-0752L	0.0014	Passed	0.4698	Passed
École secondaire de Clare	Sink Dishwasher	20-0752M	0.0011	Passed	0.1978	Passed
École secondaire de Clare	Fountain 142	20-0752N	0.0003	Passed	0.5415	Passed
École secondaire de Clare	Kitchen main	20-0752O	0.0003	Passed	0.0966	Passed
École secondaire de Clare	Mildred lounge upstairs	20-0752P	0.0000	Passed	0.0000	Passed
École secondaire de Clare	Vegeterian cuisine sink	20-0752Q	0.0005	Passed	0.2842	Passed
École secondaire de Clare	Main kitchen sink	20-0752R	0.0000	Passed	0.3185	Passed
École secondaire de Clare	Main	20-0752S	0.1530	Exceeds limits	0.6430	Passed
École secondaire de Clare	Kitchen sink fridge	20-0752T	0.0000	Passed	0.4237	Passed
Centre scolaire Étoile de l'Acadie	Main custodian sink	20-0791A	0.0012	Passed	0.1611	Passed
Centre scolaire Étoile de l'Acadie	Fountain dungeon	20-0791B	0.0012	Passed	0.1603	Passed
Centre scolaire Étoile de l'Acadie	Grandir program food sink	20-0791C	0.0010	Passed	0.3449	Passed
Centre scolaire Étoile de l'Acadie	Fountain new element	20-0791D	0.0028	Passed	0.5075	Passed
Centre scolaire Étoile de l'Acadie	Fountain new HS	20-0791E	0.0015	Passed	0.7074	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Centre scolaire Étoile de l'Acadie	Home EC / Staff 1st	20-0791F	0.0011	Passed	0.4977	Passed
Centre scolaire Étoile de l'Acadie	Fountain bottle HS	20-0791G	0.0010	Passed	0.1991	Passed
Centre scolaire Étoile de l'Acadie	Kitchen sink right	20-0791H	0.0005	Passed	0.0009	Passed
Centre scolaire Étoile de l'Acadie	Kitchen sink left	20-0791I	0.0005	Passed	0.0009	Passed
Centre scolaire Étoile de l'Acadie	École plus sink	20-0791J	0.0004	Passed	0.0009	Passed
Centre scolaire Étoile de l'Acadie	Day care kitchen sink	20-0791K	0.0005	Passed	0.0008	Passed
Centre scolaire Étoile de l'Acadie	Fountain gym	20-0791L	0.0004	Passed	0.0007	Passed
École du Grand Portage	Main boiler room	20-0738A	0.0039	Passed	0.0382	Passed
École du Grand Portage	Fountain mail	20-0738B	0.0006	Passed	0.0822	Passed
École du Grand Portage	GF #1	20-0738C	0.0000	Passed	0.1830	Passed
École du Grand Portage	GF #2	20-0738D	0.0000	Passed	0.1654	Passed
École du Grand Portage	GF kitchen	20-0738E	0.0000	Passed	0.1660	Passed
École du Grand Portage	2nd fountain	20-0738F	0.0000	Passed	0.0712	Passed
École du Grand Portage	3rd fountain	20-0738G	0.0001	Passed	0.1029	Passed
École du Grand Portage	Teachers room	20-0738H	0.0008	Passed	0.1484	Passed
École Joseph-Dugas	Office staff	20-0751A	0.0031	Passed	0.1315	Passed
École Joseph-Dugas	Office	20-0751B	0.0006	Passed	0.0362	Passed
École Joseph-Dugas	Fountain #1	20-0751C	0.0008	Passed	0.0473	Passed
École Joseph-Dugas	Fountain #2 refrigerated	20-0751D	0.0004	Passed	0.0902	Passed
École Joseph-Dugas	Fountain #3	20-0751E	0.0021	Passed	0.0336	Passed
École Joseph-Dugas	Fountain #4	20-0751F	0.0030	Passed	0.1806	Passed
École Joseph-Dugas	Main	20-0751G	0.0023	Passed	0.0552	Passed
École Joseph-Dugas	Handwash	20-0751H	0.0012	Passed	0.0754	Passed
École Joseph-Dugas	Teachers room	20-0751I	0.0023	Passed	0.0926	Passed
École Joseph-Dugas	Day care kitchen	20-0751J	0.0006	Passed	0.0993	Passed
École Joseph-Dugas	Dishwasher sink	20-0751K	0.0022	Passed	0.0349	Passed
École Joseph-Dugas	Day care	20-0751L	0.0055	Exceeds limits	0.1407	Passed
École Joseph-Dugas	Mariette sink	20-0751M	0.0000	Passed	0.0015	Passed
École Mer et Monde	Main basement	20-0737A	0.1757	Exceeds limits	0.5034	Passed
École Mer et Monde	Kitchen	20-0737B	0.0056	Exceeds limits	0.0932	Passed
École Mer et Monde	6F 110	20-0737C	0.0065	Exceeds limits	0.1627	Passed
École Mer et Monde	Central faucet	20-0737D	0.0035	Passed	0.0983	Passed
École Mer et Monde	Main central fountain	20-0737E	0.0000	Passed	0.0801	Passed
École Mer et Monde	6F 109	20-0737F	0.0053	Exceeds limits	0.1071	Passed
École Mer et Monde	Gym fountain	20-0737G	0.0000	Passed	0.1383	Passed
École Mer et Monde	2nd fountain	20-0737H	0.0000	Passed	0.0880	Passed
École Mer et Monde	Teachers room fountain	20-0737I	0.0016	Passed	0.4461	Passed
École Mer et Monde	Teachers room faucet	20-0737J	0.0494	Exceeds limits	0.1290	Passed
École Mer et Monde	Main	20-1574A	0.0087	Exceeds limits	0.0118	Passed
École Mer et Monde	Main - 5 minutes	20-1574B	0.0045	Passed	0.0140	Passed
École Mer et Monde	GF 110	20-1574C	0.0087	Exceeds limits	0.1517	Passed
École Mer et Monde	Kitchen	20-1574D	0.0056	Exceeds limits	0.1211	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
École Mer et Monde	Staff lounge	20-1574E	0.0109	Exceeds limits	0.1364	Passed
École NDA	Water main boiler room	20-0790A	0.0011	Passed	0.0736	Passed
École NDA	Fountain technology	20-0790B	0.0023	Passed	0.0811	Passed
École NDA	Fountain gym/cafeteria	20-0790C	0.0030	Passed	0.1592	Passed
École NDA	Cafeteria kitchen Island sink	20-0790D	0.0023	Passed	0.1584	Passed
École NDA	Fountain music	20-0790E	0.0011	Passed	0.0385	Passed
École NDA	Home EC Fridge sink	20-0790F	0.0047	Passed	0.5719	Passed
École NDA	Home EC Centre sink	20-0790G	0.0029	Passed	0.2113	Passed
École NDA	Home EC sink center windows	20-0790H	0.0050	Passed	0.2637	Passed
École NDA	Home EC sink windows	20-0790I	0.0047	Passed	0.3502	Passed
École NDA	Day care kitchen sink	20-0790J	0.0017	Passed	0.1636	Passed
École NDA	Fountain IPLE	20-0790K	0.0021	Passed	0.0769	Passed
École NDA	Staff room sink	20-0790L	0.0018	Passed	0.1728	Passed
École NDA	Grandir program fountain	20-0790M	0.0043	Passed	0.2280	Passed
École NDA	Grandir program sink	20-0790N	0.0036	Passed	0.0552	Passed
École NDA	Auditorium fountain	20-0790O	0.0024	Passed	0.0809	Passed
École Pubnico-Ouest	Grandir en Français	20-0731A	0.0202	Exceeds limits	3.4110	Exceeds Limit
École Pubnico-Ouest	Art room	20-0731B	0.0065	Exceeds limits	2.9230	Exceeds Limit
École Pubnico-Ouest	South lower	20-0731C	0.0234	Exceeds limits	3.3110	Exceeds Limit
École Pubnico-Ouest	Kitchen South	20-0731D	0.0042	Passed	3.9750	Exceeds Limit
École Pubnico-Ouest	Kitchen North	20-0731E	0.0054	Exceeds limits	1.0290	Passed
École Pubnico-Ouest	Locker room girls	20-0731F	0.0466	Exceeds limits	6.3910	Exceeds Limit
École Pubnico-Ouest	Northeast lower	20-0731G	0.0162	Exceeds limits	3.2560	Exceeds Limit
École Pubnico-Ouest	Day care	20-0731H	0.0302	Exceeds limits	0.5285	Passed
École Pubnico-Ouest	Teachers lounge	20-0731I	0.0150	Exceeds limits	0.3519	Passed
École Pubnico-Ouest	Upstairs Northeast	20-0731J	0.0000	Passed	0.8417	Passed
École Pubnico-Ouest	Office	20-0731K	0.0199	Exceeds limits	3.1230	Exceeds Limit
École Pubnico-Ouest	Upstairs beside ventilation	20-0731L	0.0125	Exceeds limits	4.3610	Exceeds Limit
École Pubnico-Ouest	Main	20-0731M	0.0373	Exceeds limits	0.4135	Passed
École Pubnico-Ouest	Kitchen utility	20-0731N	0.0642	Exceeds limits	3.2060	Exceeds Limit
École Pubnico-Ouest	Upstairs main door	20-0731O	0.0004	Passed	0.3954	Passed
École Pubnico-Ouest	Upstairs South	20-0731P	0.0027	Passed	0.8174	Passed
Centre scolaire de la Rive-Sud	Main	20-0742A	0.0003	Passed	0.0043	Passed
Centre scolaire de la Rive-Sud	Fountain 130	20-0742B	0.0000	Passed	0.1938	Passed
Centre scolaire de la Rive-Sud	Cafeteria	20-0742C	0.0000	Passed	0.1431	Passed
Centre scolaire de la Rive-Sud	Sink #1 - 220	20-0742D	0.0000	Passed	0.1175	Passed
Centre scolaire de la Rive-Sud	#2 - 220	20-0742E	0.0001	Passed	0.0686	Passed
Centre scolaire de la Rive-Sud	#3 - 220	20-0742F	0.0001	Passed	0.1205	Passed
Centre scolaire de la Rive-Sud	Fountain 225	20-0742G	0.0000	Passed	0.0969	Passed
Centre scolaire de la Rive-Sud	Teachers room	20-0742H	0.0000	Passed	0.1848	Passed
Centre scolaire de la Rive-Sud	Day care 162	20-0742I	0.0001	Passed	0.3202	Passed
Centre scolaire de la Rive-Sud	Day care 167	20-0742J	0.0011	Passed	0.3012	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Centre scolaire de la Rive-Sud	Day care 169	20-0742K	0.0011	Passed	0.2866	Passed
Centre scolaire de la Rive-Sud	Kitchen 164	20-0742L	0.0008	Passed	0.2239	Passed
Centre scolaire de la Rive-Sud	6F - 155	20-0742M	0.0000	Passed	0.2106	Passed
Centre scolaire de la Rive-Sud	6F - 151	20-0742N	0.0000	Passed	0.2512	Passed
Centre scolaire de la Rive-Sud	Marc Dan	20-0742O	0.0000	Passed	0.0009	Passed
École secondaire de Par-en-Bas	Kitchen 1	20-0729A	0.0039	Passed	0.5959	Passed
École secondaire de Par-en-Bas	Kitchen 2	20-0729B	0.0033	Passed	0.1303	Passed
École secondaire de Par-en-Bas	Kitchen 3	20-0729C	0.0056	Exceeds limits	0.6895	Passed
École secondaire de Par-en-Bas	Boys locker room	20-0729D	0.0036	Passed	1.2880	Passed
École secondaire de Par-en-Bas	Girls locker room	20-0729E	0.0040	Passed	1.4370	Passed
École secondaire de Par-en-Bas	Cafeteria fountain	20-0729F	0.0005	Passed	0.4297	Passed
École secondaire de Par-en-Bas	Seniors fountain	20-0729G	0.0010	Passed	0.4957	Passed
École secondaire de Par-en-Bas	Nutrition 1	20-0729H	0.0045	Passed	0.7565	Passed
École secondaire de Par-en-Bas	Nutrition 2	20-0729I	0.0035	Passed	1.1130	Passed
École secondaire de Par-en-Bas	Nutrition 3	20-0729J	0.0039	Passed	0.6929	Passed
École secondaire de Par-en-Bas	Nutrition 4	20-0729K	0.0037	Passed	1.0220	Passed
École secondaire de Par-en-Bas	Room 113	20-0729L	0.0094	Exceeds limits	0.4327	Passed
École secondaire de Par-en-Bas	Conference Centre	20-0729M	0.0065	Exceeds limits	0.5145	Passed
École secondaire de Par-en-Bas	Teachers lounge	20-0729N	0.0051	Exceeds limits	0.7008	Passed
École secondaire de Par-en-Bas	Day care 1	20-0729O	0.0039	Passed	0.6601	Passed
École secondaire de Par-en-Bas	Day care stove	20-0729P	0.0088	Exceeds limits	0.7568	Passed
École secondaire de Par-en-Bas	Office	20-0729Q	0.0038	Passed	1.3440	Passed
École secondaire de Par-en-Bas	Plastic arts	20-0729R	0.0038	Passed	0.5154	Passed
École secondaire de Par-en-Bas	Youth center 121	20-0729S	0.0048	Passed	0.7740	Passed
École secondaire de Par-en-Bas	Main	20-0729T	0.0101	Exceeds limits	0.4836	Passed
École secondaire de Par-en-Bas	Junior fountain	20-0729U	0.0006	Passed	0.2879	Passed
École Stella-Maris	Primary sink	20-0750A	0.0117	Exceeds limits	0.8208	Passed
École Stella-Maris	Main	20-0750B	0.1101	Exceeds limits	0.8736	Passed
École Stella-Maris	Natalie Leblanc	20-0750C	0.0061	Exceeds limits	0.6672	Passed
École Stella-Maris	Handwashing kitchen	20-0750D	0.0015	Passed	0.7058	Passed
École Stella-Maris	Kitchen (1) main	20-0750E	0.0052	Exceeds limits	0.5033	Passed
École Stella-Maris	Teachers lounge	20-0750F	0.0381	Exceeds limits	1.6430	Passed
École Stella-Maris	Primary fountain	20-0750G	0.0084	Exceeds limits	0.6847	Passed
École Stella-Maris	Gym fountain	20-0750H	0.0099	Exceeds limits	0.7268	Passed
Centre le Tournesol	Main basement	20-0741A	0.0008	Passed	0.0256	Passed
Centre le Tournesol	GF #1	20-0741B	0.0003	Passed	0.2265	Passed
Centre le Tournesol	GF #2	20-0741C	0.0006	Passed	0.1936	Passed
Centre le Tournesol	GF #3	20-0741D	0.0048	Passed	0.3385	Passed
Centre le Tournesol	GF #4	20-0741E	0.0040	Passed	0.2734	Passed
Centre le Tournesol	Main kitchen	20-0741F	0.0013	Passed	0.2288	Passed
Centre le Tournesol	Kitchen #2	20-0741G	0.0012	Passed	0.5065	Passed
Centre le Tournesol	Iplee	20-0741H	0.0024	Passed	0.1170	Passed

Conseil scolaire acadien provincial (CSAP)

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Centre le Tournesol	Second kitchen	20-0741I	0.0000	Passed	0.0829	Passed
École Wedgeport	Kitchen 1	20-0732A	0.0029	Passed	0.6914	Passed
École Wedgeport	Kitchen 2	20-0732B	0.0194	Exceeds limits	0.3880	Passed
École Wedgeport	Gym fountain	20-0732C	0.0075	Exceeds limits	2.4770	Exceeds Limit
École Wedgeport	Fountain upstairs	20-0732D	0.0316	Exceeds limits	11.9600	Exceeds Limit
École Wedgeport	Main	20-0732E	0.0126	Exceeds limits	0.2797	Passed
École Wedgeport	Grandir en Français	20-0732F	0.0347	Exceeds limits	1.9530	Passed
École Wedgeport	Large corridor fountain	20-0732G	0.0122	Exceeds limits	0.2984	Passed