

Water Test Results

Tri-County Regional Centre for Education



Introduction

In December of 2019, the Province of Nova Scotia committed to testing the water in all public schools across Nova Scotia after Health Canada revised its guidelines related to lead concentration levels in water. Health Canada also revised its guidelines related to copper concentration levels in water, and copper tests were also conducted. To ensure that parents were confident in the availability of safe drinking water, the government also put bottled water in every public school in Nova Scotia. This water will remain in place until appropriate remediation steps are taken.

In the meantime, Regional Centres of Education (RCEs) and Conseil scolaire acadien provincial (CSAP) have taken steps to remove access to any other water source until test results were received, and appropriate remediation steps can be taken.

Nova Scotia's Results

Nova Scotia is committed to supplying clean drinkable water to our staff and students at our public schools.

Currently, all schools receive clean drinking water. This will not change.

The following pages include the water test results for all schools in this region. To find results for a particular school, press the Ctrl or Command key and F to reveal the search menu. Schools are also listed in alphabetical order for quick reference. Data captured includes school name, location of the water source in the school, the sample ID code for the water system/plumbing route tested, and the concentration of lead and copper.

Concentrations of lead and copper are presented in milligrams per litre (mg/L). Health Canada's maximum acceptable concentration of lead in drinking water is 0.0050 mg/L; the maximum acceptable concentration of copper in drinking water is 2.0000 mg/L. The data also shows where the water "passed" the test, or if the water "exceed limits." Water taps that exceed lead and/or copper limits will not be used for drinking water. These taps will be either replaced, disconnected, taped off, or restricted to hand washing only.

Next Steps

Nova Scotia continues to deal with restrictions based on COVID-19. This means there is no access to school water fountains. Bottled water continues to be available to staff and students. Moving forward, schools will continue to receive bottled water until appropriate remediation is completed.

Nova Scotia's remediation plan for school water includes the following measures:

- ongoing remediation of water taps, plumbing and/or pipes
- restrict access to water taps that do not meet Health Canada guidelines
- ongoing communication with students and staff about water safety efforts at their school

Information about individual schools and updates on remediation can be found on your REC/CSAP website. For additional information about schools in your region, please contact your region or CSAP.

For more information about Health Canada's guidelines related to lead and copper, go to the following sites:

Lead:

www.canada.ca/en/health-canada/news/2019/03/health-canada-sets-new-guideline-for-lead-in-drinking-water-latest-in-series-of-government-actions-to-protect-canadians-from-exposure-to-lead.html

Copper:

www.canada.ca/en/health-canada/services/publications/healthy-living/water-talk-copper.html#a3

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Barrington Municipal High School	Bathroom Faucet	BH10-BF-P-001	0.0560	Exceeds Limit	3.7750	Exceeds Limit
Barrington Municipal High School	Staff Faucet	BH11-SF-P-001	0.0830	Exceeds Limit	4.7130	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH12-BF-P-001	0.0110	Exceeds Limit	2.8130	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH13-BF-P-001	0.0180	Exceeds Limit	1.8030	Passed
Barrington Municipal High School	Staff Faucet	BH14-SF-P-001	0.0130	Exceeds Limit	1.4590	Passed
Barrington Municipal High School	Water Fountain	BH15-WF-P-001	0.0010	Passed	0.0200	Passed
Barrington Municipal High School	Bathroom Faucet	BH16-BF-P-001	0.0170	Exceeds Limit	2.4700	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH17-BF-P-001	0.0420	Exceeds Limit	1.5040	Passed
Barrington Municipal High School	Bathroom Faucet	BH18-BF-P-001	0.0590	Exceeds Limit	1.3070	Passed
Barrington Municipal High School	Water Fountain	BH19-WF-P-001	0.0020	Passed	4.8810	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH1-BF-P-001	0.0240	Exceeds Limit	2.3930	Exceeds Limit
Barrington Municipal High School	Water Fountain	BH20-WF-P-001	0.0670	Exceeds Limit	1.6870	Passed
Barrington Municipal High School	Bathroom Faucet	BH21-BF-P-001	0.0500	Exceeds Limit	2.9610	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH22-CF-P-001	0.0610	Exceeds Limit	4.0390	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH23-BF-P-001	0.0120	Exceeds Limit	1.9910	Passed
Barrington Municipal High School	Water Fountain	BH24-WF-P-001	0.0040	Passed	10.7500	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH25-BF-P-001	0.0500	Exceeds Limit	1.0500	Passed
Barrington Municipal High School	Bathroom Faucet	BH26-BF-P-001	0.0290	Exceeds Limit	2.1780	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH27-BF-P-001	0.0260	Exceeds Limit	1.5870	Passed
Barrington Municipal High School	Bathroom Faucet	BH28-BF-P-001	0.0310	Exceeds Limit	1.4720	Passed
Barrington Municipal High School	Bathroom Faucet	BH29-BF-P-001	0.0290	Exceeds Limit	3.0830	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH2-BF-P-001	0.0380	Exceeds Limit	1.1080	Passed
Barrington Municipal High School	Classroom Faucet	BH30.1-CF-P-001	0.0050	Passed	3.1540	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH30-BF-P-001	0.0360	Exceeds Limit	2.4430	Exceeds Limit
Barrington Municipal High School	Custodial Sink	BH31.1-CS-P-001	0.0230	Exceeds Limit	2.1920	Exceeds Limit
Barrington Municipal High School	Custodial Sink	BH31-CS-P-001	0.0270	Exceeds Limit	4.3900	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH32-BF-P-001	0.0180	Exceeds Limit	1.5130	Passed
Barrington Municipal High School	Kitchen Faucet	BH33-KF-P-001	0.0180	Exceeds Limit	1.9340	Passed
Barrington Municipal High School	Kitchen Faucet	BH34.1-KF-P-001	0.0080	Exceeds Limit	1.4220	Passed
Barrington Municipal High School	Kitchen Faucet	BH34-KF-P-001	0.0140	Exceeds Limit	2.7800	Exceeds Limit
Barrington Municipal High School	Kitchen Faucet	BH35-KF-P-001	0.0980	Exceeds Limit	4.7660	Exceeds Limit
Barrington Municipal High School	Custodial Sink	BH36-CS-P-001	0.0100	Exceeds Limit	1.5270	Passed
Barrington Municipal High School	Classroom Faucet	BH37-CF-P-002	0.0150	Exceeds Limit	1.9970	Passed
Barrington Municipal High School	Classroom Faucet	BH38-CF-P-002	0.0100	Exceeds Limit	1.6070	Passed
Barrington Municipal High School	Bathroom Faucet	BH39-BF-P-002	0.0180	Exceeds Limit	1.7700	Passed
Barrington Municipal High School	Bathroom Faucet	BH3-BF-P-001	0.0720	Exceeds Limit	2.6550	Exceeds Limit
Barrington Municipal High School	Water Fountain	BH40-WF-P-002	0.0010	Passed	2.2310	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH41-BF-P-002	0.0310	Exceeds Limit	1.9050	Passed
Barrington Municipal High School	Bathroom Faucet	BH42-BF-P-002	0.0200	Exceeds Limit	1.1030	Passed
Barrington Municipal High School	Bathroom Faucet	BH43-BF-P-002	0.0400	Exceeds Limit	1.7810	Passed
Barrington Municipal High School	Bathroom Faucet	BH44-BF-P-002	0.0300	Exceeds Limit	2.1890	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH45-BF-P-002	0.0430	Exceeds Limit	2.3460	Exceeds Limit

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Barrington Municipal High School	Bathroom Faucet	BH46-BF-P-002	0.0390	Exceeds Limit	2.3780	Exceeds Limit
Barrington Municipal High School	Custodial Sink	BH47-CS-P-002	0.0240	Exceeds Limit	2.6850	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH48-CF-P-002	0.0600	Exceeds Limit	3.7790	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH49-CF-P-002	0.0280	Exceeds Limit	2.6880	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH4-BF-P-001	0.0400	Exceeds Limit	2.2710	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH50-CF-P-002	0.0290	Exceeds Limit	2.5880	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH51-CF-P-002	0.0820	Exceeds Limit	4.3370	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH52-CF-P-002	0.0720	Exceeds Limit	2.0040	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH53-CF-P-002	0.0250	Exceeds Limit	0.5860	Passed
Barrington Municipal High School	Classroom Faucet	BH54-CF-P-002	0.0780	Exceeds Limit	2.1780	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH55-CF-P-002	0.0350	Exceeds Limit	1.3810	Passed
Barrington Municipal High School	Bathroom Faucet	BH56-BF-P-002	0.0380	Exceeds Limit	3.7190	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH57-CF-P-002	0.0450	Exceeds Limit	1.8670	Passed
Barrington Municipal High School	Classroom Faucet	BH58-CF-P-002	0.0560	Exceeds Limit	3.1340	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH59-CF-P-002	0.0780	Exceeds Limit	3.0910	Exceeds Limit
Barrington Municipal High School	Custodial Sink	BH5-CS-P-001	0.0390	Exceeds Limit	3.5420	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH60-CF-P-002	0.0750	Exceeds Limit	2.1470	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH61-CF-P-002	0.0500	Exceeds Limit	3.3140	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH62-CF-P-002	0.0690	Exceeds Limit	2.1070	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH63-CF-P-002	0.0410	Exceeds Limit	1.0400	Passed
Barrington Municipal High School	Classroom Faucet	BH64-CF-P-002	0.1770	Exceeds Limit	1.4450	Passed
Barrington Municipal High School	Classroom Faucet	BH65.1-CF-P-002	0.0750	Exceeds Limit	2.2920	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH65-CF-P-002	0.0110	Exceeds Limit	2.2470	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH66-CF-P-002	0.1410	Exceeds Limit	1.6670	Passed
Barrington Municipal High School	Classroom Faucet	BH67-CF-P-002	0.0950	Exceeds Limit	1.7760	Passed
Barrington Municipal High School	Classroom Faucet	BH68-CF-P-002	0.0270	Exceeds Limit	1.8930	Passed
Barrington Municipal High School	Classroom Faucet	BH69-CF-P-002	0.0780	Exceeds Limit	2.5400	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH6-BF-P-001	0.0540	Exceeds Limit	2.1050	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH70-CF-P-002	0.0170	Exceeds Limit	1.2060	Passed
Barrington Municipal High School	Bathroom Faucet	BH71-BF-P-002	0.0230	Exceeds Limit	1.9540	Passed
Barrington Municipal High School	Bathroom Faucet	BH72-BF-P-002	0.0250	Exceeds Limit	2.1090	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH73-BF-P-002	0.0260	Exceeds Limit	2.8540	Exceeds Limit
Barrington Municipal High School	Custodial Sink	BH74-CS-P-002	0.0720	Exceeds Limit	2.4280	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH75-BF-P-002	0.0530	Exceeds Limit	1.1100	Passed
Barrington Municipal High School	Bathroom Faucet	BH76-BF-P-002	0.0670	Exceeds Limit	2.4340	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH77-BF-P-002	0.0450	Exceeds Limit	1.4320	Passed
Barrington Municipal High School	Water Fountain	BH78-WF-P-002	0.0010	Passed	0.0140	Passed
Barrington Municipal High School	Classroom Faucet	BH79-CF-P-002	0.0580	Exceeds Limit	2.1430	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH7-BF-P-001	0.0310	Exceeds Limit	2.4420	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH8.1-CF-P-001	0.0210	Exceeds Limit	1.0460	Passed
Barrington Municipal High School	Classroom Faucet	BH80-CF-P-002	0.0510	Exceeds Limit	2.1930	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH81-CF-P-002	0.0380	Exceeds Limit	1.8190	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Barrington Municipal High School	Classroom Faucet	BH82-CF-P-002	0.0230	Exceeds Limit	2.2040	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH84-CF-P-002	0.0220	Exceeds Limit	2.1200	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH85.1-BF-P-002	0.0120	Exceeds Limit	1.7230	Passed
Barrington Municipal High School	Bathroom Faucet	BH85.2-BF-P-002	0.0200	Exceeds Limit	5.0190	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH85-BF-P-002	0.0260	Exceeds Limit	2.2490	Exceeds Limit
Barrington Municipal High School	Bathroom Faucet	BH8-BF-P-001	0.0380	Exceeds Limit	2.2210	Exceeds Limit
Barrington Municipal High School	Classroom Faucet	BH9-CF-P-001	0.0560	Exceeds Limit	4.0690	Exceeds Limit
Carleton Consolidated School	Bathroom Faucet	CC10-BF-P-001	0.0140	Exceeds Limit	0.1580	Passed
Carleton Consolidated School	Kitchen Faucet	CC11flush-KF-F-001	0.0110	Exceeds Limit	0.2610	Passed
Carleton Consolidated School	Kitchen Faucet	CC11-KF-P-001	0.0080	Exceeds Limit	0.1030	Passed
Carleton Consolidated School	Kitchen Faucet	CC11-KF-S-001	0.0070	Exceeds Limit	0.1140	Passed
Carleton Consolidated School	Kitchen Faucet	CC13flush-KF-F-001	0.0100	Exceeds Limit	0.2610	Passed
Carleton Consolidated School	Bathroom Faucet	CC13-KF-P-001	0.0140	Exceeds Limit	0.2000	Passed
Carleton Consolidated School	Kitchen Faucet	CC13-KF-S-001	0.0300	Exceeds Limit	0.2290	Passed
Carleton Consolidated School	Bathroom Faucet	CC14-BF-P-001	0.0030	Passed	0.0820	Passed
Carleton Consolidated School	Bathroom Faucet	CC15-BF-P-001	0.0030	Passed	0.0910	Passed
Carleton Consolidated School	Bathroom Faucet	CC16-BF-P-001	0.0020	Passed	0.0530	Passed
Carleton Consolidated School	Bathroom Faucet	CC17-BF-P-001	0.0030	Passed	0.0950	Passed
Carleton Consolidated School	Bathroom Faucet	CC18-BF-P-002	0.0070	Exceeds Limit	0.1840	Passed
Carleton Consolidated School	Bathroom Faucet	CC19-BF-P-002	0.0100	Exceeds Limit	0.1690	Passed
Carleton Consolidated School	Bathroom Faucet	CC1-BF-P-001	0.0030	Passed	0.1130	Passed
Carleton Consolidated School	Bathroom Faucet	CC20-BF-P-002	0.0100	Exceeds Limit	0.2220	Passed
Carleton Consolidated School	Bathroom Faucet	CC21-BF-P-002	0.0150	Exceeds Limit	0.2080	Passed
Carleton Consolidated School	Water Fountain	CC22-WF-P-002	0.0010	Passed	0.0470	Passed
Carleton Consolidated School	Custodial Sink	CC23-CS-P-002	0.0030	Passed	0.1090	Passed
Carleton Consolidated School	Bathroom Faucet	CC24-BF-P-002	0.0140	Exceeds Limit	0.2000	Passed
Carleton Consolidated School	Bathroom Faucet	CC25-BF-P-002	0.0100	Exceeds Limit	0.1610	Passed
Carleton Consolidated School	Bathroom Faucet	CC26-BF-P-002	0.0080	Exceeds Limit	0.1570	Passed
Carleton Consolidated School	Classroom Faucet	CC27-CF-P-002	0.0050	Passed	0.1100	Passed
Carleton Consolidated School	Bathroom Faucet	CC28-BF-P-002	0.0050	Passed	0.1770	Passed
Carleton Consolidated School	Staff Faucet	CC29flush-SF-F-002	0.0010	Passed	0.0380	Passed
Carleton Consolidated School	Staff Faucet	CC29-SF-P-002	0.0090	Exceeds Limit	0.1240	Passed
Carleton Consolidated School	Staff Faucet	CC29-SF-S-002	0.0010	Passed	0.0390	Passed
Carleton Consolidated School	Bathroom Faucet	CC2-BF-P-001	0.0030	Passed	0.1370	Passed
Carleton Consolidated School	Water Fountain	CC3.1-WF-P-001	0.0020	Passed	0.0920	Passed
Carleton Consolidated School	Classroom Faucet	CC30-CF-P-002	0.0120	Exceeds Limit	0.2210	Passed
Carleton Consolidated School	Bathroom Faucet	CC3-BF-P-001	0.0160	Exceeds Limit	0.3150	Passed
Carleton Consolidated School	Bathroom Faucet	CC4-BF-P-001	0.0030	Passed	0.2240	Passed
Carleton Consolidated School	Bathroom Faucet	CC5-BF-P-001	0.0040	Passed	0.1440	Passed
Carleton Consolidated School	Bathroom Faucet	CC6-BF-P-001	0.0030	Passed	0.1630	Passed
Carleton Consolidated School	Bathroom Faucet	CC7-BF-P-001	0.0030	Passed	0.1780	Passed
Carleton Consolidated School	Bathroom Faucet	CC8-BF-P-001	0.0020	Passed	0.1410	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Carleton Consolidated School	Water Fountain	CC9-WF-P-001	0.0010	Passed	0.0880	Passed
Clark's Harbour Elementary School	Custodial Sink	CH10-CS-P-001	0.0050	Passed	0.8270	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH11-BF-P-001	0.0120	Exceeds Limit	0.7880	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH12-BF-P-001	0.0080	Exceeds Limit	0.6660	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH13-BF-P-001	0.0120	Exceeds Limit	0.7790	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH14-BF-P-001	0.0070	Exceeds Limit	0.6530	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH15-BF-P-001	0.0060	Exceeds Limit	0.7170	Passed
Clark's Harbour Elementary School	Water Fountain	CH16-WF-P-001	0.0010	Passed	0.1380	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH17-BF-P-001	0.0070	Exceeds Limit	0.7760	Passed
Clark's Harbour Elementary School	Staff Faucet	CH18-SF-P-001	0.0070	Exceeds Limit	0.7260	Passed
Clark's Harbour Elementary School	Custodial Sink	CH19-CS-P-001	0.0230	Exceeds Limit	1.4280	Passed
Clark's Harbour Elementary School	Water Fountain	CH21-WF-P-001	0.0030	Passed	0.4860	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH22-BF-P-001	0.0040	Passed	0.9510	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH23-BF-P-001	0.0070	Exceeds Limit	0.9790	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH24-BF-P-001	0.0050	Passed	0.9490	Passed
Clark's Harbour Elementary School	Kitchen Faucet	CH2-KF-P-001	0.0060	Exceeds Limit	0.6720	Passed
Clark's Harbour Elementary School	Kitchen Faucet	CH3-KF-P-001	0.0180	Exceeds Limit	0.9020	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH4-BF-P-001	0.0070	Exceeds Limit	0.6590	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH5-BF-P-001	0.0090	Exceeds Limit	1.0750	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH6-BF-P-001	0.0100	Exceeds Limit	1.2150	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH7-BF-P-001	0.0120	Exceeds Limit	1.0330	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH8-BF-P-001	0.0260	Exceeds Limit	1.3500	Passed
Clark's Harbour Elementary School	Bathroom Faucet	CH9-BF-P-001	0.0060	Exceeds Limit	1.0180	Passed
Digby Elementary School	Water Fountain	DE10-WF-P-001	0.0000	Passed	0.0210	Passed
Digby Elementary School	Custodial Sink	DE11-CS-P-001	0.0090	Exceeds Limit	0.1030	Passed
Digby Elementary School	Bathroom Faucet	DE12-BF-P-001	0.0030	Passed	0.0900	Passed
Digby Elementary School	Bathroom Faucet	DE13-BF-P-001	0.0050	Passed	0.0640	Passed
Digby Elementary School	Bathroom Faucet	DE14-BF-P-001	0.0140	Exceeds Limit	0.0760	Passed
Digby Elementary School	Bathroom Faucet	DE15-BF-P-001	0.0050	Passed	0.0610	Passed
Digby Elementary School	Bathroom Faucet	DE16-BF-P-001	0.0010	Passed	0.0580	Passed
Digby Elementary School	Bathroom Faucet	DE17-BF-P-001	0.0010	Passed	0.0530	Passed
Digby Elementary School	Bathroom Faucet	DE18-BF-P-001	0.0020	Passed	0.0550	Passed
Digby Elementary School	Bathroom Faucet	DE19-BF-P-001	0.0020	Passed	0.0460	Passed
Digby Elementary School	Bathroom Faucet	DE1-BF-P-001	0.0130	Exceeds Limit	0.1010	Passed
Digby Elementary School	Bathroom Faucet	DE20-BF-P-001	0.0010	Passed	0.0520	Passed
Digby Elementary School	Classroom Faucet	DE21-CF-P-001	0.1010	Exceeds Limit	0.2160	Passed
Digby Elementary School	Classroom Faucet	DE22-CF-P-001	0.0020	Passed	0.0640	Passed
Digby Elementary School	Bathroom Faucet	DE23-BF-P-001	0.0020	Passed	0.0300	Passed
Digby Elementary School	Bathroom Faucet	DE24-BF-P-001	0.0010	Passed	0.0420	Passed
Digby Elementary School	Classroom Faucet	DE25-CF-P-001	0.0010	Passed	0.0370	Passed
Digby Elementary School	Bathroom Faucet	DE26-BF-P-001	0.0010	Passed	0.0290	Passed
Digby Elementary School	Classroom Faucet	DE27.1-CF-P-001	0.0030	Passed	0.0260	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Digby Elementary School	Classroom Faucet	DE27.2-CF-P-001	0.0050	Passed	0.0460	Passed
Digby Elementary School	Classroom Faucet	DE27-CF-P-001	0.0010	Passed	0.0460	Passed
Digby Elementary School	Water Fountain	DE28-WF-P-002	0.0000	Passed	0.0780	Passed
Digby Elementary School	Custodial Sink	DE29-CS-P-002	0.0010	Passed	0.0690	Passed
Digby Elementary School	Water Fountain	DE2-WF-P-001	0.0000	Passed	0.0160	Passed
Digby Elementary School	Bathroom Faucet	DE30-BF-P-002	0.0040	Passed	0.1390	Passed
Digby Elementary School	Bathroom Faucet	DE31-BF-P-002	0.0020	Passed	0.0820	Passed
Digby Elementary School	Bathroom Faucet	DE32-BF-P-002	0.0010	Passed	0.0610	Passed
Digby Elementary School	Bathroom Faucet	DE33-BF-P-002	0.0040	Passed	0.1400	Passed
Digby Elementary School	Bathroom Faucet	DE34-BF-P-002	0.0020	Passed	0.0470	Passed
Digby Elementary School	Bathroom Faucet	DE35-BF-P-002	0.0030	Passed	0.0350	Passed
Digby Elementary School	Bathroom Faucet	DE36-BF-P-002	0.0010	Passed	0.0980	Passed
Digby Elementary School	Bathroom Faucet	DE37-BF-P-002	0.0010	Passed	0.0440	Passed
Digby Elementary School	Bathroom Faucet	DE38-BF-P-002	0.0010	Passed	0.0270	Passed
Digby Elementary School	Bathroom Faucet	DE39-BF-P-002	0.0020	Passed	0.0420	Passed
Digby Elementary School	Bathroom Faucet	DE3-BF-P-001	0.0010	Passed	0.0920	Passed
Digby Elementary School	Classroom Faucet	DE4.1-CF-P-001	0.0130	Exceeds Limit	0.1050	Passed
Digby Elementary School	Classroom Faucet	DE4.2-CF-P-001	0.0040	Passed	0.1250	Passed
Digby Elementary School	Bathroom Faucet	DE4.3-BF-P-001	0.0070	Exceeds Limit	0.1120	Passed
Digby Elementary School	Classroom Faucet	DE4.4-CF-P-001	0.0050	Passed	0.0870	Passed
Digby Elementary School	Classroom Faucet	DE40-CF-P-002	0.0120	Exceeds Limit	0.1030	Passed
Digby Elementary School	Bathroom Faucet	DE4-BF-P-001	0.0010	Passed	0.0090	Passed
Digby Elementary School	Staff Faucet	DE5-SF-P-001	0.0080	Exceeds Limit	0.0820	Passed
Digby Elementary School	Bathroom Faucet	DE6-BF-P-001	0.0030	Passed	0.1030	Passed
Digby Elementary School	Bathroom Faucet	DE7-BF-P-001	0.0010	Passed	0.0250	Passed
Digby Elementary School	Kitchen Faucet	DE8-KF-P-001	0.0040	Passed	0.0600	Passed
Digby Elementary School	Kitchen Faucet	DE9-KF-P-001	0.0300	Exceeds Limit	0.1160	Passed
Digby Neck Consolidated School	Classroom Faucet	DN 15 RE TEST	0.0340	Exceeds Limit	0.1300	Passed
Digby Neck Consolidated School	Classroom Faucet	DN 6 RE TEST	0.0065	Exceeds Limit	0.0560	Passed
Digby Neck Consolidated School	Classroom Faucet	DN 7 RE TEST	0.0029	Passed	0.0350	Passed
Digby Neck Consolidated School	Kitchen Faucet	DN1 - KF - P - 001	0.0042	Passed	0.4900	Passed
Digby Neck Consolidated School	Water Fountain	DN10 - WF - P - 001	0.0000	Passed	0.0260	Passed
Digby Neck Consolidated School	Bathroom Faucet	DN11 - BF - P - 001	0.0710	Exceeds Limit	1.6000	Passed
Digby Neck Consolidated School	Bathroom Faucet	DN12 - BF - P - 001	0.0650	Exceeds Limit	1.4000	Passed
Digby Neck Consolidated School	Bathroom Faucet	DN13 - BF - P - 001	0.1400	Exceeds Limit	2.3000	Exceeds Limit
Digby Neck Consolidated School	Kitchen Faucet	DN2 - KF - P - 001	0.0042	Passed	0.5900	Passed
Digby Neck Consolidated School	Bathroom Faucet	DN3 - BF - P - 001	0.0280	Exceeds Limit	0.3800	Passed
Digby Neck Consolidated School	Bathroom Faucet	DN4 - BF - P - 001	0.0073	Exceeds Limit	0.6400	Passed
Digby Neck Consolidated School	Bathroom Faucet	DN5 - BF - P - 001	0.0068	Exceeds Limit	0.3000	Passed
Digby Neck Consolidated School	Classroom Faucet	DN6 - CF - P - 001	0.0110	Exceeds Limit	0.1800	Passed
Digby Neck Consolidated School	Classroom Faucet	DN7 - CF - P - 001	0.0088	Exceeds Limit	0.2300	Passed
Digby Neck Consolidated School	Classroom Faucet	DN8 - CF - P - 001	0.0043	Passed	0.7800	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Digby Neck Consolidated School	Custodial Sink	DN9 - CS - P - 001	0.0062	Exceeds Limit	0.7800	Passed
Digby Neck Consolidated School	Bathroom Faucet	PM14 - BF - P - 001	0.0330	Exceeds Limit	1.1000	Passed
Digby Regional High School	Bathroom Faucet	DR10-BF-P-001	0.0000	Passed	0.0620	Passed
Digby Regional High School	Bathroom Faucet	DR11-BF-P-001	0.0010	Passed	0.0660	Passed
Digby Regional High School	Bathroom Faucet	DR12-BF-P-001	0.0020	Passed	0.0980	Passed
Digby Regional High School	Bathroom Faucet	DR13-BF-P-001	0.0020	Passed	0.1010	Passed
Digby Regional High School	Bathroom Faucet	DR14-BF-P-001	0.0000	Passed	0.0530	Passed
Digby Regional High School	Water Fountain	DR15.1-WF-P-001	0.0000	Passed	0.0000	Passed
Digby Regional High School	Custodial Sink	DR15-CS-P-001	0.0080	Exceeds Limit	0.0820	Passed
Digby Regional High School	Bathroom Faucet	DR16-BF-P-001	0.0070	Exceeds Limit	0.2040	Passed
Digby Regional High School	Bathroom Faucet	DR17-BF-P-001	0.0070	Exceeds Limit	0.1980	Passed
Digby Regional High School	Bathroom Faucet	DR18-BF-P-001	0.0050	Passed	0.0900	Passed
Digby Regional High School	Bathroom Faucet	DR19-BF-P-001	0.0030	Passed	0.1150	Passed
Digby Regional High School	Custodial Sink	DR1-CS-P-001	0.0010	Passed	0.0570	Passed
Digby Regional High School	Bathroom Faucet	DR20-BF-P-001	0.0020	Passed	0.0820	Passed
Digby Regional High School	Bathroom Faucet	DR21-BF-P-001	0.0040	Passed	0.1030	Passed
Digby Regional High School	Bathroom Faucet	DR22-BF-P-001	0.0050	Passed	0.1330	Passed
Digby Regional High School	Water Fountain	DR23.1-WF-P-001	0.0020	Passed	0.0020	Passed
Digby Regional High School	Water Fountain	DR23-WF-P-001	0.0010	Passed	0.0170	Passed
Digby Regional High School	Bathroom Faucet	DR24-BF-P-001	0.0010	Passed	0.0570	Passed
Digby Regional High School	Classroom Faucet	DR25-CF-P-001	0.0040	Passed	0.0960	Passed
Digby Regional High School	Classroom Faucet	DR27-CF-P-001	0.0020	Passed	0.0490	Passed
Digby Regional High School	Classroom Faucet	DR29-CF-P-001	0.0020	Passed	0.0590	Passed
Digby Regional High School	Custodial Sink	DR2-CS-P-001	0.0000	Passed	0.0530	Passed
Digby Regional High School	Classroom Faucet	DR31-CF-P-001	0.0040	Passed	0.2650	Passed
Digby Regional High School	Classroom Faucet	DR33-CF-P-001	0.0050	Passed	0.1140	Passed
Digby Regional High School	Classroom Faucet	DR34-CF-P-001	0.0090	Exceeds Limit	1.0260	Passed
Digby Regional High School	Classroom Faucet	DR35-CF-P-001	0.0160	Exceeds Limit	1.0470	Passed
Digby Regional High School	Classroom Faucet	DR36-CF-P-001	0.0050	Passed	0.0910	Passed
Digby Regional High School	Classroom Faucet	DR37-CF-P-001	0.0030	Passed	0.0800	Passed
Digby Regional High School	Classroom Faucet	DR38-CF-P-001	0.0050	Passed	0.0990	Passed
Digby Regional High School	Classroom Faucet	DR39-CF-P-001	0.0030	Passed	0.1040	Passed
Digby Regional High School	Custodial Sink	DR3-CS-P-001	0.0000	Passed	0.0500	Passed
Digby Regional High School	Kitchen Faucet	DR4.1-KF-P-001	0.0010	Passed	0.0630	Passed
Digby Regional High School	Kitchen Faucet	DR4.2-KF-P-001	0.0030	Passed	0.0650	Passed
Digby Regional High School	Kitchen Faucet	DR4.3-KF-P-001	0.0000	Passed	0.0640	Passed
Digby Regional High School	Classroom Faucet	DR40-CF-P-001	0.0040	Passed	0.1480	Passed
Digby Regional High School	Classroom Faucet	DR41-CF-P-001	0.0040	Passed	0.1130	Passed
Digby Regional High School	Classroom Faucet	DR42-CF-P-001	0.0060	Exceeds Limit	0.1680	Passed
Digby Regional High School	Classroom Faucet	DR43-CF-P-001	0.0040	Passed	0.1340	Passed
Digby Regional High School	Classroom Faucet	DR44-CF-P-001	0.0050	Passed	0.2600	Passed
Digby Regional High School	Classroom Faucet	DR45-CF-P-001	0.0060	Exceeds Limit	0.7910	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Digby Regional High School	Classroom Faucet	DR46-CF-P-001	0.0030	Passed	0.1800	Passed
Digby Regional High School	Classroom Faucet	DR47-CF-P-001	0.0040	Passed	0.0840	Passed
Digby Regional High School	Bathroom Faucet	DR49-BF-P-001	0.0040	Passed	0.0690	Passed
Digby Regional High School	Kitchen Faucet	DR4-KF-P-001	0.0000	Passed	0.0150	Passed
Digby Regional High School	Custodial Sink	DR50-CS-P-001	0.0020	Passed	0.1670	Passed
Digby Regional High School	Classroom Faucet	DR51-CF-P-001	0.0040	Passed	0.0760	Passed
Digby Regional High School	Classroom Faucet	DR52-CF-P-001	0.0040	Passed	0.0780	Passed
Digby Regional High School	Bathroom Faucet	DR53-BF-P-001	0.0020	Passed	0.0830	Passed
Digby Regional High School	Custodial Sink	DR54-CS-P-001	0.0040	Passed	0.1020	Passed
Digby Regional High School	Classroom Faucet	DR55-CF-P-001	0.0220	Exceeds Limit	0.4290	Passed
Digby Regional High School	Classroom Faucet	DR56-CF-P-001	0.0080	Exceeds Limit	0.1250	Passed
Digby Regional High School	Classroom Faucet	DR57-CF-P-001	0.0050	Passed	0.1240	Passed
Digby Regional High School	Classroom Faucet	DR58-CF-P-001	0.0080	Exceeds Limit	0.2330	Passed
Digby Regional High School	Classroom Faucet	DR59-CF-P-001	0.0050	Passed	0.0800	Passed
Digby Regional High School	Bathroom Faucet	DR5-BF-P-001	0.0000	Passed	0.0620	Passed
Digby Regional High School	Classroom Faucet	DR60-CF-P-001	0.0210	Exceeds Limit	0.7070	Passed
Digby Regional High School	Classroom Faucet	DR61-CF-P-001	0.0050	Passed	0.0950	Passed
Digby Regional High School	Classroom Faucet	DR62-CF-P-001	0.0030	Passed	0.0850	Passed
Digby Regional High School	Classroom Faucet	DR63-CF-P-001	0.0030	Passed	0.0520	Passed
Digby Regional High School	Classroom Faucet	DR64-CF-P-001	0.0030	Passed	0.0850	Passed
Digby Regional High School	Classroom Faucet	DR65-CF-P-001	0.0050	Passed	0.1460	Passed
Digby Regional High School	Classroom Faucet	DR66-CF-P-001	0.0040	Passed	0.1130	Passed
Digby Regional High School	Water Fountain	DR67-WF-P-001	0.0020	Passed	0.0100	Passed
Digby Regional High School	Classroom Faucet	DR68-CF-P-001	0.0020	Passed	0.0990	Passed
Digby Regional High School	Custodial Sink	DR69-CS-P-001	0.0030	Passed	0.0730	Passed
Digby Regional High School	Bathroom Faucet	DR6-BF-P-001	0.0000	Passed	0.0740	Passed
Digby Regional High School	Custodial Sink	DR70-CS-P-002	0.0110	Exceeds Limit	0.1240	Passed
Digby Regional High School	Bathroom Faucet	DR71-BF-P-002	0.0070	Exceeds Limit	0.0800	Passed
Digby Regional High School	Custodial Sink	DR72-CS-P-002	0.0100	Exceeds Limit	0.2340	Passed
Digby Regional High School	Custodial Sink	DR73-CS-P-002	0.0100	Exceeds Limit	0.1640	Passed
Digby Regional High School	Custodial Sink	DR74-CS-P-002	0.0070	Exceeds Limit	0.1260	Passed
Digby Regional High School	Custodial Sink	DR75-CS-P-002	0.0080	Exceeds Limit	0.1910	Passed
Digby Regional High School	Water Fountain	DR76-WF-P-002	0.0020	Passed	0.0060	Passed
Digby Regional High School	Bathroom Faucet	DR77-BF-P-002	0.0040	Passed	0.0780	Passed
Digby Regional High School	Classroom Faucet	DR78-CF-P-002	0.0050	Passed	0.1150	Passed
Digby Regional High School	Bathroom Faucet	DR79-BF-P-002	0.0040	Passed	0.0800	Passed
Digby Regional High School	Bathroom Faucet	DR7-BF-P-001	0.0000	Passed	0.0550	Passed
Digby Regional High School	Bathroom Faucet	DR81-BF-P-002	0.0070	Exceeds Limit	0.1880	Passed
Digby Regional High School	Bathroom Faucet	DR82-BF-P-002	0.0050	Passed	0.1260	Passed
Digby Regional High School	Classroom Faucet	DR83-CF-P-002	0.0050	Passed	0.1150	Passed
Digby Regional High School	Classroom Faucet	DR84-CF-P-002	0.0060	Exceeds Limit	0.1250	Passed
Digby Regional High School	Classroom Faucet	DR85-CF-P-002	0.0060	Exceeds Limit	0.1300	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Digby Regional High School	Classroom Faucet	DR86-CF-P-002	0.0060	Exceeds Limit	0.1680	Passed
Digby Regional High School	Classroom Faucet	DR87-CF-P-002	0.0050	Passed	0.1040	Passed
Digby Regional High School	Classroom Faucet	DR88-CF-P-002	0.0040	Passed	0.1320	Passed
Digby Regional High School	Custodial Sink	DR89-CS-P-002	0.0040	Passed	0.0640	Passed
Digby Regional High School	Bathroom Faucet	DR8-BF-P-001	0.0000	Passed	0.0680	Passed
Digby Regional High School	Bathroom Faucet	DR90-BF-P-002	0.0620	Exceeds Limit	2.1280	Exceeds Limit
Digby Regional High School	Bathroom Faucet	DR91-BF-P-002	0.0500	Exceeds Limit	1.4780	Passed
Digby Regional High School	Bathroom Faucet	DR92-BF-P-002	0.0410	Exceeds Limit	0.7270	Passed
Digby Regional High School	Bathroom Faucet	DR93-BF-P-002	0.0020	Passed	0.0090	Passed
Digby Regional High School	Bathroom Faucet	DR94-BF-P-002	0.0050	Passed	0.1300	Passed
Digby Regional High School	Bathroom Faucet	DR95-BF-P-002	0.0050	Passed	0.1300	Passed
Digby Regional High School	Bathroom Faucet	DR96-BF-P-002	0.0110	Exceeds Limit	0.2600	Passed
Digby Regional High School	Bathroom Faucet	DR97-BF-P-002	0.0000	Passed	0.0720	Passed
Digby Regional High School	Bathroom Faucet	DR98-BF-P-002	0.0000	Passed	0.0530	Passed
Digby Regional High School	Staff Faucet	DR99-SF-P-002	0.0020	Passed	0.0520	Passed
Digby Regional High School	Water Fountain	DR9-WF-P-001	0.0000	Passed	0.0010	Passed
Digby Regional High School	Bathroom Faucet	DST1-BF-P-001	0.0010	Passed	0.0240	Passed
Digby Regional High School	Water Fountain	DST2-WF-P-001	0.0040	Passed	0.0100	Passed
Digby Regional High School	Custodial Sink	DST3-CS-P-001	0.0010	Passed	0.0020	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D1 - BF - P - 001	0.0007	Passed	0.0320	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D10 - CF - P - 001	0.0290	Exceeds Limit	0.0780	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D11 - BF - P - 001	0.0007	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D12 - BF - P - 001	0.0000	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D13 - BF - P - 001	0.0000	Passed	0.0300	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D14 - BF - P - 001	0.0014	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D15 - BF - P - 001	0.0029	Passed	0.0220	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D16 - BF - P - 001	0.0007	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Kitchen Faucet	D17 - KF - P - 001	0.0014	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Kitchen Faucet	D18 - KF - P - 001	0.0011	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Kitchen Faucet	D19 - KF - P - 001	0.0000	Passed	0.0130	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D2 - BF - P - 001	0.0009	Passed	0.0290	Passed
Drumlin Heights Consolidated School	Kitchen Faucet	D20 - KF - P - 001	0.0052	Exceeds Limit	0.0170	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D21 - CF - P - 001	0.0100	Exceeds Limit	0.0230	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D22 - BF - P - 001	0.0000	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D23 - CF - P - 001	0.0035	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Water Fountain	D24 - WF - P - 001	0.0000	Passed	0.0076	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D25 - BF - P - 001	0.0013	Passed	0.0260	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D26 - BF - P - 001	0.0018	Passed	0.0200	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D27 - BF - P - 001	0.0000	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D28 - BF - P - 001	0.0000	Passed	0.0140	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D29 - BF - P - 001	0.0006	Passed	0.0270	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D3 - BF - P - 001	0.0068	Exceeds Limit	0.1300	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Drumlin Heights Consolidated School	Bathroom Faucet	D30 - BF - P - 001	0.0000	Passed	0.0270	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D31 - BF - P - 001	0.0000	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D32 - BF - P - 001	0.0000	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D33 - BF - P - 001	0.0006	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D34 - BF - P - 001	0.0000	Passed	0.0140	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D35 - CF - P - 001	0.0022	Passed	0.0290	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D36 - BF - P - 001	0.0006	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D37 - CF - P - 001	0.0022	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D38 - CF - P - 001	0.0018	Passed	0.0150	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D39 - CF - P - 001	0.0050	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D4 - BF - P - 001	0.0009	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D40 - CF - P - 001	0.0022	Passed	0.0240	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D41 - CF - P - 001	0.0026	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D42 - CF - P - 001	0.0019	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D43 - BF - P - 001	0.0000	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Water Fountain	D44 - WF - P - 001	0.0000	Passed	0.0140	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D45 - BF - P - 001	0.0000	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D46 - BF - P - 001	0.0000	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Staff Faucet	D47 - SF - P - 001	0.0000	Passed	0.0150	Passed
Drumlin Heights Consolidated School	Water Fountain	D48 - WF - P - 001	0.0000	Passed	0.0064	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D49 - BF - P - 001	0.0015	Passed	0.0270	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D5 - BF - P - 001	0.0012	Passed	0.0480	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D50 - BF - P - 001	0.0017	Passed	0.0220	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D51 - BF - P - 001	0.0005	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D52 - BF - P - 001	0.0006	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D53 - BF - P - 001	0.0046	Passed	0.0220	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D54 - BF - P - 001	0.0000	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D55 - BF - P - 001	0.0000	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D56 - BF - P - 001	0.0130	Exceeds Limit	0.0170	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D57 - BF - P - 001	0.0000	Passed	0.0200	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D59 - CF - P - 001	0.0007	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D6 - BF - P - 001	0.0006	Passed	0.0200	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D60 - CF - P - 001	0.0110	Exceeds Limit	0.0160	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D61 - CF - P - 001	0.0021	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D62 - CF - P - 001	0.0019	Passed	0.0190	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D63 - CF - P - 001	0.0044	Passed	0.0170	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D64 - CF - P - 001	0.0052	Exceeds Limit	0.0230	Passed
Drumlin Heights Consolidated School	Water Fountain	D65 - WF - P - 002	0.0000	Passed	0.0091	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D66 - BF - P - 002	0.0050	Passed	0.0490	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D67 - BF - P - 002	0.0036	Passed	0.0240	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D68 - BF - P - 002	0.0000	Passed	0.0190	Passed
Drumlin Heights Consolidated School		D69 - BS - P - 002	0.0054	Exceeds Limit	0.0190	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Drumlin Heights Consolidated School	Bathroom Faucet	D7 - BF - P - 001	0.0430	Exceeds Limit	1.1000	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D70 - BF - P - 002	0.0028	Passed	0.0220	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D71 - BF - P - 002	0.0020	Passed	0.0240	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D72 - BF - P - 002	0.0005	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D73 - BF - P - 002	0.0005	Passed	0.0200	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D74 - BF - P - 002	0.0043	Passed	0.0210	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D75.1 - CF - P - 002	0.0250	Exceeds Limit	0.0590	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D77 - CF - P - 002	0.0150	Exceeds Limit	0.0680	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D78 - CF - P - 002	0.0033	Passed	0.0440	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D79 - CF - P - 002	0.0058	Exceeds Limit	0.0340	Passed
Drumlin Heights Consolidated School	Bathroom Faucet	D8 - BF - P - 001	0.0006	Passed	0.0180	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D80 - CF - P - 002	0.0450	Exceeds Limit	0.3000	Passed
Drumlin Heights Consolidated School	Classroom Faucet	D81 - CF - P - 002	0.0210	Exceeds Limit	1.6000	Passed
Drumlin Heights Consolidated School	Water Fountain	D9 - WF - P - 001	0.0000	Passed	0.0085	Passed
Evelyn Richardson Memorial Elementary School	Kitchen Faucet	E1 - KF - P - 001	0.0290	Exceeds Limit	1.8000	Passed
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E10 - BF - P - 001	0.0066	Exceeds Limit	6.5000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E11 - BF - P - 001	0.0057	Exceeds Limit	6.0000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E12 - BF - P - 001	0.0092	Exceeds Limit	6.3000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E13 - BF - P - 001	0.0140	Exceeds Limit	5.5000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E14 - BF - P - 001	0.0120	Exceeds Limit	6.0000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E15 - BF - P - 001	0.0073	Exceeds Limit	4.0000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E16 - BF - P - 001	0.0029	Passed	5.3000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Custodial Sink	E17 - CS - P - 001	0.0140	Exceeds Limit	4.1000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Water Fountain	E18 - WF - P - 001	0.0000	Passed	0.9200	Passed
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E19 - BF - P - 001	0.0062	Exceeds Limit	2.2000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Kitchen Faucet	E2 - KF - P - 001	0.0066	Exceeds Limit	3.5000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E20 - BF - P - 001	0.0170	Exceeds Limit	5.8000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E21 - BF - P - 001	0.0045	Passed	7.2000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E22 - BF - P - 001	0.0008	Passed	6.7000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Classroom Faucet	E23 - CF - P - 001	0.1600	Exceeds Limit	4.2000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Custodial Sink	E24 - CS - P - 001	0.2600	Exceeds Limit	7.7000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Staff Faucet	E25 - SF - P - 001	0.0230	Exceeds Limit	6.8000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E26 - BF - P - 001	0.0021	Passed	3.8000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E27 - BF - P - 001	0.0051	Exceeds Limit	5.2000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Water Fountain	E28 - WF - P - 001	0.0160	Exceeds Limit	6.4000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Water Fountain	E28 - WF - P - 001	0.0000	Passed	0.0120	Passed
Evelyn Richardson Memorial Elementary School	Kitchen Faucet	E3 - KF - P - 001	0.0041	Passed	2.8000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E4 - BF - P - 001	0.0310	Exceeds Limit	4.9000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E5 - BF - P - 001	0.0390	Exceeds Limit	5.8000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Water Fountain	E6 - WF - P - 001	0.0095	Exceeds Limit	5.7000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E7 - BF - P - 001	0.0290	Exceeds Limit	3.0000	Exceeds Limit
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E8 - BF - P - 001	0.0093	Exceeds Limit	5.6000	Exceeds Limit

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Evelyn Richardson Memorial Elementary School	Bathroom Faucet	E9 - BF - P - 001	0.0073	Exceeds Limit	5.6000	Exceeds Limit
Forest Ridge Academy	Bathroom Faucet	FR10-BF-P-001	0.0060	Exceeds Limit	0.3230	Passed
Forest Ridge Academy	Bathroom Faucet	FR11-BF-P-001	0.0050	Passed	0.3570	Passed
Forest Ridge Academy	Bathroom Faucet	FR12-BF-P-001	0.0120	Exceeds Limit	0.4270	Passed
Forest Ridge Academy	Water Fountain	FR13-WF-P-001	0.0060	Exceeds Limit	0.0880	Passed
Forest Ridge Academy	Bathroom Faucet	FR14-BF-P-001	0.0050	Passed	0.2300	Passed
Forest Ridge Academy	Bathroom Faucet	FR15-BF-P-001	0.0080	Exceeds Limit	0.4090	Passed
Forest Ridge Academy	Bathroom Faucet	FR16.1-BF-P-001	0.0090	Exceeds Limit	0.2300	Passed
Forest Ridge Academy	Bathroom Faucet	FR16-BF-P-001	0.0110	Exceeds Limit	0.2710	Passed
Forest Ridge Academy	Bathroom Faucet	FR17-BF-P-001	0.0080	Exceeds Limit	0.3270	Passed
Forest Ridge Academy	Staff Faucet	FR18-SF-P-001	0.0080	Exceeds Limit	0.2160	Passed
Forest Ridge Academy	Bathroom Faucet	FR19.1-BF-P-001	0.0040	Passed	0.2180	Passed
Forest Ridge Academy	Bathroom Faucet	FR19-BF-P-001	0.0050	Passed	0.2070	Passed
Forest Ridge Academy	Custodial Sink	FR1-CS-P-001	0.0060	Exceeds Limit	0.0450	Passed
Forest Ridge Academy	Classroom Faucet	FR20-CF-P-001	0.0440	Exceeds Limit	0.4250	Passed
Forest Ridge Academy	Custodial Sink	FR21-CS-P-001	0.0050	Passed	0.2380	Passed
Forest Ridge Academy	Water Fountain	FR22-WF-P-001	0.0050	Passed	0.0400	Passed
Forest Ridge Academy	Classroom Faucet	FR23-CF-P-001	0.0220	Exceeds Limit	0.4270	Passed
Forest Ridge Academy	Bathroom Faucet	FR24-BF-P-001	0.0130	Exceeds Limit	0.2200	Passed
Forest Ridge Academy	Classroom Faucet	FR25-CF-P-001	0.0420	Exceeds Limit	0.2360	Passed
Forest Ridge Academy	Bathroom Faucet	FR26-BF-P-001	0.0140	Exceeds Limit	0.2600	Passed
Forest Ridge Academy	Classroom Faucet	FR27-CF-P-001	0.0570	Exceeds Limit	0.3930	Passed
Forest Ridge Academy	Classroom Faucet	FR28-CF-P-001	0.0420	Exceeds Limit	0.5140	Passed
Forest Ridge Academy	Classroom Faucet	FR29-CF-P-001	0.0170	Exceeds Limit	0.2210	Passed
Forest Ridge Academy	Classroom Faucet	FR2-CF-P-001	0.0280	Exceeds Limit	2.1700	Exceeds Limit
Forest Ridge Academy	Classroom Faucet	FR30-CF-P-001	0.1200	Exceeds Limit	0.3610	Passed
Forest Ridge Academy	Bathroom Faucet	FR31-BF-P-001	0.0100	Exceeds Limit	0.1950	Passed
Forest Ridge Academy	Bathroom Faucet	FR32-BF-P-001	0.0170	Exceeds Limit	0.3310	Passed
Forest Ridge Academy	Bathroom Faucet	FR33-BF-P-001	0.0070	Exceeds Limit	0.2500	Passed
Forest Ridge Academy	Water Fountain	FR34-WF-P-001	0.0050	Passed	0.1200	Passed
Forest Ridge Academy	Bathroom Faucet	FR35-BF-P-001	0.0120	Exceeds Limit	0.2520	Passed
Forest Ridge Academy	Bathroom Faucet	FR36-BF-P-001	0.0090	Exceeds Limit	0.2420	Passed
Forest Ridge Academy	Bathroom Faucet	FR37-BF-P-001	0.0070	Exceeds Limit	0.1910	Passed
Forest Ridge Academy	Bathroom Faucet	FR38-BF-P-001	0.0190	Exceeds Limit	0.4390	Passed
Forest Ridge Academy	Bathroom Faucet	FR39-BF-P-001	0.0140	Exceeds Limit	0.2250	Passed
Forest Ridge Academy	Classroom Faucet	FR3-CF-P-001	0.0140	Exceeds Limit	0.6550	Passed
Forest Ridge Academy	Classroom Faucet	FR4.1-CF-P-001	0.0450	Exceeds Limit	0.7780	Passed
Forest Ridge Academy	Custodial Sink	FR40-CS-P-001	0.0450	Exceeds Limit	0.1070	Passed
Forest Ridge Academy	Kitchen Faucet	FR41-KF-P-001	0.0420	Exceeds Limit	0.2920	Passed
Forest Ridge Academy	Kitchen Faucet	FR42-KF-P-001	0.0360	Exceeds Limit	0.1510	Passed
Forest Ridge Academy	Kitchen Faucet	FR43.1-KF-P-001	0.0130	Exceeds Limit	0.4950	Passed
Forest Ridge Academy	Kitchen Faucet	FR43-KF-P-001	0.0770	Exceeds Limit	0.1740	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Forest Ridge Academy	Classroom Faucet	FR4-CF-P-001	0.0140	Exceeds Limit	3.1170	Exceeds Limit
Forest Ridge Academy	Classroom Faucet	FR5-CF-P-001	0.0170	Exceeds Limit	0.5020	Passed
Forest Ridge Academy	Classroom Faucet	FR6-CF-P-001	0.0180	Exceeds Limit	0.6450	Passed
Forest Ridge Academy	Classroom Faucet	FR7-CF-P-001	0.0110	Exceeds Limit	0.3610	Passed
Forest Ridge Academy	Bathroom Faucet	FR8-BF-P-001	0.0070	Exceeds Limit	0.2550	Passed
Forest Ridge Academy	Classroom Faucet	FR9-CF-P-001	0.0270	Exceeds Limit	0.7260	Passed
Hillcrest Academy	Bathroom Faucet	H1 - BF - P - 001	0.0140	Exceeds Limit	0.0780	Passed
Hillcrest Academy	Kitchen Faucet	H10 - KF - P - 001	0.0000	Passed	0.0970	Passed
Hillcrest Academy	Kitchen Faucet	H11 - KF - P - 001	0.0008	Passed	0.0600	Passed
Hillcrest Academy	Bathroom Faucet	H12 - BF - P - 001	0.0020	Passed	0.0660	Passed
Hillcrest Academy	Classroom Faucet	H13 - CF - P - 001	0.0041	Passed	0.0900	Passed
Hillcrest Academy	Classroom Faucet	H14 - CF - P - 001	0.0110	Exceeds Limit	0.2300	Passed
Hillcrest Academy	Bathroom Faucet	H15 - BF - P - 001	0.0021	Passed	0.0530	Passed
Hillcrest Academy	Classroom Faucet	H16 - CF - P - 001	0.0039	Passed	0.0770	Passed
Hillcrest Academy	Bathroom Faucet	H17 - BF - P - 001	0.0022	Passed	0.0390	Passed
Hillcrest Academy	Classroom Faucet	H18 - CF - P - 001	0.0036	Passed	0.0750	Passed
Hillcrest Academy	Water Fountain	H19 - WF - P - 001	0.0007	Passed	0.0150	Passed
Hillcrest Academy	Water Fountain	H19 - WF - P - 001	0.0071	Exceeds Limit	0.1400	Passed
Hillcrest Academy	Bathroom Faucet	H2 - BF - P - 001	0.0013	Passed	0.0690	Passed
Hillcrest Academy	Classroom Faucet	H20 - CF - P - 001	0.0075	Exceeds Limit	0.1100	Passed
Hillcrest Academy	Bathroom Faucet	H21 - BF - P - 001	0.0057	Exceeds Limit	0.2100	Passed
Hillcrest Academy	Bathroom Faucet	H22 - BF - P - 001	0.0035	Passed	0.1100	Passed
Hillcrest Academy	Bathroom Faucet	H23 - BF - P - 001	0.0009	Passed	0.0870	Passed
Hillcrest Academy	Bathroom Faucet	H24 - BF - P - 001	0.0014	Passed	0.0760	Passed
Hillcrest Academy	Staff Faucet	H25 - SF - P - 001	0.0012	Passed	0.0700	Passed
Hillcrest Academy	Bathroom Faucet	H26 - BF - P - 001	0.0042	Passed	0.1400	Passed
Hillcrest Academy	Classroom Faucet	H27 - CF - P - 001	0.0280	Exceeds Limit	0.1900	Passed
Hillcrest Academy	Bathroom Faucet	H28 - BF - P - 001	0.0017	Passed	0.0550	Passed
Hillcrest Academy	Bathroom Faucet	H29 - BF - P - 001	0.0026	Passed	0.1300	Passed
Hillcrest Academy	Bathroom Faucet	H3 - BF - P - 001	0.0049	Passed	0.0790	Passed
Hillcrest Academy	Classroom Faucet	H30 - CF - P - 001	0.0032	Passed	0.1000	Passed
Hillcrest Academy	Classroom Faucet	H32 - CF - P - 001	0.1300	Exceeds Limit	0.0920	Passed
Hillcrest Academy	Classroom Faucet	H33 - CF - P - 001	0.0020	Passed	0.0360	Passed
Hillcrest Academy	Bathroom Faucet	H34 - BF - P - 002	0.0140	Exceeds Limit	0.0850	Passed
Hillcrest Academy	Bathroom Faucet	H35 - BF - P - 002	0.0047	Passed	0.0550	Passed
Hillcrest Academy	Bathroom Faucet	H36 - BF - P - 002	0.0032	Passed	0.0390	Passed
Hillcrest Academy	Custodial Sink	H37 - CS - P - 002	0.0024	Passed	0.0770	Passed
Hillcrest Academy	Bathroom Faucet	H38 - BF - P - 002	0.0140	Exceeds Limit	0.0740	Passed
Hillcrest Academy	Bathroom Faucet	H39 - BF - P - 002	0.0011	Passed	0.0820	Passed
Hillcrest Academy	Bathroom Faucet	H4 - BF - P - 001	0.0006	Passed	0.0600	Passed
Hillcrest Academy	Bathroom Faucet	H40 - BF - P - 002	0.0012	Passed	0.0860	Passed
Hillcrest Academy	Bathroom Faucet	H41 - BF - P - 002	0.0006	Passed	0.0600	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Hillcrest Academy	Water Fountain	H42 - WF - P - 002	0.0000	Passed	0.1400	Passed
Hillcrest Academy	Bathroom Faucet	H5 - BF - P - 001	0.0009	Passed	0.0810	Passed
Hillcrest Academy	Bathroom Faucet	H6 - BF - P - 001	0.0025	Passed	0.0610	Passed
Hillcrest Academy	Custodial Sink	H7 - CS - P - 001	0.0035	Passed	0.0190	Passed
Hillcrest Academy	Kitchen Faucet	H9 - KF - P - 001	0.0032	Passed	0.0710	Passed
Islands Consolidated School	Classroom Faucet	IC10-CF-P-001	0.0080	Exceeds Limit	0.0160	Passed
Islands Consolidated School	Classroom Faucet	IC11-CF-P-001	0.0030	Passed	0.0160	Passed
Islands Consolidated School	Kitchen Faucet	IC12-KF-P-001	0.0010	Passed	0.0080	Passed
Islands Consolidated School	Kitchen Faucet	IC13-KF-P-001	0.0010	Passed	0.0040	Passed
Islands Consolidated School	Kitchen Faucet	IC14-KF-P-001	0.0010	Passed	0.0040	Passed
Islands Consolidated School	Bathroom Faucet	IC16-BF-P-001	0.0100	Exceeds Limit	0.0220	Passed
Islands Consolidated School	Bathroom Faucet	IC17-BF-P-001	0.0020	Passed	0.0110	Passed
Islands Consolidated School	Bathroom Faucet	IC18-BF-P-001	0.0010	Passed	0.0140	Passed
Islands Consolidated School	Bathroom Faucet	IC19-BF-P-001	0.0020	Passed	0.0120	Passed
Islands Consolidated School	Staff Faucet	IC1-SF-P-001	0.0030	Passed	0.0140	Passed
Islands Consolidated School	Bathroom Faucet	IC20-BF-P-001	0.0030	Passed	0.0140	Passed
Islands Consolidated School	Classroom Faucet	IC21-CF-P-001	0.0020	Passed	0.0090	Passed
Islands Consolidated School	Water Fountain	IC23-WF-P-001	0.0010	Passed	0.0470	Passed
Islands Consolidated School	Classroom Faucet	IC24-CF-P-001	0.0030	Passed	0.0190	Passed
Islands Consolidated School	Classroom Faucet	IC25-CF-P-001	0.0040	Passed	0.0200	Passed
Islands Consolidated School	Classroom Faucet	IC26-CF-P-001	0.0050	Passed	0.0220	Passed
Islands Consolidated School	Classroom Faucet	IC27-CF-P-001	0.0030	Passed	0.0220	Passed
Islands Consolidated School	Classroom Faucet	IC28-CF-P-001	0.0240	Exceeds Limit	0.0310	Passed
Islands Consolidated School	Classroom Faucet	IC29-CF-P-001	0.0680	Exceeds Limit	0.0390	Passed
Islands Consolidated School	Bathroom Faucet	IC2-BF-P-001	0.0050	Passed	0.0160	Passed
Islands Consolidated School	Custodial Sink	IC30.1-CS-P-001	0.0030	Passed	0.0130	Passed
Islands Consolidated School	Custodial Sink	IC30-CS-P-001	0.0100	Exceeds Limit	0.0990	Passed
Islands Consolidated School	Bathroom Faucet	IC32-BF-P-001	0.0030	Passed	0.0180	Passed
Islands Consolidated School	Bathroom Faucet	IC34-BF-P-001	0.0040	Passed	0.0180	Passed
Islands Consolidated School	Water Fountain	IC35-WF-P-001	0.0010	Passed	0.0220	Passed
Islands Consolidated School	Bathroom Faucet	IC36-BF-P-001	0.0050	Passed	0.0170	Passed
Islands Consolidated School	Bathroom Faucet	IC3-BF-P-001	0.0040	Passed	0.0120	Passed
Islands Consolidated School	Bathroom Faucet	IC4-BF-P-001	0.0030	Passed	0.0190	Passed
Islands Consolidated School	Water Fountain	IC5.1-WF-P-001	0.0010	Passed	0.0770	Passed
Islands Consolidated School	Custodial Sink	IC5-CS-P-001	0.0200	Exceeds Limit	0.1520	Passed
Islands Consolidated School	Bathroom Faucet	IC6-BF-P-001	0.0060	Exceeds Limit	0.0160	Passed
Islands Consolidated School	Bathroom Faucet	IC7-BF-P-001	0.0060	Exceeds Limit	0.0160	Passed
Islands Consolidated School	Bathroom Faucet	IC8-BF-P-001	0.0040	Passed	0.0130	Passed
Islands Consolidated School	Classroom Faucet	IC9-CF-P-001	0.0040	Passed	0.0130	Passed
Lockeport Elementary School	Kitchen Faucet	LE1 - KF - P - 001	0.0043	Passed	0.3000	Passed
Lockeport Elementary School	Bathroom Faucet	LE10 - BF - P - 001	0.0011	Passed	0.1600	Passed
Lockeport Elementary School	Bathroom Faucet	LE11 - BF - P - 001	0.0075	Exceeds Limit	0.2700	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Lockeport Elementary School	Bathroom Faucet	LE12 - BF - P - 001	0.0120	Exceeds Limit	0.4600	Passed
Lockeport Elementary School	Bathroom Faucet	LE13 - BF - P - 001	0.0027	Passed	0.1600	Passed
Lockeport Elementary School	Bathroom Faucet	LE14 - BF - P - 001	0.0028	Passed	0.2300	Passed
Lockeport Elementary School	Bathroom Faucet	LE15 - BF - P - 001	0.0041	Passed	0.3400	Passed
Lockeport Elementary School	Classroom Faucet	LE16 - CF - P - 001	0.0012	Passed	0.1700	Passed
Lockeport Elementary School	Bathroom Faucet	LE17 - BF - P - 001	0.0021	Passed	0.1700	Passed
Lockeport Elementary School	Water Fountain	LE18 - WF -P-001	0.0000	Passed	0.1000	Passed
Lockeport Elementary School	Kitchen Faucet	LE2 - KF - P - 001	0.0042	Passed	0.4800	Passed
Lockeport Elementary School	Kitchen Faucet	LE3 - KF - P - 001	0.0044	Passed	0.2700	Passed
Lockeport Elementary School	Kitchen Faucet	LE4 - KF - P - 001	0.0055	Exceeds Limit	0.1400	Passed
Lockeport Elementary School	Kitchen Faucet	LE5 - KF - P - 001	0.0000	Passed	0.0011	Passed
Lockeport Elementary School	Bathroom Faucet	LE6 - BF - P - 001	0.0011	Passed	0.0830	Passed
Lockeport Elementary School	Custodial Sink	LE7 - CS - P - 001	0.0028	Passed	0.2300	Passed
Lockeport Elementary School	Staff Faucet	LE8 - SF - P - 001	0.0058	Exceeds Limit	0.2600	Passed
Lockeport Elementary School	Staff Faucet	LE9 - SF - P - 001	0.0076	Exceeds Limit	0.0110	Passed
Lockeport Regional High School	Kitchen Faucet	LH10-KF-P-001	0.0180	Exceeds Limit	0.5960	Passed
Lockeport Regional High School	Bathroom Faucet	LH11-BF-P-001	0.0130	Exceeds Limit	0.5400	Passed
Lockeport Regional High School	Bathroom Faucet	LH12-BF-P-001	0.0280	Exceeds Limit	0.5330	Passed
Lockeport Regional High School	Bathroom Faucet	LH13-BF-P-001	0.0170	Exceeds Limit	0.3300	Passed
Lockeport Regional High School	Custodial Sink	LH14-CS-P-001	0.0550	Exceeds Limit	0.8910	Passed
Lockeport Regional High School	Bathroom Faucet	LH15-BF-P-001	0.0100	Exceeds Limit	0.3130	Passed
Lockeport Regional High School	Bathroom Faucet	LH16-BF-P-001	0.0300	Exceeds Limit	0.5140	Passed
Lockeport Regional High School	Bathroom Faucet	LH17-BF-P-001	0.0420	Exceeds Limit	0.5950	Passed
Lockeport Regional High School	Water Fountain	LH18-WF-P-002	0.0010	Passed	1.9530	Passed
Lockeport Regional High School	Classroom Faucet	LH19-CF-P-002	0.0290	Exceeds Limit	0.7640	Passed
Lockeport Regional High School	Kitchen Faucet	LH1-KF-P-001	0.0470	Exceeds Limit	0.3730	Passed
Lockeport Regional High School	Staff Faucet	LH2.1-SF-P-001	0.0100	Exceeds Limit	0.0800	Passed
Lockeport Regional High School	Classroom Faucet	LH20-CF-P-002	0.0380	Exceeds Limit	0.7660	Passed
Lockeport Regional High School	Bathroom Faucet	LH21-BF-P-002	0.0110	Exceeds Limit	0.4570	Passed
Lockeport Regional High School	Bathroom Faucet	LH22-BF-P-002	0.0100	Exceeds Limit	0.5570	Passed
Lockeport Regional High School	Bathroom Faucet	LH23-BF-P-002	0.0070	Exceeds Limit	0.5380	Passed
Lockeport Regional High School	Kitchen Faucet	LH2-KF-P-001	0.0130	Exceeds Limit	0.3750	Passed
Lockeport Regional High School	Classroom Faucet	LH3.1-CF-P-001	0.0130	Exceeds Limit	0.0700	Passed
Lockeport Regional High School	Classroom Faucet	LH3.2-CF-P-001	0.0790	Exceeds Limit	0.0870	Passed
Lockeport Regional High School	Classroom Faucet	LH3.3-CF-P-001	0.0050	Passed	0.0390	Passed
Lockeport Regional High School	Water Fountain	LH3-WF-P-001	0.0010	Passed	0.4350	Passed
Lockeport Regional High School	Bathroom Faucet	LH4.1-BF-P-001	0.0330	Exceeds Limit	0.9400	Passed
Lockeport Regional High School	Custodial Sink	LH4-CS-P-001	0.0490	Exceeds Limit	0.4450	Passed
Lockeport Regional High School	Bathroom Faucet	LH5-BF-P-001	0.0200	Exceeds Limit	0.7000	Passed
Lockeport Regional High School	Bathroom Faucet	LH6-BF-P-001	0.0180	Exceeds Limit	0.6770	Passed
Lockeport Regional High School	Bathroom Faucet	LH7-BF-P-001	0.0240	Exceeds Limit	0.7550	Passed
Lockeport Regional High School	Bathroom Faucet	LH8-BF-P-001	0.0070	Exceeds Limit	0.2120	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Lockeport Regional High School	Bathroom Faucet	LH9-BF-P-001	0.0180	Exceeds Limit	0.4370	Passed
Maple Grove Education Centre	Classroom Faucet	MG10-CF-P-001	0.0750	Exceeds Limit	0.2260	Passed
Maple Grove Education Centre	Bathroom Faucet	MG11-BF-P-001	0.0060	Exceeds Limit	0.2350	Passed
Maple Grove Education Centre	Bathroom Faucet	MG12-BF-P-001	0.0140	Exceeds Limit	0.2440	Passed
Maple Grove Education Centre	Classroom Faucet	MG13-CF-P-001	0.0390	Exceeds Limit	0.3120	Passed
Maple Grove Education Centre	Classroom Faucet	MG14-CF-P-001	0.0790	Exceeds Limit	0.3380	Passed
Maple Grove Education Centre	Classroom Faucet	MG15-CF-P-001	0.0150	Exceeds Limit	0.3230	Passed
Maple Grove Education Centre	Classroom Faucet	MG16-CF-P-001	0.0040	Passed	0.3780	Passed
Maple Grove Education Centre	Water Fountain	MG17-WF-P-001	0.0040	Passed	0.2360	Passed
Maple Grove Education Centre	Custodial Sink	MG18-CS-P-001	0.0130	Exceeds Limit	0.2050	Passed
Maple Grove Education Centre	Bathroom Faucet	MG19-BF-P-001	0.0040	Passed	0.5430	Passed
Maple Grove Education Centre	Bathroom Faucet	MG1-BF-P-001	0.0220	Exceeds Limit	0.2590	Passed
Maple Grove Education Centre	Bathroom Faucet	MG20-BF-P-001	0.0230	Exceeds Limit	0.3480	Passed
Maple Grove Education Centre	Bathroom Faucet	MG21-BF-P-001	0.2130	Exceeds Limit	1.2380	Passed
Maple Grove Education Centre	Bathroom Faucet	MG22-BF-P-001	0.0140	Exceeds Limit	0.2630	Passed
Maple Grove Education Centre	Bathroom Faucet	MG23-BF-P-001	0.0060	Exceeds Limit	0.2590	Passed
Maple Grove Education Centre	Bathroom Faucet	MG24-BF-P-001	0.0170	Exceeds Limit	0.2820	Passed
Maple Grove Education Centre	Bathroom Faucet	MG25-BF-P-001	0.0030	Passed	0.4360	Passed
Maple Grove Education Centre	Bathroom Faucet	MG26-BF-P-001	0.0410	Exceeds Limit	0.6110	Passed
Maple Grove Education Centre	Custodial Sink	MG27-CS-P-001	0.0100	Exceeds Limit	0.4150	Passed
Maple Grove Education Centre	Bathroom Faucet	MG28-BF-P-001	0.0060	Exceeds Limit	0.2130	Passed
Maple Grove Education Centre	Bathroom Faucet	MG29-BF-P-001	0.0110	Exceeds Limit	0.1930	Passed
Maple Grove Education Centre	Bathroom Faucet	MG2-BF-P-001	0.0100	Exceeds Limit	0.5000	Passed
Maple Grove Education Centre	Kitchen Faucet	MG30.1 -KF-S -001	0.0130	Exceeds Limit	0.2910	Passed
Maple Grove Education Centre	Kitchen Faucet	MG30.1-KF-P-001	0.0560	Exceeds Limit	0.7260	Passed
Maple Grove Education Centre	Kitchen Faucet	MG30.2 -KF-S -001	0.0060	Exceeds Limit	0.2370	Passed
Maple Grove Education Centre	Kitchen Faucet	MG30.2-KF-P-001	0.0160	Exceeds Limit	0.5930	Passed
Maple Grove Education Centre	Kitchen Faucet	MG30-KF-P-001	0.0050	Passed	0.4530	Passed
Maple Grove Education Centre	Kitchen Faucet	MG31 -KF -S -001	0.0560	Exceeds Limit	0.3740	Passed
Maple Grove Education Centre	Kitchen Faucet	MG31-KF-P-001	0.0380	Exceeds Limit	0.3450	Passed
Maple Grove Education Centre	Classroom Faucet	MG32-CF-P-002	0.0050	Passed	0.3880	Passed
Maple Grove Education Centre	Classroom Faucet	MG33-CF-P-002	0.0030	Passed	0.4160	Passed
Maple Grove Education Centre	Bathroom Faucet	MG34-BF-P-002	0.0030	Passed	0.3870	Passed
Maple Grove Education Centre	Bathroom Faucet	MG35-BF-P-002	0.0270	Exceeds Limit	0.4330	Passed
Maple Grove Education Centre	Bathroom Faucet	MG36-BF-P-002	0.0250	Exceeds Limit	0.3220	Passed
Maple Grove Education Centre	Water Fountain	MG37-WF-P-002	0.0000	Passed	0.0810	Passed
Maple Grove Education Centre	Custodial Sink	MG38-CS-P-002	0.0120	Exceeds Limit	0.3980	Passed
Maple Grove Education Centre	Bathroom Faucet	MG39-BF-P-002	0.0070	Exceeds Limit	0.4060	Passed
Maple Grove Education Centre	Bathroom Faucet	MG3-BF-P-001	0.0140	Exceeds Limit	0.1720	Passed
Maple Grove Education Centre	Bathroom Faucet	MG40-BF-P-002	0.0190	Exceeds Limit	0.3570	Passed
Maple Grove Education Centre	Bathroom Faucet	MG41-BF-P-002	0.0160	Exceeds Limit	0.3240	Passed
Maple Grove Education Centre	Classroom Faucet	MG42-CF-P-002	0.0040	Passed	0.3030	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Maple Grove Education Centre	Water Fountain	MG43-WF-P-002	0.0020	Passed	0.7660	Passed
Maple Grove Education Centre	Bathroom Faucet	MG44-BF-P-002	0.0030	Passed	0.3130	Passed
Maple Grove Education Centre	Bathroom Faucet	MG45-BF-P-002	0.0040	Passed	0.5300	Passed
Maple Grove Education Centre	Custodial Sink	MG46-CS-P-002	0.0070	Exceeds Limit	0.3270	Passed
Maple Grove Education Centre	Bathroom Faucet	MG47-BF-P-002	0.0020	Passed	0.2300	Passed
Maple Grove Education Centre	Classroom Faucet	MG48.1-CF-P-002	0.0150	Exceeds Limit	0.2520	Passed
Maple Grove Education Centre	Classroom Faucet	MG48.2-CF-P-002	0.0730	Exceeds Limit	0.1900	Passed
Maple Grove Education Centre	Bathroom Faucet	MG48-BF-P-002	0.0020	Passed	0.2210	Passed
Maple Grove Education Centre	Classroom Faucet	MG49-CF-P-002	0.0650	Exceeds Limit	0.5470	Passed
Maple Grove Education Centre	Water Fountain	MG4-WF-P-001	0.0010	Passed	0.4800	Passed
Maple Grove Education Centre	Classroom Faucet	MG50-CF-P-002	0.0290	Exceeds Limit	0.2840	Passed
Maple Grove Education Centre	Classroom Faucet	MG51-CF-P-002	0.0740	Exceeds Limit	0.3910	Passed
Maple Grove Education Centre	Classroom Faucet	MG52-CF-P-002	0.0440	Exceeds Limit	0.3240	Passed
Maple Grove Education Centre	Classroom Faucet	MG53-CF-P-002	0.0310	Exceeds Limit	0.6080	Passed
Maple Grove Education Centre	Classroom Faucet	MG54-CF-P-002	0.0580	Exceeds Limit	0.3850	Passed
Maple Grove Education Centre	Classroom Faucet	MG55-CF-P-002	0.0370	Exceeds Limit	0.2640	Passed
Maple Grove Education Centre	Classroom Faucet	MG56-CF-P-002	0.0940	Exceeds Limit	0.6600	Passed
Maple Grove Education Centre	Classroom Faucet	MG57-CF-P-002	0.0390	Exceeds Limit	0.3060	Passed
Maple Grove Education Centre	Classroom Faucet	MG58-CF-P-002	0.0370	Exceeds Limit	0.7340	Passed
Maple Grove Education Centre	Classroom Faucet	MG59-CF-P-002	0.0790	Exceeds Limit	0.8070	Passed
Maple Grove Education Centre	Bathroom Faucet	MG5-BF-P-001	0.0030	Passed	0.2860	Passed
Maple Grove Education Centre	Kitchen Faucet	MG60 -KF -S -002	0.0050	Passed	0.2570	Passed
Maple Grove Education Centre	Classroom Faucet	MG60-CF-P-002	0.0070	Exceeds Limit	0.3650	Passed
Maple Grove Education Centre	Kitchen Faucet	MG61 -KF-S -002	0.0060	Exceeds Limit	0.2500	Passed
Maple Grove Education Centre	Classroom Faucet	MG61-CF-P-002	0.0130	Exceeds Limit	0.3790	Passed
Maple Grove Education Centre	Classroom Faucet	MG62-CF-P-002	0.0050	Passed	0.3460	Passed
Maple Grove Education Centre	Kitchen Faucet	MG63 -KF-S - 002	0.0040	Passed	0.2450	Passed
Maple Grove Education Centre	Classroom Faucet	MG63-CF-P-002	0.0060	Exceeds Limit	0.3640	Passed
Maple Grove Education Centre	Kitchen Faucet	MG64 -KF-S -002	0.0110	Exceeds Limit	0.2600	Passed
Maple Grove Education Centre	Classroom Faucet	MG64-CF-P-002	0.0210	Exceeds Limit	0.4940	Passed
Maple Grove Education Centre	Classroom Faucet	MG65-CF-P-002	0.0320	Exceeds Limit	0.3600	Passed
Maple Grove Education Centre	Bathroom Faucet	MG6-BF-P-001	0.0040	Passed	0.3320	Passed
Maple Grove Education Centre	Custodial Sink	MG7-CS-P-001	0.0080	Exceeds Limit	0.3550	Passed
Maple Grove Education Centre	Bathroom Faucet	MG8-BF-P-001	0.0030	Passed	0.2680	Passed
Maple Grove Education Centre	Bathroom Faucet	MG9-BF-P-001	0.0050	Passed	0.3550	Passed
Meadowfields Community School	Bathroom Faucet	MF10-BF-P-001	0.0010	Passed	0.1960	Passed
Meadowfields Community School	Bathroom Faucet	MF11-BF-P-001	0.0010	Passed	0.1870	Passed
Meadowfields Community School	Classroom Faucet	MF12-CF-P-001	0.0080	Exceeds Limit	0.3500	Passed
Meadowfields Community School	Classroom Faucet	MF13-CF-P-001	0.0010	Passed	0.1750	Passed
Meadowfields Community School	Kitchen Faucet	MF15-KF-P-001	0.0110	Exceeds Limit	0.7150	Passed
Meadowfields Community School	Kitchen Faucet	MF16-KF-P-001	0.0040	Passed	0.2660	Passed
Meadowfields Community School	Kitchen Faucet	MF17-KF-P-001	0.0030	Passed	0.1310	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Meadowfields Community School	Bathroom Faucet	MF18-BF-P-001	0.0060	Exceeds Limit	0.3420	Passed
Meadowfields Community School	Bathroom Faucet	MF19-BF-P-001	0.0000	Passed	0.2350	Passed
Meadowfields Community School	Custodial Sink	MF1-CS-P-001	0.0070	Exceeds Limit	0.2480	Passed
Meadowfields Community School	Bathroom Faucet	MF20-BF-P-001	0.0000	Passed	0.1370	Passed
Meadowfields Community School	Staff Faucet	MF21-SF-P-001	0.0000	Passed	0.2200	Passed
Meadowfields Community School	Bathroom Faucet	MF22-BF-P-001	0.0000	Passed	0.2170	Passed
Meadowfields Community School	Staff Faucet	MF23-SF-P-001	0.0000	Passed	0.1330	Passed
Meadowfields Community School	Water Fountain	MF24-WF-P-001	0.0000	Passed	0.6360	Passed
Meadowfields Community School	Bathroom Faucet	MF25-BF-P-001	0.0000	Passed	0.2360	Passed
Meadowfields Community School	Bathroom Faucet	MF26-BF-P-001	0.0000	Passed	0.2670	Passed
Meadowfields Community School	Custodial Sink	MF27-CS-P-001	0.0020	Passed	0.1100	Passed
Meadowfields Community School	Water Fountain	MF28-WF-P-001	0.0000	Passed	0.1330	Passed
Meadowfields Community School	Bathroom Faucet	MF29-BF-P-001	0.0000	Passed	0.1890	Passed
Meadowfields Community School	Bathroom Faucet	MF2-BF-P-001	0.0020	Passed	0.3440	Passed
Meadowfields Community School	Bathroom Faucet	MF30-BF-P-001	0.0000	Passed	0.1670	Passed
Meadowfields Community School	Bathroom Faucet	MF32-BF-P-001	0.0010	Passed	0.3280	Passed
Meadowfields Community School	Bathroom Faucet	MF33-BF-P-001	0.0000	Passed	0.2040	Passed
Meadowfields Community School	Bathroom Faucet	MF34-BF-P-001	0.0000	Passed	0.2030	Passed
Meadowfields Community School	Bathroom Faucet	MF35-BF-P-001	0.0000	Passed	0.2010	Passed
Meadowfields Community School	Custodial Sink	MF37-CS-P-001	0.0010	Passed	0.1410	Passed
Meadowfields Community School	Water Fountain	MF38.1-WF-P-001	0.0000	Passed	0.2280	Passed
Meadowfields Community School	Classroom Faucet	MF38-CF-P-001	0.0020	Passed	0.1990	Passed
Meadowfields Community School	Bathroom Faucet	MF39-BF-P-001	0.0000	Passed	0.1730	Passed
Meadowfields Community School	Bathroom Faucet	MF3-BF-P-001	0.0020	Passed	0.5560	Passed
Meadowfields Community School	Water Fountain	MF40.1-WF-P-001	0.0000	Passed	0.2220	Passed
Meadowfields Community School	Classroom Faucet	MF40-CF-P-001	0.0010	Passed	0.2120	Passed
Meadowfields Community School	Bathroom Faucet	MF41-BF-P-001	0.0000	Passed	0.2250	Passed
Meadowfields Community School	Bathroom Faucet	MF42-BF-P-001	0.0010	Passed	0.1890	Passed
Meadowfields Community School	Water Fountain	MF43.1-WF-P-001	0.0000	Passed	0.2990	Passed
Meadowfields Community School	Classroom Faucet	MF43-CF-P-001	0.0010	Passed	0.2040	Passed
Meadowfields Community School	Bathroom Faucet	MF44-BF-P-001	0.0000	Passed	0.2020	Passed
Meadowfields Community School	Water Fountain	MF45.1-WF-P-001	0.0000	Passed	0.2640	Passed
Meadowfields Community School	Classroom Faucet	MF45-CF-P-001	0.0010	Passed	0.1820	Passed
Meadowfields Community School	Water Fountain	MF46-WF-P-001	0.0010	Passed	0.2110	Passed
Meadowfields Community School	Bathroom Faucet	MF47-BF-P-001	0.0000	Passed	0.1940	Passed
Meadowfields Community School	Bathroom Faucet	MF48-BF-P-001	0.0000	Passed	0.2120	Passed
Meadowfields Community School	Bathroom Faucet	MF4-BF-P-001	0.0010	Passed	0.6350	Passed
Meadowfields Community School	Water Fountain	MF50.1-WF-P-001	0.0000	Passed	0.3170	Passed
Meadowfields Community School	Classroom Faucet	MF50-CF-P-001	0.0020	Passed	0.2060	Passed
Meadowfields Community School	Bathroom Faucet	MF51-BF-P-001	0.0000	Passed	0.2500	Passed
Meadowfields Community School	Water Fountain	MF52.1-WF-P-001	0.0000	Passed	0.2870	Passed
Meadowfields Community School	Classroom Faucet	MF52-CF-P-001	0.0010	Passed	0.1790	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Meadowfields Community School	Bathroom Faucet	MF53-BF-P-001	0.0010	Passed	0.2240	Passed
Meadowfields Community School	Bathroom Faucet	MF54-BF-P-001	0.0020	Passed	0.2570	Passed
Meadowfields Community School	Water Fountain	MF55.1-WF-P-001	0.0010	Passed	0.3150	Passed
Meadowfields Community School	Classroom Faucet	MF55-CF-P-001	0.0020	Passed	0.2290	Passed
Meadowfields Community School	Bathroom Faucet	MF56-BF-P-001	0.0020	Passed	0.2210	Passed
Meadowfields Community School	Water Fountain	MF57.1-WF-P-001	0.0000	Passed	0.3080	Passed
Meadowfields Community School	Classroom Faucet	MF57-CF-P-001	0.0010	Passed	0.2760	Passed
Meadowfields Community School	Classroom Faucet	MF58-CF-P-001	0.0000	Passed	0.0810	Passed
Meadowfields Community School	Bathroom Faucet	MF5-BF-P-001	0.0010	Passed	0.3530	Passed
Meadowfields Community School	Bathroom Faucet	MF6-BF-P-001	0.0030	Passed	0.7370	Passed
Meadowfields Community School	Water Fountain	MF7-WF-P-001	0.0010	Passed	0.4330	Passed
Meadowfields Community School	Bathroom Faucet	MF8-BF-P-001	0.0010	Passed	0.2270	Passed
Meadowfields Community School	Bathroom Faucet	MF9-BF-P-001	0.0010	Passed	0.2060	Passed
Plymouth School	Bathroom Faucet	PS10-BF-P-001	0.0100	Exceeds Limit	0.1030	Passed
Plymouth School	Bathroom Faucet	PS11-BF-P-001	0.0030	Passed	0.0890	Passed
Plymouth School	Bathroom Faucet	PS12-BF-P-001	0.0090	Exceeds Limit	0.1140	Passed
Plymouth School	Custodial Sink	PS13-CS-P-001	0.0330	Exceeds Limit	0.3720	Passed
Plymouth School	Bathroom Faucet	PS14-BF-P-001	0.0050	Passed	0.1020	Passed
Plymouth School	Bathroom Faucet	PS15-BF-P-001	0.0060	Exceeds Limit	0.2340	Passed
Plymouth School	Classroom Faucet	PS16-CF-P-001	0.0030	Passed	0.2370	Passed
Plymouth School	Classroom Faucet	PS17-CF-P-001	0.0050	Passed	0.1020	Passed
Plymouth School	Bathroom Faucet	PS18-BF-P-001	0.0320	Exceeds Limit	0.3530	Passed
Plymouth School	Bathroom Faucet	PS19-BF-P-001	0.0050	Passed	0.2070	Passed
Plymouth School	Custodial Sink	PS1-CS-P-001	0.0070	Exceeds Limit	0.0900	Passed
Plymouth School	Bathroom Faucet	PS20-BF-P-001	0.0120	Exceeds Limit	0.2820	Passed
Plymouth School	Bathroom Faucet	PS21-BF-P-001	0.0030	Passed	0.1330	Passed
Plymouth School	Bathroom Faucet	PS22-BF-P-001	0.0040	Passed	0.1370	Passed
Plymouth School	Water Fountain	PS23-WF-P-001	0.0020	Passed	0.0500	Passed
Plymouth School	Bathroom Faucet	PS24-BF-P-001	0.0070	Exceeds Limit	0.2120	Passed
Plymouth School	Bathroom Faucet	PS25.1-BF-P-001	0.0200	Exceeds Limit	0.4750	Passed
Plymouth School	Bathroom Faucet	PS25-BF-P-001	0.0050	Passed	0.1120	Passed
Plymouth School	Custodial Sink	PS26-CS-P-001	0.0040	Passed	0.1510	Passed
Plymouth School	Kitchen Faucet	PS27-KF-P-001	0.0040	Passed	0.1060	Passed
Plymouth School	Staff Faucet	PS28-SF-P-001	0.0020	Passed	0.0880	Passed
Plymouth School	Kitchen Faucet	PS29flush-KF-F-001	0.0020	Passed	0.0660	Passed
Plymouth School	Kitchen Faucet	PS29-KF-P-001	0.0060	Exceeds Limit	0.0760	Passed
Plymouth School	Kitchen Faucet	PS29-KF-S-001	0.1260	Exceeds Limit	0.1810	Passed
Plymouth School	Water Fountain	PS2-WF-P-001	0.0010	Passed	0.1080	Passed
Plymouth School	Kitchen Faucet	PS30flush-KF-F-001	0.0020	Passed	0.0600	Passed
Plymouth School	Kitchen Faucet	PS30-KF-P-001	0.0090	Exceeds Limit	0.1560	Passed
Plymouth School	Kitchen Faucet	PS30-KF-S-001	0.0270	Exceeds Limit	0.1730	Passed
Plymouth School	Water Fountain	PS31-WF-P-001	0.0010	Passed	0.3890	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Plymouth School	Classroom Faucet	PS32-CF-P-001	0.0230	Exceeds Limit	0.4240	Passed
Plymouth School	Classroom Faucet	PS32-CF-S-001	0.0200	Exceeds Limit	0.4140	Passed
Plymouth School	Classroom Faucet	PS32flush-CF-F-001	0.0060	Exceeds Limit	0.2660	Passed
Plymouth School	Bathroom Faucet	PS33-BF-P-001	0.0100	Exceeds Limit	1.2440	Passed
Plymouth School	Bathroom Faucet	PS3-BF-P-001	0.0030	Passed	0.0380	Passed
Plymouth School	Bathroom Faucet	PS4-BF-P-001	0.0060	Exceeds Limit	0.1350	Passed
Plymouth School	Water Fountain	PS5-WF-P-001	0.0040	Passed	0.3990	Passed
Plymouth School	Bathroom Faucet	PS6-BF-P-001	0.0110	Exceeds Limit	0.1090	Passed
Plymouth School	Water Fountain	PS7-WF-P-001	0.0010	Passed	0.2590	Passed
Plymouth School	Classroom Faucet	PS8-CF-P-001	0.0080	Exceeds Limit	0.1970	Passed
Plymouth School	Classroom Faucet	PS9-CF-P-001	0.1740	Exceeds Limit	0.1740	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM1 - BF - P - 001	0.0034	Passed	0.0080	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM10 - BF - P - 001	0.0012	Passed	0.0031	Passed
Port Maitland Consolidated School	Classroom Faucet	PM11 - CF - P - 001	0.0018	Passed	0.0028	Passed
Port Maitland Consolidated School	Kitchen Faucet	PM12 - KF - P - 001	0.0069	Exceeds Limit	0.0074	Passed
Port Maitland Consolidated School	Kitchen Faucet	PM12.1 - KF - P - 001	0.0033	Passed	0.0027	Passed
Port Maitland Consolidated School	Water Fountain	PM13 - WF - P - 001	0.0000	Passed	0.0029	Passed
Port Maitland Consolidated School	Classroom Faucet	PM14 - CF - P - 001	0.0039	Passed	0.0035	Passed
Port Maitland Consolidated School	Classroom Faucet	PM15 - CF - P - 001	0.0040	Passed	0.0079	Passed
Port Maitland Consolidated School	Classroom Faucet	PM16 - CF - P - 002	0.0041	Passed	0.0310	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM17 - BF - P - 002	0.0007	Passed	0.0032	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM18 - BF - P - 002	0.0000	Passed	0.0020	Passed
Port Maitland Consolidated School	Water Fountain	PM19 - WF - P - 002	0.0000	Passed	0.0017	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM2 - BF - P - 001	0.0007	Passed	0.0023	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM20 - BF - P - 002	0.0005	Passed	0.0021	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM21 - BF - P - 002	0.0000	Passed	0.0029	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM22 - BF - P - 002	0.0016	Passed	0.0068	Passed
Port Maitland Consolidated School	Staff Faucet	PM23 - SF - P - 002	0.0006	Passed	0.0039	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM3 - BF - P - 001	0.0013	Passed	0.0016	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM4 - BF - P - 001	0.0009	Passed	0.0032	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM5 - BF - P - 001	0.0014	Passed	0.0031	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM6 - BF - P - 001	0.0018	Passed	0.0023	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM7 - BF - P - 001	0.0009	Passed	0.0019	Passed
Port Maitland Consolidated School	Bathroom Faucet	PM8 - BF - P - 001	0.0015	Passed	0.0072	Passed
Port Maitland Consolidated School	Water Fountain	PM9 - WF - P - 001	0.0000	Passed	0.0032	Passed
Shelburne Regional High School	Bathroom Faucet	SH10-BF-P-001	0.0051	Exceeds Limit	0.3603	Passed
Shelburne Regional High School	Bathroom Faucet	SH11-BF-P-001	0.0054	Exceeds Limit	1.0335	Passed
Shelburne Regional High School	Bathroom Faucet	SH12-BF-P-001	0.0036	Passed	1.0605	Passed
Shelburne Regional High School	Bathroom Faucet	SH13-BF-P-001	0.0041	Passed	0.8985	Passed
Shelburne Regional High School	Bathroom Faucet	SH14-BF-P-001	0.0078	Exceeds Limit	0.8379	Passed
Shelburne Regional High School	Bathroom Faucet	SH15-BF-P-001	0.0067	Exceeds Limit	0.9667	Passed
Shelburne Regional High School	Water Fountain	SH16-WF-P-001	0.0016	Passed	0.0538	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Shelburne Regional High School	Bathroom Faucet	SH17-BF-P-001	0.0117	Exceeds Limit	0.8547	Passed
Shelburne Regional High School	Staff Faucet	SH18-SF-P-001	0.0360	Exceeds Limit	0.3720	Passed
Shelburne Regional High School	Bathroom Faucet	SH19-BF-P-001	0.0066	Exceeds Limit	0.5357	Passed
Shelburne Regional High School	Classroom Faucet	SH1-CF-P-001	0.0060	Exceeds Limit	0.7433	Passed
Shelburne Regional High School	Staff Faucet	SH20-SF-P-001	0.0030	Passed	0.2634	Passed
Shelburne Regional High School	Bathroom Faucet	SH21-BF-P-001	0.0044	Passed	0.5429	Passed
Shelburne Regional High School	Bathroom Faucet	SH22-BF-P-001	0.0027	Passed	0.6731	Passed
Shelburne Regional High School	Bathroom Faucet	SH23-BF-P-001	0.0047	Passed	0.3055	Passed
Shelburne Regional High School	Bathroom Faucet	SH24-BF-P-001	0.0034	Passed	1.5825	Passed
Shelburne Regional High School	Bathroom Faucet	SH25-BF-P-001	0.0043	Passed	1.4150	Passed
Shelburne Regional High School	Bathroom Faucet	SH26-BF-P-001	0.0056	Exceeds Limit	0.6604	Passed
Shelburne Regional High School	Custodial Sink	SH27.1-CS-P-001	0.0062	Exceeds Limit	0.3553	Passed
Shelburne Regional High School	Bathroom Faucet	SH27-BF-P-001	0.0055	Exceeds Limit	0.7927	Passed
Shelburne Regional High School	Water Fountain	SH29-WF-P-001	0.0005	Passed	2.0645	Exceeds Limit
Shelburne Regional High School	Custodial Sink	SH2-CS-P-001	0.0011	Passed	0.2971	Passed
Shelburne Regional High School	Bathroom Faucet	SH30-BF-P-001	0.0064	Exceeds Limit	0.7191	Passed
Shelburne Regional High School	Bathroom Faucet	SH31-BF-P-001	0.0068	Exceeds Limit	0.7490	Passed
Shelburne Regional High School	Bathroom Faucet	SH32-BF-P-001	0.0085	Exceeds Limit	0.9816	Passed
Shelburne Regional High School	Bathroom Faucet	SH33-BF-P-001	0.0098	Exceeds Limit	1.5840	Passed
Shelburne Regional High School	Bathroom Faucet	SH34-BF-P-001	0.0100	Exceeds Limit	1.1615	Passed
Shelburne Regional High School	Bathroom Faucet	SH35-BF-P-001	0.0073	Exceeds Limit	0.9356	Passed
Shelburne Regional High School	Bathroom Faucet	SH36-BF-P-001	0.0091	Exceeds Limit	0.4321	Passed
Shelburne Regional High School	Bathroom Faucet	SH37-BF-P-001	0.0014	Passed	0.4605	Passed
Shelburne Regional High School	Bathroom Faucet	SH38-BF-P-001	0.0050	Passed	1.6060	Passed
Shelburne Regional High School	Bathroom Faucet	SH39-BF-P-001	0.0069	Exceeds Limit	2.1670	Exceeds Limit
Shelburne Regional High School	Kitchen Faucet	SH3-KF-P-001	0.0114	Exceeds Limit	0.2438	Passed
Shelburne Regional High School	Custodial Sink	SH40-CS-P-001	0.0030	Passed	0.3210	Passed
Shelburne Regional High School	Classroom Faucet	SH41-CF-P-001	0.0040	Passed	0.3506	Passed
Shelburne Regional High School	Classroom Faucet	SH42-CF-P-001	0.0303	Exceeds Limit	0.1138	Passed
Shelburne Regional High School	Water Fountain	SH43-WF-P-002	0.0004	Passed	0.9154	Passed
Shelburne Regional High School	Bathroom Faucet	SH44-BF-P-002	0.0047	Passed	1.0965	Passed
Shelburne Regional High School	Bathroom Faucet	SH45-BF-P-002	0.0059	Exceeds Limit	1.1200	Passed
Shelburne Regional High School	Bathroom Faucet	SH46-BF-P-002	0.0049	Passed	0.8420	Passed
Shelburne Regional High School	Classroom Faucet	SH47-CF-P-002	0.0059	Exceeds Limit	0.1351	Passed
Shelburne Regional High School	Classroom Faucet	SH48-CF-P-002	0.0062	Exceeds Limit	0.2379	Passed
Shelburne Regional High School	Kitchen Faucet	SH4-KF-P-001	0.0081	Exceeds Limit	0.2661	Passed
Shelburne Regional High School	Custodial Sink	SH50-CS-P-002	0.0011	Passed	0.3459	Passed
Shelburne Regional High School	Bathroom Faucet	SH51-BF-P-002	0.0019	Passed	0.4590	Passed
Shelburne Regional High School	Staff Faucet	SH52-SF-P-002	0.0032	Passed	0.2205	Passed
Shelburne Regional High School	Classroom Faucet	SH53-CF-P-002	0.0026	Passed	0.3085	Passed
Shelburne Regional High School	Classroom Faucet	SH54-CF-P-002	0.0026	Passed	0.2630	Passed
Shelburne Regional High School	Classroom Faucet	SH55-CF-P-002	0.0036	Passed	0.2963	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Shelburne Regional High School	Classroom Faucet	SH56-CF-P-002	0.0019	Passed	0.3293	Passed
Shelburne Regional High School	Classroom Faucet	SH57-CF-P-002	0.0039	Passed	0.3758	Passed
Shelburne Regional High School	Classroom Faucet	SH58-CF-P-002	0.0035	Passed	0.5910	Passed
Shelburne Regional High School	Classroom Faucet	SH59-CF-P-002	0.0038	Passed	0.3509	Passed
Shelburne Regional High School	Kitchen Faucet	SH5-KF-P-001	0.0390	Exceeds Limit	0.1577	Passed
Shelburne Regional High School	Classroom Faucet	SH60-CF-P-002	0.0042	Passed	0.3658	Passed
Shelburne Regional High School	Classroom Faucet	SH61-CF-P-002	0.0128	Exceeds Limit	0.1781	Passed
Shelburne Regional High School	Classroom Faucet	SH62-CF-P-002	0.0149	Exceeds Limit	0.2377	Passed
Shelburne Regional High School	Classroom Faucet	SH63-CF-P-002	0.0090	Exceeds Limit	0.3330	Passed
Shelburne Regional High School	Classroom Faucet	SH64-CF-P-002	0.0081	Exceeds Limit	0.1923	Passed
Shelburne Regional High School	Classroom Faucet	SH65-CF-P-002	0.0063	Exceeds Limit	0.2202	Passed
Shelburne Regional High School	Classroom Faucet	SH66-CF-P-002	0.0072	Exceeds Limit	0.2634	Passed
Shelburne Regional High School	Bathroom Faucet	SH67-BF-P-002	0.0024	Passed	0.1866	Passed
Shelburne Regional High School	Bathroom Faucet	SH68-BF-P-002	0.0054	Exceeds Limit	1.1800	Passed
Shelburne Regional High School	Bathroom Faucet	SH69-BF-P-002	0.0074	Exceeds Limit	1.0955	Passed
Shelburne Regional High School	Kitchen Faucet	SH6-KF-P-001	0.0038	Passed	0.6705	Passed
Shelburne Regional High School	Custodial Sink	SH70-CS-P-002	0.0021	Passed	0.2761	Passed
Shelburne Regional High School	Bathroom Faucet	SH71-BF-P-002	0.0067	Exceeds Limit	0.7493	Passed
Shelburne Regional High School	Bathroom Faucet	SH72-BF-P-002	0.0074	Exceeds Limit	0.6879	Passed
Shelburne Regional High School	Bathroom Faucet	SH73-BF-P-002	0.0166	Exceeds Limit	0.8304	Passed
Shelburne Regional High School	Classroom Faucet	SH74.1-CF-P-002	0.2064	Exceeds Limit	0.4181	Passed
Shelburne Regional High School	Classroom Faucet	SH74.2-CF-P-002	0.0268	Exceeds Limit	0.2348	Passed
Shelburne Regional High School	Classroom Faucet	SH74.3-CF-P-002	0.0108	Exceeds Limit	0.2154	Passed
Shelburne Regional High School	Classroom Faucet	SH74-CF-P-002	0.0166	Exceeds Limit	0.1732	Passed
Shelburne Regional High School	Classroom Faucet	SH75-CF-P-002	0.0137	Exceeds Limit	0.2284	Passed
Shelburne Regional High School	Classroom Faucet	SH76-CF-P-002	0.0053	Exceeds Limit	0.2038	Passed
Shelburne Regional High School	Classroom Faucet	SH77-CF-P-002	0.0065	Exceeds Limit	0.2711	Passed
Shelburne Regional High School	Classroom Faucet	SH78.1-CF-P-002	0.0245	Exceeds Limit	0.1666	Passed
Shelburne Regional High School	Classroom Faucet	SH78-CF-P-002	0.1302	Exceeds Limit	1.9918	Passed
Shelburne Regional High School	Classroom Faucet	SH79-CF-P-002	0.0084	Exceeds Limit	0.2737	Passed
Shelburne Regional High School	Kitchen Faucet	SH7-KF-P-001	0.0170	Exceeds Limit	0.3418	Passed
Shelburne Regional High School	Classroom Faucet	SH80-CF-P-002	0.0300	Exceeds Limit	0.1187	Passed
Shelburne Regional High School	Classroom Faucet	SH81-CF-P-002	0.0131	Exceeds Limit	0.6204	Passed
Shelburne Regional High School	Classroom Faucet	SH82-CF-P-002	0.0722	Exceeds Limit	0.2342	Passed
Shelburne Regional High School	Classroom Faucet	SH83-CF-P-002	0.0370	Exceeds Limit	0.7100	Passed
Shelburne Regional High School	Water Fountain	SH86-WF-P-002	0.0018	Passed	0.0126	Passed
Shelburne Regional High School	Bathroom Faucet	SH87-BF-P-002	0.0072	Exceeds Limit	0.9259	Passed
Shelburne Regional High School	Classroom Faucet	SH88-CF-P-002	0.0034	Passed	0.4512	Passed
Shelburne Regional High School	Kitchen Faucet	SH8-KF-P-001	0.0035	Passed	0.2521	Passed
St. Mary's Bay Academy	Classroom Faucet	SM10-CF-P-001	0.0051	Exceeds Limit	0.3205	Passed
St. Mary's Bay Academy	Custodial Sink	SM11.1-CS-P-001	0.0109	Exceeds Limit	0.4753	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM11-BF-P-001	0.0068	Exceeds Limit	0.3358	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Mary's Bay Academy	Bathroom Faucet	SM12-BF-P-001	0.0183	Exceeds Limit	0.6570	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM13-BF-P-001	0.0093	Exceeds Limit	0.5331	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM14-BF-P-001	0.0007	Passed	0.2754	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM15-BF-P-001	0.0007	Passed	0.2683	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM16-BF-P-001	0.0013	Passed	0.1735	Passed
St. Mary's Bay Academy	Kitchen Faucet	SM17-KF-P-001	0.0007	Passed	0.3499	Passed
St. Mary's Bay Academy	Kitchen Faucet	SM18-KF-P-001	0.0014	Passed	0.3750	Passed
St. Mary's Bay Academy	Kitchen Faucet	SM19-KF-P-001	0.0014	Passed	0.3663	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM1-BF-P-001	0.0097	Exceeds Limit	0.3228	Passed
St. Mary's Bay Academy	Kitchen Faucet	SM20-KF-P-001	0.0016	Passed	0.2342	Passed
St. Mary's Bay Academy	Classroom Faucet	SM21-CF-P-001	0.0050	Passed	0.3508	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM22-BF-P-001	0.0006	Passed	0.3222	Passed
St. Mary's Bay Academy	Classroom Faucet	SM23-CF-P-001	0.0006	Passed	0.3143	Passed
St. Mary's Bay Academy	Water Fountain	SM24-WF-P-001	0.0010	Passed	0.3224	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM25-BF-P-001	0.0007	Passed	0.2225	Passed
St. Mary's Bay Academy	Custodial Sink	SM26.1-CS-P-001	0.0354	Exceeds Limit	0.2633	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM26-BF-P-001	0.0010	Passed	0.2122	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM27-BF-P-001	0.0046	Passed	0.5036	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM28-BF-P-001	0.0012	Passed	0.2744	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM29-BF-P-001	0.0045	Passed	0.3623	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM2-BF-P-001	0.0006	Passed	0.3003	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM30-BF-P-001	0.0013	Passed	0.3597	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM31-BF-P-001	0.0015	Passed	0.3156	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM32-BF-P-001	0.0009	Passed	0.3639	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM33-BF-P-001	0.0011	Passed	0.2846	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM34-BF-P-001	0.0062	Exceeds Limit	0.3493	Passed
St. Mary's Bay Academy	Classroom Faucet	SM35-CF-P-001	0.0009	Passed	0.3569	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM36-BF-P-001	0.0009	Passed	0.3515	Passed
St. Mary's Bay Academy	Classroom Faucet	SM37-CF-P-001	0.0010	Passed	0.0073	Passed
St. Mary's Bay Academy	Classroom Faucet	SM38-CF-P-001	0.0044	Passed	0.2606	Passed
St. Mary's Bay Academy	Classroom Faucet	SM39-CF-P-001	0.0020	Passed	0.2518	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM3-BF-P-001	0.0017	Passed	0.1589	Passed
St. Mary's Bay Academy	Classroom Faucet	SM40-CF-P-001	0.0009	Passed	0.1794	Passed
St. Mary's Bay Academy	Classroom Faucet	SM41-CF-P-001	0.0024	Passed	0.1890	Passed
St. Mary's Bay Academy	Classroom Faucet	SM42-CF-P-001	0.0023	Passed	0.1828	Passed
St. Mary's Bay Academy	Classroom Faucet	SM43.1-CF-P-001	0.0113	Exceeds Limit	0.3980	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM43-BF-P-001	0.0031	Passed	0.4208	Passed
St. Mary's Bay Academy	Water Fountain	SM44-WF-P-001	0.0033	Passed	0.2773	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM45-BF-P-001	0.0016	Passed	0.2631	Passed
St. Mary's Bay Academy	Classroom Faucet	SM46.1-CF-P-001	0.0023	Passed	0.2990	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM46-BF-P-001	0.0015	Passed	0.2871	Passed
St. Mary's Bay Academy	Staff Faucet	SM47-SF-P-001	0.0092	Exceeds Limit	1.5570	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
St. Mary's Bay Academy	Water Fountain	SM48-WF-P-001	0.0048	Passed	0.6165	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM49-BF-P-001	0.0158	Exceeds Limit	0.3029	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM4-BF-P-001	0.0015	Passed	0.2919	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM50-BF-P-001	0.0028	Passed	0.0991	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM51-BF-P-001	0.0011	Passed	0.2393	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM52-BF-P-001	0.0022	Passed	0.2561	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM53-BF-P-001	0.0009	Passed	0.2492	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM54-BF-P-001	0.0031	Passed	0.1973	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM55-BF-P-001	0.0046	Passed	0.1921	Passed
St. Mary's Bay Academy	Classroom Faucet	SM56.1-CF-P-001	0.0011	Passed	0.3366	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM56-BF-P-001	0.0010	Passed	0.1601	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM57-BF-P-001	0.0014	Passed	0.2148	Passed
St. Mary's Bay Academy	Classroom Faucet	SM58-CF-P-001	0.0010	Passed	0.3165	Passed
St. Mary's Bay Academy	Classroom Faucet	SM59.1-CF-P-001	0.0024	Passed	0.2940	Passed
St. Mary's Bay Academy	Classroom Faucet	SM59-CF-P-001	0.0031	Passed	0.3367	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM5-BF-P-001	0.0020	Passed	0.3122	Passed
St. Mary's Bay Academy	Classroom Faucet	SM60-CF-P-001	0.0015	Passed	0.3251	Passed
St. Mary's Bay Academy	Classroom Faucet	SM61-CF-P-001	0.0007	Passed	0.2526	Passed
St. Mary's Bay Academy	Classroom Faucet	SM62-CF-P-001	0.0022	Passed	0.2767	Passed
St. Mary's Bay Academy	Classroom Faucet	SM63-CF-P-001	0.0017	Passed	0.2822	Passed
St. Mary's Bay Academy	Classroom Faucet	SM64-CF-P-001	0.0141	Exceeds Limit	0.2044	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM65.1-BF-P-001	0.0010	Passed	0.3220	Passed
St. Mary's Bay Academy	Water Fountain	SM65-WF-P-001	0.0020	Passed	0.2701	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM66-BF-P-001	0.0009	Passed	0.3170	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM67-BF-P-001	0.0019	Passed	0.3472	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM68-BF-P-001	0.0022	Passed	0.3592	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM69-BS-P-001	0.0000	Passed	0.0535	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM6-BF-P-001	0.0011	Passed	0.2993	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM70-BF-P-001	0.0008	Passed	0.2981	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM71-BF-P-001	0.0007	Passed	0.3117	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM72-BF-P-001	0.0008	Passed	0.2759	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM73-BF-P-001	0.0016	Passed	0.1686	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM74-BF-P-001	0.0009	Passed	0.3072	Passed
St. Mary's Bay Academy	Classroom Faucet	SM75-CF-P-001	0.0066	Exceeds Limit	0.2120	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM7-BF-P-001	0.0009	Passed	0.2883	Passed
St. Mary's Bay Academy	Bathroom Faucet	SM8-BF-P-001	0.0022	Passed	0.3777	Passed
St. Mary's Bay Academy	Water Fountain	SM9-WF-P-001	0.0012	Passed	0.0043	Passed
Weymouth Consolidated School	Custodial Sink	W1 - CS - P - 00B	0.0310	Exceeds Limit	0.0940	Passed
Weymouth Consolidated School	Classroom Faucet	W10 - CF - P - 001	0.0049	Passed	0.1200	Passed
Weymouth Consolidated School	Kitchen Faucet	W11 - KF - P - 001	0.0060	Exceeds Limit	0.1200	Passed
Weymouth Consolidated School	Kitchen Faucet	W13 - KF - P - 001	0.0017	Passed	0.1200	Passed
Weymouth Consolidated School	Kitchen Faucet	W14 - KF - P - 001	0.0110	Exceeds Limit	0.1000	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Weymouth Consolidated School	Bathroom Faucet	W15 - BF - P - 001	0.0039	Passed	0.0920	Passed
Weymouth Consolidated School	Bathroom Faucet	W18 - BF - P - 001	0.0026	Passed	0.1700	Passed
Weymouth Consolidated School	Bathroom Faucet	W19 - BF - P - 001	0.0049	Passed	0.1600	Passed
Weymouth Consolidated School	Staff Faucet	W2 - SF - P - 001	0.0038	Passed	0.1000	Passed
Weymouth Consolidated School	Bathroom Faucet	W20 - BF - P - 001	0.0021	Passed	0.1700	Passed
Weymouth Consolidated School	Water Fountain	W21 - WF - P - 001	0.0013	Passed	0.1100	Passed
Weymouth Consolidated School	Custodial Sink	W22 - CS - P - 001	0.0013	Passed	0.1000	Passed
Weymouth Consolidated School	Bathroom Faucet	W23 - BF - P - 001	0.0066	Exceeds Limit	0.1200	Passed
Weymouth Consolidated School	Bathroom Faucet	W24 - BF - P - 001	0.0048	Passed	0.1400	Passed
Weymouth Consolidated School	Bathroom Faucet	W25 - BF - P - 001	0.0025	Passed	0.1200	Passed
Weymouth Consolidated School	Bathroom Faucet	W26 - BF - P - 001	0.0040	Passed	0.1100	Passed
Weymouth Consolidated School	Bathroom Faucet	W29 - BF - P - 001	0.0043	Passed	0.1600	Passed
Weymouth Consolidated School	Classroom Faucet	W3 - CF - P - 001	0.0069	Exceeds Limit	0.1600	Passed
Weymouth Consolidated School	Bathroom Faucet	W30 - BF - P - 001	0.0028	Passed	0.1600	Passed
Weymouth Consolidated School	Bathroom Faucet	W31 - BF - P - 001	0.0051	Exceeds Limit	0.1900	Passed
Weymouth Consolidated School	Bathroom Faucet	W33 - BF - P - 001	0.0047	Passed	0.1600	Passed
Weymouth Consolidated School	Classroom Faucet	W34 - CF - P - 001	0.1300	Exceeds Limit	2.2000	Exceeds Limit
Weymouth Consolidated School	Bathroom Faucet	W36 - BF - P - 001	0.0025	Passed	0.0950	Passed
Weymouth Consolidated School	Bathroom Faucet	W37 - BF - P - 001	0.0023	Passed	0.0830	Passed
Weymouth Consolidated School	Bathroom Faucet	W38 - BF - P - 001	0.0015	Passed	0.0620	Passed
Weymouth Consolidated School	Custodial Sink	W39 - CS - P - 001	0.0056	Exceeds Limit	0.1700	Passed
Weymouth Consolidated School	Classroom Faucet	W4 - CF - P - 001	0.0052	Exceeds Limit	0.2500	Passed
Weymouth Consolidated School	Bathroom Faucet	W40 - BF - P - 001	0.0019	Passed	0.1300	Passed
Weymouth Consolidated School	Bathroom Faucet	W41 - BF - P - 001	0.0023	Passed	0.1900	Passed
Weymouth Consolidated School	Bathroom Faucet	W42 - BF - P - 001	0.0014	Passed	0.1100	Passed
Weymouth Consolidated School	Classroom Faucet	W5 - CF - P - 001	0.0180	Exceeds Limit	0.1800	Passed
Weymouth Consolidated School	Classroom Faucet	W6 - CF - P - 001	0.0096	Exceeds Limit	0.2000	Passed
Weymouth Consolidated School	Classroom Faucet	W8 - CF - P - 001	0.0075	Exceeds Limit	0.2500	Passed
Weymouth Consolidated School	Classroom Faucet	W9 - CF - P - 001	0.0075	Exceeds Limit	0.2100	Passed
Weymouth Consolidated School	Water Fountain	WF17 - WF - P - 001	0.0000	Passed	0.1200	Passed
Weymouth Consolidated School	Water Fountain	WF28 - WF - P - 001	0.0000	Passed	0.0720	Passed
Weymouth Consolidated School	Water Fountain	WF35 - WF - P - 001	0.0015	Passed	0.1100	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH100-CF-P-002	0.0040	Passed	2.9570	Exceeds Limit
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH101-CF-P-002	0.0210	Exceeds Limit	0.4010	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH102-CF-P-002	0.0070	Exceeds Limit	0.4340	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH103-CF-P-002	0.0050	Passed	0.5110	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH104-CS-P-002	0.0010	Passed	0.2560	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH10-BF-P-001	0.0010	Passed	0.4460	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH11-BF-P-001	0.0010	Passed	0.3690	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH12-BF-P-001	0.0010	Passed	0.3860	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH13-BF-P-001	0.0000	Passed	0.4370	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH14-BF-P-001	0.0020	Passed	0.7100	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH15-BF-P-001	0.0010	Passed	0.3440	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH16-BF-P-001	0.0030	Passed	0.3980	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH17-BF-P-001	0.0010	Passed	0.4780	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH18-BF-P-001	0.0010	Passed	0.3360	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH19-BF-P-001	0.0010	Passed	0.3480	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH1-CS-P-001	0.0010	Passed	0.3640	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH20-BF-P-001	0.0010	Passed	0.3610	Passed
Yarmouth Consolidated Memorial High School	Water Fountain	YH21-WF-P-001	0.0010	Passed	0.0070	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH22-BF-P-001	0.0010	Passed	0.4420	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH23-BF-P-001	0.0010	Passed	0.2990	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH24-BF-P-001	0.0010	Passed	0.2870	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH25-BF-P-001	0.0010	Passed	0.3720	Passed
Yarmouth Consolidated Memorial High School	Kitchen Faucet	YH26-KF-P-001	0.0000	Passed	0.1380	Passed
Yarmouth Consolidated Memorial High School	Kitchen Faucet	YH27.1-KF-P-001	0.0000	Passed	0.2820	Passed
Yarmouth Consolidated Memorial High School	Kitchen Faucet	YH27-KF-P-001	0.0010	Passed	0.3010	Passed
Yarmouth Consolidated Memorial High School	Kitchen Faucet	YH28-KF-P-001	0.0010	Passed	0.7540	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH29-CS-P-001	0.0010	Passed	0.2870	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH2-CF-P-001	0.0000	Passed	0.2640	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH31-CF-P-001	0.0010	Passed	0.3220	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH32-BF-P-001	0.0000	Passed	0.3560	Passed
Yarmouth Consolidated Memorial High School	Water Fountain	YH33-WF-P-001	0.0010	Passed	0.0320	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH34-CS-P-001	0.0040	Passed	0.5450	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH35-BF-P-001	0.0010	Passed	0.4620	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH36-BF-P-001	0.0010	Passed	0.4510	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH37-BF-P-001	0.0010	Passed	0.4390	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH38-BF-P-001	0.0000	Passed	0.3580	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH39-BF-P-001	0.0010	Passed	0.4480	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH3-CF-P-001	0.0000	Passed	0.2950	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH40-BF-P-001	0.0010	Passed	0.4090	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH41-BF-P-001	0.0010	Passed	0.4050	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH42-BF-P-001	0.0020	Passed	0.0490	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH43-BF-P-001	0.0000	Passed	1.2090	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH44-CF-P-001	0.0000	Passed	0.3280	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH45-CF-P-002	0.0370	Exceeds Limit	0.6190	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH46-CF-P-002	0.0070	Exceeds Limit	0.5320	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH47-CF-P-002	0.0030	Passed	0.6760	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH48-CF-P-002	0.0050	Passed	1.0660	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH49.1-CF-P-002	0.0030	Passed	1.0940	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH49.2-CF-P-002	0.0020	Passed	0.5750	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH49-CF-P-002	0.0040	Passed	1.0350	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH4-CF-P-001	0.0010	Passed	0.3250	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH50-CF-P-002	0.0020	Passed	0.3250	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH51-CF-P-002	0.0030	Passed	0.5640	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH52-CF-P-002	0.0030	Passed	0.9780	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH53-CF-P-002	0.0020	Passed	0.3240	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH54-CF-P-002	0.0010	Passed	0.5170	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH55-CF-P-002	0.0040	Passed	1.2430	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH56-CF-P-002	0.0010	Passed	0.2720	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH57-CF-P-002	0.0020	Passed	1.0000	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH58-CF-P-002	0.0070	Exceeds Limit	0.7670	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH59-CF-P-002	0.0100	Exceeds Limit	0.6640	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH5-CF-P-001	0.0000	Passed	0.3130	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH61-CS-P-002	0.0010	Passed	0.3070	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH62-CF-P-002	0.0010	Passed	0.6390	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH63-CF-P-002	0.0050	Passed	0.5640	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH64-CF-P-002	0.0040	Passed	0.6680	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH65-CF-P-002	0.0010	Passed	0.7360	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH66-CF-P-002	0.0000	Passed	0.2130	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH67-BF-P-002	0.0010	Passed	0.5810	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH68-CS-P-002	0.0010	Passed	0.5200	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH69-BF-P-002	0.0010	Passed	0.3270	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH6-CF-P-001	0.0010	Passed	0.3530	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH70-BF-P-002	0.0000	Passed	0.2610	Passed
Yarmouth Consolidated Memorial High School	Staff Faucet	YH71-SF-P-002	0.0000	Passed	0.4530	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH72-CS-P-002	0.0020	Passed	0.1090	Passed
Yarmouth Consolidated Memorial High School	Water Fountain	YH73-WF-P-002	0.0010	Passed	0.0150	Passed
Yarmouth Consolidated Memorial High School	Custodial Sink	YH74-CS-P-002	0.0010	Passed	0.5180	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH75-BF-P-002	0.0010	Passed	0.3040	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH76-BF-P-002	0.0010	Passed	0.3600	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH77-BF-P-002	0.0010	Passed	0.3450	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH78-BF-P-002	0.0010	Passed	0.3080	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH79-BF-P-002	0.0010	Passed	0.4990	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH7-CF-P-001	0.0010	Passed	0.3400	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH80-BF-P-002	0.0010	Passed	0.3530	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH81-BF-P-002	0.0010	Passed	0.3200	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH82-CF-P-002	0.0040	Passed	0.1870	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH83-CF-P-002	0.0020	Passed	0.3420	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH84-CF-P-002	0.0050	Passed	1.1700	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH85-CF-P-002	0.0030	Passed	0.8610	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH86-CF-P-002	0.0030	Passed	0.6140	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH87-CF-P-002	0.0020	Passed	0.5100	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH88-CF-P-002	0.0030	Passed	0.7750	Passed
Yarmouth Consolidated Memorial High School	Water Fountain	YH89-WF-P-002	0.0010	Passed	0.0110	Passed
Yarmouth Consolidated Memorial High School	Water Fountain	YH8-WF-P-001	0.0000	Passed	0.0370	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Yarmouth Consolidated Memorial High School	Custodial Sink	YH90-CS-P-002	0.0130	Exceeds Limit	0.5220	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH91-BF-P-002	0.0010	Passed	0.4800	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH92-BF-P-002	0.0010	Passed	0.3490	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH93-BF-P-002	0.0010	Passed	0.3710	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH94-BF-P-002	0.0000	Passed	0.1610	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH95-BF-P-002	0.0010	Passed	0.3520	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH96-BF-P-002	0.0010	Passed	0.4900	Passed
Yarmouth Consolidated Memorial High School	Bathroom Faucet	YH97-BF-P-002	0.0010	Passed	0.3720	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH98-CF-P-002	0.0010	Passed	0.3780	Passed
Yarmouth Consolidated Memorial High School	Classroom Faucet	YH99-CF-P-002	0.0020	Passed	2.2700	Exceeds Limit
Yarmouth Consolidated Memorial High School	Custodial Sink	YH9-CS-P-001	0.0100	Exceeds Limit	0.6370	Passed
Yarmouth Elementary School	Bathroom Faucet	YE10-BF-P-001	0.0010	Passed	0.1050	Passed
Yarmouth Elementary School	Bathroom Faucet	YE11-BF-P-001	0.0000	Passed	0.1540	Passed
Yarmouth Elementary School	Bathroom Faucet	YE12-BF-P-001	0.0000	Passed	0.1050	Passed
Yarmouth Elementary School	Bathroom Faucet	YE13-BF-P-001	0.0010	Passed	0.3220	Passed
Yarmouth Elementary School	Bathroom Faucet	YE14-BF-P-001	0.0010	Passed	0.4390	Passed
Yarmouth Elementary School	Bathroom Faucet	YE15-BF-P-001	0.0010	Passed	0.3430	Passed
Yarmouth Elementary School	Bathroom Faucet	YE16-BF-P-001	0.0010	Passed	0.3500	Passed
Yarmouth Elementary School	Classroom Faucet	YE17-CF-P-001	0.0020	Passed	0.3170	Passed
Yarmouth Elementary School	Classroom Faucet	YE18-CF-P-001	0.0010	Passed	0.3980	Passed
Yarmouth Elementary School	Bathroom Faucet	YE19-BF-P-001	0.0010	Passed	0.0530	Passed
Yarmouth Elementary School	Classroom Faucet	YE1-CF-P-001	0.0010	Passed	0.1680	Passed
Yarmouth Elementary School	Bathroom Faucet	YE20-BF-P-001	0.0010	Passed	0.0600	Passed
Yarmouth Elementary School	Bathroom Faucet	YE21-BF-P-001	0.0010	Passed	0.0600	Passed
Yarmouth Elementary School	Custodial Sink	YE22-CS-P-001	0.0020	Passed	0.4400	Passed
Yarmouth Elementary School	Water Fountain	YE23-WF-P-001	0.0010	Passed	0.4500	Passed
Yarmouth Elementary School	Water Fountain	YE24-WF-P-001	0.0010	Passed	0.5490	Passed
Yarmouth Elementary School	Custodial Sink	YE25-CS-P-001	0.0010	Passed	0.1110	Passed
Yarmouth Elementary School	Classroom Faucet	YE27-CF-P-001	0.0010	Passed	0.2570	Passed
Yarmouth Elementary School	Bathroom Faucet	YE28-BF-P-001	0.0010	Passed	0.4650	Passed
Yarmouth Elementary School	Bathroom Faucet	YE29-BF-P-001	0.0010	Passed	0.4320	Passed
Yarmouth Elementary School	Bathroom Faucet	YE2-BF-P-001	0.0010	Passed	0.1320	Passed
Yarmouth Elementary School	Classroom Faucet	YE30-CF-P-001	0.0010	Passed	0.1860	Passed
Yarmouth Elementary School	Bathroom Faucet	YE31-BF-P-001	0.0010	Passed	0.4970	Passed
Yarmouth Elementary School	Classroom Faucet	YE32-CF-P-001	0.0010	Passed	0.2420	Passed
Yarmouth Elementary School	Classroom Faucet	YE33-CF-P-001	0.0010	Passed	0.2420	Passed
Yarmouth Elementary School	Bathroom Faucet	YE34-BF-P-001	0.0010	Passed	0.3300	Passed
Yarmouth Elementary School	Bathroom Faucet	YE35-BF-P-001	0.0010	Passed	0.5300	Passed
Yarmouth Elementary School	Classroom Faucet	YE36-CF-P-001	0.0010	Passed	0.2100	Passed
Yarmouth Elementary School	Classroom Faucet	YE37-CF-P-001	0.0010	Passed	0.2530	Passed
Yarmouth Elementary School	Classroom Faucet	YE38-CF-P-001	0.0010	Passed	0.1910	Passed
Yarmouth Elementary School	Kitchen Faucet	YE39-KF-P-001	0.0010	Passed	0.0530	Passed

Tri-County Regional Centre for Education

School Name	Location	Sample ID	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result
Yarmouth Elementary School	Kitchen Faucet	YE3-KF-P-001	0.0010	Passed	0.1590	Passed
Yarmouth Elementary School	Kitchen Faucet	YE40-KF-P-001	0.0020	Passed	0.3010	Passed
Yarmouth Elementary School	Kitchen Faucet	YE41-KF-P-001	0.0040	Passed	0.4320	Passed
Yarmouth Elementary School	Kitchen Faucet	YE42-KF-P-001	0.0160	Exceeds Limit	0.7660	Passed
Yarmouth Elementary School	Classroom Faucet	YE43-CF-P-002	0.0010	Passed	0.2060	Passed
Yarmouth Elementary School	Classroom Faucet	YE44-CF-P-002	0.0010	Passed	0.1760	Passed
Yarmouth Elementary School	Classroom Faucet	YE45-CF-P-002	0.0010	Passed	0.1920	Passed
Yarmouth Elementary School	Water Fountain	YE46-WF-P-002	0.0010	Passed	0.6280	Passed
Yarmouth Elementary School	Classroom Faucet	YE47-CF-P-002	0.0010	Passed	0.2070	Passed
Yarmouth Elementary School	Bathroom Faucet	YE48-BF-P-002	0.0010	Passed	0.4750	Passed
Yarmouth Elementary School	Classroom Faucet	YE49-CF-P-002	0.0010	Passed	0.2030	Passed
Yarmouth Elementary School	Bathroom Faucet	YE50-BF-P-002	0.0010	Passed	0.3320	Passed
Yarmouth Elementary School	Staff Faucet	YE51-SF-P-002	0.0010	Passed	0.2980	Passed
Yarmouth Elementary School	Custodial Sink	YE52-CS-P-002	0.0040	Passed	0.5590	Passed
Yarmouth Elementary School	Classroom Faucet	YE53-CF-P-002	0.0010	Passed	0.2320	Passed
Yarmouth Elementary School	Bathroom Faucet	YE54-BF-P-002	0.0020	Passed	0.0870	Passed
Yarmouth Elementary School	Bathroom Faucet	YE55-BF-P-002	0.0010	Passed	0.0930	Passed
Yarmouth Elementary School	Bathroom Faucet	YE56-BF-P-002	0.0010	Passed	0.0850	Passed
Yarmouth Elementary School	Classroom Faucet	YE57-CF-P-002	0.0010	Passed	0.2740	Passed
Yarmouth Elementary School	Classroom Faucet	YE58-CF-P-002	0.0010	Passed	0.2860	Passed
Yarmouth Elementary School	Custodial Sink	YE59-CS-P-001	0.0020	Passed	0.1550	Passed
Yarmouth Elementary School	Classroom Faucet	YE5-CF-P-001	0.0010	Passed	0.2300	Passed
Yarmouth Elementary School	Custodial Sink	YE60-CS-P-002	0.0000	Passed	0.1890	Passed
Yarmouth Elementary School	Custodial Sink	YE61-CS-P-002	0.0010	Passed	0.2710	Passed
Yarmouth Elementary School	Bathroom Faucet	YE6-BF-P-001	0.0010	Passed	0.5330	Passed
Yarmouth Elementary School	Bathroom Faucet	YE7-BF-P-001	0.0010	Passed	0.4290	Passed
Yarmouth Elementary School	Water Fountain	YE8-WF-P-001	0.0000	Passed	0.1320	Passed
Yarmouth Elementary School	Custodial Sink	YE9.1-CS-P-001	0.0170	Exceeds Limit	0.1160	Passed
Yarmouth Elementary School	Water Fountain	YE9-WF-P-001	0.0010	Passed	0.1340	Passed